



TEMPLATE EXPLANATION

This template must be used by **AusNet Services** to report service performance information for the **2014** calendar year. It is **part 1** of 2 templates. This template is relevant to the **1 January to 31 March 2014** performance.

Yellow worksheets (**'Inputs - Performance'** and **'Inputs - Exclusions'**) are for inputs, including performance and exclusion information. The TNSP **only needs to enter data on these worksheets.**

Purple worksheets **'S1' to 'S9'** are the s-factor results based on the performance inputs from the 'Inputs - Performance' worksheet.

Blue worksheet **'Revenue Calculation'** quantifies the appropriate revenue to be applied to the s-factor results adjusted for CPI.

Red worksheet **'Outcomes'** shows the total performance, s-factor and financial incentive results based on the TNSP's performance in 'Inputs-Performance' and 'Revenue Calculation' worksheets.

TNSP input
calculation
Input sourced from revenue proposal
Input from other source

S	Performance parameter	Performance Inputs				Performance	Performance
		Collar	Target	Cap	Revenue at Risk	without exclusions	with exclusions
S1	Total circuit availability	0.9841	0.9873	0.9905	0.200%	99.45%	99.47%
S2	Peak critical availability	0.9862	0.9939	0.9978	0.200%	99.75%	99.78%
S3	Peak non-critical availability	0.9883	0.994	0.9969	0.050%	99.70%	99.71%
S4	Intermediate critical availability	0.9729	0.9867	0.9936	0.000%	0.00%	0.00%
S5	Intermediate non-critical availability	0.9757	0.9873	0.9931	0.000%	0.00%	0.00%
S6	Loss of supply event frequency (no. of events > 0.05 system minutes per annum)	3	2	1	0.125%	2	0
S7	Loss of supply event frequency (no. of events > 0.3 system minutes per annum)	2	1	0	0.125%	0	0
S8	Average outage duration– lines (minutes)	667	382	98	0.125%	104.087	104.087
S9	Average outage duration– transformers (minutes)	556	412	268	0.125%	242.4	212.78

Other inputs

TNSP
STPIS version
Regulatory Determination
Base Year Allowed Revenue
Base Year
X-factor
Commencement of regulatory year

AusNet
Version 1 - January, 2007
2008/09-2013/14
\$454,974,504.00
2008/09
-1.01%
1/04/2008

Assessment
Financial year to
Date prepared
Revision date
Number of
circuits as at 31

2014
2014/15
22/01/2015
29/01/2015
211

Annual revenue adjusted for CPI
CPI (old ABS index) CPI (new ABS index)

Dec-07	160.1	89.1
Dec-08	166.0	92.4
Dec-09	169.5	94.3
Dec-10	174.0	96.9
Dec-11	179.4	99.8
Dec-12	0.0	102.0
Dec-13	0.0	104.8
Dec-14		

Public holidays 2014

1/01/2014	Number of total circuits	211
27/01/2014	Number of critical circuits	147
18/04/2014 19/04/2014	Number of non critical circuits	64
20/04/2014	Peak hours in 1 Jan - 31 March 2014	539
21/04/2014 25/04/2014 9/06/2014 6/10/2014 25/12/2014 26/12/2014	Intermediate hours in 1 Jan - 31 March 2014	0

AusNet - Proposed exclusions

Circuit availability	Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Start date	Start time	End date	End time	Circuits affected	Reactive plant or transformer	Quantitative impact	Reasons for exclusion request	Further references	Comments	
Name of any circuit availability parameters applying to AusNet	Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	Start dd/mm/yy	Start hh:mm:ss	End dd/mm/yy	End hh:mm:ss	Hours+Minutes unavailable (min)	Name of circuits affected	Name of any reactive plant or transformer affected	Impact of exclusion event on availability sub-parameter	Full details of the reason/s for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg. Exclusion 1.2 Third party event.	A TNSP may provide further details of an exclusion event. TNSP to provide reference.	Details of reference attachments if applicable
51 Total circuit availability	BLTS: B3 Trans outage		FAULT	9/01/14	19:46:00	9/01/14	20:43:00	0:57		B3 220/66KV TRANS AT BLTS	0.0000005	Clause 1.2 Connection Asset	WO # 10413224	
	Disconnect No2 Trans from Its No 2 Bus 220KV CB	XB12 - (GNTS) STATION REDEVELOPMENT	SPICAPX	14/01/14	04:35:00	14/01/14	08:44:00	4:09		B2 220/66KV TRANS AT GNTS	0.0000022	Clause 1.2 Connection Asset	WO # XB1258E9	
	KGTS-WETS-RCTS trip		FAULT	15/01/14	23:05:00	15/01/14	23:35:00	0:30		B1 220/66KV TRANS AT WETS	0.0000003	Clause 1.1 Unregulated Transmission Asset	WO # 10419376	
	MWTS/MP5 220KV CB TRIP		FAULT	15/01/14	23:11:00	15/01/14	23:49:00	0:38		B3 220/66KV TRANS AT MWTS	0.0000003	Clause 1.2 Connection Asset	WO # 10413388	
	MWTS/MP5 220KV CB TRIP		FAULT	15/01/14	23:11:00	15/01/14	23:49:00	0:38		NO.1 11/220KV TRANS BANK AT MPS	0.0000003	Clause 1.2 Connection Asset	WO # 10413389	
	MWTS/MP5 220KV CB TRIP		FAULT	15/01/14	23:11:00	15/01/14	23:49:00	0:38		NO.2 11/220KV TRANS BANK AT MPS	0.0000003	Clause 1.2 Connection Asset	WO # 10413390	
	KGTS-WETS-RCTS trip		FAULT	16/01/14	13:45:00	16/01/14	13:56:00	0:11		B1 220/66KV TRANS AT WETS	0.0000001	Clause 1.1 Unregulated Transmission Asset	WO # 10419379	
	Replace broken insulator- No2 Trans 66KV Neut Isol		FORCED	16/01/14	15:02:00	16/01/14	18:16:00	3:14		B2 220/66KV TRANS AT BATS	0.0000017	Clause 1.2 Connection Asset	WO # 10413422	
	KGTS-WETS-RCTS trip		FAULT	16/01/14	15:54:00	16/01/14	15:59:00	0:05		B1 220/66KV TRANS AT WETS	0.0000000	Clause 1.1 Unregulated Transmission Asset	WO # 10419382	
	Operator Training		SPIMAIN	21/01/14	09:49:00	21/01/14	15:46:00	5:57		B3 220/66KV TRANS AT TTS	0.0000032	Clause 1.2 Connection Asset	WO # 10413229	
	Replace No2 Trans 22kv VT/s		SPIMAIN	23/01/14	07:55:00	23/01/14	16:26:00	8:31		B2 220/66KV TRANS AT BATS	0.0000046	Clause 1.2 Connection Asset	WO # 10413506	
	Top Up Low 220KV Bushing Oil		SPIMAIN	24/01/14	06:37:00	24/01/14	11:40:00	5:03		B1 220/66KV TRANS AT WMWTS	0.0000027	Clause 1.2 Connection Asset	WO # 10413672	
	Replace Trans Gearbox Gear & O/H 66KV Isol	VC13 - REPAIR TRANSFORMER OIL LEAKS - CENTRAL	SPIMAIN	29/01/14	06:04:00	30/01/14	15:09:00	33:05		B5 220/66KV TRANS AT TTS	0.0000179	Clause 1.2 Connection Asset	WO # VCI358A6	
	VSCAP to PTH	Outage requested by APDALCOA	APDALCOA	29/01/14	06:38:00	29/01/14	14:30:00	7:52	PT. HENRY NO.1 220KV LINE AT GTS		0.0000043	Clause 1.3 Third Party Outage	WO # 10413651 Attached.	
	Replace faulty fans & pump on B3 Transformer		SPIMAIN	29/01/14	13:28:00	29/01/14	16:43:00	3:15		B3 220/66KV TRANS AT HTS	0.0000018	Clause 1.2 Connection Asset	WO # 10413729	
	RWTS B3 Trans tripped with No2 220kv Bus		FAULT	29/01/14	14:43:00	29/01/14	15:31:00	0:48		B3 220/66KV TRANS AT RWTS	0.0000004	Clause 1.2 Connection Asset	WO # 10414003	
	L2 Trans trip (RWTS No2 220kv Bus Trip)		FAULT	29/01/14	14:43:00	29/01/14	15:31:00	0:48		L2 220/22KV TRANS AT RWTS	0.0000004	Clause 1.2 Connection Asset	WO # 10414004	
	Install new 22kv Bus work from No2 22kv Cap Bank	X7F0 - (RWTS) REBUILD 220 & 22KV SWITCHYARDS	SPICAPX	6/02/14	06:31:00	6/02/14	11:18:00	4:47		NO.3 22KV CAPACITOR BANK AT RWTS	0.0000026	Clause 1.2 Connection Asset	WO # X7F058T6	
	Perf Calc W/O- No1 Trans MV during 66KV CB outage		SPIMAIN	6/02/14	07:27:00	6/02/14	15:04:00	7:37		X1 330/66/22KV TRANS AT WOTS	0.0000041	Clause 1.2 Connection Asset	WO # 10413297	
	SCAP YPS Aux E	Outage requested by GENCO	GENCO	11/02/14	08:07:00	11/02/14	14:46:00	6:39		AUX E 220/22KV TRANS AT YPS	0.0000036	Clause 1.2 Connection Asset	WO # 10413896	
	220KV Line Trip		FAULT	14/02/14	05:47:00	14/02/14	10:14:00	4:27		B3 220/66KV TRANS AT MWTS	0.0000024	Clause 1.2 Connection Asset	WO # 10414826	
	220KV Line Trip		FAULT	14/02/14	05:47:00	14/02/14	10:14:00	4:27		NO.1 11/220KV TRANS BANK AT MPS	0.0000024	Clause 1.2 Connection Asset	WO # 10414827	
	220KV Line Trip		FAULT	14/02/14	05:47:00	14/02/14	10:14:00	4:27		NO.2 11/220KV TRANS BANK AT MPS	0.0000024	Clause 1.2 Connection Asset	WO # 10414830	
	Perf Calc w/o No1 Trans during its 22kv CB OH		SPIMAIN	14/02/14	07:25:00	14/02/14	17:23:00	9:58		B1 220/66/22KV TRANS AT KGTS	0.0000054	Clause 1.2 Connection Asset	WO # 10412670	
	Insul Washing		FORCED	14/02/14	12:47:00	14/02/14	15:16:00	2:29		B3 220/66KV TRANS AT MWTS	0.0000013	Clause 1.2 Connection Asset	WO # 10439603	
	Insul Washing		FORCED	14/02/14	12:47:00	14/02/14	15:17:00	2:30		NO.1 11/220KV TRANS BANK AT MPS	0.0000014	Clause 1.2 Connection Asset	WO # 10439604	
	Insul washing		FORCED	14/02/14	12:47:00	14/02/14	15:16:00	2:29		NO.2 11/220KV TRANS BANK AT MPS	0.0000013	Clause 1.2 Connection Asset	WO # 10439605	
	Replace pole 110 on CBTS-FTS No1 Line		SPIMAIN	15/02/14	06:43:00	15/02/14	19:34:00	12:51	CBTS NO.1 66KV LINE AT FTS		0.0000070	Clause 1.2 Connection Asset	WO # 10413531	
	Wash Down & Repair Oil Leak	VC13 - REPAIR TRANSFORMER OIL LEAKS - CENTRAL	SPIMAIN	17/02/14	06:34:00	21/02/14	15:41:00	10:07		B3 220/66KV TRANS AT KTS	0.0000059	Clause 1.2 Connection Asset	WO # VCI358A7	
	SCAP to desal	Outage requested by HVCUST	HVCUST	19/02/14	07:14:00	21/02/14	10:42:00	51:28		L2 220/22KV TRANS AT WDP	0.0000278	Clause 1.1 Unregulated Transmission Asset	WO # 10414931	
	Top Up Wph 220KV Bushing		SPIMAIN	19/02/14	12:08:00	19/02/14	15:39:00	3:31		B1 220/66KV TRANS AT WMWTS	0.0000019	Clause 1.2 Connection Asset	WO # 10414737	
	CBTS NO.1 66KV LINE AT FTS		SPIMAIN	22/02/14	06:31:00	22/02/14	18:55:00	12:24	CBTS NO.1 66KV LINE AT FTS		0.0000067	Clause 1.2 Connection Asset	WO # 10414686	
	SVTS: B2 Trans off load		FORCED	22/02/14	10:45:00	22/02/14	17:15:00	6:30		B2 220/66KV TRANS AT SVTS	0.0000035	Clause 1.2 Connection Asset	WO # 10415086	
	CBTS NO.1 66KV LINE AT FTS		SPIMAIN	23/02/14	06:30:00	23/02/14	14:19:00	7:49	CBTS NO.1 66KV LINE AT FTS		0.0000042	Clause 1.2 Connection Asset	WO # 10414686	
	B1 Trans		FORCED	26/02/14	00:11:00	27/02/14	15:05:00	38:54		B1 220/66KV TRANS AT TTS	0.0000210	Clause 1.2 Connection Asset	WO # 10415164	
	Replace Pole & Cross Arms (Book to 291531)		SPIMAIN	1/03/14	06:03:00	1/03/14	18:59:00	12:56	CBTS NO.2 66KV LINE AT FTS		0.0000070	Clause 1.2 Connection Asset	WO # 10414919	
	REBATE BUS OUTAGE B1 Trans @ MWTS		SPIMAIN	1/03/14	07:00:00	1/03/14	16:20:00	9:20		B1 220/66KV TRANS AT MWTS	0.0000050	Clause 1.2 Connection Asset	WO # 10413765	
	Replace Pole & Cross Arms (Book to 291531)		SPIMAIN	2/03/14	06:06:00	2/03/14	14:49:00	8:43	CBTS NO.2 66KV LINE AT FTS		0.0000047	Clause 1.2 Connection Asset	WO # 10414919	
	Class 2 O/HAUL Transformer and Div Sw (EM)		SPIMAIN	4/03/14	07:01:00	4/03/14	14:30:00	7:29		B1 220/66KV TRANS AT RTS	0.0000040	Clause 1.2 Connection Asset	WO # 10366548	
	SCAP to YMA	Outage requested by HVCUST	HVCUST	4/03/14	07:10:00	4/03/14	16:02:00	8:52		AUX D 220/22KV TRANS AT YPS	0.0000048	Clause 1.2 Connection Asset	WO # 10415059	
	Class 2 O/HAUL Transmtr and Trafo Union Div Sw (N)		SPIMAIN	4/03/14	07:11:00	6/03/14	10:33:00	51:22		B2 220/66KV TRANS AT GNTS	0.0000278	Clause 1.2 Connection Asset	WO # 10367304	
	NPSD-BLTS 220KV WY De-Energised	Outage requested by DISTCO	DBPROX	4/03/14	11:43:00	4/03/14	22:20:00	10:37	NPSD-BLTS 220KV WY		0.0000057	Clause 1.3 Third Party Outage	WO # 10415421 Attached.	
	Line offload for Alcoa	Outage requested by APDALCOA	APDALCOA	6/03/14	07:51:00	6/03/14	19:13:00	11:22	HYTS-APD 1 500KV W		0.0000061	Clause 1.3 Third Party Outage	WO # 10415448 Attached.	
	Line offload for Alcoa	Outage requested by APDALCOA	APDALCOA	8/03/14	18:30:00	8/03/14	18:58:00	0:28	HYTS-APD 1 500KV W		0.0000003	Clause 1.3 Third Party Outage	WO # 10415569. Line offloaded at APD end by APD.	
	SFT HV Test On Spare Metro Transformer		SPIMAIN	11/03/14	08:30:00	18/03/14	09:45:00	169:15		SPARE METRO 220/66KV 150MVA	0.0000916	Clause 1.2 Connection Asset	WO # 10414375	
	Repair oil leak on B2 Transformer	VC13 - REPAIR TRANSFORMER OIL LEAKS - CENTRAL	SPICAPX	12/03/14	08:18:00	14/03/14	15:31:00	55:13		B2 220/66KV TRANS AT TBTS	0.0000299	Clause 1.2 Connection Asset	WO # VCI358A4	
	O/H 220/66KV TRANSFORMER		SPIMAIN	17/03/14	07:34:00	17/03/14	15:11:00	7:37		B1 220/66KV TRANS AT MWTS	0.0000041	Clause 1.2 Connection Asset	WO # 10353311	
	Replace B1 Trans & decommis No1 & No5 S5 Trans	XB17 - (GTS) REPLACE B1 & B3 TRANS & 66KV CBS	SPICAPX	18/03/14	05:43:45	19/03/14	11:10:00	29:26		EX - B1 220/66KV TRANS AT GTS	0.0000159	Clause 1.2 Connection Asset	WO # XB1758F2	
	Overhaul No 2 220/66 kv Trans at MWTS		SPIMAIN	18/03/14	08:01:00	18/03/14	15:16:00	7:15		B2 220/66KV TRANS AT MWTS	0.0000039	Clause 1.2 Connection Asset	WO # 10352539	
	Transgrid outage	Outage requested by TRANSGRD	TRANSGRD	19/03/14	10:42:00	19/03/14	17:37:00	6:55	MSS-DDTS 1 330KV NW		0.0000037	Clause 1.3 Third Party Outage	WO # 10415595 Attached.	
	Transgrid outage	Outage requested by TRANSGRD	TRANSGRD	24/03/14	07:06:00	24/03/14	16:49:00	9:43	MSS-DDTS 1 330KV NW		0.0000053	Clause 1.3 Third Party Outage	WO # 10415596 Attached.	
	Disconnect #2 SS 415V & Connect #4 SS 415V	Z907 - (BETS) INSTALL TWO NEW 75MVA 220/22KV	DB_AUG	25/03/14	05:58:00	25/03/14	18:00:00	12:02		B4 220/66KV TRANS AT BETS	0.0000065	Clause 1.2 Connection Asset	WO # Z90758M7	
	O/Haul - 220KV Cap Bank (incl ESW,CT,Reactor)		SPIMAIN	25/03/14	07:36:00	25/03/14	13:41:00	6:05		NO.2 220KV CAPACITOR BANK AT MLTS	0.0000033	Clause 1.1 Unregulated Transmission Asset	WO # 10367932	
	B4 Trans isolated for 66KV CB new Cont1 & alarms	XA24 - (SHTS) CLEAN UP RTUS	SPICAPX	27/03/14	07:25:00	27/03/14	18:20:00	10:55		B4 220/66KV TRANS AT SHTS	0.0000059	Clause 1.2 Connection Asset	WO # XA2458B7	
	Maintain 220KV Cap Bank (incl ESW,CT,Reactor)		SPIMAIN	28/03/14	07:35:00	28/03/14	16:13:00	8:38		NO.1 220KV CAPACITOR BANK AT DDTS	0.0000047	Clause 1.1 Unregulated Transmission Asset	WO # 10408031	
	B1 Trans Delta Earth Alarm at HTS		SPIMAIN	28/03/14	11:02:00	28/03/14	16:01:00	4:59		B1 220/66KV TRANS AT HTS	0.0000027	Clause 1.2 Connection Asset	WO # 10416218	
	Investigate B2 Trans Oil Pump Failure		SPIMAIN	28/03/14	11:36:00	28/03/14	15:17:00	3:41		B2 220/66KV TRANS AT ATS	0.0000020	Clause 1.2 Connection Asset	WO # 10415621	
	Transgrid outage	Outage requested by TRANSGRD	TRANSGRD	31/03/14	07:00:00	31/03/14	17:31:00	10:31	MSS-DDTS 1 330KV NW		0.0000057	Clause 1.3 Third Party Outage	WO # 10415597 Attached.	
	Class 2 O/HAUL Transformer and Div Sw (EM)		SPIMAIN	31/03/14	07:07:00	31/03/14	15:49:00	8:42		B3 220/66KV TRANS AT CBTS	0.0000047	Clause 1.1 Unregulated Transmission Asset	WO # 10369825	
	Perf calc w/o No1 Trans during its 22kv CB OH		SPIMAIN	31/03/14	07:20:00	31/03/14	16:59:00	9:39		B1 220/66/22KV TRANS AT KGTS	0.0000052	Clause 1.2 Connection Asset	WO # 10415443	
52 Peak critical availability	VSCAP to PTH	Outage requested by APDALCOA	APDALCOA	29/01/14	06:38:00	29/01/14	14:30:00	7:52	PT. HENRY NO.1 220KV LINE AT GTS		0.0000099	Clause 1.3 Third Party Outage	WO # 10413651 Attached.	
	NPSD-BLTS 220KV WY De-Energised	Outage requested by DISTCO	DBPROX	4/03/14	11:43:00	4/03/14	22:20:00	10:37	NPSD-BLTS 220KV WY		0.000134	Clause 1.3 Third Party Outage	WO # 10415421 Attached.	
	Line offload for Alcoa	Outage requested by APDALCOA	APDALCOA	6/03/14	07:51:00	6/03/14	19:13:00	11:22	HYTS-APD 1 500KV W		0.000143	Clause 1.3 Third Party Outage	WO # 10415448 Attached.	
53 Peak non-critical availability	O/Haul NO.2 66KV REACTOR AT RCTS		SPIMAIN	23/01/14	07:11									

AusNet - Proposed exclusions															
S6	Loss of supply event frequency (no. of events > 0.05 system minutes per annum)	KGTS-WETS-RCTS trip	At HOTS, at 1345 on 16/01/14, the RCTS 220 kV line tripped via protection. This is the 2nd of the 3 tripping events occurred on this line due to smoke from a bushfire nearly 110 km south of RCTS. All the 3 events also unforeseeably caused the simultaneous tripping of the KGTS-WETS-RCTS 220 kV line and the consequential supply interruption to Powercor customers supplied from the WETS.	The simultaneous tripping of these 220 kV lines was caused by the SOTF function of the X protection relay at WETS. The SOTF function for X protection of RCTS and KGTS lines at WETS has been now disabled. The protection operations on the RCTS-WETS-KGTS 220 kV transmission line would not normally be expected to occur for a fault on the RCTS-HOTS 220 kV transmission line. However, the protection design did not envisage this type of incident.	16/01/14	13:45:00	16/01/14	14:36:00	0:51	B1 220/66KV TRANS AT WETS	10446	34 MW for 51 minutes	0.0354	EXCLUDE 9.1 Unregulated transmission asset	SIR 10413432; AEMO report: Power System Operating Incident Report – Trip of Red Cliffs–Horsham and Red Cliffs–Wemen–Kerang 220 kV transmission lines on 15 January 2014
S6	Loss of supply event frequency (no. of events > 0.05 system minutes)								0:00				0	no impact	
S7	Loss of supply event frequency (no. of events > 0.5 system minutes)								0:00				0	no impact	
S7	Loss of supply event frequency (no. of events > 0.5 system minutes)								0:00				0	no impact	
S7	Loss of supply event frequency (no. of events > 0.5 system minutes)								0:00				0	no impact	


AVERAGE OUTAGE DURATION														
Event proposed for exclusion		Description of the event and its impact on the network and performance	Cause of the event	Start date	Start time	End date	End time	Total hours + minutes unavailable	Circuits affected	Quantitative impact	Capped impact (if applicable)	Reasons for exclusion request	Further references	
Name of the event		Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	Start dd/mm/yy	Start hh:mm:ss	End dd/mm/yy	End hh:mm:ss		Name of circuits or plant affected	Name of any reactive plant or transformer affected	Number of hours, mins etc interrupted	Impact of exclusion event on AOD parameter (min)	Full details of the reason for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg. Exclusion 1.2 Third party event	A TNSP may provide further details of an exclusion event. TNSP to provide reference.
Name of any average outage duration parameters applying to AusNet														
S8	Average outage duration– lines (minutes)													
S8	Average outage duration– lines (minutes)													
S8	Average outage duration– lines (minutes)													
S9	Average outage duration– transformers (minutes)	KGTS-WETS-RCTS trip	At HOTS, at 2305 on 15/01/14, the RCTS 220 kV line tripped via protection. This is the 1st of the 3 tripping events occurred on this line due to smoke from a bushfire nearly 110 km south of RCTS. All the 3 events also unforeseeably caused the simultaneous tripping of the KGTS-WETS-RCTS 220 kV line and the consequential supply interruption to Powercor customers supplied from the WETS.	FAULT	15/01/14	23:05:00	15/01/14	23:35:00	0:30	B1 220/66KV TRANS AT WETS	0:30	Not applicable	EXCLUDE 9.1 Unregulated transmission asset	SIR 10413379
S9	Average outage duration– transformers (minutes)	KGTS-WETS-RCTS trip	At HOTS, at 1345 on 16/01/14, the RCTS 220 kV line tripped via protection. This is the 2nd of the 3 tripping events occurred on this line due to smoke from a bushfire nearly 110 km south of RCTS. All the 3 events also unforeseeably caused the simultaneous tripping of the KGTS-WETS-RCTS 220 kV line and the consequential supply interruption to Powercor customers supplied from the WETS.	FAULT	16/01/14	13:45:00	16/01/14	14:36:00	0:51	B1 220/66KV TRANS AT WETS	0:51	Not applicable	EXCLUDE 9.1 Unregulated transmission asset	SIR 10413432
S9	Average outage duration– transformers (minutes)	KGTS-WETS-RCTS trip	At HOTS, at 1554 on 16/01/14, the RCTS 220 kV line tripped via protection. This is the 3rd of the 3 tripping events occurred on this line due to smoke from a bushfire nearly 110 km south of RCTS. All the 3 events also unforeseeably caused the simultaneous tripping of the KGTS-WETS-RCTS 220 kV line and the consequential supply interruption to Powercor customers supplied from the WETS.	FAULT	16/01/14	15:54:00	16/01/14	15:59:00	0:05	B1 220/66KV TRANS AT WETS	0:05	Not applicable	EXCLUDE 9.1 Unregulated transmission asset	SIR 10413434

AusNet - S1 - Total circuit availability

Performance Targets	Graph	Collar	Target	Cap	Graph
Total circuit availability	0.9820	0.9841	0.9873	0.9905	0.9960
Weighting	-0.002	-0.0020	0.0000	0.0020	0.002

Performance Formulae	Formulae				When:	Conditions	S- Calc 1	S- Calc 2
Performance	=	-0.0020				Availability < 0.9841	-0.0020	-0.0020
	=	0.6250	x	Total circuit :	+	0.9841 ≤ Availability ≤ 0.9873	0.0045	0.0046
	=	0.6250	x	Total circuit :	+	0.9873 ≤ Availability ≤ 0.9905	0.0045	0.0046
	=	0.0020				0.9905 < Availability	0.0020	0.0020

Performance Outcomes	Performance without exclusions	Performance with exclusions
Total circuit availability	= 0.9945	0.9947
S-Factor	= 0.2000%	0.2000%




AusNet - S2 - Peak critical availability

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Peak critical availability	0.9840	0.9862	0.9939	0.9978	1
Weighting	-0.002	-0.0020	0.0000	0.0020	0.002

Performance Formulae	Formulae					Conditions	S- Calc 1	S- Calc 2
Performance	=	-0.0020				When: Availability < 0.9862	-0.0020	-0.0020
	=	0.2597	x	Peak critical	+	0.9862 ≤ Availability ≤ 0.9939	0.0009	0.0010
	=	0.5128	x	Peak critical	+	0.9939 ≤ Availability ≤ 0.9978	0.0018	0.0020
	=	0.0020				0.9978 < Availability	0.0020	0.0020

Performance Outcomes	Performance without exclusions	Performance with exclusions
Peak critical availability	= 0.9975	0.9978
S-Factor	= 0.1840%	0.1982%




AusNet - S3 - Peak non-critical availability

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Peak non-critical availability	0.9860	0.9883	0.9940	0.9969	0.999
Weighting	-0.0005	-0.0005	0.0000	0.0005	0.0005

Performance Formulae	Formulae					Conditions	S- Calc 1	S- Calc 2
Performance	=	-0.0005				When: Availability < 0.9883	-0.0005	-0.0005
	=	0.0877	x	Peak non-cr	+	0.9883 ≤ Availability ≤ 0.9940	0.0003	0.0003
	=	0.1724	x	Peak non-cr	+	0.9940 ≤ Availability < 0.9969	0.0005	0.0005
	=	0.0005				Availability < 0.9969	0.0005	0.0005

Performance Outcomes		Performance without exclusions	Performance with exclusions
Peak non-critical availability	=	0.9970	0.9971
S-Factor	=	0.0500%	0.0500%



AusNet - S4 - Intermediate critical availability

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Intermediate critical availability	0.9700	0.9729	0.9867	0.9936	0.9990
Weighting	0	0.0000	0.0000	0.0000	0

Performance Formulae	Formulae					Conditions	S- Calc 1	S- Calc 2
Performance	=	0.0000				When: Availability < 0.9729	0.0000	0.0000
	=	0.0000	x	Intermediate	+	0.9729 ≤ Availability ≤ 0.9867	0.0000	0.0000
	=	0.0000	x	Intermediate	+	0.9867 ≤ Availability ≤ 0.9936	0.0000	0.0000
	=	0.0000				0.9936 < Availability	0.0000	0.0000

Performance Outcomes		Performance without exclusions	Performance exclusions
Intermediate critical availability	=	0.0000	0.0000
S-Factor	=	0.0000%	0.0000%

AusNet - S5 - Intermediate non-critical availability

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Intermediate non-critical availability	0.9740	0.9757	0.9873	0.9931	0.9950
Weighting	0	0.0000	0.0000	0.0000	0

Performance Formulae	Formulae				When:	Conditions	S- Calc 1	S- Calc 2
Performance	=	0.0000			0.9757	Availability <	0.0000	0.0000
	=	0.0000	x	Intermediate	0.9757	Availability ≤	0.0000	0.0000
	=	0.0000	x	Intermediate	0.9873	Availability ≤	0.0000	0.0000
	=	0.0000			0.9931	Availability <	0.0000	0.0000


Performance Outcomes		Performance without exclusions	Performance with exclusions
Intermediate non-critical availability	=	0.0000	0.0000
S-Factor	=	0.0000%	0.0000%

AusNet - S6 - Loss of supply event frequency (no. of events > 0.05 system minutes per annum)

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Loss of supply event frequency (no. of events > 0.05 system minutes per annum)	5.00	3.00	2.00	1.00	0.00
Weighting	-0.00125	-0.0013	0.0000	0.0013	0.00125

Performance Formulae	Formulae	Conditions	S- Calc 1	S- Calc 2
		3 ≤ No. of events	-0.0013	-0.0013
		No. of events = 2	0.0000	0.0000
		No. of events = 1	0.0013	0.0013
		No. of events = 0	0.0013	0.0013

Loss of supply event frequency (no. of events > 0.05 system minutes per annum)	Performance without exclusions	Performance with exclusions
Loss of supply event frequency (no. of events > 0.05 system minutes per annum)	= 2	0
S-Factor	= 0.0000%	0.1250%




AusNet - S7 - Loss of supply event frequency (no. of events > 0.3 system minutes per annum)

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Loss of supply event frequency (no. of events > 0.3 system minutes per annum)	4.00	2.00	1.00	0.00	0
Weighting	-0.00125	-0.00125	0.00000	0.00125	0.00125

Performance Formulae	Formulae	Conditions	S- Calc 1	S- Calc 2
Performance		2 ≤ No. of events	-0.00125	-0.00125
		No. of events = 1	0.00000	0.00000
		No. of events = 0	0.00125	0.00125

Loss of supply event frequency (no. of events > 0.3 system minutes per annum)	Performance without exclusions	Performance with exclusions
Loss of supply event frequency (no. of events > 0.3 system minutes per annum)	=	0
S-Factor	=	0.1250%




AusNet - S8 - Average outage duration– lines (minutes)

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Average outage duration– lines (minutes)	867	667	382	98	0
Weighting	-0.00125	-0.0013	0.0000	0.0013	0.00125

Performance Formulae	Formulae					Conditions		S- Calc 1	S- Calc 2			
Performance	=	-0.0013				667	<	Duration	-0.0013	-0.0013		
	=	0.0000	x	Average outage	+	0.0017		382	≤	Duration	0.0012	0.0012
	=	0.0000	x	Average outage	+	0.0017		98	≤	Duration	0.0012	0.0012
	=	0.0013						98	<	Duration	0.0013	0.0013

Average outage duration– lines (minutes)		Performance without exclusions	Performance with exclusions
Average outage duration– lines (minutes)	=	104.0870	104.0870
S-Factor		0.1223%	0.1223%




AusNet - S9 - Average outage duration- transformers (minutes)

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Average outage duration- transformers (minutes)	756	556	412	268	0
Weighting	-0.00125	-0.0013	0.0000	0.0013	0.00125

Performance Formulae	Formulae				Conditions	S- Calc 1	S- Calc 2
Performance	=	-0.0013			556 < Duration	-0.0013	-0.0013
	=	0.0000	x	Average outage duration- tra	412 ≤ Duration	0.0015	0.0017
	=	0.0000	x	Average outage duration- tra	268 ≤ Duration	0.0015	0.0017
	=	0.0013			Duration < 268	0.0013	0.0013

Average outage duration- transformers (minutes)	Performance without exclusions	Performance with exclusions
Average outage duration- transformers (minutes)	= 242.4000	212.7800
S-Factor	= 0.1250%	0.1250%



AusNet - Revenue Calculation

Revenue cap information

Base year allowed revenue	454,974,504
Base year	2008/09
X-factor	-1.01%
Commencement of regulatory period	1/04/2008

Annual revenue adjusted for CPI	Dec-07	Dec-08	Dec-09	Dec-10	Dec-11	Dec-12	Dec-13	Dec-14
CPI (new index)	89.1	92.4	94.3	96.9	99.8	102	104.8	0

Nominal annual revenue	2008-09	2009-10	2010-11	2011-12	2012-13	2013-14
Allowed Revenue	454,974,504	476,590,848	491,303,424	509,948,415	530,514,651	547,685,677

Calendar year revenue	2008	2009	2010	2011	2012	2013	2014
Revenue	341,230,878	471,186,762	487,625,280	505,287,168	525,373,092	543,392,920	136,921,419

Revenue calendar year

136,921,419

S	Performance parameter	Target	Performance without exclusions			Performance with exclusions			Impact of exclusions	
			Performance	S-Factor	Final Incentive	Performance	S-Factor	Final Incentive		
S1	Total circuit availability	0.9873	0.9945	0.2000%	\$273,843	0.9947	0.2000%	\$273,843	0.000%	
S2	Peak critical availability	0.9939	0.9975	0.1840%	\$251,935	0.9978	0.1982%	\$271,432	0.014%	
S3	Peak non-critical availability	0.9940	0.9970	0.0500%	\$68,461	0.9971	0.0500%	\$68,461	0.000%	
S4	Intermediate critical availability	0.9867	0.0000	0.0000%	\$0	0.0000	0.0000%	\$0	0.000%	
S5	Intermediate non-critical availability	0.9873	0.0000	0.0000%	\$0	0.0000	0.0000%	\$0	0.000%	
S6	Loss of supply event frequency (no. of events > 0.05 system minutes per annum)	2	2	0.0000%	\$0	0	0.1250%	\$171,152	0.125%	
S7	Loss of supply event frequency (no. of events > 0.3 system minutes per annum)	1	0	0.1250%	\$171,152	0	0.1250%	\$171,152	0.000%	
S8	Average outage duration– lines (minutes)	382	104	0.1223%	\$167,483	104	0.1223%	\$167,483	0.000%	
S9	Average outage duration– transformers (minutes)	412	242	0.1250%	\$171,152	213	0.1250%	\$171,152	0.000%	
TOTALS					0.8063%	\$1,104,026		0.9456%	\$1,294,674	0.1392%

Aggregate outcome

S-factor	0.9456%
Financial Incentive	1,294,674
Financial year affected by financial incentive	2014/15