

## Instructions

This template must be used by **TasNetworks** to report service performance information for **2H 2015** (1 Jul - 31 Dec 2015)

### Inputs

- Blue, yellow and green worksheets are for inputs, including performance and exclusion information. The TNSP only needs to enter data on these worksheets.
  - To add more rows in the Inputs-exclusions tabs please insert rows after row 4.
- Cells where TNSP input is required are shaded orange:
- Cells where the input is sourced from the revenue proposal are shaded green:

TNSP input re  
revenue prop

### Calculations

- Purple worksheets are the s-factor results based on the performance inputs entered by the TNSP. These are automatically calculated.
- cells where a calculation occurs are shaded grey with orange text:

calculation c

### Outcomes

- The red worksheet shows the total performance, s-factor and financial incentive results based on the TNSP's performance inputs.

	Collar	Target	Cap	Weighting
s1	64.59	31.17	13.39	0.2
s2	17.28	11.60	7.03	0.2
s3	9.99	3.33	0.17	0.1
s4	17.62	9.99	2.67	0.0
s5	4.37	2.82	1.28	0.0
s6	32.82	14.00	1.07	0.0

s7	6	5	4	0.15
s8	3	2	0	0.15

s9	169.76	111.52	63.99	0.2

s10	14.0	9.0	5.0	0.0
s11	25.0	8.0	0.0	0.0
s12	8.0	4.0	1.0	0.0

TNSP  
STPIS version  
Regulatory Determination  
Base Year Allowed Revenue  
Base Year  
Commencement of regulatory year  
X factor

TasNetworks  
December, 2012  
2014/15 - 2017/18  
186,931,284  
2014-15  
1 Jul 2014  
9.81%

	2014-15	2015-16	2016-17	2017-18	2018-19
Annual revenue (\$2014-15)	186,931,284				
Annual revenue adjusted for CPI	186,931,284	171,494,719			

	2H 2015	2016	2017	2018	1H 2019
Calendar year revenue	85,747,359				

**Other inputs**  
Assessment Period  
Financial year to affect revenue:  
Date prepared:  
Revision date:

2H 2015  
2016/17  
28-Jan-16

Unit	Performance	
	without exclusions	with exclusions
average circuit outage rate (%)	20.1	17.8
average circuit outage rate (%)	7.3	7.3
average circuit outage rate (%)	20.8	20.8
average circuit outage rate (%)	11.2	8.4
average circuit outage rate (%)	14.2	14.2
average circuit outage rate (%)	70.8	70.8

Unit	exclusions	
number of events per annum	3	3
number of events per annum	0	0

Unit	Average outage duration	
number of LOS events	12	12
Aggregate LOS minutes	1,581	1,546
Average outage duration	132	137
number of events per annum	4	4
number of events per annum	2	2
number of events per annum	6	6

Dec-13  
CPI 104.8

Dec-14  
106.6

Dec-15

Dec-16

Dec-17

Dec-18

Number of events pa - 2015			
without exclusions	with exclusions	exclusions	no. or defined circuits
24	21	3	107
8	8	0	109
1	1	0	12
10	7	3	107
14	14	0	109
3	3	0	12

12	12	0
883	883	0
74	74	0

Number of events pa - 2014			
without exclusions	with exclusions	exclusions	no. or defined circuits
19	17	2	107
8	8	0	109
4	4	0	12
14	11	3	107
17	17	0	109
14	14	0	12

12	11	1
2278	2,208	70
190	201	70

Average (2014, 2015)			
without exclusions	with exclusions	exclusions	no. or defined circuits
22	19	3	107
8	8	0	109
3	3	0	12
12	9	3	107
16	16	0	109
9	9	0	12

12	12	1
1,581	1,546	35
132	137	35

Parameter	Average circuit outage rate	Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Count of circuit events	Circuits affected	Reasons for exclusion request	Further references
	Name of any average circuit outage rate parameters applying to TasNetworks	Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	Identify the events that are to be excluded from the performance measure	Name of circuits affected	Full details of the reason/s for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg. Exclusion 1.2 Third party event.	A TNSP may provide further details of an exclusion event. Please provide reference to any attachments submitted.
S1	TLacor-fault	fault outage of WY-CA 220 kV Transmission Circuit 13 Jan 2015	IR1673 WY-CA 220 kV transmission circuit tripped due to intertrip from Hydro.	Intertrip		WY-CA 220 kV Transmission 1 Circuit	Defined Exclusion 1.3 Third Party Outage	see incident investigation report exclusion ref E005
S1	TLacor-fault	fault outage of FA-RC 2 220 kV Transmission Circuit 13 March 2015	IR1686 FA-RC 2 220 kV transmission circuit tripped due to third party inter trip.	Intertrip		FA-RC 2 220 kV Transmission 1 Circuit	Defined Exclusion 1.3 Third Party Outage	see incident investigation report exclusion ref E008
S1	TLacor-fault	fault outage of GT-TV 1 110 kV Transmission Circuit 15 Dec 2015	IR? GT-TV 1 110 kV transmission circuit tripped during protection testing at AETV.	Intertrip		GT-TV 1 110 kV Transmission 1 Circuit	Defined Exclusion 1.3 Third Party Outage	see incident investigation report exclusion ref E004
S2						0		
S3						0		
S4	TLacor-forced	forced outage of FA-MA 110 kV Transmission Circuit 26 Sep 2015	Farrell - Mackintosh 110kV transmission line to be Opened at Farrell and Mackintosh at Hydro request while planned fuel reduction burn by Parks & Wildlife is in progress on Saturday 26/9/2015	Hydro request, fuel reduction burn		FA-MA 110 kV Transmission 1 Circuit	Defined Exclusion 1.3 Third Party Outage	Not in Hydro outage record.
S4	TLacor-forced	forced outage of PO-PM 6 220 kV Transmission Circuit 12 Nov 2015	Hydro request for earth fault relay tests at Poatina. Generator out of service.	Hydro request, relay tests		PO-PM 6 220 kV Transmission 1 Circuit	Defined Exclusion 1.3 Third Party Outage	See Hydro outage record showing machine OOS
S4	TLacor-forced	forced outage of GT-TV 1 110 kV Transmission Circuit 15-16 Dec 2015	Hydro request.	Hydro request.		GT-TV 1 110 kV Transmission 1 Circuit	Defined Exclusion 1.3 Third Party Outage	Not shown in Hydro record for BBT1, but no isolation and available for service. See also exclusion ref E014.
S5						0		
S6						0		

S

Parameter	LOS event frequency	Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Start date	Start time	End date	End time	Quantitative impact	Demand shed and time	Circuits affected	Maximum system demand	Reasons for exclusion request	Further references
S	Name of any LOS event parameters applying to TasNetworks	Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	dd/mm/yy	hh:mm:ss	dd/mm/yy	hh:mm:ss	Hours+Minutes unavailable (min)	The (MW) demand shed and the duration it was shed for.	Name of circuits or plant affected	The max system demand that occurred up until the time of the event	Full details of the reason/s for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg.	A TNSP may provide further details of an exclusion event. Please provide reference to any attachments submitted.
S7									0:00					
S8									0:00					

Average Outage Duration	Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Start date	Start time	End date	End time	Hours+Minutes unavailable (min)	Quantitative impact of exclusion event on AOD Parameter	Capped impact of exclusion event on AOD	Circuits affected	Reasons for exclusion request	Further references
	Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	dd/mm/yy	hh:mm:ss	dd/mm/yy	hh:mm:ss					Full details of the reason for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg. Exclusion 1.2 Third party event	A TNSP may provide further details of an exclusion event. Please provide reference to any attachments submitted.
								0:00		0:00			

Parameter	Average circuit outage rate	Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Count of circuit events	Circuits affected	Reasons for exclusion request	Further references
	Name of any average circuit outage rate parameters applying to TasNetworks	Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	Identify the events that are to be excluded from the performance measure	Name of circuits affected	Full details of the reason/s for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg. Exclusion 1.2 Third party event.	A TNSP may provide further details of an exclusion event. Please provide reference to any attachments submitted.
S1	TLacor-fault	fault outage of PO-PM 3 220 kV Transmission Circuit 14 Jun 2014	IR1632 PO-PM No 3 220 kV transmission line circuit tripped following an intertrip received from the generator.	Intertrip	1	PO-PM 3 220 kV Transmission Circuit	Defined Exclusion 1.3 Third Party Outage	see incident investigation report exclusion ref E009
S1	TLacor-fault	fault outage of TU-LE-WA 1 110 kV Transmission Circuit 15 Jul 2014	IR1636 TU-LE-WA 1 110 kV transmission circuit tripped when an intertrip was received from the generator.	Intertrip	1	TU-LE-WA 1 110 kV Transmission Circuit	Defined Exclusion 1.3 Third Party Outage	see incident investigation report exclusion ref E010
S2					0			
S3					0			
S4	TLacor-forced	forced outage of SH-LM 220 kV Transmission Circuit 1 Apr 2014	Sheffield - Lemonthyme T/L outage at Hydro Tasmania request to allow corrective maintenance of motorised disconnecter 29 at Lemonthyme.	Hydro request	1	SH-LM 220 kV Transmission Circuit	Defined Exclusion 1.3 Third Party Outage	see Hydro outage list ref E011, restriction number 1000001432
S4	TLacor-forced	forced outage of PO-PM 1 110 kV Transmission Circuit 17 May 2014	Hydro Tasmania requested PO-PM No 1 110kV Transmission Line out of service to conduct work on Poatina T1	Hydro request	1	PO-PM 1 110 kV Transmission Circuit	Defined Exclusion 1.3 Third Party Outage	see Hydro outage list ref E011, restriction number 1000001662
S4	TLacor-forced	forced outage of LI-WY 220 kV Transmission Circuit 27 May 2014	Open LI-WY Transline for Hydro	Hydro request	1	LI-WY 220 kV Transmission Circuit	Defined Exclusion 1.3 Third Party Outage	see Hydro outage list ref E011, restriction number 1000001739 and 1000001752
S5					0			
S6					0			


Average Outage Duration	Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Start date	Start time	End date	End time	Quantitative impact	Capped impact	Circuits affected	Reasons for exclusion request	Further references	
	Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	dd/mm/yy	hh:mm:ss	dd/mm/yy	hh:mm:ss	Hours+Minutes unavailable (min)	Impact of exclusion event on AOD Parameter	Impact of capped exclusion event on AOD parameter - the impact is capped at seven days	Name of circuits or plant affected	Full details of the reason for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg. Exclusion 1.2 Third party event	A TNSP may provide further details of an exclusion event. Please provide reference to any attachments submitted.
s9	fault outage of QU 22 kV A Bus	IR1655 Que 22 kV bus bar tripped following a customer feeder fault	Inspections found a damaged insulator on the private distribution line supplying the Hellyer and Que River Mines.	24/10/14	12:12:00	24/10/14	13:22:00	1:10	1	1:10	QU 22 kV A Bus	Defined Exclusion 1.3 Third Party Outage	see incident investigation report exclusion ref E012

**TasNetworks - s1 - line outage - fault**

Performance Targets					Performance Outcomes				
	Graph start	Collar	Target	Cap	Graph end			without exclusions	with exclusions
line outage - fault	84.6%	64.6%	31.2%	13.4%	-1.4%	line outage - fault	=	20%	18%
Weighting	-0.2000%	-0.2000%	0.0000%	0.2000%	0.2000%	S-Factor	=	0.12%	0.15%

Performance Formulae					Conditions						
	Formulae					Conditions					
Performance	=	-0.0020				64.6% <	line outage		S- Calc 1	S- Calc 2	
	=	-0.0060	x	line outage	+	31.2% ≤	line outage	≤	64.6%	0.0007	0.0008
	=	-0.0112	x	line outage	+	13.4% ≤	line outage	≤	31.2%	0.0012	0.0015
	=	0.0020					line outage	<	13.4%	0.0020	0.0020




**TasNetworks - s2 - transformer outage - fault**

Performance Targets					Performance Outcomes				
	Graph start	Collar	Target	Cap	Graph end			without exclusions	with exclusions
transformer outage - fault	37.30%	17.28%	11.60%	7.03%	-13.00%	transformer outage - fault	=	7%	7%
Weighting	-0.2000%	-0.2000%	0.0000%	0.2000%	0.2000%	S-Factor	=	0.19%	0.19%

Performance Formulae					Conditions						
	Formulae					Conditions					
Performance	=	-0.0020				17.28% <	transformers outage		S- Calc 1	S- Calc 2	
	=	-0.0352	x	transformers ou	+	11.6% ≤	transformers outage	≤	17.3%	0.0015	0.0015
	=	-0.0438	x	transformers ou	+	7.0% ≤	transformers outage	≤	11.6%	0.0019	0.0019
	=	0.0020					transformers outage	<	7.0%	0.0020	0.0020




**TasNetworks - s3 - reactive plant - fault**

Performance Targets					Performance Outcomes				
	Graph start	Collar	Target	Cap	Graph end			without exclusions	with exclusions
reactive plant - fault	30.00%	9.99%	3.33%	0.17%	0.00%	reactive plant - fault	=	21%	21%
Weighting	-0.10%	-0.10%	0.00%	0.10%	0.10%	S-Factor	=	-0.10%	-0.10%

Performance Formulae					Conditions						
	Formulae					Conditions					
Performance	=	-0.0010				9.99% ≤	reactive plant outage		S- Calc 1	S- Calc 2	
	=	-0.0150	x	reactive plant o	+	3.3% ≤	reactive plant outage	≤	10.0%	-0.0026	-0.0026
	=	-0.0316	x	reactive plant o	+	0.2% ≤	reactive plant outage	≤	3.3%	-0.0055	-0.0055
	=	0.0010					reactive plant outage	<	0.2%	0.0010	0.0010



**TasNetworks - s4 - line outage - forced**

Performance Targets					Performance Outcomes				
	Graph start	Collar	Target	Cap	Graph end			without exclusions	with exclusions
line outage - forced	17.40%	17.62%	9.99%	2.67%	2.90%	line outage - forced	=	11%	8%
Weighting	0.00%	0.00%	0.00%	0.00%	0.00%	S-Factor	=	0.00%	0.00%

Performance Formulae					Conditions						
	Formulae					Conditions					
Performance	=	0.0000				17.62% ≤	line outage (force)		S- Calc 1	S- Calc 2	
	=	0.0000	x	line outage (fo	+	10.0% ≤	line outage (force)	≤	17.6%	0.0000	0.0000
	=	0.0000	x	line outage (fo	+	2.7% ≤	line outage (force)	≤	10.0%	0.0000	0.0000
	=	0.0000					line outage (force)	<	2.7%	0.0000	0.0000



**TasNetworks - s5 - transformer outage - forced**

<b>Performance Targets</b>		Graph start	Collar	Target	Cap	Graph end	<b>Performance Outcomes</b>		without exclusions	with exclusions
transformer outage - forced		4.20%	4.37%	2.82%	1.28%	1.50%	transformer outage - forced	=	14%	14%
Weighting		0.00%	0.00%	0.00%	0.00%	0.00%	S-Factor	=	0.00%	0.00%

<b>Performance Formulae</b>		Formulae				Conditions		S- Calc 1	S- Calc 2
Performance	=	0.0000					4.37% ≤ transformers outage (force)	0.0000	0.0000
	=	0.0000	x	transformers ou	+	0.0000	2.8% ≤ transformers outage (force ≤	4.4%	0.0000
	=	0.0000	x	transformers ou	+	0.0000	1.3% ≤ transformers outage (force ≤	2.8%	0.0000
	=	0.0000					transformers outage (force <	1.3%	0.0000

**TasNetworks - s6 - reactive plant - forced**

<b>Performance Targets</b>		Graph start	Collar	Target	Cap	Graph end	<b>Performance Outcomes</b>		without exclusions	with exclusions
reactive plant - forced		32.60%	32.82%	14.00%	1.07%	1.30%	reactive plant - forced	=	71%	71%
Weighting		0.00%	0.00%	0.00%	0.00%	0.00%	S-Factor	=	0.00%	0.00%

<b>Performance Formulae</b>		Formulae				Conditions		S- Calc 1	S- Calc 2
Performance	=	0.0000					32.82% ≤ reactive plant outage (force)	0.0000	0.0000
	=	0.0000	x	reactive plant o	+	0.0000	14.0% ≤ reactive plant outage (for ≤	32.8%	0.0000
	=	0.0000	x	reactive plant o	+	0.0000	1.1% ≤ reactive plant outage (for ≤	14.0%	0.0000
	=	0.0000					reactive plant outage (for <	1.1%	0.0000

**TasNetworks - s7 - Loss of supply event frequency: >0.10 system minutes**

**Performance Targets**

>0.10 system minutes  
Weighting

Graph start	Collar	Target	Cap	Graph end
8	6.0	5.0	4.0	0
-0.00150	-0.00150	0.00000	0.00150	0.00150

**Performance Formulae**

Performance

Formulae

**Performance Outcomes**

>0.10 system minutes  
S-Factor


	without exclusions	with exclusions
=	3	3
=	0.15%	0.15%
S- Calc 1	-0.0015	-0.0015
S- Calc 2	0.0000	0.0000
	0.0015	0.0015

When: 6.0 <

Conditions

No. of events = 5  
No. of events = 4

TasNetworks - S7 - Loss of supply event frequency: >0.10 system minutes



**TasNetworks - s8 - Loss of supply event frequency: >1.00 system minutes**

**Performance Targets**

>1.00 system minutes  
Weighting

Graph start	Collar	Target	Cap	Graph end
4	3.0	2.0	0.0	0
-0.0015	-0.0015	0.0000	0.0015	0.0015

**Performance Formulae**

Performance

Formulae

**Performance Outcomes**

>1.00 system minutes  
S-Factor


	without exclusions	with exclusions
=	0	0
=	0.15%	0.15%
S- Calc 1	-0.0015	-0.0015
S- Calc 2	0.0000	0.0000
	0.0015	0.0015

When: 2.0 <

Conditions

No. of events = 1  
No. of events = 0

TasNetworks - S8 - Loss of supply event frequency: > 1.00 system minutes



TasNetworks - s9 - Average outage duration

Performance Targets

	Graph start	Collar	Target	Cap	Graph end
Average outage duration	300	170	112	64	0
Weighting	-0.00200	-0.00200	0.00000	0.00200	0.00200

Performance Formulae


	Formulae				
Performance	=	-0.0020			
	=	0.0000	x	No. of events	+ 0.0038
	=	0.0000	x	No. of events	+ 0.0047
	=	0.0020			

Performance Outcomes

		without exclusions	with exclusions
Average outage duration	=	132	137
S-Factor	=	-0.07%	-0.09%

Conditions

When:	Conditions	S- Calc 1	S- Calc 2
170	< No. of events	-0.0020	-0.0020
111.52	≤ No. of events	-0.0007	-0.0009
63.99	≤ No. of events	-0.0008	-0.0011
	= No. of events	0.0020	0.0020



## TasNetworks - Performance outcomes

### Aggregate outcome

S-factor	0.449%
Financial Incentive	\$385,264
Financial year affected by financial incentive	2015-16

S	Performance parameter	Target	Performance without exclusions			Performance with exclusions			Impact of exclusions
			Performance	S-Factor	Final Incentive	Performance	S-Factor	Final Incentive	
s1	line outage - fault	31.17%	20.09%	0.12%	\$106,837	17.76%	0.15%	\$129,373	0.03%
s2	transformer outage - fault	11.60%	7.34%	0.19%	\$159,882	7.34%	0.19%	\$159,882	0.00%
s3	reactive plant - fault	3.33%	20.83%	-0.10%	-\$85,747	20.83%	-0.10%	-\$85,747	0.00%
s4	line outage - forced	9.99%	11.21%	0.00%	\$0	8.41%	0.00%	\$0	0.00%
s5	transformer outage - forced	2.82%	14.22%	0.00%	\$0	14.22%	0.00%	\$0	0.00%
s6	reactive plant - forced	14.00%	70.83%	0.00%	\$0	70.83%	0.00%	\$0	0.00%
s7	LOS >0.10 system minutes	5	3	0.15%	\$128,621	3	0.15%	\$128,621	0.00%
s8	LOS >1.00 system minutes	2	0	0.15%	\$128,621	0	0.15%	\$128,621	0.00%
s9	Average outage duration	111.52	132	-0.07%	-\$59,447	137	-0.09%	-\$75,486	-0.02%
<b>TOTALS</b>				<b>0.44%</b>	<b>\$378,767</b>		<b>0.45%</b>	<b>\$385,264</b>	<b>0.01%</b>

Revenue calendar year: \$85,747,359