



Rowville Terminal Station Gas Insulated Lines (GIL) Replacement

TRR Network Study Results

AusNet Services

21 October 2025

Document Control

Version	Date	Author	Reviewer	Approver	Description
0.1	8 Oct 2025	[C.I.C]	[C.I.C]	[C.I.C]	First issue for customer's review
1.0	21 Oct 2025	[C.I.C]	[C.I.C]	[C.I.C]	Final issue to customer

Disclaimer

Elite Power Solutions (EPS) has prepared this document for the sole use of the client and for a specific purpose, each as expressly stated in the document. This document has been prepared for the titled project or named part thereof and should not be relied upon or used for any other project without an independent check being carried out as to its suitability and prior written authority EPS being obtained. This document has been prepared based on the client's description of its requirements and EPS's experience, having regard to assumptions that can reasonably be expected to make in accordance with sound professional principles.

EPS accepts no responsibility or liability for the consequence of this document being used for a purpose other than those for which it was commissioned. Any person using or relying on the document for such other purpose will by such use or reliance be taken to confirm his agreement to indemnify EPS for all losses or damages resulting therefrom. EPS accepts no responsibility or liability for this document to any party other than the person by whom it was commissioned.

To the extent that any report issued by EPS on the basis of this proposal is based on information supplied by other parties, EPS accepts no liability for any loss or damage suffered by the client, whether contractual or tortious, stemming from any conclusions based on data supplied by parties other than EPS and used by EPS in preparing any such report.

Table of Contents

Document Control.....	2
Disclaimer.....	2
1 Introduction.....	4
2 Study Methodology.....	5
2.1 Network Operation Scenarios.....	5
2.2 General Approach for Contingency Analysis	5
2.3 PSSE Base Case & Load (Bus Numbers)	6
2.4 New ROTS A3 1,000 MVA 500/220 kV Transformer Impedance.....	7
2.5 Assumptions used for the Element Ratings	8
2.6 Network Configuration (Status Quo & new ROTS A3 Transformer).....	9
3 Results	10
4 Summary	11
5 Appendix	12
6 References	12

1 Introduction

AusNet Services is preparing business cases for several major station replacement projects in connection with the 2027-2032 Transmission Revenue Reset (TRR). Some of these projects require network studies (steady-state load flow studies) to assess the market impact of asset failures. To that end, Elite Power Solutions Pty Ltd (“EPS”) were engaged by AusNet Services to conduct load flow studies for certain projects and scenarios using software, models, information and equipment provided by AusNet Services.

The avoided cost of an asset failure will be used to economically justify the investment in support of AusNet Services’ TRR Capex forecast and will be used as supporting information for the TRR revenue application. The economic justification and related calculations for these projects are not included in EPS’s scope but will be completed by others.

There are two Gas Insulated Lines (GIL) with a length of approximately 300m each at Rowville Terminal Station. These GIL are Rowville-Thomastown 220 kV line and Rowville-South Morang No.3 500 kV line were previously installed for the purpose and function of avoiding multiple 500kV and 220kV transmission line crossings. AusNet Services has conducted an asset condition assessment of these GIL of which they are found to be in poor condition with leaks and are targeted for replacement in the 2027-2032 TRR period.

The results in this document refer to network studies carried out for the potential replacement of the GIL section of the Rowville – Thomastown 220kV line and Rowville-South-Morang No.3 500kV line and are purely technical in nature.



Figure 1: Gas Insulated Lines (GIL) at Rowville Terminal Station

2 Study Methodology

2.1 Network Operation Scenarios

AusNet Services obtained an updated PSSE OPDMS network model from AEMO and provided to EPS. The assessment is conducted using this PSSE OPDMS network model to quantify the Maximum Supportable Demand (MSD) that may be impacted due to the failure (outage) of ROTS-TTS 220kV line and ROTS-SMTS No.3 500 kV line.

Loadflow modelling was conducted using the existing network and potential augmentation of installing a new ROTS A3 500/220 kV Transformer referencing the Project Specification Consultation Report (PSCR) for Eastern Victoria Grid Reinforcement [1]. The installation of the new ROTS A3 500/220 kV Transformer is to relieve N condition loading of ROTS A1 500/220 kV Transformer.

The specific operating scenarios are shown in Table 1 below.

Table 1: Status Quo Network Configuration & Operating Scenarios

Scenario	Asset Failure Contingency N-1	Asset Failure Contingency N-2	Asset Failure Contingency N-3	Secure Operating State Contingency
1	None	None	None	Trip of every element in VIC (one at a time)
2	ROTS-TTS 220kV line	None	None	Trip of every element in VIC (one at a time)
3	ROTS-SMTS No.3 500 kV line	None	None	Trip of every element in VIC (one at a time)
4	ROTS-TTS 220kV line	ROTS-SMTS No.3 500kV line	None	Trip of every element in VIC (one at a time)

2.2 General Approach for Contingency Analysis

Asset Failure Contingency N-1

- PSSE Contingency Analysis (ACCC) Simulation
 - Step 1: Switch Out Element and ensure that no other Element (transformer/lines) overloads its Continuous Rating. If overload is found, System Demand is reduced.
 - Step 2: Run N-1-1 Contingency Analysis by using Short-Term Rating. System Demand is reduced and re-run ACCC until no overload is found using Short Term Rating
- Maximum Supportable Demand: System Demand – Load Shed (Step 1) – Load Shed (Step 2)

Asset Failure Contingency N-2

- PSSE Contingency Analysis (ACCC) Simulation
 - Step 1: Switch Out 2 x Elements and ensure that no other Element (transformer/lines) overloads its Continuous Rating. If overload is found, System Demand is reduced.
 - Step 2: Run N-1-1 Contingency Analysis by using Short-Term Rating. System Demand is reduced and re-run ACCC until no overload is found using Short Term Rating
- Maximum Supportable Demand: System Demand – Load Shed (Step 1) – Load Shed (Step 2)

Asset Failure Contingency N-3

- PSSE Contingency Analysis (ACCC) Simulation
 - Step 1: Switch Out 3 x Elements and ensure that no other Element (transformer/lines) overloads its Continuous Rating. If overload is found, System Demand is reduced.
 - Step 2: Run N-1-1 Contingency Analysis by using Short-Term Rating. System Demand is reduced and re-run ACCC until no overload is found using Short Term Rating
- Maximum Supportable Demand: System Demand – Load Shed (Step 1) – Load Shed (Step 2)

2.3 PSSE Base Case & Load (Bus Numbers)

PSSE Base Case (VAPR20223) was used with the demand forecast of year 2025 and load are scaled up to its MSD. Below are the PSSE bus numbers used for load scaling.

Subsystem (SMTS+ROTS+CBTS Supply Points)

324001,324031,321030,381030,379001,379002,373030,371031,315033,315020,365032,315020,365032,365022,366030,366031,366020,377031,377002,374001,332001,349030,349020,340080,340081

ERTS

324001,324031

CBTS

321030

TBTS

381030

TTS

379001,379002

SMTS

373030,371031

BTS

315033

315020

RTS

365032

365022

RWTS

366030,366031

366020

TSTS

377031,377002

SVTS

374001

HTS
332001

MTS
349030
349020

JLA
340080,340081

2.4 New ROTS A3 1,000 MVA 500/220 kV Transformer Impedance

Below is the impedance used for the proposed option

Two Winding Transformer Data Record

Power Flow Short Circuit

Line Data

From Bus Number 368082 From Bus Name ROWVLE_220C 220.00 ☒ In Service

To Bus Number 368091 To Bus Name 3ROWVLE_500B500.00 ☐ Metered on From end

Branch ID 3 Transformer Name ROTS_500_A3TR_220 ☐ Winding 1 on From end

Vector Group

I/O Data

Winding I/O Code 3 - Turns ratio (pu on nom wind kV) Impedance I/O Code 1 - Z pu (winding kV system MVA) Admittance I/O Code 1 - Y pu (system base)

Transformer Impedance Data

Specified R (pu) 0.000180 Specified X (pu) 0.018230

Magnetizing G (pu) 0.00000 Magnetizing B (pu) 0.00000

Impedance Table

0

R table corrected (pu) 0.00018 X table corrected (pu) 0.01823

Owner Data

Owner Fraction

1 Select ... 1.000

0 Select ... 1.000

0 Select ... 1.000

0 Select ... 1.000

Transformer Nominal Ratings Data

Winding 1 Ratio (pu) 0.9750 Winding 1 Nominal kV 500.0000 Ratings (MVA) NORM 1000.0

Winding 2 Ratio (pu) 1.0000 Winding 2 Nominal kV 220.0000 EMER 1250.0

Winding (1-2) Angle (degrees) 0.00 Winding MVA 100.0000 LD SH 1500.0

RATE4 0.0

Control Data

Controlled Bus Number 368082 Controlled Bus Name ROWVLE_220C Control Mode 1- Voltage

☐ Controlled Bus On Winding Side ☐ Auto Adjust

Tap Positions Wnd Connect Angle

17 0.00000

R1max (pu) 1.10000 R1min (pu) 0.90000

Vmax (pu) 1.03000 Vmin (pu) 0.97890

Load Drop Comp

Load Drop Comp R (pu) 0.00000

Load Drop Comp X (pu) 0.00000


OK Cancel

2.5 Assumptions used for the Element Ratings

- KTS A2, A3 & A4 Transformer: 750 MVA (Continuous) & 810 MVA (Short-Term)
- KTS A2, A3 & A4 Transformer: 1,000 MVA (Continuous) & 1,500 MVA (Short-Term)
- ROTS A1, A2 & A3 (new) Transformer: 1,000 MVA (Continuous) & 1,500 MVA (Short-Term)
- MLTS A1 & A2 Transformer: 1,000 MVA (Continuous) & 1,500 MVA (Short-Term)
- CBTS A1 Transformer: 1,000 MVA (Continuous) & 1,500 MVA (Short-Term)
- SMTS H1 Transformer: 700 MVA (Continuous & Short-Term)
- MLTS-GTS No.1 220kV line: 772 MVA (Continuous & Short-Term) / 1049 MVA (Uprate Continuous & Short-Term)
- MLTS-GTS No.2 220kV line: 775 MVA (Continuous & Short-Term) / 1049 MVA (Uprate Continuous & Short-Term)
- GTS-DPTS 220kV line: 425.5 MVA (Continuous & Short-Term)
- GTS-KTS No.1 & No.3 220kV line: 425.5 MVA (Continuous & Short-Term)
- 45degC ratings are applied on all other elements

2.6 Network Configuration (Status Quo & new ROTS A3 Transformer)

SMTS, ROTS & CBTS subsystems have a total demand of 4,894 MW.



4894MW - Original VAPR2023 Case

(SMTS+TTS+BTS+RTS+RWTS+TSTS+SVTS+HTS+MTS+ERTS+TBTS+CBTS+JLA[block load])

* WDP (offline, not considered)

3 Results

Summary of results are shown in Tables 2 and 3. Detailed results are presented in the Appendix section.

Table 2: Status Quo Network

No	Scenario	Summer			Winter		
		SMTS+ROTS + CBTS Subsystem (MW)	Maximum Supportable Demand (MW)	Load at Risk (MW)	SMTS+ROTS+CBTS Subsystem (MW)	Maximum Supportable Demand (MW)	Load at Risk (MW)
1	System Intact	4894	4894		4894	4894	
1a	Prior Outage ROTs-TTS	4894	4894	0	4894	4894	0
1b	Prior Outage ROTs-SMTS	4894	4894	0	4894	4894	0

Table 3: Install New ROTs A3 Transformer

No	Scenario	Summer			Winter		
		SMTS+ROTS + CBTS Subsystem (MW)	Maximum Supportable Demand (MW)	Load at Risk (MW)	SMTS+ROTS+CBTS Subsystem (MW)	Maximum Supportable Demand (MW)	Load at Risk (MW)
2	System Intact	5803	5803		5803	5803	
2a	Prior Outage ROTs-TTS	5803	5803	0	5803	5803	0
2b	Prior Outage ROTs-SMTS	5250	5250	553	5250	5250	553
2c	Prior Outages ROTs-TTS & ROTs-SMTS	5220	5220	583	5220	5220	583

4 Summary

1. Status Quo Network

- **System Intact:** There are existing network constraints (loss of ROTS A1 Transformer) in the base case but is not attributed to ROTS-TTS 220 kV line or ROTS-SMTS No.3 500 kV line outage. Summer and Winter Maximum Supportable Demand is approximately 4.894 MW. As such, no load at risk.
- **Prior Outage of ROTS-TTS 220 kV line:** For a contingent trip of ROTS A1 Transformer (most critical), no overloads attributed to this prior outage. Note that there are existing network constraints as stated in the System Intact (base case). Summer and Winter Maximum Supportable Demand is approximately 4.894 MW. As such, no load at risk.
- **Prior Outage of ROTS-SMTS No.3 500 kV line:** For a contingent trip of ROTS A1 Transformer (most critical), no overloads attributed to this prior outage. Note that there are existing network constraints as stated in the System Intact case. Summer and Winter Maximum Supportable Demand is approximately 4.894 MW. As such, no load at risk.

2. Install New ROTS A3 Transformer

In order to address the N loading of ROTS A1 Transformer, a new ROTS A3 Transformer is installed.

- **System Intact:** SMTS-ROTS-CBTS subsystems are globally scaled to 5,803 MW as a base. For a contingent trip of KTS A3 Transformer (most critical), no overloads to any element found. Summer and Winter Maximum Supportable Demand is approximately 5.803 MW. As such, no load at risk.
- **Prior Outage of ROTS-TTS 220 kV line:** For a contingent trip of KTS A3 Transformer (most critical), no overloads to any element found. Summer and Winter Maximum Supportable Demand is approximately 5.803 MW. As such, no load at risk.
- **Prior Outage of ROTS-SMTS No.3 500 kV line:** For a contingent trip of CBTS-HWTS No.4 500 kV line (most critical), voltage collapse is observed in the 500 kV and 220kV part of the network, in the vicinity of HWTS and SMTS. Load shedding of 213 MW (load at risk) is required to address the voltage collapse. Summer and Winter Maximum Supportable Demand is approximately 5.590 MW.
- **Simultaneous Prior Outages of ROTS-TTS 220 kV line and ROTS-SMTS No.3 500 kV line:** For a contingent trip of CBTS-HWTS No.4 500 kV line (most critical), overload on SMTS-TTS No.1 220kV (**105%**). Load shedding of 583 MW (load at risk) is required to address the overload. Summer and Winter Maximum Supportable Demand is approximately 5.250 MW.

5 Appendix

Detailed results are shown in the respective spreadsheets:

- Summary_ROTTS_GIL_Rev2.xlsx

6 References

- [1] Eastern Victoria Grid Reinforcement
<https://www.aemo.com.au/initiatives/major-programs/eastern-victoria-grid-reinforcement>