

PROCEDURE

NETWORK ASSET USEFUL LIVES

ELE-999-PR-IN-012

Revision Number: 5

Revision Date: 12/08/2024

AUTHORISATION

Reviewed by

Name	Job Title	Signature	Date
Stephen Henry	Asset Investment Analyst		

Approved by

Name	Job Title	Signature	Date
David Spears	Network Investment and Delivery Manager		

INTERNAL

© Jemena Limited. All rights reserved. Copyright in the whole or every part of this document belongs to Jemena Limited, and cannot be used, transferred, copied or reproduced in whole or in part in any manner or form or in any media to any person other than with the prior written consent of Jemena.

Printed or downloaded copies of this document are deemed uncontrolled

DOCUMENT HISTORY

Revision	Date	Author	Description of Changes
1	15/10/2014	Fatimah Husin	First Issue.
1.1	24/08/2015	Dalibor Balicevic	Document reclassified from Public to Internal. Public classification relates to the regulatory review process only.
2	11/10/2018	Stephen Henry	Update of graphics and useful lives data
3	10/11/2021	Stephen Henry	Template update and minor changes
4	09/05/2022	Stephen Henry	Minor updates
5	12/08/2024	Stephen Henry	Addition of new equipment types into useful lives table

OWNING FUNCTIONAL GROUP & DEPARTMENT / TEAM

Asset and Operations : Network Investment and Delivery

REVIEW DETAILS

Review Period: Review Date + 2 years

Next Review Due: August 2026

TABLE OF CONTENTS

1	INTRODUCTION	4
1.1	PURPOSE.....	4
1.2	SCOPE	4
2	PROCEDURE / PROCESS / DOCUMENT DETAILS	5
2.1	CBRM FRAMEWORK.....	5
2.2	DEFINITION	5
2.2.1	ASSET USEFUL LIVES DEFINITION	5
2.2.2	ASSET USEFUL LIVES IMPACT ON CURRENT MODEL OUTPUTS (CBRM).....	5
2.3	HISTORICAL REVIEWS OF ASSET USEFUL LIVES	6
2.4	SUMMARY OF ASSET USEFUL LIVES.....	8
2.5	PROCESS TO DETERMINE ASSET USEFUL LIVES.....	11
3	REFERENCES	12
3.1	INTERNAL.....	12
3.2	EXTERNAL	12
4	APPENDICES	13
4.1	APPENDIX A – EDPR ASSET LIVES COMPARISON	13

1 INTRODUCTION

1.1 PURPOSE

This document outlines the historical development of the asset useful lives for the infrastructure assets installed on the Jemena Electricity Network (**JEN**). The asset useful lives are used as inputs for JEN asset management documentation; Asset Class Strategies, the Condition Based Risk Management (**CBRM**) Model and Business Cases. The asset useful lives are also used for accounting purposes.

The asset useful lives are listed on Section 2.4 of this document.

1.2 SCOPE


The scope of this document is to list the asset useful lives for the infrastructure assets installed on the Jemena Electricity Network (**JEN**).

2 PROCEDURE / PROCESS / DOCUMENT DETAILS

2.1 CBRM FRAMEWORK

Figure 1 shows how this document influences the Condition Based Risk Management (**CBRM**) framework. The framework outlines the inputs and analysis tools used to achieve the output documents that lead to the investment programs.

Figure 1 Condition Based Risk Management (CBRM) Framework



2.2 DEFINITION

2.2.1 ASSET USEFUL LIVES DEFINITION

Asset useful lives are an indication of when, on average, the network assets are likely to require replacement. The assignment of asset useful lives is an iterative process and the chosen asset useful lives should be derived from average replacement lives achieved in practice throughout the industry, manufacturer's recommendations, and theoretical technical examination. Asset useful lives will vary from utility to utility and country to country and are not absolute figures, asset lives can, for valid reasons, be changed during the life of the asset.


2.2.2 ASSET USEFUL LIVES IMPACT ON CURRENT MODEL OUTPUTS (CBRM)

Asset useful lives are assigned to each category of assets in the Condition Based Risk Management (**CBRM**) Model in order to provide a basis for asset replacement. The asset useful life is used as a starting point for forecasting asset replacement requirements and then a number of other factors such as condition of the assets, replacement policies, and risk to the network are incorporated to modify and achieve a more realistic replacement forecast.

The useful lives of network assets also have an impact on the fixed asset register via the 347 table in SAP. The 347 table acts as an interface between the Project System (**PS**) module of SAP and the Fixed Asset Register (**FAR**). Once settlement runs on a TECO'd PM Order, the 347 table determines the cost

split across the assets. Once the cost split is determined, the next step is the assignment of a useful life based on the Object Type selected in the installed equipment in the PM Order. The useful life data in the 347 table then determines the rate of depreciation to be applied to the asset. There are tax and accounting useful lives that cover off depreciation for both accounting and tax purposes. Figure 2 demonstrates this process.

Figure 2 Application of the 347 Table on a Routine Project in SAP



2.3 HISTORICAL REVIEWS OF ASSET USEFUL LIVES

In November 2001 a preliminary comparative analysis was undertaken of the asset useful lives as prescribed in the AGLE 2001 Electricity Distribution Pricing Review (**EDPR**) Submission, as recommended in a PB Power report and the asset useful lives applied in the SAP accounting books at the time.

This initial analysis led to further investigation and analysis of the asset useful lives in March 2002 and included a review of several reports. These reports were:


- the Agility Asset Management Plan Electricity report (dated 16 May 2001); and
- an extract from the 2001 Electricity Distribution Pricing Review (**EDPR**) Submission.

The scope was broadened in April 2002 to include several PB Power reports which detail asset useful lives for AGL:

- 2001 Distribution Price Review. Non Load related Capital Expenditure Report;
- 2001 Electricity Distribution Price Review. Final Analysis of Distributors EDPR 2001 Submissions; and
- A PB Power model showing the weighted average useful lives of assets

In 2006, the same modelling exercise was performed by PB Power. The model used during this analysis had been developed further since the 1999/2000 period.

Asset useful lives were used in the 2009 PB Asset Replacement Model to forecast future asset replacement requirement in EDPR, primarily for high volume, low value assets (such as poles and crossarms). PB provided a report "JEN Forecast Asset Replacement Volumes" in July 2010 that compared the asset useful lives used in the 2004 and 2009 EDPR submissions and concluded that the lives used were appropriate.

Figure 3 Asset Useful Lives Process Timeline

In 2012, a technical review of the asset useful lives was undertaken with reference to the condition, technological changes and performance of the assets. Subsequent reviews were undertaken in 2014, 2018 and 2021.

Jemena's Asset and Operations Electricity team undertook this review and recommended changes to the useful lives of the network assets. The asset useful lives are based on good industry practice and the specific Jemena experiences, and represent the lives of assets at which end-of-life replacement will be considered. For good industry practice, Jemena has referenced a number of reviews of asset useful lives: GHD review in May 2007 and PB review (as part of 2011-15 EDPR preparation) in July 2010 as well as discussions with AusNet Services in 2012.

In actual engineering practice, assets are replaced either (1) when their condition deteriorates to the extent requiring replacement; (2) after the asset has actually failed, or (3) replaced for other purposes such as third party work or reinforcement. The "actual replacement lives" can therefore vary considerably, and are best described in statistical terms (such as mean replacement lives and standard deviations). However, these statistic terms are only valid when there is a large population of such assets near the end of their lives. Jemena's Asset and Operations Electricity team allocates "asset useful lives" based on good industry practice and other relevant experiences. Assets are not replaced when they reach their "asset useful life". Rather the "asset useful lives" are used to trigger more intensive condition monitoring programs so that assets are replaced just prior to failure.

The legacy SAP system (ex-Agility) was configured to create assets at an aggregate level within asset classes. Asset useful lives were applied at the asset class level. For example, the asset class "High Voltage Poles and Pole tops" (**HVPP**) contained an aggregation of all types of HV poles and pole tops with a common useful life.

JSAP (Jemena SAP) was configured to record asset transactions at a more granular level. Project Completion Forms (**PCF**) for non-routine projects are used to support the master data creation. Routine projects continue to follow the aggregation process but are created at a more granular level, compared to the ex-Agility SAP e.g. pole tops are segregated from poles.

The granularity of assets to be recorded in the Fixed Asset Register (**FAR**) for non-routine projects is derived from the Electricity Industry Guideline No.14 relating to Provision of Services by Electricity Distributors and suitably modified in agreement with the engineers.

2.4 SUMMARY OF ASSET USEFUL LIVES

The following table compares the asset useful lives that have been used historically, extracted from various sources.

SAP Asset Class	Asset Description	Current Useful life	Useful life per SAP (Ex-Agility) ¹	Historical Engineers Assessments ²
	Sub-transmission Poles and Pole Tops		45-60	60
5005	Sub-trans Poles (Wooden)	54		
5005	Sub-trans Poles (Wooden Staked)	80		
5005	Sub-trans Poles (Steel Towers)	70		
5005	Sub-trans Poles (Concrete)	70		
5005	Sub-trans Pole Tops (Wooden)	45		
5005	Sub-trans Pole Tops (Steel)	70		
	HV Poles and Pole Tops		45-60	50
5005	HV Poles (Wooden)	54		
5005	HV Poles (Wooden staked)	80		
5005	HV Poles (Concrete)	70		
5005	HV Poles (Steel)	30		
5005	HV Pole Tops (Wooden)	45		
5005	HV Pole Tops (Steel)	70		
5005	HV Pole Tops (Steel)	70		
5005	Insulator (set)	30		
	LV Poles and Pole Tops		45-60	45
5005	LV Poles (Wooden)	54		
5005	LV Poles (Wooden Staked)	80		
5005	LV Poles (Concrete)	70		
5005	LV Poles (Steel)	35		
5005	LV Pole Tops (Wooden)	45		
	Sub-transmission U/G Cable		45	70
5009	Sub-trans U/G Cable (Oil)	70		
5009	Sub-trans U/G Cable (XLPE)	40		
	HV U/G Cable		45	45
5034	HV U/G Cable (XLPE)	40		
5034	HV U/G Cable (Paper)	70		
	LV U/G Cable		45	60

¹ Refer to Energy Networks Asset Report – Review of Useful Lives (2002)

² Refer to Energy Networks Asset Report – Review of Useful Lives (2002)

SAP Asset Class	Asset Description	Current Useful life	Useful life per SAP (Ex-Agility) ¹	Historical Engineers Assessments ²
5044	LV U/G Cable XLPE	55		
5044	LV U/G Cable Paper	70		
	O/H Conductor			
5004	Sub-transmission O/H Conductor	65	45	60
5004	Overhead Spreader	65		
5031	HV O/H Conductor	60	45	60
5031	Vibration Damper	60		
5041	LV O/H Conductor	60	45	60
	Services		40	40
5060	Services (above ground)	40		
5061	Services (underground)	50		
5043	Distribution Box	40		
5043	Distribution Surge Diverter	40		
5043	Pillars	50		30
5043	Pits	40		40
	Transformers			
5008	Sub-transmission Transformers	60	45	50
5020	Active Voltage Controller	15		
5020	Battery Energy Storage System (BESS)	15		
5020	Capacitive Balancing Unit (CBU)	15		
5020	CBU Control Box	15		
5020	MPLS Chassis	10		
5020	MPLS Card	10		
5020	Operational Phone Network – OTN/ETN	20		
5020	Operational Phone Network – Fixed Line	10		
5020	Phase Switching Device	15		
5020	Power Compensation Device	15		
5020	Power Conversion System	15		
5020	Timing Repeater	10		
5021	Distribution Transformers	50	40	45
	Switchgear			
5007	Sub-transmission Switchyard Equipment	50	45	60
5007	Zone Substation Indoor CB	50		
5007	Zone Substation Outdoor CB	50		
5033	HV Switchgear and Protection	50	15	35

SAP Asset Class	Asset Description	Current Useful life	Useful life per SAP (Ex-Agility) ¹	Historical Engineers Assessments ²
5033	Fault Indicator	40		
5033	Zone Substation Surge Diverter	50		
5043	LV Switchgear	50	15	30
	Public Lighting			
5050	Public Lighting Poles	35	45	45
5050	Sustainable Public Lighting Poles	35		
5080	Street Lights ³	20	20	20
5080	Security Beams	30		
	SCADA Network & Monitoring System			
5001	Sub-transmission Control & Monitoring Equipment	20	10	45
5002	Sub-transmission Meters/Time switches	15	25	20
5030	HV Meters/Time switches	15	25	20
5030	LV Meters/Time switches	15	25	40
5010	Supervisory Cable	50		
5010	Communication Equipment	20		
5020	Distribution Control and Monitoring Equipment	20	10	15
5001	Relay (Electronic/Digital)	20		
5001	Relay (Electro-mechanical)	40		
5020	Radio Equipment	15		
5030	Smart meters	15	25	20
5001	Zone Substation RTU	20		
	Zone Substation			
2500	Zone Substation Engineering Workstation	10		
2500	Zone Substation HMI Monitor	4		
5006	Sub-transmission Reactive Plant	40	45	45
1013	Zone Substation Station Building	70	50	
5007	Zone Substation Outdoor Buses	50		
5008	Zone Substation CT	50		
5008	Zone Substation VT	50		
5006	Natural Earthing Resistor	40		
5003	Earth grid conductors	70		

³ Street Lights with 20-years asset lives are applicable for new lights such as T5 and LED. For conventional street lights like MV80, the asset lives would be longer up to 30 years.

SAP Asset Class	Asset Description	Current Useful life	Useful life per SAP (Ex-Agility) ¹	Historical Engineers Assessments ²
8000	Air Conditioner	5		
8000	Generator	10		
8000	Pump	5		
8000	Winch	50		
8000	Oil Separation Pit	50		
8000	Lifting equipment	50		

2.5 PROCESS TO DETERMINE ASSET USEFUL LIVES

This document defines the asset useful lives that are currently used by Jemena. In 2014, Jemena has undertaken an extensive review of the quality of the asset technical data (GIS asset data and SAP technical object data) in relation to the asset installation date. This has enabled the re-assessment of asset useful lives using installation dates with improved accuracy.


When the extensive review mentioned above was completed, all assets in GIS and SAP have been assigned with either installed date or estimated installed date and also removed date.

For the annual RIN C submission, where it is required to record economic life of an asset (mean and standard deviation) in the Age Profile template, the following inputs are required in order to calculate average age of asset useful lives for each asset category in the network:

- Asset installation date/estimated installed date
- Removed date
- A sample size large enough to make the calculation of Standard Deviation meaningful.

The calculated average asset age is the input of asset useful lives of this document. The Age Profile RIN is prepared annually and is a part of the RIN known as RIN C (Regulatory Information Notice for Category Analysis).

Figure 4 Process to Determine Asset Useful Lives



3 REFERENCES

3.1 INTERNAL

JEN Forecast Asset Replacement Volumes". PB Power. 1 July 2010

Useful Life Review – JEN Network Assets. Jemena. 10 November 2013

ELE GU 0005 Condition Based Risk Management (CBRM) Guideline

ELE PR 0011 Asset Age Profiling Methodology. 24 November 2014

3.2 EXTERNAL

2001 Distribution Price Review. Non Load related Capital Expenditure Report.

2001 Electricity Distribution Price Review. Final analysis of Distributors EDPR 2001 Submissions

2006 EDPR Replacement Capital Expenditure Modelling. PB Power. 26 November 2004

Energy Networks Asset Reports – Review of Useful Lives. Agility. 22 October 2002

Category Analysis Regulatory Information Notice. 9 December 2020

4 APPENDICES

4.1 APPENDIX A – EDPR ASSET LIVES COMPARISON

Standard Asset Lives

Asset Lives for Materials		EDPR11	EDPR16	EDPR21
Wooden Pole	Years	60	54	54
Concrete Pole	Years	80	70	70
Steel Pole – HV	Years	40	40	40
Steel Pole - LV	Years	30	35	35
Steel Cross Arms (incl. Insulators)	Years	70	70	70
Wood Cross Arms (incl. Insulators)	Years	70	45	45
Bare Conductors (Al)	Years	60	60	60
Insulated Conductors - HV	Years	35	-	-
Insulated Conductors - LV	Years	50	60	60
Bare conductors (steel)	Years	50	50	50
Underground Cables and Cable head - HV, XLPE	Years	40	40	40
Underground Cables and Cable head - LV, XLPE	Years	60	55	55
Supervisory Cable - Fibre Optic	Years	40	50	50
Capacitor Banks	Years	40	40	40
Power Transformers - Zone Substation	Years	55	55	55
Power Transformers - Distribution	Years	50	50	50
NER	Years	40	40	40
Circuit Breakers - Indoor	Years	50	50	50
Circuit Breakers - Outdoor	Years	45	50	50
Zone Substation Batteries	Years	15	15	15
Zone Substation Battery Chargers	Years	20	20	20
Zone Substation Building	Years	50	70	70
HV Disconnectors / Isolators	Years	55	40	40
LV Disconnectors / Isolators	Years	35	40	40
Reclosers / Gas Switches	Years	35	40	40
Surge Diverters	Years	25	25	25
Fault Indicators	Years	15	15	15
Pillars / Pits	Years	35	35	35
Services (above-ground)	Years	40	40	40
Services (under-ground)	Years	50	50	50
Public lighting	Years	20	20	20
Relays - Digital / Microprocessor	Years	20	20	20
Relays - Electro-Mechanical	Years	40	40	40
SCADA - RTU	Years	20	20	20
Fence	Years	50	50	50
Ring Main Unit	Years	35	35	35

On each regulatory submission, JEN submits various asset lives for assets listed in the table above for its tax and regulatory depreciation purposes. Variances could be found between the two regulatory periods for some asset lives. The variances could be shorter, longer or zero.

From EDPR 2011 to EDPR 2016, JEN has improved its asset data stored in its Works Management (**SAP**) and Geographical Information (**GIS**) systems significantly. For instance, all assets recorded in GIS and SAP now have installed date and estimated installed date. It is also now mandatory for all assets that are removed from the field to have a removed date recorded in GIS and SAP. This will facilitate improved analysis of an asset's useful life.

The adjustments to the useful lives shown in the table above are based on different reasons and justifications:

- The asset lives for the high volume asset classes such as wooden poles, concrete poles and wooden cross-arms (incl. insulators) have reduced for EDPR 2016. JEN was able to more accurately calculate the useful asset lives for these assets as a result of improved data quality relating to installation and removal dates.
- For insulated conductor – The useful asset life of HV insulated conductor is now zero due to the fact that JEN no longer installs HV ABC on its network.
- There are classifications of assets that JEN considers to be recent introductions to the network: insulated conductors – LV, supervisory cable – fibre optic, LV disconnectors / isolators, reclosers and gas switches. As JEN moves to the new regulatory period, JEN now has further experience in understanding the performance of these assets. These asset classes now have longer asset lives in EDPR 2016 compared to EDPR 2011.
- For underground cables and cable head – LV, XLPE; JEN has developed a documented failure history for LV underground cable in the network. This has enabled JEN to re-assess the asset life for LV underground cable and reduce the useful life for this asset class.
- For low volume asset classes such as outdoor circuit breakers JEN has a good understanding of the individual assets (due to the low volume) and therefore JEN has been able to accurately analyse the useful asset lives. Based on comprehensive maintenance records, assets such as outdoor circuit breakers outdoor now have a longer asset life than what was reported in EDPR 2011.
- Another low volume asset class, zone substation buildings have an increased asset life for EDPR 2016 compared with EDPR 2011. Better building designs and materials have extended the useful life.
- For specific asset such as HV disconnectors / isolator, initially JEN reported the asset life to be 55 years in EDPR 2011. However the useful life has been reduced to 40 years in EDPR 2016 due to issues identified regarding the performance of those assets.
- For steel pole – LV; JEN has decided to change the asset life from 30 years to 35 years in EDPR 2016 in order to be aligned with AER's public lighting model.