

January 2026

Powerlink 2027-32 Revenue Proposal

Project Pack

Geographic Line Refit Programme



Project Status: Unapproved

Network Requirement

Powerlink's fleet of steel lattice transmission line towers reflects the stages of development of the Queensland electricity transmission network. The oldest structures that remain in service are 110kV and 132kV structures from the 1960's when many regional parts of the state were receiving grid connected electricity supply for the first time, and existing urban electrical load centres were rapidly expanding. From the early 1970's the stand-alone regional grids in the north, centre and south of the State were progressively interconnected with each other through the coastal 275kV backbone network that remains in service today. This core backbone network has been incrementally extended and augmented since then, including through interconnection with New South Wales at 330kV.

Of the current fleet of nearly 24,000 structures, over 10,000 (40%) will exceed 50 years of age by the end of the 2027-32 regulatory control period. The fleet is dispersed across a wide range of climatic conditions ranging from coastal tropical and heavy industrial environments where corrosion of steel components is accelerated to more benign dry inland environments. Even within built sections of transmission lines micro-environments exist such that deterioration is not uniform. The result is that while age alone is not a determinant of the need to reinvest in transmission line assets it nevertheless provides an indication that reinvestment needs are likely to increase over time.

Following feedback from the AER in its draft and final decisions on Powerlink's 2023-27 Revenue Proposal Powerlink established an Asset Reinvestment Review (ARR) Working Group to examine alternative approaches to its approach to reinvestment in transmission line assets that still addresses the identified risks associated with asset deterioration.

The ARR Working Group recommended that [1]:

1. There be no change to Powerlink's asset definition for transmission – a built section being a section of transmission line that was built/commissioned under a single project and generally contains structure with identical or very similar characteristics.
2. Compliance works such as replacement of signage and upgrade of climbing aids be only undertaken on structure where condition-based work is to be performed – not necessarily on all structures comprising the built section.
3. Both Powerlink's current approach and the alternative bundling approach be modelled for future transmission line refit investment decisions, and the most cost effective solution progressed based upon detailed condition and cost information, while allowing for the developing network needs to support the energy transformation.

In developing its Revenue Proposal for the 2027-32 regulatory control period Powerlink has adopted the recommendations from the ARR Working Group. As a result, Powerlink has identified four transmission line built sections where the reinvestment need is of sufficient scale to justify a stand-alone project for each of those built sections.

Across the rest of the fleet of transmission line towers a total of 235 structures have been identified where the structure health index (HI) is projected to exceed HI8 by the end of the regulatory control period in 2032 [2]. A Health Index of 8 indicates extensive corrosion on greater than 20% of steel components – that is, the mechanical strength of the structure will have been reduced.

Forecast Capital Expenditure - Capital Project Summary

Powerlink 2027-32 Revenue Proposal

January 2026

Recommended Option

As the projects that comprise this programme of works are all currently ‘Unapproved’, project needs and options will be subjected to the public RIT-T consultation process to identify the preferred option closer to the time of investment.

The current recommended option is to undertake refit works on selected structures across a range of transmission line built sections consistent with the recommendations of the ARR Working Group. The 235 structures projected to exceed HI8 by 2032, 112 of 110/132kV and 123 of 275kV, have been grouped into regional packages. This bundling approach is designed to improve delivery efficiency and reduce costs compared to managing multiple small stand-alone projects.

Powerlink has already identified that each of the transmission lines which contain these 235 structures are required to remain in service to meet the reliability of supply standard in Powerlink’s Transmission Authority. Powerlink does not consider non-network options are likely to be able to meet the identified need to manage the risk of deterioration of the condition of transmission line structures.

Details of the built sections and structures to be refit are set out in Table 1 below.

Table 1 Refit structure summary

Built section	Voltage	Commissioning Year	Total structures	Structures to be refit
Cairns area				
- BS1236 Woree – STR-0140	275/132kV	1998	23	5
- BS1253 Chalumbin – Turkinje	132kV	1986	219	22
- BS1254 Woree – White Rock	275kV	1998	10	5
- BS1664 Bayview Heights – Davies Creek	275kV	1998	37	12
Townsville / Mackay area				
- BS1204 Mackay – Pioneer Valley	132kV	1977	56	12
- BS1213 Strathmore – Ross	275kV	1978	421	11
- BS1218 Townsville South – STR-1506	132kV	1982	3	2
- BS1224 Townsville South – STR-1069	132kV	1984	3	1
- BS1241 Pioneer Valley – Eton Tee	132kV	1977	42	27
- BS1626 Nebo – Pioneer Valley	132kV	2008	178	22

Forecast Capital Expenditure - Capital Project Summary

Powerlink 2027-32 Revenue Proposal

January 2026

Built section	Voltage	Commissioning Year	Total structures	Structures to be refit
Rockhampton / Gladstone area				
- BS1100 Gladstone South – QAL	132kV	1966	14	4
- BS1101 Gladstone South – QAL	132kV	1966	15	9
- BS1160 Calliope River – STR-011	275kV	1980	6	1
- BS1178 Bouldercombe – STR-0770	275kV	1977	2	1
Southern Queensland area				
- BS1003 Blackstone – Abermain	110kV	1966	48	4
- BS1008 Belmont – Loganlea	110kV	1982	10	4
- BS1015 Goodna – Belmont	275kV	1972	61	4
- BS1018 Greenbank – Mudgeeraba	275kV	1975	165	17
- BS1019 Greenbank – Mudgeeraba	275kV	1974	165	17
- BS1021 South Pine – Palmwoods	275kV	1976	162	21
- BS1025 Woolooga – Gin Gin	275kV	1976	364	14
- BS1038 West Darra – Sumner	110kV	1963	16	5
- BS1046 Blackwall – Goodna	275kV	1970	14	10
- BS1048 Palmwoods - Woolooga	275kV	1976	207	5

Forecast Capital Expenditure - Capital Project Summary

Powerlink 2027-32 Revenue Proposal

January 2026

Cost and Timing

To estimate the costs of the regional packages of work Powerlink has adopted the estimated cost per structure from estimates prepared for the four individually identified built section reinvestment projects. Where there is a range of unit rates inferred for a particular voltage level Powerlink has adopted the lowest inferred unit rate.

The estimated costs to refit transmission line structure in the regional packages of works are set out in Table 2 below.

Table 2 Line refit programme cost estimates

Work Package	Number of structures		Estimated cost (\$ Real, 2025/26)	Target commissioning date
	275kV	110/132kV		
C55.3330 Cairns – Geographical lines refit program	22	22	\$17.3 million	June 3032
C55.3331 Townsville / Mackay – Geographical lines refit program	11	64	\$25.1 million	June 3032
C55.3332 Rockhampton / Gladstone – Geographical lines refit program	2	13	\$4.9 million	June 3032
C55.3333 Southern – Geographical lines refit program	88	13	\$42.7 million	June 3032
Total – Geographical lines refit programme	235	112	\$90.0 million	

Documents in Geographic Line Refit Programme Project Pack

Public Documents

1. Asset Reinvestment Review – Working Group Report
2. Transmission Line Refit Strategy 2028 - 2032



Powerlink Queensland

Asset Reinvestment Review

Working Group Report

June 2023

Contents

Executive Summary	3
1 Background	5
Origins for the Asset Reinvestment Review	5
Scope of the Asset Reinvestment Review	5
2 Engagement Process	7
Engagement objectives	7
Asset Reinvestment Review Working Group	7
Membership	7
Process and focus areas	8
Purpose of this report	8
3 Existing Asset Management Approach for Reinvestment	9
Reinvestment decision	9
Transmission line reinvestment	11
Risk cost	14
4 Options Investigated	16
Current approach to reinvestment projects	16
Alternative approaches investigated	17
Case Study: Refit of Ross to Chalumbin 275kV transmission line	18
5 Further Analysis and Modelling	21
Sensitivities and scenarios modelled	22
6 Findings and Recommendations	23
Modelling observations, conclusions and recommendations	23
Implementation of recommendations	23
Aligning recommendations to AER concerns	24
Aligning outcomes to the scope of the review	25
Working Group – key insights	26
Next steps following completion of the review	26
Attachments	28
A1: Review process – overview	28
A2: Comparison of variance between single up-front intervention and two interventions within 15 year period with various sensitivities	29
A3: Proposed alternative approach to bundling	30

Executive Summary

During the revenue determination process for our 2023-27 regulatory period, the Australian Energy Regulator (AER) raised, in its Draft Decision¹, the potential for improvements in Powerlink's transmission lines asset management and replacement practices. Powerlink is committed to seeking continuous improvement across all of our business operations and recognises that affordability is a key concern for our customers. In line with this commitment, and in response to the potential opportunities identified by the AER, we undertook to review our approach to network asset reinvestment, particularly for overhead transmission lines.

A Working Group was established with members from Powerlink, Powerlink's Customer Panel, members of the AER Consumer Challenge Panel subgroup that had been involved in Powerlink's 2023-27 revenue determination process and the AER to guide its direction and considerations. The review considered our risk cost modelling approach, the impact of risk on economic decisions, the role of deterministic criteria in an economic assessment framework and the balance or trade-off between capital and operating expenditure.

Our current approach, which consists of refit work that is expected to achieve a life extension of a nominal 15 years across an entire asset, bundled in a single up-front intervention, was reviewed and explored by the Working Group. Typically such works consist of a combination of condition driven works and compliance driven works, and adopts a hybrid risk/deterministic approach.

The review considered whether there is an alternative approach to transmission line refit that drives a materially better outcome for customers. To this end, the Working Group considered the outcomes (net present value comparisons and trade-offs between capital expenditure and operating expenditure) of alternative asset definitions and work-bundling approaches.

Four project case studies were assessed as part of the review. Each of the four projects had been included in our revenue proposal, and had sufficient condition information, project scopes and estimates available to inform the assessment of alternative asset definitions and work-bundling approaches. The different bundling approaches resulted in various life extension outcomes, so any subsequent condition intervention was specifically modelled in the assessment.

This report presents the following recommendations of the Working Group derived from the assessment of these case studies:

1. no change be implemented to Powerlink's asset definition for transmission lines (i.e. built section)
2. compliance works are only undertaken on structures where condition based work is to be performed
3. both Powerlink's current approach and the alternative bundling approach be modelled for future transmission line refit investment decisions, and the most cost effective solution progressed based upon detailed condition and cost information, while allowing for the developing network needs to support the energy transformation.

These recommendations should be introduced as soon as practicable, as they are not expected to result in any material change in risk. The Working Group also noted that the alternative bundling approach could also enable a more flexible delivery and resourcing model through better staging of projects based on risk, ensuring that reinvestment decisions are made in a way that efficiently accommodates potential future scenarios.

¹ AER, Draft Decision, [Powerlink Queensland Transmission Determination 2022 to 2027, Attachment 5 Capital Expenditure](#), September 2021, page 7.

Powerlink anticipates that these recommendations will be implemented in 2023/24, while we will report back to our Customer Panel on the progress made in embedding the recommendations from this review into our business as usual processes one year after finalisation of the review.

Powerlink would like to acknowledge the time and effort committed by all of those members of the Working Group external to Powerlink, and thank all of those members for their constructive engagement throughout the process and invaluable insights provided that have resulted in a thorough review of our processes.

1 Background

Powerlink lodged its Revenue Proposal for its 2023-27 regulatory period with the Australian Energy Regulator (AER) in January 2021. The proposal set out Powerlink's revenue requirements for prescribed transmission services over the period from 1 July 2022 to 30 June 2027.

Our overarching goal was to deliver a Revenue Proposal that was capable of acceptance by our customers, the AER and Powerlink. In preparing our Revenue Proposal, we undertook extensive engagement with our customers, stakeholders, the AER and the AER's Consumer Challenge Panel (CCP23) on all key elements of our Revenue Proposal during its development. Our engagement built on the strong foundations we undertake in the normal course of business.

Origins for the Asset Reinvestment Review

In its Draft Decision², the AER accepted our total forecast capital expenditure. The AER found our capital expenditure forecasting methodology to be a significant improvement on the methodology used in our previous 2018-22 Revenue Proposal and that our risk-cost based analysis and supporting economic modelling are a significant step forward. The AER also identified potential opportunities for a more targeted economic risk based approach, particularly for overhead transmission lines reinvestment, and raised concerns with our use of the Repex Model (replacement expenditure model) for forecasting purposes.

In light of this feedback, and consistent with our drive for continuous improvement, we committed to a review of our approach to network asset reinvestment. In our letter to the AER³, we identified a number of matters that we considered would be relevant to the review and noted that the review would need to have regard to what is reasonably required to deliver network reinvestment works in the Queensland operating environment. In addition, we flagged our intention to publish the outcomes of the review and adopt improvements over the remainder of the 2023-27 regulatory period.

Scope of the Asset Reinvestment Review

From the matters raised in our letter to the AER, Powerlink developed criteria for the Working Group to consider while developing the scope of the review. We identified that the review should focus on both the prudence and efficiency elements of reinvestment capital expenditure.

Through discussion with the Working Group, it was agreed that the scope of the review should consider:

- social licence to operate over the asset life
- built section definition and its impact on the intervention timing and scale of works
- how to better capture the benefits, including financial, of 'bundling' condition and compliance driven works within transmission line projects
- how to better capture the challenges and costs, of access for Powerlink assets, both from a remote geographic and network outage perspective
- what is optimal at both a project and portfolio level

² AER, Draft Decision, [Powerlink Queensland Transmission Determination 2022 to 2027, Attachment 5 Capital Expenditure](#), September 2021, page 8

³ Powerlink, Letter to Justin Oliver, September 2021, [Powerlink - Review of Powerlink's Approach to Network Asset Reinvestments - September 2021 Redacted.pdf](#) (aer.gov.au).

- the AER Industry practice application note asset replacement planning⁴
- how to incorporate best practice approaches used by other networks
- future-proofing – given the rapidly changing environment, there is a need to ensure improvements to asset reinvestments are sustainable of the longer-term
- how to ensure predictable and repeatable outcomes.

However, the scope of the review excluded consideration of use of the Repex Model for future revenue proposals, as this is not used to determine reinvestment requirements in the normal course of business. Powerlink will consider how to forecast its reinvestment expenditure ahead of commencing our 2028-32 Revenue Proposal process. The capital expenditure forecast approach to be undertaken at that time will be developed with engagement with our Customer Panel.

⁴ AER, [Industry practice application note for asset replacement planning](#), January 2019

2 Engagement Process

Engagement objectives

To guide engagement throughout the review, Powerlink set the following objectives:

- enable in-depth and timely discussion on key elements of the asset reinvestment review, including its scope
- ensure customer, stakeholder and AER insights are heard and considered
- build an understanding of Powerlink's asset reinvestment requirements.

To achieve these objectives, we undertook the following engagement approach.

Asset Reinvestment Review Working Group

Powerlink commenced a review of its asset reinvestment approach and criteria in early 2022 to ensure consistency with sound asset management and risk-based decision frameworks.

To inform the direction of the review and ensure that customer, stakeholder and AER perspectives were appropriately considered, we established an Asset Reinvestment Review (ARR) Working Group as the primary engagement body for the review.

Membership was drawn from Powerlink's Customer Panel and members of the AER's Consumer Challenge Panel subgroup that had been involved in Powerlink's 2023-27 revenue determination process through an expression of interest process, while a representative from the AER was also invited to participate. The Working Group was advisory in nature, with members predominantly engaged at the *Involve* level of the IAP2 Spectrum.

A formal Terms of Reference was developed for the ARR Working Group outlining its purpose, membership and responsibilities. More detail can be found on Powerlink's website in the [Asset Reinvestment Review Working Group Terms of Reference](#).

Membership

The ARR Working Group comprised the following standing members:

Term	Percentage
GMOs	~75%
Organic	~90%
Natural	~85%
Artificial	~65%
Organic	~80%
Natural	~78%
Artificial	~82%
Organic	~92%
Natural	~88%
Artificial	~95%
Organic	~55%

Process and focus areas

The ARR Working Group initially discussed and finalised the [scope](#) of the review. A [glossary of terms](#) was developed by Powerlink to assist in providing a common understanding of the terminology adopted within asset management, and for transmission lines assets in particular. The following table outlines a summary of ARR Working Group meetings and key focus areas progressed throughout the review process.

Month	Key focus area
March 2022	Discussed review scope.
April 2022	Glossary of terms, current approach overview, deep dive into Ross to Chalumbin Transmission Line Reinvestment case study.
May 2022	Confirmed scope of the review, built section definition.
June 2022	Site visit to Rocklea Tower Farm and Goodna tower site to view towers, climbing techniques and access tracks.
July 2022	Strawman outline of five options for the breakdown of built sections: <ol style="list-style-type: none"> 1. Powerlink current approach 2. Environment 3. Fixed length 4. Assets defined based on function (structure, insulator, conductor, etc.) 5. Accessibility.
October 2022	Use Ross to Chalumbin case study to compare three approaches: <ul style="list-style-type: none"> • Current approach • Each asset type with a built section is one asset – i.e. four assets per built section • Each individual asset component is one asset – every structure, conductor span, insulator, etc. (more than 3,000 assets in case study built section).
February 2023	Use of a graphic representation to review three approaches: <ul style="list-style-type: none"> • Review of the economic modelling of alternative options for built section of Ross to Chalumbin case study. • Results of economic modelling on a range of built sections • Preliminary recommendations • Next steps • Review of potential high level report structure.
April 2023	Presentation of Draft Asset Reinvestment Review Report for comment by Working Group members.
May 2023	Finalise report and complete review.

Table 1 Summary of meetings

A full list of meeting presentations and minutes can be found on Powerlink's website [here](#).

Purpose of this report

The purpose of this report is to document the process undertaken to review Powerlink's asset reinvestment decision making, with respect to overhead transmission lines, and the resultant changes to asset management processes to be implemented. An overview of the process undertaken as part of this review is presented diagrammatically in Attachment A1.

Beyond the Asset Reinvestment Working Group, the audience is primarily internal Powerlink management and employees as it seeks to justify, and present the rationale for, the proposed changes to asset management processes. This report will be published on Powerlink's website.

3 Existing Asset Management Approach for Reinvestment

Reinvestment decision

Powerlink is committed to ensuring the sustainable long-term performance of its assets to deliver safe, reliable and cost-effective transmission services to customers, stakeholders and communities across Queensland. This is supported by adopting a proactive approach to asset management that optimises whole of life-cycle costs, benefits and risks, while ensuring compliance with applicable legislation, regulations, standards, statutory requirements, and other relevant instruments.

We examine assets from a whole of life perspective as part of our Asset Management System. The asset planning and reinvestment process is a key component of the asset management life cycle. We define the asset life cycle and main activities throughout nine stages shown in Figure 1 below.




Figure 1 Asset management life cycle [source: Powerlink]

Monitoring and evaluating asset health, condition, and performance is a key component of a comprehensive asset management strategy, and is used by Powerlink across the network to enable a considered approach and prudent decision-making for future reinvestment needs.

The emerging operating environment

The transmission network plays a critical role in enabling the energy transformation to achieve a lower carbon future and Powerlink is taking an active role in strategic planning to guide and shape the power system.

As highlighted in the Integrated System Plan⁵ (ISP) and Queensland Energy and Jobs Plan⁶ (QEJP), Powerlink's network will require augmentation to enable the transfer of large amounts of energy between Renewable Energy Zones (REZ), storage facilities and load centres. As the transmission network expands, Powerlink is committed to proactive engagement in working with communities, industry and stakeholders to create and sustain long-term value for customers.

In line with principle 8⁷ of the AER Industry practice application note for asset replacement planning, specifically principle, the future operational environment and service levels support greater emphasis on preserving optionality over time when considering large-scale reinvestments.

However, our current approach is more targeted at efficient utilisation of scarce specialist resources (both internal skilled labour and external contractors) and network access (outages) than preserving optionality, as efficiency of delivery was a key issue during a period of low growth. However, we recognise that optionality becomes increasingly important during the emerging energy transformation. Our current approach is described further in Section 4.

As part of the Asset Reinvestment Review, considerable emphasis was given to a flexible and integrated approach for future reinvestment needs and options, such as using a new approach to project bundling that enables flexibility in reinvestment planning amongst future network development activities.

Integrated planning approach

Powerlink takes a flexible and integrated planning approach to optimise network development based on the analysis of future network needs. Our approach aims to deliver positive outcomes for customers while ensuring the ongoing safe, secure and reliable supply of electricity.

We regularly assess the current and forecast performance of the transmission system to ensure that we make prudent and cost effective asset investment decisions in a timely manner. Asset planning decisions are linked to customer outcomes and may involve augmentation to the network, reinvestment into existing network assets, implementation of non-network alternatives, or responding to opportunities that provide cost efficiencies and/or additional value for our customers.

Our asset management and joint planning approaches ensure asset reinvestments are not considered on a like-for-like replacement basis, but rather the enduring need of network assets and optimisation of the network to meet current and future needs are assessed. We perform a detailed analysis of both asset condition and network capability prior to proposing a reinvestment in order to identify the optimal solutions.

Asset reinvestment

Assets reach their end of technical life when the assessed condition shows a reduction in the assets ongoing ability to maintain required service levels beyond typical operational maintenance. This triggers an assessment of options to address emerging condition and/or performance related issues for the network asset. These options may encompass a range of investment strategies including reinvestment, network reconfiguration, non-network solutions and/or asset retirement. It is important to assess asset condition and non-network solutions holistically with the enduring network need for the asset so that the optimal network solutions can be identified.

⁵ Australian Energy Market Operator, [Integrated System Plan](#), June 2022

⁶ Queensland Government, [Queensland Energy and Jobs Plan](#), September 2022

⁷ AER, [Industry practice application note for asset replacement planning](#), January 2019, Page 9 - “flexibility, small scale actions, and deferral have economic ‘option’ value”

Transmission line reinvestment

The decision of what investment is appropriate for a regulated transmission line is complex, involving prediction of the changing condition of all aspects of the line over time, identification of environmental influences, as well as identification of possible safety and reliability consequences should any components deteriorate to the point of loss of strength. Structures are very secure and our current standards are designed to ensure that failures are highly unlikely to occur.

The grading of steel deterioration is through subjective visual assessment, while modelling of environment related deterioration (e.g. wear and corrosion) many years into the future can be highly variable between structures on the same line. Further, a transmission network is composed of many thousands of structures and each structure is composed of several components, each with many individual elements (as shown in Figure 2), which further compounds the complexity of accurate condition modelling.




Figure 2 Typical transmission line asset components [source: Powerlink]

Consequently, asset management of transmission lines necessarily requires a fleet management approach. In practice, line condition is not easily reduced to a single value, but is a distribution of conditions representing every component condition (structure, foundation, conductor, insulator, etc.). The necessary timing of interventions, although usually referenced to a commissioning date, is a probability based decision reflecting what is known, and the possibility of more significant deterioration which has not been identified (due to the large number of components and the sampling nature of condition monitoring).

Condition triggers for investment

The primary criterion which we use to ensure compliance with legislation, and for determination of the optimum timing of line reinvestments, is asset condition. For steel transmission structures and foundations, this means the level of steel corrosion. This is monitored by an inspection regime which records the extent of corrosion on a sample of structures at a point in time and assigns a structure health index (HI) based on the accumulated level of corrosion of components. The system also uses regional corrosion rates in line with AS4312 (Atmospheric Corrosivity Zones in Australia) to predict structure corrosion levels and health into the future. This forms the basis of the Powerlink risk calculation model. Corrosion progression is modelled through a series of tables showing the average corrosion levels by age for each corrosion region.

Where risk costs and benefits do not provide a reinvestment trigger then the recommended reinvestment trigger timing is in the year in which a specific, predetermined corrosion threshold, based on percentages of bolts and members in different categories, is exceeded. The following corrosion grades for galvanised steel form the basis of Powerlink's system:

Grade 1 (G1) – good condition, galvanised surface intact.

Grade 2 (G2) – break down of corrosion protection has commenced - speckled rust appearing through galvanising layer.

Grade 3 (G3) – rapid corrosion has commenced, with rust patches evident (more than 50% of bolt surface affected).

Grade 4 (G4) – degraded to a point where galvanising no longer exists and structural integrity is becoming compromised, i.e. loss of shape has commenced and will accelerate.

Galvanised tower bolts and thin steel members (<5mm) have a small galvanising thickness and will start to show signs of corrosion in advance of the heavier galvanised steel members (>5mm). Bolt condition is therefore a good early indicator of the expected galvanising life of a tower and a good predictor of end-of-life timing. The point which is used by Powerlink (20% grade 3 bolts and 3.5% grade 4 bolts) reflects:

- that the point has been reached when a substantial level of condition based maintenance is required under Powerlink standards
- the level of maintenance to replace bolts will require a significant resource for medium and long length, and remote lines
- the time until a decline in structural integrity is close in comparison to the typical time required to undertake a transmission line reinvestment project (in the order of 3 years)
- that beyond this point, corrosion levels will increase exponentially as galvanising is completely lost on structure sections and components.

The threshold value of 3.5% grade 4 is a relatively small proportion of structure bolts (of the order of 50-60 bolts out of a typical total in excess of 1,500 per structure). However, this can be a large total quantity of bolts on long lines. Additionally, the investment needs to deal not only with the current level of corrosion but the expected levels of corrosion into the future, i.e. those bolts which will change from grade 3 to grade 4 during the period prior to investment.

These grades are applied to discrete items, e.g. a single bolt, member or component. To develop a model for lattice steel towers, which contain many hundred bolts and members, data and information from the Galvanisers Association of Australia and AS4312 is applied.

Transmission line health indices

Powerlink's health index (HI) methodology is used as a tool to compare assets and provide a guide to when intervention is expected to be necessary. The timing of intervention is determined by application of Powerlink's Reinvestment Criteria Framework⁸, while the nature of the intervention, such as decommissioning, maintenance, refit or replacement, is determined by undertaking an economic assessment of all identified feasible options to address the condition risks.

The inputs used and the methodology applied to derive health indices for transmission lines are described below.

Inputs - data collection of structure corrosion levels

Data is obtained from a number of sources (direct data input by line-workers, ad hoc assessments, photographic evidence) and from different inspection types (climbing, aerial, ground and drone inspections) over a number of years.

Inspection and grading of corrosion levels are reported against standard measurement points and reference a consistent approach to the visual identification of corrosion, from grade 1 to grade 4, including the percentages of each grade for structure zones. Similar data collection and processing takes place for insulators and earth wires.

Data processing to calculate structure health index

Structure corrosion level data is automatically aggregated for each structure to determine a structure health index at a point in time (the inspection time). Structure health indices have a normal operating range from 0 (new) to 10, at which point structure strength is reduced below rated value and the probability of structure failure increases significantly.

Health indices are theoretically projected beyond 10 to predict significantly reduced strength due to extensive untreated corrosion, but Powerlink does not plan to operate in this region.

Structure health index projection in time

Structure health indices are individually projected forward to predict developing corrosion over time. Projection can be based on the performance to date of the asset, typically in condition assessment projections, or the corrosion region, typically for economic risk modelling.

Built section health index

A built section (BS) is a section of transmission line that was built/commissioned under a single project, and generally contains structures with identical or very similar characteristics. This effectively defines a single transmission line asset.

A built section health index is calculated as a percentile value of the distribution of known structure health indices. The percentile used varies depending on the number of structures in the built section. Very high percentile values (e.g. 95th percentile) are used for long lines, and lower percentile values (e.g. 65th percentile) are used for lines with a small number of structures.

This process is intended to ensure that the point in time when a significant number of structures will reach a highly degraded state, typically considered to be 10 to 20 structures based upon the criticality of the transmission line, is clearly identified. This allows time to identify options for intervention and carry out work before the rate of deterioration increases significantly such that deterioration of the built section is more significant and widespread.

Further description of our built section health index is included in the following table.

⁸ Powerlink, [Reinvestment Criteria Framework](#), May 2020 (included with our 2023-27 Revenue Proposal)

Built Section Health Index Range	Description of Asset	Action
>10	Widespread extensive corrosion resulting in imminent risk of multiple failures in moderate to significant weather events	Modelling purposes only (well beyond normal operating range)
10	Widespread corrosion/strength reduction on a significant number of structures resulting in increased risk of failure in extreme weather event	Corrective work urgently required
9	Advanced corrosion, greater than 20% of components on a large number of structures, increasing risk of failure occurring during extreme weather event	Urgent planned works must be underway to address high risk components
8	Extensive corrosion of greater than 20% of components on a significant number of structures (a significant number of structures have $HI \geq 8$ with reduced strength)	Treatment to be completed to ensure built section HI8 not exceeded
5-7	Ageing condition, surface corrosion evident, but no significant strength reduction	Coordination of scheduled inspections to confirm expected timing to exceed built section HI8 (if untreated)
1-4	Good condition	Routine inspections from half expected life
0	New asset	No action

Table 2 Built section health index [source: Powerlink]

Risk cost

Risk Cost is a quantitative measure that monetises the risk of events, and is usually expressed on an annual basis for asset planning. Powerlink's risk cost methodology⁹ follows guidance as set out in the AER Industry practice application note for asset replacement planning where asset failure and consequence are used as the driver for risk cost, as shown in Figure 2.



Figure 3 Risk cost definition [source: Powerlink]

In our methodology, the Probability of Failure (PoF) represents the irreparable failure of the network asset or component for a particular mode of failure. As the Health Index of an asset increases (i.e. the condition of the asset deteriorates), the likelihood that the asset will fail generally increases. For example, higher levels of corrosion indicate that the structure is less likely to withstand expected weather events.

⁹ Powerlink, [Overview of Asset Risk Cost Methodology](#), May 2019

When an asset does fail, there is a potential associated impact resulting from that failure. For example, there could be a loss of supply to customers, or an injury resulting from the failure. The Cost of Consequence (CoC) represents the financial (or monetised) equivalent of the risk consequence. The Likelihood of Consequence (LoC) represents the moderating factors used when assessing the consequences of failure (e.g. the likelihood of someone being in the proximity of the tower that fails). A combination of consequences may be modelled for any individual failure mode or event, and some consequences may only arise as a result of a combination of multiple failures.

The Risk Costs for network assets approaching end of life are calculated for each failure type and consequence category. Four main categories of risk are assessed within Powerlink's risk approach:

- Network risks – e.g. unserved energy due to a failed structure
- Safety risks – e.g. to the public or workers due to a tower collapse
- Financial risks – e.g. cost to replace a failed structure in an emergency manner
- Environmental risks – e.g. bushfire or contamination of insulating medium.

Risk cost modelling is used to quantify the risks associated with network assets approaching the end of their technical and economic life for the purposes of determining reinvestment decisions, refer Figure 4. The quantification of risk is one input to the economic comparison of options used within the Regulatory Investment Test for Transmission (RIT-T) economic cost benefit analysis of options.




Figure 4 Asset Reinvestment Decision Process [source: Powerlink]

The AER Industry practice application note for asset replacement planning extends economic benefits to the mitigation of risk for assets approaching end of life. The RIT-T uses a cost-benefit economic analysis to assess the lowest cost recommended solution. That is, the risk cost avoided or not incurred by implementing an option can be expressed as a benefit within the economic assessment.

Not all options will equally reduce or fully eliminate the risk and this can vary with, and inform, the scope, timing and intervention for options considered. There may be other quantifiable benefits (including market benefits) or additional costs to be included to determine and compare the net economic benefit from implementing the option (or set of options including potential non-network solutions).

The health indices of assets are used to identify that some form of intervention is required. However, it is important to note that this is a trigger for additional investigation into the condition of the asset and potential actions to address the assessed condition. Once the need for intervention is established, various options to address this need will be considered and assessed in terms of cost to implement and the relative benefits that each option is expected to deliver (including the monetised reduction in risk). In this way, risk cost is factored into all reinvestment decisions.

4 Options Investigated

Current approach to reinvestment projects

Powerlink's transmission line assets are currently defined by built section, where all structures, conductors, insulators and overhead earth wire (OHEW) elements within a transmission line section are defined as a single asset. Despite this definition, in scoping reinvestment projects for a transmission line built section, only identified degraded components required to be replaced to achieve the enduring need of the life extension are included in the scope (not all components). A project is initiated to assess options to address the need when a maintenance solution is no longer sufficient.

Transmission line reinvestments are typically in the form of life extension (or refit) projects. These types of projects are generally a single up-front investment targeted to achieve a 10 to 20 year life extension (nominally 15 years). Components within the transmission line section can vary both in condition and life expectancy based on their type (e.g. conductor, structure, or insulator) and the environment. The project scope therefore only includes necessary work to address components reaching end of technical life in order to extend the life of the transmission line, for example components on structures that are expected to reach a health index of 8 and have an enduring need.

As such, the approach enables rectification of key condition issues which are likely to lead to failure within the life extension period. Ultimately, the range of network and non-network options are compared using a cost-benefit economic analysis to recommend the lowest cost solution, including potential non-network solutions, to meet the identified minimum need.

As the intent of the reinvestment under the current approach is to extend the useful life of the whole built section for a nominal 15 years, some compliance works were typically bundled with condition based works, such as signage replacement and replacement of climbing bolts. The bundling of compliance works are included for two reasons:

- to ensure the efficient use of resources through the single establishment to any given built section over a nominal 15 year period – this is to avoid consistent upgrade of access tracks and other recurrent costs
- to ensure the ongoing compliance of the whole asset (built section) with current requirements for the duration of the life extension.

As part of the review process, members of the Working Group were invited to attend Powerlink's Rocklea Tower Farm and a tower site in the region. Access to the tower site was via the typical access tracks that are maintained suitable for maintenance access only (i.e. 4-wheel drive all-weather access). The difficulty the group experienced traversing the access tracks illustrated the work necessary to upgrade access tracks following their degradation from weather and erosion to gain access for construction vehicles. This illustrated the benefits of bundling work to maximise utilisation of upgraded access tracks, before they are allowed to revert to normal condition suitable for maintenance access.

Notwithstanding this, as a result of this review, Powerlink has reviewed the range of compliance works typically bundled with the condition based works. Through engagement with the relevant business areas, we have reviewed the drivers of the compliance needs and have determined that these works can be delayed in line with condition triggers for any given structure. We are satisfied that this approach will not result in any additional material compliance risk, while emerging minor risks will be addressed under maintenance. This change to our approach was subsequently presented to the Working Group, who supported the proposed change in bundling works.

Alternative approaches investigated

The Working Group identified a range of alternative approaches to investigate, both in isolation and in combination. These considered alternative asset (built section) definitions and bundling approaches.

Asset definition

The initial approaches identified by the Working Group in respect of the asset definition were as follows:

- Powerlink's current approach of defining an asset by built section
- grouping adjacent structures based upon common environmental conditions
- establishing assets based upon a common, fixed length of transmission line
- defining assets based upon their function within the built section (structure, insulator, conductor, etc.)
- grouping adjacent structures based upon common accessibility.

Powerlink then assessed the proposed asset definitions, to ensure that the proposed approach was feasible and in line with improving outcomes for customers, by comparing them to a set of criteria to ensure that the asset definition:

- was able to be well defined at start of life and consistent throughout asset lifecycle
- was consistent with transmission industry practice
- provided additional customer benefits over the current classification
- was practical from a general business perspective, i.e. did not result in major and widespread process changes that would likely offset any benefit identified.

Following this analysis, it was agreed with the Working Group to model the following three asset definitions for a specific case study, being the current approach and two alternatives that disaggregated the asset into smaller components.

1. Powerlink's current approach of defining an asset by built section.
2. Grouping each asset type within a built section and valuing each group as one asset, i.e. four assets per built section.
3. Defining each individual asset component as one asset, i.e. every structure, conductor span, insulator, etc. (more than 3,000 assets in the case study built section).

Bundling of work

The Working Group identified four approaches to bundling work to inform the analysis and demonstrate potential benefits.

1. Powerlink's current approach of a single up-front bundled intervention (base case).
2. Two bundled interventions based upon specific observed structure condition information.
3. Three bundled interventions with a nominal 5 year separation between interventions.
4. Annual interventions based upon expected condition projections over time.

The different bundling approaches resulted in various life extension outcomes, so any subsequent condition intervention was specifically modelled in the assessment of the specific case study.

Case Study: Refit of Ross to Chalumbin 275kV transmission line

The Ross to Chalumbin refit project was used as a case study, as it is representative of the wider network, traversing a mixture of micro-environmental conditions, and there was extensive condition data available given it formed part of Powerlink's 2023-27 Revenue Proposal. The assessment was to consider cost outcomes in net present terms and trade-offs between capital expenditure (capex) and operating expenditure (opex).

In our 2023-27 Revenue Proposal, the refit work on the Ross to Chalumbin transmission line was proposed to be undertaken from 2026 and extend the useful life of the asset for 15 years. Costs that extend the useful life of an asset are capitalised.

Methodology of the modelling undertaken

The specific estimated costs for the project were assessed and allocated between fixed costs (such as contractor establishment) and variable costs (such as unit rates), and further allocated between components of asset (disaggregated assets). These costs were then collated to derive unit rates as required for the modelling input.

For option two of the bundling approaches, specific forecasts of when structures would reach HI8 were plotted to identify a logical bundling of structures, as shown in Figure 3 below. This also informed the timing of the subsequent intervention.




Figure 5 Bundling and timing of works for bundling option 2 [source: Powerlink]

For modelling purposes, returns were calculated over 30 years – based upon the current regulatory life for refit assets – and no allowance was included for update of business systems and processes to implement change in asset definition. The alternative approaches were then compared based on the net present cost of the total return, i.e. both capex and opex.

Quantitative and qualitative results of case study analysis

The following table presents the net present cost outcomes of the modelling undertaken for Ross to Chalumbin transmission line refit options.

	Built section [*base case]	Variance to base case	Asset types (4)	Variance to base case	Asset components (3000)	Variance to base case
Single intervention	\$24.8m*	NA	\$24.8m	-	\$24.8m	-
Two bundled interventions	\$23.4m	(\$1.4m)	\$23.4m	(\$1.4m)	\$23.4m	(\$1.4m)
Three bundled interventions	\$23.2m	(\$1.6m)	\$23.0m	(\$1.8m)	\$23.0m	(\$1.8m)
Annual interventions	\$36.4m	\$11.6m	\$34.6m	\$9.8m	\$31.7m	\$6.9m

Table 3 Net present cost outcomes [source: Powerlink]

The following table collates quantitative and qualitative considerations of each option and ranks them based upon this combined assessment.

Description	Value Proposition	Ranking
Single intervention (base case)	<p>Only address the minimum work required for each asset component to achieve the required enduring need in a single mobilisation.</p> <ul style="list-style-type: none"> ✗ Higher net present cost due to bundling up-front ✓ Lowest total cost due to bundling efficiency and reduced scope (mix of items that have reached worsened state of condition) ✓ Risk Mitigation – carries slightly decreased risk compared to other options due to up-front investment 	3
Two bundled interventions (observed structure condition)	<p>Only address the minimum work required for each asset component grouped by frequency distribution of condition state triggers. Balanced approach between up-front investment and just in time approach.</p> <ul style="list-style-type: none"> ✓ Lowest net present cost due to trade-off between timing and mobilisation, note: timing tailored to specific investment needs which would vary for other investments ✗ Slightly higher total cost due to additional mobilisation but retaining bundling efficiency ✓ Risk Mitigation – no material difference 	2
Three bundled interventions (nominal 5 years)	<p>Only address the minimum work required for each asset component grouped by 5-yearly based on condition state triggers in that period. Balanced approach.</p> <ul style="list-style-type: none"> ✓ Lowest net present cost due to trade-off between timing and mobilisation, note: timing is repeatable for similar investments, and number of mobilisations depend on need and length of life extension ✗ Slightly higher total cost due to additional mobilisation but retaining bundling efficiency, and reserves ability to reassess condition nearer to trigger compared to forecast ✓ Risk Mitigation – no material difference 	1

Description	Value Proposition	Ranking
Annual interventions	<p>Only address the minimum work required for each asset component at the time (year) each reaches the worsened condition state trigger.</p> <ul style="list-style-type: none"> x Highest net present cost x Higher total cost due to additional mobilisation and works establishment costs ✓ Risk Mitigation – no material difference 	4

Table 4 Quantitative and qualitative considerations [source: Powerlink]

Preliminary results

It was evident from the results of the modelling that there are significant disadvantages in unbundling the works completely and implementing annual interventions. Therefore, we excluded this approach from any further consideration.

The economic outcomes for two interventions or three interventions were very similar, and it was deduced that these are effectively the same scenario, as the practicalities of project delivery, such as resources and access to network outages, would effectively determine the actual timing of such interventions. We therefore determined to model two interventions only for additional projects.

This resulted in two bundling scenarios remaining, which would be applied to additional projects to validate the results from the initial case study.

5 Further Analysis and Modelling

Three additional transmission line refit projects were selected from those presented in our 2023-27 Revenue Proposal, as these had the most complete data on cost and condition available. In combination, the four projects selected as case studies accounted for almost 75% of our forecast transmission line refit capital expenditure in the 2023-27 regulatory period.

- Calliope River to Wurdong Tee (project 2644)
- Davies Creek to Bayview Heights (project 2754)
- Greenbank to Mudgeeraba (project 2415).

Cost information for each of the projects was developed from existing cost estimates, in the same way as the allocation undertaken for Ross to Chalumbin (project 2750). As discussed in the previous section, only two bundling scenarios were modelled for the projects – our current approach based on a single intervention and an alternative approach with timing notionally 5-7 years apart.

To ensure that asset definitions were sufficiently tested, all three options for asset definition were retained for modelling against the additional projects

Common modelling parameters were applied throughout the assessments undertaken. The modelling period was set at 30 years, in line with the current regulatory life for refit assets, while the commercial discount rate applied was 5.08%. Annual inflation was assumed to be a consistent 2.65%.

The economic results, net present cost, of the analysis are presented below.

	Built section [*base case]	Variance to base case	Asset types (4)	Variance to base case	Asset components (3000)	Variance to base case
Project 2750 – current	\$24.8m*	NA	\$24.8m	-	\$24.8m	-
Project 2750 – alternative	\$23.2m	(\$1.6m)	\$23.0m	(\$1.8m)	\$23.0m	(\$1.8m)
Project 2644 – current	\$4.7m*	NA	\$4.7m	-	\$4.7m	-
Project 2644 – alternative	\$4.8m	\$0.1m	\$4.8m	\$0.1m	\$4.8m	\$0.1m
Project 2754 – current	\$37.7m*	NA	\$37.7m	-	\$37.7m	-
Project 2754 – alternative	\$37.9m	\$0.2m	\$37.9m	\$0.2m	\$37.9m	\$0.2m
Project 2415 – current	\$30.5m*	NA	\$30.5m	-	\$30.5m	-
Project 2415 – alternative	\$31.8m	\$1.3m	\$31.8m	\$1.3m	\$31.8m	\$1.3m

Table 5 Net present cost outcomes [source: Powerlink]

Sensitivities and scenarios modelled

To test the validity of the results derived from the economic modelling, a number of sensitivities and scenarios were modelled.

The initial economic analysis utilised project specific inputs for each built section. Therefore a sensitivity was undertaken whereby all project costs were derived from the Ross to Chalumbin transmission line refit project – effectively applying standard unit rates to all projects. This was selected as the cost information is the most mature, based upon the condition information available on the transmission line.

This sensitivity did not result in any change in the relative results of the analysis undertaken.

A second sensitivity was undertaken to assess how long the second intervention had to be deferred for there to be no variance between bundling approaches. This was undertaken through a trial and error approach and found that results of the economic analysis consistently converged to no variance if the second intervention was delayed by two years. This was expected given the very similar results between the bundling approaches in the initial economic assessment.

As a final validation, these sensitivities were then combined together with variations applied to discount rate and modelling period to establish a range of scenarios for the economic modelling. This scenario modelling found that changes in economic outcomes were generally relative to the initial results, suggesting that the economic analysis is valid for a range of sensitivities and scenarios.

The outcome of these modelled scenarios are presented in Attachment A2.

6 Findings and Recommendations

Modelling observations, conclusions and recommendations

The Working Group has made the following observations and derived the following conclusions from the results of the modelling undertaken, together with sensitivities and scenarios tested.

The results of the modelling discussed in Section 5 has demonstrated that there is no material difference between the current approach and any of the alternative approaches in net present terms. The highest observed variance in net present cost between an alternative approach and the current approach is -7% for the Ross to Chalumbin case study, while other projects result in a positive variance. This suggests that there is no material difference between the modelled approaches.

However, in addition to economic outcomes, the alternative bundling approach has the potential benefit to defer works for longer built sections, offering flexibility in the utilisation of skilled resources and deferring more significant investment decisions until there is an improved view of trade-offs based on detailed condition assessment and cost estimates.

The asset definition made no difference to economic outcomes in almost all cases. The only exceptions to this were in respect of the Ross to Chalumbin transmission line refit, where for annual interventions the asset definition had a material impact on the economic outcomes. However, this was discounted as a non-feasible option given the high cost in net present terms, and impracticality of its implementation due to impacts on skilled resources and network outage access. There is no justification to change the asset definition (i.e. from built section), especially given the undefined costs to update systems and processes to accommodate such a change to the asset management approach.

1. It is recommended that no change be implemented to Powerlink's asset definition for transmission lines (i.e. built section).

Powerlink has confirmed that the compliance works that was typically bundled with condition based works, such as signage replacement and replacement of climbing bolts, can be delayed in line with condition triggers for any given structure. This is not expected to result in any additional material compliance risk, while any emerging minor risks will be addressed under maintenance.

2. It is recommended that compliance works are only undertaken on structures where condition based work is to be performed.

There is no single most efficient option for all cases. This suggests the need to compare single and multiple staged bundling approaches to any given asset reinvestment decision, based upon the most detailed condition and cost information available at the time, and the emerging energy environment and resulting network needs. This is consistent with the RIT-T principles, which requires alternative credible options to be assessed as part of the investment decision.

3. It is recommended that both Powerlink's current approach and the alternative bundling approach be modelled for future transmission line refit investment decisions, and the most cost effective solution progressed based upon detailed condition and cost information, while allowing for the developing network needs to support the energy transformation. The difference between the two approaches is further described in Attachment A3.

Implementation of recommendations

It is proposed that these recommendations should be introduced as soon as practicable, as they are not expected to result in any material change in risk, provided that projects target completion of structures with a health index of 8 or greater in a timely fashion. Powerlink anticipates that these recommendations will be implemented in 2023/24.

Following completion of this review with the issue of this report, we will identify relevant asset management process documentation, such as our Asset Management Framework and Asset Reinvestment Process, and update in order to reflect the recommendations of this review. This will effectively operationalise the recommendations into our ongoing business as usual processes.

Powerlink is currently implementing enhancements to our risk cost modelling approach, in order to better quantify emerging risks at a project and an entire portfolio level. This is expected to deliver a tool to ensure that we achieve a consistent and repeatable process to quantify specific project risks. Consequently, we have started to incorporate the recommendations and the insights derived from this review into our developing risk cost modelling approach.

In parallel to the enhanced risk cost modelling approach, we will apply the alternative bundling approach to project options as part of the RIT-T economic cost benefit analysis with immediate effect. In this way, we will identify the specific option that presents the most cost effective outcome to customers while considering the benefits arising from preserving future optionality.

Aligning recommendations to AER concerns

The AER noted two key concerns with the approach taken by Powerlink in formulating its reinvestment capex forecast for transmission lines¹⁰. The AER went on to note two additional issues of concern, somewhat informed by and overlapping with the key concerns.

These four concerns are detailed in the following table, which also relates the specific recommendations to the original AER concerns in respect of our asset reinvestment decision making process for transmission lines.

AER concern	Addressed by
Powerlink does not base its transmission line replacement scope of works on individual transmission line tower cost benefit analysis ¹¹	<ul style="list-style-type: none"> Recommendation 2 Recommendation 3 (with further discussion in Section 3)
Powerlink's economic analysis does not consider the option of a more targeted refurbishment of the individual towers ¹²	<ul style="list-style-type: none"> Recommendation 3
Powerlink's use of the HI is reasonable, we still have some concerns about how the HI is modelled ¹³	<ul style="list-style-type: none"> Recommendation 3 (with further discussion in Section 3)
Intervention earlier than required to maintain asset performance is generally inefficient as it brings forward costs without matching benefits ¹⁴	<ul style="list-style-type: none"> Recommendation 2 Recommendation 3

Table 6 Comparison of recommendations to AER concerns [source: Powerlink]

¹⁰ AER, Draft Decision, [Powerlink Queensland Transmission Determination 2022 to 2027, Attachment 5 Capital Expenditure](#), September 2021, page 16.

¹¹ Ibid, page 16.

¹² Ibid, page 16.

¹³ Ibid, page 16.

¹⁴ Ibid, page 17.

Aligning outcomes to the scope of the review

The following table relates the outcomes and recommendations of the review to the specific scope elements developed by the Working Group, and also identifies any issue not fully addressed as part of this review where further actions are to be progressed.

Scope element	Addressed by
Social licence to operate over the asset life	This was not addressed specifically due to the complexity and project specificity. Commitment included in next steps following completion of the review.
Built section definition and its impact on the intervention timing and scale of works	Recommendation 1 The analysis has demonstrated that there is no material benefit in changing asset definitions for transmission lines.
How to better capture the benefits, including financial, of 'bundling' condition and compliance driven works within transmission line projects	Recommendations 2 and 3 Addressing compliance only with condition triggers and consideration of both approaches in RIT-T will explicitly identify the benefits of bundling works on a project-by-project basis.
How to better capture the challenges and costs, of access for Powerlink assets, both from a remote geographic and network outage perspective	Recommendation 3 Consideration of both approaches in RIT-T will explicitly identify the costs associated with physical and network access on a project-by-project basis.
What is optimal at both a project and portfolio level	Recommendation 3 Capital expenditure forecasts to inform the portfolio impacts will reflect a balance between both approaches. Consideration of optionality will also assist in optimising portfolio level outcomes.
The AER Industry practice application note asset replacement planning	This is discussed in section 3. Powerlink considers its processes to be consistent with the AER application note.
How to incorporate best practice approaches used by other networks	Asset definition considered as part of review. Commitment also included in next steps following completion of the review.
Future-proofing – given the rapidly changing environment, there is a need to ensure improvements to asset reinvestments are sustainable of the longer-term	Recommendation 3 Consideration of optionality to address the emerging energy transformation will ensure reinvestment is only undertaken where there is reasonable confidence in an enduring need for the assets.
How to ensure predictable and repeatable outcomes	Recommendation 3 The commitment to report back to our Customer Panel will also ensure that we continue to adopt a consistent approach to reinvestment decisions.

Table 7 Comparison of outcomes to scope elements [source: Powerlink]

Working Group – key insights

The following are observations and insights provided by the Working Group members external to Powerlink.

- Supporting this review to be undertaken following the conclusion of the regulatory process was a show of faith by the AER that the good engagement undertaken by Powerlink in developing the revenue proposal gave confidence that the issue would be considered appropriately. This faith has been maintained by the thorough process that Powerlink has lead in preparing this report
- Throughout the lifecycle of the Working Group, Powerlink demonstrated transparent and collaborative behaviour. The Working Group comprised of members selected from Powerlink's Customer Panel, the AER, members of the AER's Consumer Challenge Panel (CCP23) and subject matter experts within Powerlink. Both the Terms of Reference and agendas were co-designed, which ensured the Working Group focused on achieving the intended objectives, while ensuring the approach and recommendations could be practically deployed. Clear, objective and comprehensive information was provided, which enabled the Working Group to reach the review's conclusions and recommendations. Powerlink demonstrated that the perspectives of Working Group members were incorporated in a way that shaped the overall review process, conclusions and recommendations
- The Working Group have confidence that the recommendations can be practically implemented and will improve the robustness of future investment evaluations. Powerlink have committed to publishing a report, to outline how the recommendations have been embedded into internal systems, processes, procedures and investment evaluations.

The Working Group also identified the importance of Powerlink ensuring that reinvestment decisions are made in a way that efficiently accommodates potential future scenarios, i.e. future-proof reinvestment decisions by preserving future optionality. Specifically, the Working Group noted that the alternative bundling approach could enable a more flexible delivery and resourcing model through better staging of projects based on risk, which may provide improved ability to react to the emerging energy environment and resulting network needs.

Next steps following completion of the review

We have committed to report back to our Customer Panel on the progress made in embedding the recommendations from this review into our business as usual processes, and any observed outcomes arising, one year after finalisation of the review. It is envisaged that this will be undertaken by way of an update within one of the quarterly meetings, but the approach will be discussed and agreed with the Customer Panel upon finalisation of this review. Any quantifiable benefits identified through specific RIT-T assessments, such as cost efficiencies or efficient utilisation of resources, will be used to inform the feedback provided to the Customer Panel.

In addition to these specific recommendations, and in line with our commitment to continuous improvement, we will review our contracting and resourcing approach for delivery of transmission line reinvestment works. This will be used to better inform up-front investment decisions in line with the capability and capacity of available resources. This is an internal management action to be undertaken as part of a wider review of our works delivery capability, which we have commenced, as we seek to position ourselves to deliver the energy transformation in a timely and efficient manner.

The need for further work has been identified in consideration of the trade-offs between flexible staging of works (more frequent incursions onto landholders' property) and a single bundled up-front intervention in terms of impact on our ongoing social licence to operate our assets. Although this work is not yet scoped, we expect that it will be informed through our ongoing engagement


with communities and landholders, and will be factored into assessments on a project specific basis.

Finally, although the review has resulted in some actions that align with other network businesses, such as the reduction of compliance works on built sections, it demonstrated no benefit in changing the underlying definition of an asset (with the resultant impacts on classification of works between capital and operating). However, we acknowledge the need to continually review the approach of other network businesses with respect to identification of prudent practices given the prevalent circumstances. Hence, we will continue to monitor the approach of other network businesses, through our connection with Energy Networks Australia.

Powerlink considers that the recommendations to be implemented from this review, together with the next steps to be investigated following completion of the review, will assist in enhancing the future capital reinvestment forecasts for transmission lines within the current regulatory period and future regulatory periods. The scope of the review excluded consideration of use of the Repex Model for future revenue proposals, as this is not used to determine reinvestment requirements in the normal course of business. Powerlink will consider how to forecast its reinvestment expenditure ahead of commencing our 2028-32 Revenue Proposal process. Notwithstanding this, the revised approach to the bundling of works, including only addressing compliance works on a structure with condition triggers, will be reflected in our actual capital expenditure going forward.

Attachments

A1: Review process – overview



Scenario analysis:

Original analysis and sensitivities were considered independently and in combination with variations applied to discount rate and modeling period as follows:

Discount rate:	5.08%	2.54%	7.62%	5.08%
Modelling period:	30 yrs	30 yrs	30 yrs	15 yrs

A2: Comparison of variance between single up-front intervention and two interventions within 15 year period with various sensitivities

	Discount rate = 5.08% Model period = 30 years			
	Initial analysis	BS1220 costs	Stage 2 delay 2yrs	BS1220 costs +2yr
Project 2644	-0.07	-0.69	0.02	-0.55
Project 2754	-0.24	-0.77	0.36	-0.66
Project 2415	-1.39	-0.62	-0.79	-0.37
Project 2750	0.66	0.66	1.44	1.44
Average	-0.26	-0.36	0.25	-0.04

	Discount rate = 2.54% Model period = 30 years			
	Initial analysis	BS1220 costs	Stage 2 delay 2yrs	BS1220 costs +2yr
Project 2644	-0.04	-0.39	0.01	-0.31
Project 2754	-0.13	-0.43	0.20	-0.37
Project 2415	-0.78	-0.35	-0.44	-0.21
Project 2750	0.37	0.37	0.81	0.81
Average	-0.15	-0.20	0.14	-0.02

Built Section	Discount rate = 7.62% Model period = 30 years			
	Initial analysis	BS1220 costs	Stage 2 delay 2yrs	BS1220 costs +2yr
Project 2644	-0.11	-1.00	0.03	-0.79
Project 2754	-0.34	-1.12	0.51	-0.95
Project 2415	-2.00	-0.90	-1.14	-0.54
Project 2750	0.95	0.95	2.07	2.07
Average	-0.37	-0.51	0.37	-0.05

Built Section	Discount rate = 5.08% Model period = 15 years			
	Initial analysis	BS1220 costs	Stage 2 delay 2yrs	BS1220 costs +2yr
Project 2644	0.21	-0.02	0.36	0.22
Project 2754	1.48	-0.15	2.45	0.03
Project 2415	0.28	0.10	1.26	0.50
Project 2750	2.20	2.20	3.48	3.48
Average	1.04	0.53	1.89	1.06

A3: Proposed alternative approach to bundling

The alternative bundling approach enables the subdivision of refit projects into stages based on condition (grouping elements with worse condition into the first stage and others with less severe condition into subsequent stage/s). A built section refit could be completed in a single or in multiple stages depending on the most economic option, largely driven by bundling efficiencies compared with economic savings through capital deferral. A typical five-yearly staged project was found to be a repeatable approach that may provide a net benefit for longer transmission lines. No significant change in probability of failure risk is expected provided:

- the condition of all structures is known
- the project targets the completion of structures with a health index of 8 or higher in a timely fashion.

The bundling approaches are illustrated in Figure 4.




Figure 6 Summary of current vs alternative approach [source: Powerlink]

This change would effectively change the scoping for projects to introduce a new bundling method, or stages, as a standard option for life extension projects. The proposed change would have no impact on the definition of a built section (i.e. asset structure). The cost to change asset structure would likely be significant but project modelling did not demonstrate any material benefit to support this change. Nonetheless, strict application of financial accounting principles is required when determining capital or operational expenditure for projects.

Transmission Line Refit Strategy 2028-2032

Executive Summary

Powerlink Queensland's Transmission Line Refit Strategy for 2028–2032 refines the organisation's approach to asset reinvestment, responding to regulatory feedback and internal reviews. The strategy prioritises optimising timing, scope, and cost-effectiveness for transmission line refit projects, with the dual goals of maintaining network reliability and safety while managing financial and operational risks. Key elements include the adoption of risk-cost based analysis for project prioritisation, consideration of both full and staged refit options, and bundling smaller projects into regional packages to achieve delivery efficiencies.

Over the 2028-2032 period, four (4) standalone refit projects are planned which will incorporate the ARR recommendations with the remaining refits to be bundled into regionalised refits as follows:

Region	110/ 132kV	275kV	Str Qty
Cairns	22	22	44
Townsville/Mackay	64	11	75
Central	13	2	15
Southern	13	88	101
Network Wide	112	123	235

Background

Asset Reinvestment Review (ARR) Outcomes and Powerlink Response

The AER's 2022–27 draft revenue determination endorsed Powerlink's improved risk-cost based capital expenditure forecasting, while recommending a more targeted economic approach for overhead transmission line reinvestment and raising concerns about the Repex Model. In response, Powerlink's Asset Reinvestment Review Working Group advised maintaining the current asset definition, limiting compliance works to structures requiring condition-based interventions, and comparing single versus staged bundled investment approaches using detailed condition and cost data. Line Strategies subsequently updated asset management methods, risk-cost approaches, and project scopes, revising the reinvestment criteria from an asset health index of 7 to 8, which led to project deferrals across the transmission line portfolio.

Transmission Line Refit Program 2028-32

The Transmission Line Refit Program 2028–32 adopts the ARR recommendations, considering both single intervention and bundled strategies for refit projects, with economic analysis guiding the selection of the most cost-effective option. For the revenue proposal, Powerlink prioritised 30 transmission line-built sections forecast to reach end of life by 2032, using overall asset risk cost (safety, financial, bushfire), unitised risk cost per 100km, and asset health index (AHI) as key criteria. Refer Appendix A.

Each Refit project was assessed for two treatment options:

- **Full refit:** Replace G3/G4 components to restore all structures to approximately HI4, including bundled insulators and earthwire.
- **Targeted refit:** Address only towers above HI8 (end-of-life) by 2032, with further interventions in subsequent regulatory periods.

Large-scale, high-priority projects form the tier 1 list, while smaller transmission lines are bundled into regional refit packs for delivery efficiency. Prioritisation excludes detailed options and NPV analysis, relying on normalised risk cost values, revised risk cost methodology, and sample-based health projections. Network risk and market impact are excluded due to unavailable data, and bushfire risk is assessed using Project Ignis data.

Tier 1 Refit List

- CP.02631 Ross – Dan Gleeson BS1257 Refit
- CP.02750 BS1220 Ross to Chalumbin Line Refit
- CP.02818 BS1020 Woolooga-South Pine 275kV Refit
- CP.03196 BS1009 Mudgeeraba to STR-1731 Line Refit

Regional Refit List

Transmission line refit projects not classified as tier 1 were grouped into regional packages for the 2028–2032 reset. This bundling approach is designed to improve delivery efficiency and reduce costs compared to managing smaller standalone projects. Network wide, the regional refit includes 235 towers, 112 of 110/132kV and 123 of 275kV towers.

Region	Sub-Region	110/ 132kV	275kV	Str Qty
Cairns		22	22	44
	Cairns	22	22	44
Townsville/Mackay		64	11	75
	Townsville	3	11	14
	Mackay	61	0	61
Central		13	2	15
	Rockhampton/Gladstone	13	2	15
Southern		13	88	101
	Brisbane	9	25	34
	Gold Coast	0	34	34
	Gympie	0	19	19
	SEQ West	4	10	14
Network Wide		112	123	235

Refer Appendix B for a breakdown of structures to be refit in sub-regions and itemised per voltage.

Refer Appendix C for a complete list of all structures which form the basis of the quantities. Extrapolated health indices are based on recent condition inspections and have HIs projected to 2032. Structures with no condition data used interpolated health indices only.

Regional Refit Works Overview

Undertake transmission line works on built sections in the region as follows:

- Condition assessment of all targeted built sections to provide measuring point data for input into SAP.

Pending the results of the condition assessments, the structural refit will include the following works package at nominated structures which meet the reinvestment criteria:

- Repair of cracked, damaged or corroded foundations,
- Install or upgrade of gradient earthing where required,
- Replacement of step bolts as per the latest design standard
- Replacement of bolts that are G3 and above (20%)
- Repair or replacement of members that are either damaged or are corrosion grade G3 or above (1%)
- Upgrade any anti-climb barriers that are not consistent with the area classification
- Address all open notifications related to the nominated structure

In addition, a second works package along nominated built sections will include:

- Replacement of insulator and hardware assemblies that are G3 or above
- Replacement of OHEW and OPGW hardware assemblies that are G3 or above

Update all SAP records in accordance with standards and specifications.

Appendix A: Network Investment Outlook Asset Risk Priority

Budget	Project No	C55_No	Description	2032 AHI	2032 RC (Safety, Financial and Bushfire only)	2032 Risk per 100km (Safety, Financial and Bushfire only)
Capital	CP.02776	1368	BS1100 & BS1101 Gladstone Sth to QAL Re-invest	10.79897	\$ 68,144,198	\$ 47,985,493
Capital	CP.02775	1370	BS1132 Bouldercombe to Nebo Re-invest	10.17398	\$ 30,534,989	\$ 11,753,268
Capital	CP.02750	1177	BS1220 Ross to Chalumbin Line Refit	10.3359	\$ 10,346,453	\$ 4,238,612
Capital	C55.0696	696	Mudgeeraba to STR-1731 (NSW Boarder Terranora) Line Refit (1009)	8.480061	\$ 13,576,960	\$ 100,868,948
Capital	C55.2220	2220	BS1143 Wurdong to Boyne Refit/Rebuild	10.03372	\$ 12,862,840	\$ 173,120,318
Capital	CP.02631	485	Ross-Dan Gleeson B1257 TL Refit	9.111875	\$ 2,281,366	\$ 25,691,064
Capital	CP.02292	360	Blackstone-Abermain BS1003 Line Refit	8.286524	\$ 4,677,414	\$ 36,428,462
Capital	CP.02818	698	Woolooga-South Pine 275kV Modified Refit BS1020	8.966447	\$ 17,677,023	\$ 11,053,666
Capital	C55.1208	1208	BS1021 South Pine to Palmwoods Life Extension	8.123796	\$ 9,776,376	\$ 13,002,230
Capital	CP.02532	27	Bergins Hill-Goodna-Belmont 275kV TL Refit	7.822184	\$ 19,227,697	\$ 50,880,383
Capital	C55.1046	1046	BS1223 Dan Gleeson-Alan Sherriff life extension	7.412398	\$ 811,926	\$ 14,269,347
Capital	C55.1283	1283	BS1046 and 1066 Bergins Hill Karana Downs Life Extension	7.875849	\$ 853,256	\$ 864,758
Capital	CP.02415	416	Greenbank - Mudgeeraba 275kV TL Refit	7.66126	\$ 12,986,685	\$ 9,840,634
Capital	CP.02150	1209	BS1025 Gin Gin to Woolooga TL Refit	7.873909	\$ 298,109	\$ 198,700
Capital	CP.01657	188	Raglan to Larcom Creek 275kV TL Refit (BS1532)	7.548759	\$ 214,954	\$ 830,578
Capital	C55.1648	1648	BSs1213 Strathmore to BS1635 (Ross) First Refit	7.420463	\$ 115,282	\$ 72,209
Capital	C55.0699	699	Richlands-Algester 110kV Life Refit (1043)	7.371928	\$ 515,178	\$ 6,463,959
Capital	C55.1140	1140	BS1224 Life Extension	8.987298	\$ 44,119	\$ 5,252,255
Capital	C55.1327	1327	exBS1235 Chalumbin-Woree 275kV refit and paint	7.071232	\$ 2,807,846	\$ 7,067,320
Capital	CP.02749	1310	BS1142 Wurdong to Boyne Line Refit	6.05221	\$ 3,212,784	\$ 46,360,522
Capital	CP.02306	366	Nebo - Eton 132kV TL Refit	6.785435	\$ 99,106	\$ 182,516
Capital	CP.01648	182	Swanbank-Redbank Plains-West Darra 110kV TL Refit	6.100525	\$ 16,123,065	\$ 95,177,480
Capital	CP.02565	460	Karana Downs to South Pine TL Refit	6.885674	\$ 16,805,478	\$ 52,029,345
Capital	C55.0381	381	BS1167 Bouldercombe - Bouldercombe Tee Life Ext	4.390285	\$ 1,600	\$ 59,260
Capital	C55.1165	1165	BS1024 Woolooga - Gin Gin Life Extension	7.255957	\$ 295,158	\$ 198,092
Capital	CP.02189	318	West Darra - Upper Kedron 110kV Refit	6.195434	\$ 11,313,161	\$ 65,018,167
Capital	C55.1333	1333	BS1028 Teebar Ck to Gin Gin refit	5.814084	\$ 75,615	\$ 75,015
Capital	C55.1893	1893	BS1140 F856 Stanwell To Broadsound	7.020699	\$ 173,717	\$ 136,452
Capital	CP.02304	365	Collinsville/Strathmore - Clare TL Refit	5.81028	\$ 130,658	\$ 124,436

Appendix B – Refit Structure Summary

Built Section (SEQ West)	Voltage	Comm. Year	Structures	Nr. Strs HI > 8 in 2032
BS1003 Blackstone -- Abermain	110kV	1966	48	4
BS1046 Blackwall – Goodna	275kV	1970	14	10
<hr/>				
Built Section (Brisbane)	Voltage	Comm. Year	Structures	Nr. Strs HI > 8 in 2032
BS1008 Belmont -- Loganlea	110kV	1982	10	4
BS1015 Goodna – Belmont	275kV	1972	61	4
BS1021 South Pine – Palmwoods	275kV	1976	162	21
BS1038 West Darra – Sumner	110kV	1963	16	5
<hr/>				
Built Section (Gympie)	Voltage	Comm. Year	Structures	Nr. Strs HI > 8 in 2032
BS1025 Woolooga – Gin Gin	275kV	1976	364	14
BS1048 Palmwoods – Woolooga	275kV	1976	207	5
<hr/>				
Built Section (Gold Coast)	Voltage	Comm. Year	Structures	Nr. Strs HI > 8 in 2032
BS1018 Greenbank – Mudgeeraba	275kV	1975	165	17
BS1019 Greenbank – Mudgeeraba	275kV	1974	165	17
<hr/>				
Built Section (Townsville)	Voltage	Comm. Year	Structures	Nr. Strs HI > 8 in 2032
BS1213 Strathmore (STR-1000) – Ross (STR-0919)	275kV	1978	421	11
BS1218 Townsville South – STR-1506	132kV	1982	3	2
BS1224 Townsville South – STR-1069	132kV	1984	3	1
<hr/>				
Built Section (Mackay)	Voltage	Comm. Year	Structures	Nr. Strs HI > 8 in 2032
BS1204 Mackay – Pioneer Valley	132kV	1977	56	12
BS1241 Pioneer Valley – Eton Tee	132kV	1977	42	27
BS1626 Nebo – Pioneer Valley	132kV	2008	178	22
<hr/>				
Built Section (Cairns)	Voltage	Comm. Year	Structures	Nr. Strs HI > 8 in 2032
BS1236 Woree – STR-0140	275kV/132kV	1998	23	5
BS1253 Chalumbin – Turkinje	132kV	1986	219	22
BS1254 Woree – STR-0130	275kV	1998	10	5
BS1664 Bayview Heights – STR-0085	275kV	1998	37	12
<hr/>				
Built Section (Rockhampton - Gladstone)	Voltage	Comm. Year	Structures	Nr. Strs HI > 8 in 2032
BS1100 Gladstone South to QAL	132kV	1966	14	4
BS1101 Gladstone South to QAL	132kV	1966	15	9
BS1160 Calliope River to STR-011	275kV	1980	6	1
BS1178 STR-0770 to Bouldercombe	275kV	1977	2	1

Appendix C – Raw Data

Cairns Region

BS	Asset functional location	EQUIP	Risk_Model_Name	2026 Health Index	2027 Health Index	2028 Health Index	2029 Health Index	2030 Health Index	2031 Health Index	2032 Health Index	2032 Health Index
1236	1236-STR-0150	STRUCTURE D2S15J+18	C55LIN004 - Lattice Steel - Suspension - C5	6.40	6.62	6.84	7.13	7.63	8.13	8.63	8.63
1236	1236-STR-0151	STRUCTURE D2S15J+18 text	C55LIN004 - Lattice Steel - Suspension - C5	7.00	7.50	8.00	8.50	9.00	9.50	10.00	10.00
1236	1236-STR-0152	STRUCTURE D2S15J+18	C55LIN004 - Lattice Steel - Suspension - C5								8.81
1236	1236-STR-0154	STRUCTURE D2T70J+12	C55LIN003 - Lattice Steel - Tension - C5	7.40	7.90	8.40	8.90	9.40	9.90	10.40	10.40
1236	1236-STR-0155	STRUCTURE D2S15J+9	C55LIN004 - Lattice Steel - Suspension - C5								8.55
1253	1253-STR-6061	STRUCTURE D1S2A-3	C55LIN004 - Lattice Steel - Suspension - C5	9.60	10.10	10.60	11.10	11.60	12.10	12.60	12.60
1253	1253-STR-6062	STRUCTURE D1S2A-9	C55LIN004 - Lattice Steel - Suspension - C5	7.01	7.51	8.01	8.51	9.01	9.51	10.01	10.01
1253	1253-STR-6067	STRUCTURE D1S2A-3	C55LIN004 - Lattice Steel - Suspension - C4	6.48	6.65	6.83	7.00	7.38	7.75	8.13	8.13
1253	1253-STR-6069	STRUCTURE D1S2A-3	C55LIN004 - Lattice Steel - Suspension - C4	6.75	6.93	7.21	7.59	7.96	8.34	8.71	8.71
1253	1253-STR-6070	STRUCTURE D1S2A+0	C55LIN004 - Lattice Steel - Suspension - C4								11.11
1253	1253-STR-6071	STRUCTURE D1S2A-3	C55LIN004 - Lattice Steel - Suspension - C5	10.50	11.00	11.50	12.00	12.50	13.00	13.50	13.50
1253	1253-STR-6073	STRUCTURE D1S10A+0	C55LIN004 - Lattice Steel - Suspension - C5	10.00	10.50	11.00	11.50	12.00	12.50	13.00	13.00
1253	1253-STR-6074	STRUCTURE D1S10A-6	C55LIN004 - Lattice Steel - Suspension - C4	10.13	10.50	10.88	11.25	11.63	12.00	12.38	12.38
1253	1253-STR-6075	STRUCTURE D1S2A-6	C55LIN004 - Lattice Steel - Suspension - C4	8.83	9.20	9.58	9.95	10.33	10.70	11.08	11.08
1253	1253-STR-6076	STRUCTURE D1S0A+0	C55LIN004 - Lattice Steel - Suspension - C4	7.75	8.13	8.50	8.88	9.25	9.63	10.00	10.00
1253	1253-STR-6077	STRUCTURE D1S10A+3	C55LIN004 - Lattice Steel - Suspension - C4								8.44
1253	1253-STR-6091	STRUCTURE D1S2A-9	C55LIN004 - Lattice Steel - Suspension - C4	6.73	6.90	7.16	7.54	7.91	8.29	8.66	8.66
1253	1253-STR-6112	STRUCTURE D1S10A-3	C55LIN004 - Lattice Steel - Suspension - C4	6.83	7.00	7.38	7.75	8.13	8.50	8.88	8.88
1253	1253-STR-6118	STRUCTURE D1S2A+3	C55LIN004 - Lattice Steel - Suspension - C4								8.38
1253	1253-STR-6119	STRUCTURE D1T70A+3	C55LIN003 - Lattice Steel - Tension - C4								8.89
1253	1253-STR-6120	STRUCTURE D1T70A+3	C55LIN003 - Lattice Steel - Tension - C4								9.39
1253	1253-STR-6121	STRUCTURE D1S0A-3	C55LIN004 - Lattice Steel - Suspension - C4								9.89
1253	1253-STR-7203	STRUCTURE D2T15+0	C55LIN003 - Lattice Steel - Tension - C5	7.39	7.89	8.39	8.89	9.39	9.89	10.39	10.39
1253	1253-STR-7272	STRUCTURE D1S2A-8	C55LIN004 - Lattice Steel - Suspension - C4	6.43	6.60	6.78	6.95	7.27	7.64	8.02	8.02
1253	1253-STR-7294	STRUCTURE D1T40A-12	C55LIN003 - Lattice Steel - Tension - C4	6.63	6.80	6.98	7.32	7.70	8.07	8.45	8.45
1253	1253-STR-7355	STRUCTURE D1S2A+12	C55LIN004 - Lattice Steel - Suspension - C4	6.73	6.90	7.16	7.54	7.91	8.29	8.66	8.66
1253	1253-STR-7356	STRUCTURE D1S2A+12	C55LIN004 - Lattice Steel - Suspension - C4	6.73	6.90	7.16	7.54	7.91	8.29	8.66	8.66
1254	1254-STR-0132	STRUCTURE D2S15J+18 text	C55LIN004 - Lattice Steel - Suspension - C5	8.90	9.40	9.90	10.40	10.90	11.40	11.90	11.90
1254	1254-STR-0133	STRUCTURE D2T70J+12	C55LIN003 - Lattice Steel - Tension - C5	9.04	9.54	10.04	10.54	11.04	11.54	12.04	12.04
1254	1254-STR-0134	STRUCTURE D2T70J+12 text	C55LIN003 - Lattice Steel - Tension - C5	7.48	7.98	8.48	8.98	9.48	9.98	10.48	10.48
1254	1254-STR-0135	STRUCTURE D2S15J+9	C55LIN004 - Lattice Steel - Suspension - C5	6.90	7.27	7.77	8.27	8.77	9.27	9.77	9.77
1254	1254-STR-0138	STRUCTURE D2T70J+18 text	C55LIN003 - Lattice Steel - Tension - C5	8.50	9.00	9.50	10.00	10.50	11.00	11.50	11.50
1664	1664-STR-0085	STRUCTURE D2T60E+9	C55LIN003 - Lattice Steel - Tension - C4	9.35	9.73	10.10	10.48	10.85	11.23	11.60	11.60
1664	1664-STR-0089	STRUCTURE D2S0H+30	C55LIN004 - Lattice Steel - Suspension - C5	6.80	7.04	7.54	8.04	8.54	9.04	9.54	9.54
1664	1664-STR-0096	STRUCTURE D2S0H+33	C55LIN004 - Lattice Steel - Suspension - C5	7.04	7.54	8.04	8.54	9.04	9.54	10.04	10.04
1664	1664-STR-0098	STRUCTURE D2S0H+24	C55LIN004 - Lattice Steel - Suspension - C5	6.34	6.56	6.78	6.99	7.49	7.99	8.49	8.49
1664	1664-STR-0100	STRUCTURE D2S0H+6	C55LIN004 - Lattice Steel - Suspension - C5	6.74	6.96	7.40	7.90	8.40	8.90	9.40	9.40
1664	1664-STR-0106	STRUCTURE D2S0H+21	C55LIN004 - Lattice Steel - Suspension - C5	6.84	7.13	7.63	8.13	8.63	9.13	9.63	9.63
1664	1664-STR-0111	STRUCTURE D2S0H+6	C55LIN004 - Lattice Steel - Suspension - C5	6.34	6.56	6.78	6.99	7.49	7.99	8.49	8.49
1664	1664-STR-0114	STRUCTURE D2T45H+6	C55LIN003 - Lattice Steel - Tension - C5	6.34	6.56	6.78	6.99	7.49	7.99	8.49	8.49
1664	1664-STR-0115	STRUCTURE D2S0H+33	C55LIN004 - Lattice Steel - Suspension - C5	8.60	9.10	9.60	10.10	10.60	11.10	11.60	11.60
1664	1664-STR-0116	STRUCTURE D2S0H+30	C55LIN004 - Lattice Steel - Suspension - C5	8.50	9.00	9.50	10.00	10.50	11.00	11.50	11.50
1664	1664-STR-0117	STRUCTURE D2T45H+12	C55LIN003 - Lattice Steel - Tension - C5	6.94	7.36	7.86	8.36	8.86	9.36	9.86	9.86
1664	1664-STR-0121	STRUCTURE D2T70J+3	C55LIN003 - Lattice Steel - Tension - C5	10.00	10.50	11.00	11.50	12.00	12.50	13.00	13.00

Central Region

BS	Asset functional location	EQUIP	Risk_Model_Name	2026 Health Index	2027 Health Index	2028 Health Index	2029 Health Index	2030 Health Index	2031 Health Index	2032 Health Index	2032 Health Index
1100	1100-STR-0002	STRUCTURE GW+0	C55LIN004 - Lattice Steel - Suspension - C4	7.45	7.83	8.20	8.58	8.95	9.33	9.70	9.70
1100	1100-STR-0009	STRUCTURE QW30+10	C55LIN003 - Lattice Steel - Tension - C4	7.73	8.10	8.48	8.85	9.23	9.60	9.98	9.98
1100	1100-STR-0010	STRUCTURE GW+0	C55LIN004 - Lattice Steel - Suspension - C4	7.45	7.83	8.20	8.58	8.95	9.33	9.70	9.70
1100	1100-STR-0011	STRUCTURE QTW90+0	C55LIN003 - Lattice Steel - Tension - C4	9.25	9.63	10.00	10.38	10.75	11.13	11.50	11.50
1101	1101-STR-0001	STRUCTURE QTW90+10	C55LIN003 - Lattice Steel - Tension - C4	8.48	8.85	9.23	9.60	9.98	10.35	10.73	10.73
1101	1101-STR-0003	STRUCTURE QW30+10	C55LIN003 - Lattice Steel - Tension - C4	9.18	9.55	9.93	10.30	10.68	11.05	11.43	11.43
1101	1101-STR-0004	STRUCTURE QW30+10	C55LIN003 - Lattice Steel - Tension - C4	6.93	7.21	7.59	7.96	8.34	8.71	9.09	9.09
1101	1101-STR-0005	STRUCTURE GW+10	C55LIN004 - Lattice Steel - Suspension - C4	7.83	8.20	8.58	8.95	9.33	9.70	10.08	10.08
1101	1101-STR-0006	STRUCTURE GW+10	C55LIN004 - Lattice Steel - Suspension - C4	6.43	6.60	6.78	6.95	7.27	7.64	8.02	8.02
1101	1101-STR-0008	STRUCTURE GW+20	C55LIN004 - Lattice Steel - Suspension - C4	8.28	8.65	9.03	9.40	9.78	10.15	10.53	10.53
1101	1101-STR-0009	STRUCTURE QW30+10	C55LIN003 - Lattice Steel - Tension - C4	9.58	9.95	10.33	10.70	11.08	11.45	11.83	11.83
1101	1101-STR-0010	STRUCTURE GW+10	C55LIN004 - Lattice Steel - Suspension - C4	12.18	12.55	12.93	13.30	13.68	14.05	14.43	14.43
1101	1101-STR-0011	STRUCTURE QTW90+10	C55LIN003 - Lattice Steel - Tension - C4	11.38	11.75	12.13	12.50	12.88	13.25	13.63	13.63
1160	1160-STR-0008	STRUCTURE PSAM/C+0	C55LIN003 - Lattice Steel - Tension - C4	8.13	8.50	8.88	9.25	9.63	10.00	10.38	10.38
1178	1178-STR-0770	STRUCTURE PDAM/T-3	C55LIN003 - Lattice Steel - Tension - C3	6.94	7.17	7.47	7.77	8.07	8.37	8.67	8.67

Townsville/Mackay Region

BS	Asset functional location	EQUIP	Risk_Model_Name	2026 Health Index	2027 Health Index	2028 Health Index	2029 Health Index	2030 Health Index	2031 Health Index	2032 Health Index	2033 Health Index
1204	1204-STR-1651	STRUCTURE LDSH+18	C55LIN004 - Lattice Steel - Suspension - C5	6.84	7.14	7.64	8.14	8.64	9.14	9.64	9.64
1204	1204-STR-1652	STRUCTURE LDSL+3	C55LIN004 - Lattice Steel - Suspension - C5	6.84	7.14	7.64	8.14	8.64	9.14	9.64	9.64
1204	1204-STR-1655	STRUCTURE LDSL+12	C55LIN004 - Lattice Steel - Suspension - C5	8.10	8.60	9.10	9.60	10.10	10.60	11.10	11.10
1204	1204-STR-1656	STRUCTURE LDSL+12	C55LIN004 - Lattice Steel - Suspension - C5	6.84	7.14	7.64	8.14	8.64	9.14	9.64	9.64
1204	1204-STR-1657	STRUCTURE LDAM+6	C55LIN003 - Lattice Steel - Tension - C5	6.84	7.14	7.64	8.14	8.64	9.14	9.64	9.64
1204	1204-STR-1659	STRUCTURE LDSL+6	C55LIN004 - Lattice Steel - Suspension - C5	6.84	7.14	7.64	8.14	8.64	9.14	9.64	9.64
1204	1204-STR-1660	STRUCTURE LDSL+15	C55LIN004 - Lattice Steel - Suspension - C5	6.84	7.14	7.64	8.14	8.64	9.14	9.64	9.64
1204	1204-STR-1661	STRUCTURE LDSH+12	C55LIN004 - Lattice Steel - Suspension - C5	6.84	7.14	7.64	8.14	8.64	9.14	9.64	9.64
1204	1204-STR-1663	STRUCTURE LDAL+S0	C55LIN004 - Lattice Steel - Suspension - C5	6.84	7.14	7.64	8.14	8.64	9.14	9.64	9.64
1204	1204-STR-1665	STRUCTURE LDAL+6	C55LIN003 - Lattice Steel - Tension - C5	6.84	7.14	7.64	8.14	8.64	9.14	9.64	9.64
1204	1204-STR-1666	STRUCTURE LDAL+6	C55LIN003 - Lattice Steel - Tension - C5	6.84	7.14	7.64	8.14	8.64	9.14	9.64	9.64
1204	1204-STR-1691	STRUCTURE LDSL+3	C55LIN004 - Lattice Steel - Suspension - C4	6.88	7.11	7.48	7.86	8.23	8.61	8.98	8.98
1213	1213-STR-0506	STRUCTURE PSSL/5-3	C55LIN004 - Lattice Steel - Suspension - C2	7.03	7.28	7.53	7.78	8.03	8.28	8.53	8.53
1213	1213-STR-0617	STRUCTURE PSSL/5+0	C55LIN004 - Lattice Steel - Suspension - C3	6.92	7.13	7.43	7.73	8.03	8.33	8.63	8.63
1213	1213-STR-0618	STRUCTURE PSSL/5+0	C55LIN004 - Lattice Steel - Suspension - C3	6.92	7.13	7.43	7.73	8.03	8.33	8.63	8.63
1213	1213-STR-0619	STRUCTURE PSSL/5-6	C55LIN004 - Lattice Steel - Suspension - C3	6.92	7.13	7.43	7.73	8.03	8.33	8.63	8.63
1213	1213-STR-0706	STRUCTURE PSSL/7+3	C55LIN004 - Lattice Steel - Suspension - C3	6.78	6.92	7.13	7.43	7.73	8.03	8.33	8.33
1213	1213-STR-0776	STRUCTURE PSSL/7+0	C55LIN004 - Lattice Steel - Suspension - C2	7.27	7.52	7.77	8.02	8.27	8.52	8.77	8.77
1213	1213-STR-0778	STRUCTURE PSSL/7+0	C55LIN004 - Lattice Steel - Suspension - C2	7.27	7.52	7.77	8.02	8.27	8.52	8.77	8.77
1213	1213-STR-0798	STRUCTURE PSSL/7+0	C55LIN004 - Lattice Steel - Suspension - C2	7.27	7.52	7.77	8.02	8.27	8.52	8.77	8.77
1213	1213-STR-0818	STRUCTURE PSSL/7-6	C55LIN004 - Lattice Steel - Suspension - C2	7.03	7.28	7.53	7.78	8.03	8.28	8.53	8.53
1213	1213-STR-0832	STRUCTURE PSSL/7+0	C55LIN004 - Lattice Steel - Suspension - C2	6.92	7.07	7.32	7.57	7.82	8.07	8.32	8.32
1213	1213-STR-0868	STRUCTURE PSSL/7+0	C55LIN004 - Lattice Steel - Suspension - C2	7.73	7.98	8.23	8.48	8.73	8.98	9.23	9.23
1218	1218-STR-1504	STRUCTURE DTH-3	C55LIN003 - Lattice Steel - Tension - C3	8.00	8.30	8.60	8.90	9.20	9.50	9.80	9.80
1218	1218-STR-1505	STRUCTURE DTH+0	C55LIN003 - Lattice Steel - Tension - C3	9.40	9.70	10.00	10.30	10.60	10.90	11.20	11.20
1224	1224-STR-1071	STRUCTURE LDAM/T+3	C55LIN003 - Lattice Steel - Tension - C3	8.30	8.60	8.90	9.20	9.50	9.80	10.10	10.10
1241	1241-STR-1701	STRUCTURE LDSL+3	C55LIN004 - Lattice Steel - Suspension - C4	7.38	7.75	8.13	8.50	8.88	9.25	9.63	9.63
1241	1241-STR-1702	STRUCTURE LDSL+9	C55LIN004 - Lattice Steel - Suspension - C4	9.00	9.38	9.75	10.13	10.50	10.88	11.25	11.25
1241	1241-STR-1703	STRUCTURE LDSL+9	C55LIN004 - Lattice Steel - Suspension - C4	9.38	9.75	10.13	10.50	10.88	11.25	11.63	11.63
1241	1241-STR-1704	STRUCTURE LDSM+6	C55LIN004 - Lattice Steel - Suspension - C4	7.08	7.45	7.83	8.20	8.58	8.95	9.33	9.33
1241	1241-STR-1705	STRUCTURE LDSM+6	C55LIN004 - Lattice Steel - Suspension - C4	7.10	7.48	7.85	8.23	8.60	8.98	9.35	9.35
1241	1241-STR-1706	STRUCTURE LDSL+0	C55LIN004 - Lattice Steel - Suspension - C4	7.68	8.05	8.43	8.80	9.18	9.55	9.93	9.93
1241	1241-STR-1707	STRUCTURE LDSL+0	C55LIN004 - Lattice Steel - Suspension - C4	7.08	7.45	7.83	8.20	8.58	8.95	9.33	9.33
1241	1241-STR-1708	STRUCTURE LDSL+3	C55LIN004 - Lattice Steel - Suspension - C4	7.30	7.68	8.05	8.43	8.80	9.18	9.55	9.55
1241	1241-STR-1710	STRUCTURE LDSL+6	C55LIN004 - Lattice Steel - Suspension - C4	7.48	7.85	8.23	8.60	8.98	9.35	9.73	9.73
1241	1241-STR-1713	STRUCTURE LDSL+3	C55LIN004 - Lattice Steel - Suspension - C4	8.08	8.45	8.83	9.20	9.58	9.95	10.33	10.33
1241	1241-STR-1715	STRUCTURE LDSL+9	C55LIN004 - Lattice Steel - Suspension - C4	6.58	6.75	6.93	7.21	7.59	7.96	8.34	8.34
1241	1241-STR-1716	STRUCTURE LDSM+9	C55LIN004 - Lattice Steel - Suspension - C4	9.55	9.93	10.30	10.68	11.05	11.43	11.80	11.80
1241	1241-STR-1717	STRUCTURE LDSL+0	C55LIN004 - Lattice Steel - Suspension - C4	8.45	8.83	9.20	9.58	9.95	10.33	10.70	10.70
1241	1241-STR-1718	STRUCTURE LDAM+3	C55LIN003 - Lattice Steel - Tension - C4	7.20	7.58	7.95	8.33	8.70	9.08	9.45	9.45
1241	1241-STR-1719	STRUCTURE LDSM+9	C55LIN004 - Lattice Steel - Suspension - C4	8.65	9.03	9.40	9.78	10.15	10.53	10.90	10.90
1241	1241-STR-1720	STRUCTURE LDSM+9	C55LIN004 - Lattice Steel - Suspension - C4	8.55	8.93	9.30	9.68	10.05	10.43	10.80	10.80
1241	1241-STR-1721	STRUCTURE LDSM+0	C55LIN004 - Lattice Steel - Suspension - C4	7.45	7.83	8.20	8.58	8.95	9.33	9.70	9.70
1241	1241-STR-1722	STRUCTURE LDSL+0	C55LIN004 - Lattice Steel - Suspension - C4	6.95	7.27	7.64	8.02	8.39	8.77	9.14	9.14
1241	1241-STR-1724	STRUCTURE LDSM+3	C55LIN004 - Lattice Steel - Suspension - C4	6.80	6.98	7.32	7.70	8.07	8.45	8.82	8.82
1241	1241-STR-1725	STRUCTURE LDSL+0	C55LIN004 - Lattice Steel - Suspension - C4	6.65	6.83	7.00	7.38	7.75	8.13	8.50	8.50
1241	1241-STR-1726	STRUCTURE LDAL/TR-6	C55LIN003 - Lattice Steel - Tension - C4	8.35	8.73	9.10	9.48	9.85	10.23	10.60	10.60
1241	1241-STR-1727	STRUCTURE LDSM+0	C55LIN004 - Lattice Steel - Suspension - C4	8.65	9.03	9.40	9.78	10.15	10.53	10.90	10.90
1241	1241-STR-1728	STRUCTURE LDSL+0	C55LIN004 - Lattice Steel - Suspension - C4	6.60	6.78	6.95	7.27	7.64	8.02	8.39	8.39
1241	1241-STR-1731	STRUCTURE LDSL+12	C55LIN004 - Lattice Steel - Suspension - C4	9.05	9.43	9.80	10.18	10.55	10.93	11.30	11.30
1241	1241-STR-1737	STRUCTURE LDSL+0	C55LIN004 - Lattice Steel - Suspension - C4	6.88	7.11	7.48	7.86	8.23	8.61	8.98	8.98
1241	1241-STR-1738	STRUCTURE LDSL+6	C55LIN004 - Lattice Steel - Suspension - C4	6.68	6.85	7.05	7.43	7.80	8.18	8.55	8.55
1241	1241-STR-1742	STRUCTURE LDAM/T+3	C55LIN003 - Lattice Steel - Tension - C4	6.88	7.11	7.48	7.86	8.23	8.61	8.98	8.98
1626	1626-STR-2700	STRUCTURE D1S0E+0	C55LIN004 - Lattice Steel - Suspension - C3								8.48
1626	1626-STR-2701	STRUCTURE D1S0E+3	C55LIN004 - Lattice Steel - Suspension - C3								8.98
1626	1626-STR-2702	STRUCTURE D1S0E+0	C55LIN004 - Lattice Steel - Suspension - C3								9.48
1626	1626-STR-2703	STRUCTURE D1T70E+0	C55LIN003 - Lattice Steel - Tension - C3	8.18	8.48	8.78	9.08	9.38	9.68	9.98	9.98
1626	1626-STR-2704	STRUCTURE D1S0E+6	C55LIN004 - Lattice Steel - Suspension - C3								8.94
1626	1626-STR-2715	STRUCTURE D1T40E+6	C55LIN003 - Lattice Steel - Tension - C4								8.36
1626	1626-STR-2716	STRUCTURE D1T40E+6	C55LIN003 - Lattice Steel - Tension - C4								8.87
1626	1626-STR-2717	STRUCTURE D1S0E+12	C55LIN004 - Lattice Steel - Suspension - C4								9.38
1626	1626-STR-2718	STRUCTURE D1T40E+12	C55LIN003 - Lattice Steel - Tension - C4								9.89
1626	1626-STR-2719	STRUCTURE D1T70E-9	C55LIN003 - Lattice Steel - Tension - C4	8.15	8.53	8.90	9.28	9.65	10.03	10.40	10.40
1626	1626-STR-2720	STRUCTURE D1S0E+0	C55LIN004 - Lattice Steel - Suspension - C4								10.15
1626	1626-STR-2721	STRUCTURE D1S0E-6	C55LIN004 - Lattice Steel - Suspension - C4								9.91
1626	1626-STR-2722	STRUCTURE D1S0E+3	C55LIN004 - Lattice Steel - Suspension - C4								9.66
1626	1626-STR-2723	STRUCTURE D1S0E+3	C55LIN004 - Lattice Steel - Suspension - C4								9.42
1626	1626-STR-2724	STRUCTURE D1S0E+3	C55LIN004 - Lattice Steel - Suspension - C4								9.17
1626	1626-STR-2725	STRUCTURE D1S0E+12	C55LIN004 - Lattice Steel - Suspension - C4								8.93
1626	1626-STR-2726	STRUCTURE D1S0E+12	C55LIN004 - Lattice Steel - Suspension - C4								8.68
1626	1626-STR-2727	STRUCTURE D1S0E-6	C55LIN004 - Lattice Steel - Suspension - C4								8.44
1626	1626-STR-2728	STRUCTURE D1S0E-9	C55LIN004 - Lattice Steel - Suspension - C4								8.19
1626	1626-STR-2774	STRUCTURE D1T70E+0	C55LIN003 - Lattice Steel - Tension - C4	6.55	6.73	6.90	7.16	7.54	7.91	8.29	8.29
1626	1626-STR-2775	STRUCTURE D1T70E-6 text	C55LIN003 - Lattice Steel - Tension - C4	7.75	8.13	8.50	8.88	9.25	9.63	10.00	10.00
1626	1626-STR-2776	STRUCTURE D1T70E-6	C55LIN003 - Lattice Steel - Tension - C4								10.00

Southern Region

BS	Asset functional location	EQUIP	Risk_Model_Name	2026 Health Index	2027 Health Index	2028 Health Index	2029 Health Index	2030 Health Index	2031 Health Index	2032 Health Index	2032 Health Index
1003	1003-STR-1303	STRUCTURE AH+20	C55LIN004 - Lattice Steel - Suspension - C2								8.20
1003	1003-STR-1304	STRUCTURE AH+30	C55LIN004 - Lattice Steel - Suspension - C2	7.95	8.20	8.45	8.70	8.95	9.20	9.45	9.45
1003	1003-STR-1324	STRUCTURE D+20	C55LIN003 - Lattice Steel - Tension - C2	8.65	8.90	9.15	9.40	9.65	9.90	10.15	10.15
1003	1003-STR-1325	STRUCTURE D-0	C55LIN003 - Lattice Steel - Tension - C2								8.07
1008	1008-STR-8101	STRUCTURE D1S2-3	C55LIN004 - Lattice Steel - Suspension - C3	9.14	9.44	9.74	10.04	10.34	10.64	10.94	10.94
1008	1008-STR-8102	STRUCTURE D1S2+0	C55LIN004 - Lattice Steel - Suspension - C3	9.14	9.44	9.74	10.04	10.34	10.64	10.94	10.94
1008	1008-STR-8105	STRUCTURE D1T40+9	C55LIN003 - Lattice Steel - Tension - C3	9.70	10.00	10.30	10.60	10.90	11.20	11.50	11.50
1008	1008-STR-8108	STRUCTURE D1T70+0	C55LIN003 - Lattice Steel - Tension - C3	9.70	10.00	10.30	10.60	10.90	11.20	11.50	11.50
1015	1015-STR-2238	STRUCTURE D2T80-30	C55LIN003 - Lattice Steel - Tension - C2	8.27	8.52	8.77	9.02	9.27	9.52	9.77	9.77
1015	1015-STR-2239	STRUCTURE D2T80+20	C55LIN003 - Lattice Steel - Tension - C2	8.50	8.75	9.00	9.25	9.50	9.75	10.00	10.00
1015	1015-STR-2241	STRUCTURE D2T15-10	C55LIN003 - Lattice Steel - Tension - C2	8.27	8.52	8.77	9.02	9.27	9.52	9.77	9.77
1015	1015-STR-2241	STRUCTURE D2S2-0	C55LIN004 - Lattice Steel - Suspension - C2	7.00	7.25	7.50	7.75	8.00	8.25	8.50	8.50
1021	1021-STR-5000	STRUCTURE S2T70+50	C55LIN003 - Lattice Steel - Tension - C3	8.60	8.90	9.20	9.50	9.80	10.10	10.40	10.40
1021	1021-STR-5001	STRUCTURE S2T70+60	C55LIN003 - Lattice Steel - Tension - C3	6.84	6.98	7.26	7.56	7.86	8.16	8.46	8.46
1021	1021-STR-5002	STRUCTURE S2T40+21	C55LIN003 - Lattice Steel - Tension - C3	9.70	10.00	10.30	10.60	10.90	11.20	11.50	11.50
1021	1021-STR-5005	STRUCTURE S2T40+12	C55LIN003 - Lattice Steel - Tension - C2	6.82	6.93	7.11	7.36	7.61	7.86	8.11	8.11
1021	1021-STR-5036	STRUCTURE S2S2-6 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	7.95	8.20	8.45	8.70	8.95	9.20	9.45	9.45
1021	1021-STR-5037	STRUCTURE S2S2-3 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	9.05	9.30	9.55	9.80	10.05	10.30	10.55	10.55
1021	1021-STR-5038	STRUCTURE S2T40-3	C55LIN003 - Lattice Steel - Tension - C2	7.85	8.10	8.35	8.60	8.85	9.10	9.35	9.35
1021	1021-STR-5043	STRUCTURE S2T5-3	C55LIN003 - Lattice Steel - Tension - C2	7.85	8.10	8.35	8.60	8.85	9.10	9.35	9.35
1021	1021-STR-5049	STRUCTURE S2S2-12 *Maint W	C55LIN004 - Lattice Steel - Suspension - C3	6.84	6.98	7.26	7.56	7.86	8.16	8.46	8.46
1021	1021-STR-5050	STRUCTURE S2S2-4 *Maint W	C55LIN004 - Lattice Steel - Suspension - C3	7.00	7.30	7.60	7.90	8.20	8.50	8.80	8.80
1021	1021-STR-5080	STRUCTURE S2S2-12 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	7.60	7.85	8.10	8.35	8.60	8.85	9.10	9.10
1021	1021-STR-5091	STRUCTURE S2S2-12 *Maint W	C55LIN004 - Lattice Steel - Suspension - C3								8.27
1021	1021-STR-5092	STRUCTURE S2S2-4 *Maint W	C55LIN004 - Lattice Steel - Suspension - C3	7.60	7.90	8.20	8.50	8.80	9.10	9.40	9.40
1021	1021-STR-5093	STRUCTURE S2S2-9 *Maint W	C55LIN004 - Lattice Steel - Suspension - C3								8.04
1021	1021-STR-5107	STRUCTURE S2S2-3 *Maint W	C55LIN004 - Lattice Steel - Suspension - C3	7.40	7.70	8.00	8.30	8.60	8.90	9.20	9.20
1021	1021-STR-5110	STRUCTURE S2S2-12 *Maint W	C55LIN004 - Lattice Steel - Suspension - C3	8.00	8.30	8.60	8.90	9.20	9.50	9.80	9.80
1021	1021-STR-5144	STRUCTURE S2T40-3	C55LIN003 - Lattice Steel - Tension - C3	8.70	9.00	9.30	9.60	9.90	10.20	10.50	10.50
1021	1021-STR-5145	STRUCTURE S2S0+3 *Maint W	C55LIN004 - Lattice Steel - Suspension - C3	7.90	8.20	8.50	8.80	9.10	9.40	9.70	9.70
1021	1021-STR-5146	STRUCTURE S2T40-3	C55LIN003 - Lattice Steel - Tension - C3	9.20	9.50	9.80	10.10	10.40	10.70	11.00	11.00
1021	1021-STR-5149	STRUCTURE S2T40+3	C55LIN003 - Lattice Steel - Tension - C3	8.10	8.40	8.70	9.00	9.30	9.60	9.90	9.90
1021	1021-STR-5150	STRUCTURE S2S2-9 *Maint W	C55LIN004 - Lattice Steel - Suspension - C3	8.00	8.30	8.60	8.90	9.20	9.50	9.80	9.80
1025	1025-STR-5372	STRUCTURE S2S2-3 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	7.22	7.47	7.72	7.97	8.22	8.47	8.72	8.72
1025	1025-STR-5392	STRUCTURE S2S2-0 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	6.98	7.21	7.46	7.71	7.96	8.21	8.46	8.46
1025	1025-STR-5393	STRUCTURE S2S2+15 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	7.95	8.20	8.45	8.70	8.95	9.20	9.45	9.45
1025	1025-STR-5434	STRUCTURE S2S2-6 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	7.85	8.10	8.35	8.60	8.85	9.10	9.35	9.35
1025	1025-STR-5474	STRUCTURE S2S2-6 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	7.95	8.20	8.45	8.70	8.95	9.20	9.45	9.45
1025	1025-STR-5478	STRUCTURE S2S2-4 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	6.80	6.92	7.07	7.32	7.57	7.82	8.07	8.07
1025	1025-STR-5490	STRUCTURE S2S2-0 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	7.25	7.50	7.75	8.00	8.25	8.50	8.75	8.75
1025	1025-STR-5514	STRUCTURE S2S2-0 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	8.05	8.30	8.55	8.80	9.05	9.30	9.55	9.55
1025	1025-STR-5533	STRUCTURE S2S2-3 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	7.10	7.35	7.60	7.85	8.10	8.35	8.60	8.60
1025	1025-STR-5539	STRUCTURE S2S0-3 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2								8.14
1025	1025-STR-5552	STRUCTURE S2S0-3 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	8.02	8.27	8.52	8.77	9.02	9.27	9.52	9.52
1025	1025-STR-5558	STRUCTURE S2S2-3 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2	7.20	7.45	7.70	7.95	8.20	8.45	8.70	8.70
1025	1025-STR-5584	STRUCTURE S2S2-3 *Maint W	C55LIN004 - Lattice Steel - Suspension - C2								8.24
1025	1025-STR-5585	STRUCTURE S2T5+6	C55LIN003 - Lattice Steel - Tension - C2	7.02	7.27	7.52	7.77	8.02	8.27	8.52	8.52
1038	1038-STR-0021	STRUCTURE D+20	C55LIN003 - Lattice Steel - Tension - C2	8.03	8.28	8.53	8.78	9.03	9.28	9.53	9.53
1038	1038-STR-0022	STRUCTURE A+10	C55LIN004 - Lattice Steel - Suspension - C2	8.03	8.28	8.53	8.78	9.03	9.28	9.53	9.53
1038	1038-STR-0023	STRUCTURE A-0	C55LIN004 - Lattice Steel - Suspension - C2	8.70	8.95	9.20	9.45	9.70	9.95	10.20	10.20
1038	1038-STR-0026	STRUCTURE D-10	C55LIN003 - Lattice Steel - Tension - C2	7.23	7.48	7.73	7.98	8.23	8.48	8.73	8.73
1038	1038-STR-0035	STRUCTURE D+10	C55LIN003 - Lattice Steel - Tension - C2	7.73	7.98	8.23	8.48	8.73	8.98	9.23	9.23
1046	1046-STR-2025	STRUCTURE DD2+30	C55LIN003 - Lattice Steel - Tension - C2	7.77	8.02	8.27	8.52	8.77	9.02	9.27	9.27
1046	1046-STR-2027	STRUCTURE DD2-0	C55LIN003 - Lattice Steel - Tension - C2	7.30	7.55	7.80	8.05	8.30	8.55	8.80	8.80
1046	1046-STR-2028	STRUCTURE DC2+10	C55LIN003 - Lattice Steel - Tension - C2	7.77	8.02	8.27	8.52	8.77	9.02	9.27	9.27
1046	1046-STR-2028	STRUCTURE DB2+40	C55LIN004 - Lattice Steel - Suspension - C2	7.30	7.55	7.80	8.05	8.30	8.55	8.80	8.80
1046	1046-STR-2031	STRUCTURE DA2+20	C55LIN004 - Lattice Steel - Suspension - C2	7.77	8.02	8.27	8.52	8.77	9.02	9.27	9.27
1046	1046-STR-2032	STRUCTURE DD2-30	C55LIN003 - Lattice Steel - Tension - C2	7.30	7.55	7.80	8.05	8.30	8.55	8.80	8.80
1046	1046-STR-2033	STRUCTURE DA2-0	C55LIN004 - Lattice Steel - Suspension - C2	6.87	6.98	7.21	7.46	7.71	7.96	8.21	8.21
1046	1046-STR-2034	STRUCTURE DC2-30	C55LIN003 - Lattice Steel - Tension - C2	6.77	6.88	7.00	7.25	7.50	7.75	8.00	8.00
1046	1046-STR-2035	STRUCTURE DB2-0	C55LIN004 - Lattice Steel - Suspension - C2	6.87	6.98	7.21	7.46	7.71	7.96	8.21	8.21
1046	1046-STR-2036	STRUCTURE DC2-30	C55LIN003 - Lattice Steel - Tension - C2	7.30	7.55	7.80	8.05	8.30	8.55	8.80	8.80
1048	1048-STR-5182	STRUCTURE S2S2-3 *Maint W	C55LIN004 - Lattice Steel - Suspension - C3	8.30	8.60	8.90	9.20	9.50	9.80	10.10	10.10
1048	1048-STR-5190	STRUCTURE S2S2-12 *Maint W	C55LIN004 - Lattice Steel - Suspension - C4	6.65	6.83	7.00	7.38	7.75	8.13	8.50	8.50
1048	1048-STR-5232	STRUCTURE S2S2-12 *Maint W	C55LIN004 - Lattice Steel - Suspension - C3	8.20	8.50	8.80	9.10	9.40	9.70	10.00	10.00
1048	1048-STR-5250	STRUCTURE S2S2-0 *Maint W	C55LIN004 - Lattice Steel - Suspension - C4	6.65	6.83	7.00	7.38	7.75	8.13	8.50	8.50
1048	1048-STR-5354	STRUCTURE S2T5+6	C55LIN003 - Lattice Steel - Tension - C3	8.18	8.48	8.78	9.08	9.38	9.68	9.98	9.98

BS	Asset functional location	EQUIP	Risk_Model_Name	Health Index							
				2026	2027	2028	2029	2030	2031	2032	2033
1018	1018-STR-3107	STRUCTURE S2S2-10 *Maint	W C55LIN004 - Lattice Steel - Suspension - C3								8.75
1018	1018-STR-3108	STRUCTURE S2T40-20	C55LIN003 - Lattice Steel - Tension - C3	8.60	8.90	9.20	9.50	9.80	10.10	10.40	10.40
1018	1018-STR-3112	STRUCTURE S2T5-10	C55LIN003 - Lattice Steel - Tension - C3	7.20	7.50	7.80	8.10	8.40	8.70	9.00	9.00
1018	1018-STR-3118	STRUCTURE S2S2+30 *Maint	C55LIN004 - Lattice Steel - Suspension - C3	6.86	7.00	7.30	7.60	7.90	8.20	8.50	8.50
1018	1018-STR-3124	STRUCTURE S2T5E+3	C55LIN003 - Lattice Steel - Tension - C3	8.20	8.50	8.80	9.10	9.40	9.70	10.00	10.00
1018	1018-STR-3148	STRUCTURE S2T5E-7	C55LIN003 - Lattice Steel - Tension - C3	7.90	8.20	8.50	8.80	9.10	9.40	9.70	9.70
1018	1018-STR-3149	STRUCTURE S2T40-20	C55LIN003 - Lattice Steel - Tension - C3								9.25
1018	1018-STR-3150	STRUCTURE S2S2+40 *Maint	C55LIN004 - Lattice Steel - Suspension - C3								8.81
1018	1018-STR-3151	STRUCTURE S2S2+10 *Maint	C55LIN004 - Lattice Steel - Suspension - C3								8.36
1018	1018-STR-3169	STRUCTURE S2S2+40 *Maint	C55LIN004 - Lattice Steel - Suspension - C3	6.64	6.78	6.92	7.13	7.43	7.73	8.03	8.03
1018	1018-STR-3170	STRUCTURE S2S2+40 *Maint	C55LIN004 - Lattice Steel - Suspension - C3								9.02
1018	1018-STR-3171	STRUCTURE S2S2+30 *Maint	C55LIN004 - Lattice Steel - Suspension - C3								10.01
1018	1018-STR-3172	STRUCTURE S2T40-0	C55LIN003 - Lattice Steel - Tension - C3	9.20	9.50	9.80	10.10	10.40	10.70	11.00	11.00
1018	1018-STR-3173	STRUCTURE S2S2+30 *Maint	C55LIN004 - Lattice Steel - Suspension - C3								9.91
1018	1018-STR-3174	STRUCTURE S2T5E-17	C55LIN003 - Lattice Steel - Tension - C3	7.02	7.32	7.62	7.92	8.22	8.52	8.82	8.82
1018	1018-STR-3180	STRUCTURE S2S2+20 *Maint	C55LIN004 - Lattice Steel - Suspension - C3	6.64	6.78	6.92	7.13	7.43	7.73	8.03	8.03
1018	1018-STR-3192	STRUCTURE S2T5-10	C55LIN003 - Lattice Steel - Tension - C3	6.64	6.78	6.92	7.13	7.43	7.73	8.03	8.03
1019	1019-STR-3308	STRUCTURE S2T55-20	C55LIN003 - Lattice Steel - Tension - C3	7.40	7.70	8.00	8.30	8.60	8.90	9.20	9.20
1019	1019-STR-3309	STRUCTURE S2T15-0	C55LIN003 - Lattice Steel - Tension - C3								8.70
1019	1019-STR-3310	STRUCTURE S2S2+20 *Maint	C55LIN004 - Lattice Steel - Suspension - C3								8.21
1019	1019-STR-3345	STRUCTURE S2T15+10	C55LIN003 - Lattice Steel - Tension - C3	7.54	7.84	8.14	8.44	8.74	9.04	9.34	9.34
1019	1019-STR-3346	STRUCTURE S2T15+10	C55LIN003 - Lattice Steel - Tension - C3								9.29
1019	1019-STR-3347	STRUCTURE S2S2-10 *Maint	C55LIN004 - Lattice Steel - Suspension - C3								9.25
1019	1019-STR-3348	STRUCTURE S2T15-0	C55LIN003 - Lattice Steel - Tension - C3	7.40	7.70	8.00	8.30	8.60	8.90	9.20	9.20
1019	1019-STR-3349	STRUCTURE S2T15-10	C55LIN003 - Lattice Steel - Tension - C3								9.03
1019	1019-STR-3350	STRUCTURE S2S2+20 *Maint	C55LIN004 - Lattice Steel - Suspension - C3								8.86
1019	1019-STR-3351	STRUCTURE S2S2+10 *Maint	C55LIN004 - Lattice Steel - Suspension - C3								8.69
1019	1019-STR-3352	STRUCTURE S2T55+30	C55LIN003 - Lattice Steel - Tension - C3								8.53
1019	1019-STR-3353	STRUCTURE S2T15+40	C55LIN003 - Lattice Steel - Tension - C3								8.36
1019	1019-STR-3354	STRUCTURE S2T2-10 *Maint	C55LIN004 - Lattice Steel - Suspension - C3								8.19
1019	1019-STR-3355	STRUCTURE S2T15-20	C55LIN003 - Lattice Steel - Tension - C3								8.02
1019	1019-STR-3371	STRUCTURE S2S2+50 *Maint	C55LIN004 - Lattice Steel - Suspension - C3	6.88	7.04	7.34	7.64	7.94	8.24	8.54	8.54
1019	1019-STR-3373	STRUCTURE S2S2+20 *Maint	C55LIN004 - Lattice Steel - Suspension - C3	6.88	7.04	7.34	7.64	7.94	8.24	8.54	8.54
1019	1019-STR-3401	STRUCTURE S2T90-0	C55LIN003 - Lattice Steel - Tension - C3	7.66	7.96	8.26	8.56	8.86	9.16	9.46	9.46