

## **1 Energy Forecasting Methodology Overview**

### **1.1 Summary**

In summary, energy forecasts are prepared at the tariff level by analysing metered consumption data and customer numbers and seeking to understand the trends which are influencing these two key components of the forecasts. AusNet Services compiles the relevant information into an energy forecasting model which produces outputs of energy (and demand where applicable) for every billable tariff category.

This section sets out an overview of the energy forecasting methodology. The fundamental steps in the current forecasting process are:

- Extract historical customer numbers by tariff;
- Apportion forecast customer growth to individual tariff codes;
- Correlate historical energy consumption with weather conditions;
- Estimate the impact on energy consumption of:
  - solar PV;
  - retail electricity price changes;
  - energy efficiency
  - other likely drivers of energy consumption, e.g. electric vehicles, batteries.
- Enter any step changes (up or down) in expected load from large customers
- Validate energy forecasts by undertaking a top-down analysis of energy at the tariff level and comparing it to the forecasts derived from the bottom-up process
- Where needed, apply post-model adjustments to reflect any differences between top-down and bottom-up results.

#### **1.1.1 Extract historical customer numbers by tariff**

The number of customers assigned to each of AusNet Services' electricity distribution tariffs are extracted from the monthly revenue accruals model, which in turn is based on billing data. This allows the energy forecasting model to be calibrated to the current number of customers per tariff.

#### **1.1.2 Apportion forecast customer growth to individual tariff codes**

AusNet Services prepares customer growth forecasts as a key input to its annual maximum demand forecasts.

Those customer forecasts are compiled by having reference to both the historical trend in customer growth and the Victorian government's projections of structured private dwellings (SPD) in the Victoria in Future (VIF) planning publication.<sup>1</sup> Where there is evidence that the VIF forecast growth rates are not reflective of actual growth, more weight may be given to historical trends.

Based on the observed trends in customer growth rates within certain tariffs, the customer growth forecasts from the above process are then allocated to individual tariffs. For example, tariffs which are closed to new entrants receive a zero allocation, the demand forecast's growth in solar connections are allocated to solar tariffs, and so on.

#### **1.1.3 Correlate historical energy data with weather conditions**

Monthly billing data is extracted for each of the timeblocks (e.g. peak, off-peak, shoulder, etc.) for every tariff.

---

<sup>1</sup> <https://www.planning.vic.gov.au/land-use-and-population-research/victoria-in-future> (accessed 9 Sep 2019)

---

## Energy Forecasting Methodology – Electricity Distribution Network

---

Temperature, wind and sunlight hours data is extracted from OSIpI and historic BOM data. This data is used to calculate Cooling Degree Days (CDDs) and Effective Degree Days (EDDs).

Energy consumption within the timeblocks is then correlated with CDDs and EDDs via multivariate regression analysis in order to understand the relationship between weather and energy usage at the tariff and time block level.

### 1.1.4 Estimate the impact on energy consumption of various drivers

The preceding step provides a baseline consumption per customer which can be multiplied by the number of customers over the forecast period to produce a base energy consumption forecast. However, it does not at this stage take into account future changes in consumption caused by drivers that are not in, or will be different to, the baseline.

There are multiple drivers of future energy consumption, including:

- solar PV;
- retail electricity price changes;
- changes in energy efficiency;
- electric vehicles;
- batteries.

Some of these drivers are longer term (electric vehicles, batteries) and some are shorter term (solar, energy efficiency, price). For annual pricing submissions, which only require a one-year ahead forecast, the impact of longer term technologies such as electric vehicles and (to a lesser extent) batteries, is not especially relevant.

### 1.1.5 Estimate the impact on energy consumption from COVID-19 impacts

For the updated 2020 and 2021 forecasts, it was necessary to adjust expected energy consumption to take account of the likely impacts of COVID-19.

AusNet Services has been tracking year-on-year changes in electricity consumption to estimate the impact of COVID-19 since March 2020. Given the current level of restrictions and taking weather into account, it is estimated that residential consumption is approximately 8% higher than average and commercial/industrial consumption is approximately 15% lower than average.

These increments and decrements have been applied to each tariff starting from the first month of the forecast (September 2020).

Given Victoria's current roadmap out of COVID-19 restrictions, it is assumed that by January 2021, 40% the current residential impact will be negated due to customers returning to work (or being on annual leave as they normally would be). This residential uplift is steadily reduced as more people return to work and from May 2021, the residential impact of COVID-19 is nil.

Given the impact that COVID-19 has had on businesses, it is assumed that only 20% of the estimated 15% downward impact is recovered by January 2021. The remainder of the COVID-19 impact is steadily unwound until June 2021, when demand is assumed to return to 'normal' levels.

It is important to note that the above increments and decrements relate to energy per customer. The impact of COVID-19 is also realised through a large reduction in the number of connections in FY21.

### 1.1.6 Enter any step changes in large customers

To the extent that AusNet Services has been made aware of any planned changes in consumption for large (>160 MWh per annum) customers, these will be reflected in the modelling. This information can be sourced directly from the customers (for example, via meetings), or publicly announced closures/expansions.

### 1.1.7 Validate energy forecasts

The above steps result in a bottom-up energy forecast for all tariffs (and timeblocks) for which AusNet Services has active customers. To ensure that these forecasts have not resulted in an over-statement or under-statement

## Energy Forecasting Methodology – Electricity Distribution Network

---

of energy consumed for each tariff, the results are compared to actual monthly energy delivered for a period of at least the previous 12 months.

To the extent that there are differences between the forecast energy and actual energy delivered, the model inputs and assumptions are reviewed to understand why these differences may exist. Post-model adjustments may be included in instances where the bottom-up drivers are not adequately capturing expected demand.