



AusNet Transmission Group Pty Ltd

Transmission Revenue Review 2017-2022

**Appendix 4B: 2014 DNSP Vic
Terminal Station Demand Forecasts
for 2014-15 to 2024-25 Report**

Submitted: 30 October 2015



30 September 2014

Level 22
530 Collins Street
Melbourne VIC 3000

Postal Address:
GPO Box 2008
Melbourne VIC 3001

T 1300 858724
F 03 9609 8010

DNSP – Victorian Terminal Station Demand Forecasts for 2014-15 to 2024-25

This report provides demand forecasts for points of connection within the Victorian transmission network, as required by the National Electricity Rules, clause 5.11.1(a).

The demand forecasts are not developed by AEMO; they are compiled by AEMO from forecasts provided by Victorian participants (distribution network service providers (DNSPs) and direct-connect customers), and reflect participant expectations of future demand.

Yours sincerely,

A handwritten signature in black ink, appearing to read "Joe Spurio".

Joe Spurio
Group Manager, Forecasting

Attachment: DNSP – Victorian Terminal Station Demand Forecasts for 2014-15 to 2024-25



DNSP – VICTORIAN TERMINAL STATION DEMAND FORECASTS

FOR 2014–15 TO 2024–25

FORECASTS PREPARED BY VICTORIAN DISTRIBUTION
NETWORK SERVICE PROVIDERS AND COLLATED BY AEMO

Published: September 2014





IMPORTANT NOTICE

Purpose

AEMO has prepared this document to provide information about transmission connection point forecasts for Victoria.

The demand forecasts are compiled by AEMO from forecasts provided by Victorian participants (distribution network service providers (DNSPs) and direct-connect customers), and reflect participant expectations of future demand. These forecasts are not developed by AEMO.

Disclaimer

AEMO has made every effort to ensure the quality of the information in this publication but cannot guarantee that information, forecasts and assumptions are accurate, complete or appropriate for your circumstances. This publication does not include all of the information that an investor, participant or potential participant in the national electricity market might require, and does not amount to a recommendation of any investment.

Anyone proposing to use the information in this publication (including information and reports from third parties) should independently verify and check its accuracy, completeness and suitability for purpose, and obtain independent and specific advice from appropriate experts.

Accordingly, to the maximum extent permitted by law, AEMO and its officers, employees and consultants involved in the preparation of this publication:

- make no representation or warranty, express or implied, as to the currency, accuracy, reliability or completeness of the information in this publication; and
- are not liable (whether by reason of negligence or otherwise) for any statements, opinions, information or other matters contained in or derived from this publication, or any omissions from it, or in respect of a person's use of the information in this publication.



CONTENTS

1. INTRODUCTION	3
2. DEMAND FORECASTS BY CONNECTION POINT	5
3. METHODOLOGY	69
3.1 Date ranges and times	69
3.2 Embedded generation	69
3.3 Capacitance and reactance	71
3.4 Demand diversity	71
4. VICTORIAN MAXIMUM DEMAND FORECASTS	72
4.1 NEFR forecast	72
4.2 TSDF system forecast	72
4.3 Summer MD	72
4.4 Winter MD	73
4.5 Difference between the NEFR and TSDF forecasts	74
4.6 Reactive demand forecasts	74
5. ACTUAL DEMAND AND PREVIOUS FORECAST COMPARISONS	76
5.1 Summer MD	76
5.2 Winter MD	76
5.3 Chart notes	76
MEASURES AND ABBREVIATIONS	79
Units of measure	79
Abbreviations	79

TABLES

Table 1 Connection point and bus locations	5
Table 2 Terminal station and bus locations	69

FIGURES

Figure 1 TSDF and NEFR summer MD forecasts	73
Figure 2 TSDF and NEFR winter MD forecasts	74
Figure 3 Summer MD reactive demand forecast	75
Figure 4 Winter MD reactive demand forecast	75
Figure 5 Summer MD actual and forecast comparison by location	76
Figure 6 Summer MD actual and forecast reactive demand comparison by location	77
Figure 7 Winter MD actual and forecast comparison by location	77
Figure 8 Winter MD actual and forecast reactive demand comparison by location	78



1. INTRODUCTION

This report provides demand forecasts for points of connection within the Victorian transmission network, as required by the National Electricity Rules, clause 5.11.1(a).

The demand forecasts are not developed by AEMO; they are compiled by AEMO from forecasts provided by Victorian participants (distribution network service providers (DNSPs) and direct-connect customers), and reflect participant expectations of future demand.

For each connection point, this report provides the following:

- Maximum active power demands forecast to occur for summer and winter on average one-year-in-two (50% probability of exceedance (POE)) and one-year-in-ten (10% POE), for each financial year from 2014–15 to 2024–25.
- Reactive power demands forecast to occur at the same time as a terminal station's maximum active power demands (for both 50% and 10% POE).
- Representative daily active and reactive demand profiles for days of maximum active power demand.
- Maximum active and coincident reactive actual demands for the summer and winter periods of the preceding year (2013–14 and 2014 respectively).

Participants supplied AEMO with forecast maximum levels of active demand and the associated reactive demand levels expected at the 10% and 50% POE levels. These are separated according to their connection point at each terminal station. They have been provided for summer and winter over an 11 year period. AEMO has aggregated these forecasts by terminal station.

Alongside this Victorian Terminal Station Demand Forecasts (TSDF) report, AEMO has also separately published its first electricity transmission connection point forecasts for Victoria.¹ AEMO developed this report at the request of the Council of Australian Governments (COAG) as part of its energy market reform implementation plan. The forecasts contained in this report were developed using the methodology published on the AEMO website in June 2013² and which will be applied consistently across all National Electricity Market (NEM) regions for all future electricity transmission connection point forecasts. These forecasts have been calculated at the transmission node identifier (TNI) level.

¹ AEMO *Transmission connection point forecasting report for Victoria*
Available at: <http://www.aemo.com.au/Electricity/Planning/Forecasting>.

² AEMO. *Connection Point Forecasting: A Nationally Consistent Methodology for Forecasting Maximum Demand – Report*.
Available at: <http://www.aemo.com.au/Electricity/Planning/Forecasting/Connection-Point-Forecasting>. Viewed 16/09/2014.



2. DEMAND FORECASTS BY CONNECTION POINT

This section provides a summary of the total forecast demand for each connection point.

In most cases, the connection points in this report correspond directly to physical terminal stations. In some cases, a connection point may cover only a portion of a terminal station (for example a bus group including a subset of the transformers at the terminal station), or portions of multiple terminal stations. In other cases, some points of connection relate to direct-connect customers rather than terminal stations.

Connection points are not mutually exclusive and the same demand may be reported under more than one connection point. For example, connection points which are split into bus groups are also forecast as an entire station; a forecast is provided for KTS, but also for KTS East and KTS West. This is done to accommodate a range of requirements.

Due to demand diversity, the summated split bus group forecasts may exceed the forecast for the whole terminal station. Where a connection point supplies electricity at different voltage levels, these are treated as separate connection points and reported separately.

Table 1 lists the connection points included in this report. Locations are listed alphabetically based on abbreviation, which generally includes an abbreviation of the terminal station name along with the voltage level.

Table 1 Connection point and bus locations

Abbreviation	Type	Description
APD500	Entire	Portland 500 kV bus
ATS_BLTS66	Hybrid	Altona/Brooklyn Terminal Station 66 kV bus
ATS_West66	Hybrid	Altona West Terminal Station 66 kV bus
BATS66	Entire	Ballarat Terminal Station 66 kV bus
BETS22	Entire	Bendigo Terminal Station 22 kV bus
BETS66	Entire	Bendigo Terminal Station 66 kV bus
BLTS22	Entire	Brooklyn Terminal Station 22 kV bus
BLTS-SCI66	Hybrid	Brooklyn-SCI 66 kV bus
BTS22	Entire	Brunswick Terminal Station 22 kV bus
BTS66	Entire	Brunswick Terminal Station 66 kV bus
CBTS66	Entire	Cranbourne Terminal Station 66 kV bus
DPTS	Entire	Deer Park Terminal Station 66 kV bus
ERTS1266	Split bus	East Rowville Terminal Station buses 1&2 66 kV bus
ERTS3466	Split bus	East Rowville Terminal Station buses 3&4 66 kV bus
ERTS66	Entire	East Rowville Terminal Station 66 kV bus
FBTS66	Entire	Fishermans Bend Terminal Station 66 kV bus
FVTS220	Entire	Fosterville Terminal Station 220 kV bus
GNTS66	Entire	Glenrowan Terminal Station 66 kV bus
GTS66	Entire	Geelong Terminal Station 66 kV bus
HOTS66	Entire	Horsham Terminal Station 66 kV bus
HTS66	Entire	Heatherton Terminal Station 66 kV bus
HYTS22	Entire	Heywood Terminal Station 22 kV bus
JLA220	Entire	John Lysaght 220 kV bus
KGTS22	Entire	Kerang Terminal Station 22 kV bus
KGTS66	Entire	Kerang Terminal Station 66 kV bus
KTS_East66	Split bus	Eastern area served by Keilor Terminal Station 66 kV bus
KTS_West66	Split bus	Western area served by Keilor Terminal Station 66 kV bus
KTS66	Entire	Keilor Terminal Station 66 kV bus
LY66	Entire	Loy Yang Substation 66 kV bus



Abbreviation	Type	Description
MBTS66	Entire	Mount Beauty Terminal Station 66 kV bus
MTS22	Entire	Malvern Terminal Station 22 kV bus
MTS66	Entire	Malvern Terminal Station 66 kV bus
MTS6622	Entire	Malvern Terminal Station – 66 kV and 22 kV loads combined.
MWTS66	Entire	Morwell Terminal Station 66 kV bus
PTH220	Entire	Point Henry 220 kV bus
RCTS22	Entire	Red Cliffs Terminal Station 22 kV bus
RCTS66	Entire	Red Cliffs Terminal Station 66 kV bus
RTS22	Entire	Richmond Terminal Station 22 kV bus
RTS1266	Split bus	Richmond Terminal Station buses 1&2 66 kV bus (Transformers B1 and B4)
RTS3466	Split bus	Richmond Terminal Station buses 3&4 66 kV bus (Transformers B2 and B3)
RTS66	Entire	Richmond Terminal Station 66 kV bus
RWTS22	Entire	Ringwood Terminal Station 22 kV bus
RWTS1366	Split bus	Ringwood Terminal Station 1&3 66 kV bus
RWTS2466	Split bus	Ringwood Terminal Station 2&4 66 kV bus
RWTS66	Entire	Ringwood Terminal Station 66 kV bus
SHTS66	Entire	Shepparton Terminal Station 66 kV bus
SMTS66	Entire	South Morang Terminal Station 66kV bus
SVTS1266	Split bus	Springvale Terminal Station buses 1&2 66kV bus
SVTS3466	Split bus	Springvale Terminal Station buses 3&4 66kV bus
SVTS66	Entire	Springvale Terminal Station 66kV bus
TBTS66	Entire	Tyabb Terminal Station 66kV bus
TGTS66	Entire	Terang Terminal Station 66kV bus
TSTS66	Entire	Templestowe Terminal Station 66kV bus
TTS1266	Split bus	Thomastown Terminal Station 1&2 66kV bus
TTS3466	Split bus	Thomastown Terminal Station 3&4 66kV bus
TTS66	Entire	Thomastown Terminal Station 66kV bus
WETS66	Entire	Wemen Terminal Station 66kV bus
WMTS22	Entire	West Melbourne Terminal Station 22kV bus
WMTS66	Entire	West Melbourne Terminal Station 66kV bus
WOTS22	Entire	Wodonga Terminal Station 22kV bus
WOTS66	Entire	Wodonga Terminal Station 66kV bus
YPS11	Entire	Yallourn PS Terminal Station 11kV bus





APD500: Portland 500 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 01 Nov 2013 14:30 509.3 197.6



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	515.8	240.0	515.8	240.0
15-16	515.8	240.0	515.8	240.0
16-17	515.8	240.0	515.8	240.0
17-18	515.8	240.0	515.8	240.0
18-19	515.8	240.0	515.8	240.0
19-20	515.8	240.0	515.8	240.0
20-21	515.8	240.0	515.8	240.0
21-22	515.8	240.0	515.8	240.0
22-23	515.8	240.0	515.8	240.0
23-24	515.8	240.0	515.8	240.0
24-25	515.8	240.0	515.8	240.0

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD **MW MVAR**
 26 May 2013 15:00 509.5 316.4

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	515.8	240.0	515.8	240.0
2015	515.8	240.0	515.8	240.0
2016	515.8	240.0	515.8	240.0
2017	515.8	240.0	515.8	240.0
2018	515.8	240.0	515.8	240.0
2019	515.8	240.0	515.8	240.0
2020	515.8	240.0	515.8	240.0
2021	515.8	240.0	515.8	240.0
2022	515.8	240.0	515.8	240.0
2023	515.8	240.0	515.8	240.0
2024	515.8	240.0	515.8	240.0

Load Curve on High Demand Day**Forecast****Notes:**

For embedded generation details, please see section 3.2 on page 70.

Portland aluminium smelter is directly connected to the transmission system.





ATS_BLTS66: Altona/Brooklyn Terminal Station 66 kV bus

Summer Demand

2013-14 MD MW MVAR
 28 Jan 2014 14:30 295.8 76.2



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	306.9	123.9	292.6	118.3
15-16	313.4	126.8	298.5	120.9
16-17	320.0	129.6	304.8	123.6
17-18	288.9	119.4	275.4	114.0
18-19	292.4	121.0	278.4	115.4
19-20	296.5	122.9	282.1	117.0
20-21	300.4	124.7	285.5	118.6
21-22	304.3	126.5	289.5	120.4
22-23	307.5	128.1	291.8	121.7
23-24	311.8	130.0	295.4	123.4
24-25	315.6	131.8	298.5	124.9

Load Curve on High Demand Day*Forecast*

Winter Demand

2013 MD MW MVAR
 28 May 2013 09:00 269.6 58.4

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	283.7	97.4	274.5	94.0
2015	291.1	100.6	281.2	96.9
2016	298.9	103.8	288.7	100.0
2017	304.5	106.3	294.0	102.3
2018	270.1	95.4	262.6	92.4
2019	273.9	97.1	266.2	94.0
2020	277.7	98.8	269.6	95.6
2021	281.9	100.7	273.5	97.3
2022	286.1	102.6	277.5	99.1
2023	288.2	103.8	279.4	100.2
2024	292.3	105.7	283.1	102.0

Load Curve on High Demand Day*Forecast*

Notes:

For embedded generation details, please see section 3.2.

ATS/BLTS comprises demand that is serviced jointly by parts of ATS and BLTS. Load will be transferred to the new Deer Park 66 kV Terminal Station from summer 2017–18. This transfer has been modelled in this forecast.




ATS_WEST66: Altona West Terminal Station 66 kV bus


Summer Demand

2013-14 MD MW MVAR
 28 Jan 2014 09:00 213.7 79.8

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	226.2	88.5	205.5	80.6
15-16	235.5	92.1	213.9	83.8
16-17	248.2	96.9	225.8	88.4
17-18	237.5	92.9	215.9	84.6
18-19	244.5	95.6	222.0	87.0
19-20	242.8	94.9	220.1	86.2
20-21	241.7	94.5	218.8	85.8
21-22	247.9	96.9	224.1	87.8
22-23	241.1	94.3	217.5	85.3
23-24	247.0	96.6	222.4	87.2
24-25	252.7	98.8	227.3	89.0




Forecast




Winter Demand

2013 MD MW MVAR
 24 Jun 2013 18:30 154.1 31.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	159.2	35.7	151.0	34.1
2015	166.6	37.1	158.1	35.4
2016	173.4	38.5	164.6	36.7
2017	183.6	40.5	174.5	38.7
2018	172.8	38.6	163.8	36.8
2019	177.1	39.5	167.8	37.6
2020	173.8	39.0	164.3	37.1
2021	171.0	38.6	161.4	36.6
2022	174.4	39.3	164.4	37.3
2023	166.4	37.9	156.4	35.9
2024	169.5	38.5	158.4	36.3



Forecast



Notes:

For embedded generation details, please see section 3.2.

The area that is serviced by the west part of ATS. Load will be transferred to the new Deer Park 66 kV Terminal Station from summer 2017–18. This transfer has been modelled in this forecast.




BATS66: Ballarat Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 15 Jan 2014 15:00 171.9 52.1


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	204.0	64.1	173.2	54.4
15-16	210.7	66.2	178.6	56.1
16-17	217.5	68.3	183.8	57.7
17-18	224.3	70.4	185.2	58.2
18-19	231.3	72.6	188.6	59.2
19-20	238.5	74.9	191.9	60.3
20-21	240.2	75.4	188.1	59.1
21-22	245.2	77.0	193.1	60.6
22-23	252.3	79.2	198.1	62.2
23-24	259.6	81.5	203.2	63.8
24-25	263.5	82.7	204.7	64.3



Winter Demand

2013 MD **MW** **MVAR**
 20 Jun 2013 18:30 170.1 22.7

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	169.4	36.9	160.7	35.0
2015	167.9	36.6	159.4	34.7
2016	167.7	36.6	159.4	34.8
2017	168.6	36.8	160.0	34.9
2018	168.2	36.7	159.6	34.8
2019	167.5	36.5	157.9	34.4
2020	166.7	36.3	157.9	34.4
2021	162.9	35.5	154.2	33.6
2022	161.6	35.2	152.5	33.3
2023	161.0	35.1	151.9	33.1
2024	159.8	34.8	150.4	32.8



Notes:

Coincident generation 5 MW.

For embedded generation details, please see section 3.2.




BETS22: Bendigo Terminal Station 22 kV bus

Summer Demand

2013-14 MD
15 Jan 2014 17:30 MW MVAR
53.7 9.0


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	79.2	21.5	71.4	19.4
15-16	82.0	22.3	73.6	20.0
16-17	85.0	23.1	76.3	20.7
17-18	88.1	24.0	79.0	21.5
18-19	91.3	24.8	81.8	22.3
19-20	94.5	25.7	84.7	23.0
20-21	97.9	26.6	87.7	23.9
21-22	101.4	27.6	90.8	24.7
22-23	105.0	28.6	94.0	25.6
23-24	108.8	29.6	97.3	26.5
24-25	112.2	30.5	100.3	27.3



Winter Demand

2013 MD
22 Jul 2013 18:30 MW MVAR
36.0 -0.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	42.1	4.0	40.5	3.8
2015	50.3	4.7	48.6	4.6
2016	51.9	4.9	50.3	4.7
2017	53.2	5.0	51.5	4.8
2018	54.3	5.1	52.8	5.0
2019	55.7	5.2	54.0	5.1
2020	56.9	5.3	55.1	5.2
2021	58.1	5.5	56.2	5.3
2022	59.6	5.6	57.7	5.4
2023	61.1	5.7	59.3	5.6
2024	62.6	5.9	60.5	5.7



Notes:

This includes only the 22 kV demand at BETS.

For embedded generation details, please see section 3.2.




BETS66: Bendigo Terminal Station 66 kV bus


Summer Demand

2013-14 MD MW MVAR
 15 Jan 2014 16:00 176.9 33.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	193.3	35.0	164.8	29.8
15-16	198.4	35.9	170.6	30.9
16-17	204.9	37.1	176.5	31.9
17-18	202.5	36.6	175.7	31.8
18-19	205.6	37.2	176.0	31.9
19-20	208.9	37.8	176.7	32.0
20-21	212.0	38.4	181.9	32.9
21-22	218.6	39.5	184.9	33.4
22-23	225.2	40.7	190.1	34.4
23-24	229.3	41.5	191.6	34.7
24-25	235.0	42.5	196.5	35.6



Forecast




Winter Demand


2013 MD MW MVAR
 21 Jun 2013 00:00 122.8 -7.4

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	133.5	1.4	128.7	1.3
2015	126.2	1.3	121.2	1.3
2016	130.4	1.3	125.2	1.3
2017	136.1	1.4	130.9	1.4
2018	133.5	1.4	128.5	1.3
2019	130.7	1.4	125.8	1.3
2020	132.4	1.4	127.2	1.3
2021	131.6	1.4	126.9	1.3
2022	132.2	1.4	127.3	1.3
2023	131.6	1.4	126.7	1.3
2024	131.9	1.4	126.6	1.3

Load Curve on High Demand Day



Forecast



Notes:

For embedded generation details, please see section 3.2.




BLTS22: Brooklyn Terminal Station 22 kV bus

Summer Demand

2013-14 MD MW MVAR
 15 Jan 2014 12:00 60.1 34.5


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	62.4	37.9	61.1	37.1
15-16	63.3	38.5	61.8	37.6
16-17	64.0	38.9	62.5	38.0
17-18	65.1	39.5	63.1	38.3
18-19	65.8	40.0	63.6	38.7
19-20	66.2	40.2	64.0	38.9
20-21	66.8	40.6	64.3	39.0
21-22	67.6	41.0	64.9	39.4
22-23	69.1	41.9	65.7	39.9
23-24	69.9	42.4	66.0	40.1
24-25	70.8	43.0	66.6	40.4



Winter Demand

2013 MD MW MVAR
 09 Aug 2013 10:30 55.0 31.2

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	56.6	32.6	55.8	32.2
2015	57.1	32.9	56.2	32.5
2016	57.4	33.1	56.5	32.6
2017	57.8	33.3	56.9	32.8
2018	58.1	33.5	57.2	33.0
2019	58.2	33.6	57.4	33.1
2020	58.6	33.8	57.6	33.2
2021	58.5	33.8	57.6	33.2
2022	58.7	33.8	57.8	33.3
2023	58.9	33.9	58.0	33.4
2024	59.2	34.1	58.1	33.5



Notes:

This includes only the 22 kV demand at BLTS.

For embedded generation details, please see section 3.2.




BLTS-SCI66: Brooklyn-SCI 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 25 Jan 2014 00:30 61.6 7.9


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	61.8	5.6	61.8	5.6
15-16	61.8	5.6	61.8	5.6
16-17	61.8	5.6	61.8	5.6
17-18	61.8	5.6	61.8	5.6
18-19	61.8	5.6	61.8	5.6
19-20	61.8	5.6	61.8	5.6
20-21	61.8	5.6	61.8	5.6
21-22	61.8	5.6	61.8	5.6
22-23	61.8	5.6	61.8	5.6
23-24	61.8	5.6	61.8	5.6
24-25	61.8	5.6	61.8	5.6



Winter Demand

2013 MD **MW MVAR**
 03 Jun 2013 12:30 62.6 5.5

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	69.2	4.8	69.2	4.8
2015	69.2	4.8	69.2	4.8
2016	69.2	4.8	69.2	4.8
2017	69.2	4.8	69.2	4.8
2018	69.2	4.8	69.2	4.8
2019	69.2	4.8	69.2	4.8
2020	69.2	4.8	69.2	4.8
2021	69.2	4.8	69.2	4.8
2022	69.2	4.8	69.2	4.8
2023	69.2	4.8	69.2	4.8
2024	69.2	4.8	69.2	4.8



Notes:

Industrial demand (steel mill) serviced out of BLTS.

For embedded generation details, please see section 3.2.




BTS22: Brunswick Terminal Station 22 kV bus

Summer Demand

2013-14 MD MW MVAR
 28 Jan 2014 16:30 96.4 36.4


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	97.4	38.2	88.8	34.8
15-16	99.6	39.0	90.6	35.4
16-17	102.9	40.3	93.6	36.6
17-18	94.5	40.1	85.1	36.3
18-19	97.1	41.2	87.3	37.2
19-20	99.3	42.1	88.9	37.9
20-21	101.4	43.0	90.2	38.5
21-22	102.7	43.5	91.1	38.8
22-23	104.3	44.2	91.7	39.1
23-24	105.4	44.7	92.2	39.3
24-25	106.8	45.2	92.7	39.6



Winter Demand

2013 MD MW MVAR
 24 Jun 2013 19:00 83.2 26.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	85.7	23.1	81.9	22.1
2015	87.2	23.5	83.4	22.5
2016	89.6	24.2	85.7	23.1
2017	92.2	24.9	88.0	23.7
2018	85.8	24.5	81.8	23.3
2019	86.8	24.7	82.8	23.6
2020	87.6	24.9	83.5	23.8
2021	87.5	24.9	83.4	23.7
2022	87.5	24.8	83.3	23.7
2023	87.1	24.7	82.9	23.6
2024	86.6	24.6	82.2	23.4



Notes:

For embedded generation details, please see section 3.2.

This includes only the 22 kV demand at BTS. Load will be transferred to the new Brunswick 66 kV Terminal Station in 2018. This transfer has been modelled in this forecast.





BTS66: Brunswick Terminal Station 66 kV bus

Summer Demand

2013-14 MD MW MVAR
 #N/A #N/A #N/A



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	0.0	0.0	0.0	0.0
15-16	0.0	0.0	0.0	0.0
16-17	146.0	19.5	141.8	19.0
17-18	260.0	34.8	252.4	33.8
18-19	265.4	35.5	257.6	34.5
19-20	268.0	35.9	260.2	34.8
20-21	271.2	36.3	263.3	35.2
21-22	275.4	36.8	267.3	35.8
22-23	281.2	37.6	273.0	36.5
23-24	286.8	38.4	278.5	37.3
24-25	292.6	39.2	284.1	38.0

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD MW MVAR
 #N/A #N/A #N/A

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	0.0	0.0	0.0	0.0
2015	0.0	0.0	0.0	0.0
2016	0.0	0.0	0.0	0.0
2017	106.5	10.9	103.4	10.5
2018	203.3	20.7	197.4	20.1
2019	201.9	20.6	196.0	20.0
2020	200.4	20.4	194.6	19.8
2021	198.3	20.2	192.5	19.6
2022	196.1	20.0	190.4	19.4
2023	194.3	19.8	188.7	19.2
2024	196.3	20.0	190.6	19.4

Load Curve on High Demand Day**Forecast****Notes:**

For embedded generation details, please see section 3.2.

This includes only the 66 kV load at BTS. Load will be transferred from WMITS66 (in 2017), BTS22 (in 2018) and RTS66 (in 2018) to BTS66.





CBTS66: Cranbourne Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 28 Jan 2014 17:00 415.4 122.5



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	440.2	129.8	410.3	121.1
15-16	450.0	132.9	419.5	123.9
16-17	464.7	137.3	432.3	127.7
17-18	479.7	141.7	447.2	132.2
18-19	495.7	146.4	460.6	136.1
19-20	506.8	149.7	473.1	139.8
20-21	518.0	153.0	483.9	143.0
21-22	530.5	156.7	495.5	146.5
22-23	545.2	161.0	507.2	149.9
23-24	558.7	165.0	520.3	153.8
24-25	571.9	168.9	533.1	157.6



Winter Demand

2013 MD **MW MVAR**
 20 Aug 2013 19:00 313.9 47.6

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	330.1	50.8	314.4	48.3
2015	338.6	52.1	322.5	49.6
2016	346.4	53.4	329.9	50.8
2017	354.8	54.7	338.0	52.0
2018	363.3	56.1	346.1	53.3
2019	371.6	57.3	354.0	54.6
2020	381.0	58.8	363.0	55.9
2021	386.7	59.7	368.6	56.8
2022	394.4	60.9	375.9	58.0
2023	401.3	62.0	382.5	59.0
2024	409.5	63.3	390.4	60.3



Notes:

For embedded generation details, please see section 3.2.





DPTS66: Deer Park Terminal Station 66 kV bus

Summer Demand

2013-14 MD MW MVAR
 #N/A #N/A #N/A



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	0.0	0.0	0.0	0.0
15-16	0.0	0.0	0.0	0.0
16-17	0.0	0.0	0.0	0.0
17-18	225.9	40.0	205.4	36.3
18-19	233.4	41.3	212.1	37.5
19-20	248.6	44.0	226.0	40.0
20-21	268.2	47.4	243.8	43.1
21-22	277.1	49.0	251.9	44.5
22-23	304.3	53.8	276.6	48.9
23-24	313.6	55.5	285.1	50.4
24-25	323.2	57.2	293.8	52.0

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD MW MVAR
 #N/A #N/A #N/A

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	0.0	0.0	0.0	0.0
2015	0.0	0.0	0.0	0.0
2016	0.0	0.0	0.0	0.0
2017	0.0	0.0	0.0	0.0
2018	164.6	2.8	159.8	2.7
2019	167.5	2.8	162.6	2.7
2020	177.8	3.0	172.6	2.9
2021	190.0	3.2	184.4	3.1
2022	193.8	3.3	188.1	3.2
2023	211.2	3.6	205.0	3.5
2024	215.5	3.6	209.3	3.5

Load Curve on High Demand Day**Forecast****Notes:**

For embedded generation details, please see section 3.2.

In November 2017, load will be transferred from ATS_West66 , ATS_BLTS66, KTS_East and KTS_West to DPTS66.




ERTS1266: East Rowville Terminal Station buses 1&2 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 17:30 238.9 48.0


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	251.2	53.5	233.2	49.5
15-16	251.7	53.6	233.5	49.6
16-17	256.7	54.5	237.1	50.2
17-18	262.1	55.6	242.7	51.3
18-19	268.3	56.7	247.0	52.1
19-20	271.3	57.3	251.4	52.9
20-21	274.4	57.9	254.3	53.5
21-22	278.1	58.6	257.5	54.1
22-23	284.5	59.8	261.6	54.9
23-24	288.9	60.6	265.9	55.7
24-25	293.0	61.4	270.0	56.4



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 18:30 171.9 21.0

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	177.1	21.4	167.4	20.2
2015	179.0	21.7	169.4	20.5
2016	181.0	21.9	171.3	20.7
2017	183.3	22.2	173.5	21.0
2018	185.7	22.4	175.8	21.2
2019	187.6	22.7	177.6	21.5
2020	189.5	22.9	179.4	21.7
2021	191.0	23.1	180.8	21.8
2022	192.0	23.2	181.7	21.9
2023	193.6	23.4	183.2	22.1
2024	196.3	23.7	185.7	22.4



Notes:

Buses 1 and 2 at ERTS.

For embedded generation details, please see section 3.2.





ERTS3466: East Rowville Terminal Station buses 3&4 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 15 Jan 2014 07:30 238.5 82.7



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	263.6	90.0	245.7	84.0
15-16	264.8	90.4	246.6	84.3
16-17	273.1	93.3	252.7	86.4
17-18	282.0	96.4	261.8	89.6
18-19	292.9	100.2	269.8	92.4
19-20	298.9	102.2	277.7	95.1
20-21	305.4	104.4	283.8	97.2
21-22	312.2	106.8	289.8	99.2
22-23	323.8	110.7	297.6	101.9
23-24	331.4	113.3	304.9	104.4
24-25	338.4	115.8	311.7	106.7

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD **MW MVAR**
 31 Jul 2013 09:30 208.6 66.5

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	236.3	80.1	225.5	76.5
2015	229.8	77.9	219.5	74.4
2016	233.1	79.0	222.6	75.5
2017	236.9	80.3	226.3	76.7
2018	241.6	81.9	230.7	78.2
2019	245.8	83.3	234.7	79.6
2020	250.4	84.9	238.9	81.0
2021	253.9	86.1	242.1	82.1
2022	256.6	87.0	244.5	82.9
2023	260.1	88.1	247.7	84.0
2024	265.4	89.9	252.7	85.7

Load Curve on High Demand Day**Forecast**
Notes:

For embedded generation details, please see section 3.2.

Buses 3 and 4 at ERTS. Approximately 6 MW of demand will be transferred away from ERTS to HTS in 2014–15 when the new Keysborough zone substation is commissioned.





ERTS66: East Rowville Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 15 Jan 2014 17:30 433.6 117.4



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	449.3	122.2	419.4	114.2
15-16	450.8	122.6	420.4	114.5
16-17	463.3	126.1	429.5	117.0
17-18	476.8	129.9	443.5	121.0
18-19	493.0	134.4	455.1	124.2
19-20	501.4	136.7	466.6	127.4
20-21	510.2	139.2	475.0	129.7
21-22	519.9	141.9	483.4	132.1
22-23	536.9	146.6	494.6	135.2
23-24	548.1	149.7	505.4	138.2
24-25	558.4	152.6	515.6	141.0

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD **MW MVAR**
 20 Jun 2013 09:00 363.7 99.8

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	350.0	91.8	335.4	88.4
2015	345.3	90.4	331.4	87.2
2016	350.1	91.7	335.9	88.5
2017	355.8	93.3	341.3	90.0
2018	362.2	95.1	347.4	91.7
2019	367.6	96.5	352.5	93.1
2020	373.1	98.0	357.7	94.5
2021	377.3	99.1	361.5	95.5
2022	380.2	99.9	364.2	96.2
2023	384.6	101.1	368.3	97.3
2024	391.7	103.0	375.0	99.2

Load Curve on High Demand Day**Forecast****Notes:**

For embedded generation details, please see section 3.2.

Approximately 6 MW of demand will be transferred away from ERTS to HTS in 2014–15 when the new Keysborough zone substation is commissioned.





FBTS66: Fishermans Bend Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 16 Jan 2014 14:00 282.5 89.0



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	326.2	106.0	309.2	100.4
15-16	339.7	110.4	322.1	104.6
16-17	360.8	117.2	342.3	111.2
17-18	380.4	123.6	360.2	117.0
18-19	390.2	126.7	365.9	118.9
19-20	393.0	127.6	369.2	119.9
20-21	406.4	132.0	382.3	124.2
21-22	412.2	133.9	385.4	125.2
22-23	420.7	136.7	391.9	127.3
23-24	430.4	139.8	398.7	129.5
24-25	439.3	142.7	406.1	131.9

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD **MW** **MVAR**
 24 Jun 2013 10:30 195.5 27.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	218.6	38.6	208.4	36.8
2015	244.3	43.2	233.7	41.3
2016	252.1	44.5	241.8	42.7
2017	268.0	47.4	256.9	45.4
2018	282.2	49.9	269.2	47.6
2019	282.6	49.9	271.1	47.9
2020	285.8	50.5	271.4	48.0
2021	291.4	51.5	279.3	49.4
2022	291.8	51.6	278.1	49.1
2023	292.0	51.6	278.6	49.2
2024	296.6	52.4	278.4	49.2

Load Curve on High Demand Day**Forecast**

Notes:

For embedded generation details, please see section 3.2.




FVTS220: Fosterville Terminal Station 220 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 22 Feb 2014 20:30 12.2 0.0


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	13.2	4.0	13.2	4.0
15-16	13.2	4.0	13.2	4.0
16-17	13.2	4.0	13.2	4.0
17-18	13.2	4.0	13.2	4.0
18-19	13.2	4.0	13.2	4.0
19-20	13.2	4.0	13.2	4.0
20-21	13.2	4.0	13.2	4.0
21-22	13.2	4.0	13.2	4.0
22-23	13.2	4.0	13.2	4.0
23-24	13.2	4.0	13.2	4.0
24-25	13.2	4.0	13.2	4.0



Winter Demand

2013 MD **MW** **MVAR**
 13 Jul 2013 17:00 11.7 0.0

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	13.2	4.0	13.2	4.0
2015	13.2	4.0	13.2	4.0
2016	13.2	4.0	13.2	4.0
2017	13.2	4.0	13.2	4.0
2018	13.2	4.0	13.2	4.0
2019	13.2	4.0	13.2	4.0
2020	13.2	4.0	13.2	4.0
2021	13.2	4.0	13.2	4.0
2022	13.2	4.0	13.2	4.0
2023	13.2	4.0	13.2	4.0
2024	13.2	4.0	13.2	4.0



Notes:

For embedded generation details, please see section 3.2 on page 70.

The Forestville gold mine is directly connected to this terminal station.




GNTS66: Glenrowan Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 18:00 101.6 40.7


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	105.6	42.3	97.3	39.0
15-16	106.1	42.5	97.8	39.2
16-17	106.5	42.7	98.2	39.3
17-18	107.0	42.8	98.6	39.5
18-19	107.3	43.0	99.0	39.7
19-20	107.7	43.1	99.4	39.8
20-21	108.1	43.3	99.7	39.9
21-22	108.4	43.4	100.1	40.1
22-23	108.8	43.6	100.4	40.2
23-24	109.2	43.7	100.8	40.4
24-25	109.6	43.9	101.2	40.5



Winter Demand

2013 MD **MW MVAR**
 09 Jul 2013 02:00 89.3 11.7

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	94.0	12.3	86.6	11.3
2015	94.4	12.3	87.0	11.4
2016	94.8	12.4	87.4	11.4
2017	95.2	12.4	87.8	11.5
2018	95.5	12.5	88.1	11.5
2019	95.8	12.5	88.4	11.6
2020	96.2	12.6	88.7	11.6
2021	96.5	12.6	89.0	11.6
2022	96.8	12.7	89.4	11.7
2023	97.2	12.7	89.7	11.7
2024	97.5	12.8	90.0	11.8



Notes:

For embedded generation details, please see section 3.2.





GTS66: Geelong Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 15:30 440.6 90.8



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	506.1	136.7	472.2	127.5
15-16	526.9	142.3	491.7	132.8
16-17	521.9	140.9	485.2	131.0
17-18	541.1	146.1	502.9	135.8
18-19	560.9	151.4	521.3	140.7
19-20	581.5	157.0	540.3	145.9
20-21	602.9	162.8	560.0	151.2
21-22	625.1	168.8	580.5	156.7
22-23	648.1	175.0	601.7	162.5
23-24	672.0	181.4	623.7	168.4
24-25	693.8	187.3	643.8	173.8

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD **MW MVAR**
 09 Jul 2013 18:30 323.8 30.2

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	343.3	47.4	335.4	46.3
2015	357.8	49.4	349.5	48.2
2016	353.4	48.8	345.3	47.7
2017	347.7	48.0	339.1	46.8
2018	354.5	48.9	345.5	47.7
2019	358.9	49.5	350.8	48.4
2020	362.8	50.1	354.7	49.0
2021	363.6	50.2	355.8	49.1
2022	366.6	50.6	359.3	49.6
2023	372.8	51.4	364.7	50.3
2024	379.1	52.3	370.2	51.1

Load Curve on High Demand Day**Forecast**
Notes:

For embedded generation details, please see section 3.2.




HOTS66: Horsham Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 15 Jan 2014 15:00 83.5 19.3


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	106.6	34.3	93.6	30.1
15-16	109.8	35.3	96.1	30.9
16-17	113.8	36.7	99.6	32.1
17-18	118.2	38.0	103.0	33.2
18-19	119.6	38.5	103.5	33.3
19-20	122.5	39.5	106.4	34.3
20-21	123.8	39.9	106.4	34.3
21-22	127.6	41.1	110.1	35.4
22-23	132.6	42.7	113.8	36.6
23-24	136.1	43.8	115.5	37.2
24-25	139.3	44.9	118.1	38.0



Winter Demand

2013 MD **MW** **MVAR**
 09 Jul 2013 00:00 79.0 1.0

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	89.2	11.8	84.1	11.1
2015	92.5	12.2	87.2	11.5
2016	95.9	12.7	90.3	11.9
2017	99.4	13.1	93.6	12.4
2018	103.0	13.6	96.9	12.8
2019	106.6	14.1	100.4	13.2
2020	110.4	14.6	103.9	13.7
2021	114.3	15.1	107.5	14.2
2022	118.2	15.6	111.2	14.7
2023	122.3	16.1	115.0	15.2
2024	126.5	16.7	118.9	15.7



Notes:

For embedded generation details, please see section 3.2.




HTS66: Heatherton Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 28 Jan 2014 15:30 331.8 76.0


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	376.6	86.3	342.4	78.4
15-16	378.3	86.7	343.3	78.6
16-17	385.5	88.3	347.0	79.5
17-18	394.5	90.4	356.2	81.6
18-19	404.6	92.7	361.6	82.8
19-20	405.7	92.9	366.0	83.8
20-21	406.8	93.2	367.0	84.1
21-22	411.1	94.2	370.0	84.8
22-23	421.4	96.5	374.5	85.8
23-24	423.8	97.1	376.7	86.3
24-25	426.4	97.7	379.3	86.9



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 11:00 236.1 57.3

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	239.5	58.1	221.8	53.8
2015	256.9	62.3	236.6	57.4
2016	258.6	62.7	238.4	57.8
2017	259.8	63.0	239.8	58.2
2018	260.7	63.2	240.7	58.4
2019	262.5	63.7	242.7	58.9
2020	264.4	64.1	244.6	59.3
2021	267.4	64.9	247.7	60.1
2022	271.3	65.8	251.6	61.0
2023	274.1	66.5	254.4	61.7
2024	274.4	66.6	255.0	61.9



Notes:

For embedded generation details, please see section 3.2.

Approximately 24 MW of demand will be transferred onto HTS in 2014–15 from SVTS and ERTS when the new Keysborough zone substation is commissioned.





HYTS22: Heywood Terminal Station 22 kV bus

Summer Demand

2013-14 MD MW MVAR
 21 Mar 2014 07:00 1.6 0.5



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	2.0	1.0	2.0	1.0
15-16	2.0	1.0	2.0	1.0
16-17	2.1	1.0	2.1	1.0
17-18	2.1	1.0	2.1	1.0
18-19	2.1	1.0	2.1	1.0
19-20	2.1	1.0	2.1	1.0
20-21	2.1	1.0	2.1	1.0
21-22	2.1	1.1	2.1	1.1
22-23	2.1	1.1	2.1	1.1
23-24	2.1	1.1	2.1	1.1
24-25	2.1	1.1	2.1	1.1

Load Curve on High Demand Day***Forecast***

Winter Demand

2013 MD MW MVAR
 25 Oct 2013 07:00 1.5 0.4

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	2.1	0.6	2.1	0.6
2015	1.7	0.9	1.7	0.9
2016	1.7	0.9	1.7	0.9
2017	1.7	0.9	1.7	0.9
2018	1.7	0.9	1.7	0.9
2019	1.7	0.9	1.7	0.9
2020	1.8	0.9	1.8	0.9
2021	1.8	0.9	1.8	0.9
2022	1.8	0.9	1.8	0.9
2023	1.8	0.9	1.8	0.9
2024	1.8	0.9	1.8	0.9

Load Curve on High Demand Day***Forecast******Notes:***

For embedded generation details, please see section 3.2.

HYTS 22 kV supply was established in 2009. The terminal station mainly consist of industrial and agricultural load.




JLA220: John Lysaght 220 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 12 Mar 2014 18:30 29.3 9.8


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	30.0	10.0	30.0	10.0
15-16	30.0	10.0	30.0	10.0
16-17	30.0	10.0	30.0	10.0
17-18	30.0	10.0	30.0	10.0
18-19	30.0	10.0	30.0	10.0
19-20	30.0	10.0	30.0	10.0
20-21	30.0	10.0	30.0	10.0
21-22	30.0	10.0	30.0	10.0
22-23	30.0	10.0	30.0	10.0
23-24	30.0	10.0	30.0	10.0
24-25	30.0	10.0	30.0	10.0



Winter Demand

2013 MD **MW** **MVAR**
 11 Jul 2013 12:00 29.6 9.9

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	30.0	10.0	30.0	10.0
2015	30.0	10.0	30.0	10.0
2016	30.0	10.0	30.0	10.0
2017	30.0	10.0	30.0	10.0
2018	30.0	10.0	30.0	10.0
2019	30.0	10.0	30.0	10.0
2020	30.0	10.0	30.0	10.0
2021	30.0	10.0	30.0	10.0
2022	30.0	10.0	30.0	10.0
2023	30.0	10.0	30.0	10.0
2024	30.0	10.0	30.0	10.0



Notes:

For embedded generation details, please see section 3.2 on page 70.

This load is a direct-connect customer, near Tyabb Terminal Station.




KGTS22: Kerang Terminal Station 22 kV bus

Summer Demand

2013-14 MD
15 Jan 2014 17:30 MW MVAR
12.4 -1.2


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	13.9	3.3	13.0	3.1
15-16	14.5	3.5	13.6	3.3
16-17	15.1	3.6	14.2	3.4
17-18	15.8	3.8	14.8	3.5
18-19	16.4	3.9	15.4	3.7
19-20	17.1	4.1	16.0	3.8
20-21	17.8	4.3	16.7	4.0
21-22	18.5	4.4	17.3	4.2
22-23	19.2	4.6	18.0	4.3
23-24	20.0	4.8	18.7	4.5
24-25	20.7	5.0	19.4	4.6



Winter Demand

2013 MD
20 Aug 2013 00:00 MW MVAR
14.3 0.3

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	14.8	1.8	14.3	1.7
2015	15.4	1.9	14.9	1.8
2016	16.0	1.9	15.6	1.9
2017	16.7	2.0	16.2	2.0
2018	17.4	2.1	16.9	2.0
2019	18.1	2.2	17.6	2.1
2020	18.9	2.3	18.3	2.2
2021	19.6	2.4	19.1	2.3
2022	20.4	2.5	19.8	2.4
2023	21.3	2.6	20.6	2.5
2024	22.1	2.7	21.4	2.6



Notes:

This includes only the 22 kV demand at KGTS.

For embedded generation details, please see section 3.2.




KGTS66: Kerang Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 30 Jan 2014 16:30 54.6 10.6


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	61.5	11.3	56.0	10.3
15-16	62.7	11.5	56.8	10.4
16-17	63.1	11.6	56.9	10.5
17-18	62.5	11.5	56.3	10.3
18-19	62.4	11.5	56.4	10.4
19-20	62.5	11.5	56.6	10.4
20-21	62.5	11.5	56.5	10.4
21-22	62.2	11.4	56.6	10.4
22-23	63.8	11.7	57.8	10.6
23-24	63.5	11.7	56.9	10.5
24-25	63.9	11.7	57.5	10.6



Winter Demand

2013 MD **MW MVAR**
 20 Aug 2013 00:00 43.6 -2.0

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	40.8	-2.7	38.0	-2.5
2015	38.4	-2.6	36.1	-2.4
2016	39.6	-2.6	37.3	-2.5
2017	40.9	-2.7	38.5	-2.6
2018	40.4	-2.7	37.9	-2.5
2019	39.3	-2.6	37.2	-2.5
2020	39.7	-2.6	37.3	-2.5
2021	38.7	-2.6	36.4	-2.4
2022	39.5	-2.6	36.6	-2.4
2023	38.9	-2.6	36.4	-2.4
2024	39.0	-2.6	36.1	-2.4



Notes:

For embedded generation details, please see section 3.2.




KTS_East66: Eastern area served by Keilor Terminal Stn. 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 14:30 382.6 156.4


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	410.2	168.4	376.0	154.4
15-16	423.5	174.0	388.8	159.7
16-17	440.2	180.8	405.3	166.4
17-18	360.0	146.0	326.9	132.4
18-19	370.0	150.2	336.1	136.1
19-20	380.8	154.6	346.8	140.5
20-21	391.9	159.2	356.4	144.4
21-22	401.6	163.3	367.2	148.8
22-23	414.0	168.4	378.1	153.3
23-24	424.2	172.7	387.6	157.3
24-25	433.7	176.6	395.8	160.7



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 10:30 280.3 93.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	281.3	86.4	275.0	84.4
2015	291.2	89.5	284.6	87.4
2016	302.3	92.8	295.4	90.7
2017	311.2	95.5	304.0	93.3
2018	252.7	73.6	247.4	72.1
2019	259.3	75.5	254.1	74.0
2020	266.1	77.5	260.8	76.0
2021	272.5	79.4	267.0	77.8
2022	279.8	81.6	274.0	79.9
2023	285.7	83.3	279.9	81.6
2024	292.3	85.3	285.8	83.4



Notes:

For embedded generation details, please see section 3.2.

KTS is split for planning purposes. KTS_East is supplied by transformers 1, 2 and 3. Load will be transferred to the new Deer Park 66 kV Terminal Station in November 2017. This transfer has been modelled in this forecast.




KTS_West66: Western area served by Keilor Terminal Stn. 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 28 Jan 2014 18:00 270.3 93.2


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	301.6	103.2	268.8	91.9
15-16	311.8	106.6	277.6	94.9
16-17	322.9	110.5	287.3	98.3
17-18	250.4	89.2	222.8	79.3
18-19	258.3	92.0	229.5	81.7
19-20	266.9	95.1	236.2	84.1
20-21	268.3	96.0	231.9	83.1
21-22	276.1	98.8	238.6	85.5
22-23	284.9	102.0	245.4	88.0
23-24	293.3	105.0	251.9	90.4
24-25	301.1	107.9	256.0	92.0



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 18:30 197.1 31.8

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	207.8	43.6	200.5	42.0
2015	214.4	45.0	206.8	43.4
2016	220.0	46.2	212.0	44.5
2017	222.9	47.0	214.9	45.3
2018	166.6	38.3	165.0	37.6
2019	168.5	38.9	166.7	38.2
2020	170.8	39.6	168.8	38.8
2021	164.8	39.0	163.7	38.3
2022	166.4	39.6	165.5	38.9
2023	168.8	40.3	167.5	39.6
2024	171.2	41.0	169.4	40.2



Notes:

For embedded generation details, please see section 3.2.

KTS is split for planning purposes. KTS_West is supplied by transformers 3 and 4. Load will be transferred to the new Deer Park 66 kV Terminal Station in November 2017. This transfer has been modelled in this forecast.




KTS66: Keilor Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 17 Jan 2014 18:00 643.1 241.3


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	703.4	268.5	637.2	243.5
15-16	726.6	277.4	658.4	251.7
16-17	754.0	287.9	684.4	261.7
17-18	601.4	231.8	541.5	208.6
18-19	619.1	238.7	557.1	214.6
19-20	638.2	246.1	574.2	221.3
20-21	650.5	251.5	579.3	224.1
21-22	667.8	258.3	596.6	230.9
22-23	688.6	266.5	614.1	237.8
23-24	707.1	273.8	629.8	244.0
24-25	724.2	280.5	642.0	248.9



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 18:30 465.2 88.6

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	487.3	129.5	473.7	126.0
2015	503.7	134.0	489.6	130.3
2016	520.3	138.6	505.4	134.7
2017	532.1	142.0	516.9	138.0
2018	416.5	111.1	409.7	108.9
2019	424.9	113.6	417.9	111.4
2020	434.0	116.3	426.7	114.0
2021	434.3	117.5	427.8	115.3
2022	443.1	120.3	436.4	118.0
2023	451.4	122.7	444.3	120.3
2024	460.3	125.4	452.0	122.7


Notes:

For embedded generation details, please see section 3.2.

KTS is split for planning purposes. Please see KTS_East and KTS_West.




LY66: Loy Yang Substation 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 22 Mar 2014 06:00 47.2 37.9


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	33.8	22.4	33.8	22.4
15-16	33.8	22.4	33.8	22.4
16-17	33.8	22.4	33.8	22.4
17-18	33.8	22.4	33.8	22.4
18-19	33.8	22.4	33.8	22.4
19-20	33.8	22.4	33.8	22.4
20-21	33.8	22.4	33.8	22.4
21-22	33.8	22.4	33.8	22.4
22-23	33.8	22.4	33.8	22.4
23-24	33.8	22.4	33.8	22.4
24-25	33.8	22.4	33.8	22.4



Winter Demand

2013 MD **MW MVAR**
 30 Aug 2013 21:00 48.0 39.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	38.5	25.9	38.5	25.9
2015	38.5	25.9	38.5	25.9
2016	38.5	25.9	38.5	25.9
2017	38.5	25.9	38.5	25.9
2018	38.5	25.9	38.5	25.9
2019	38.5	25.9	38.5	25.9
2020	38.5	25.9	38.5	25.9
2021	38.5	25.9	38.5	25.9
2022	38.5	25.9	38.5	25.9
2023	38.5	25.9	38.5	25.9
2024	38.5	25.9	38.5	25.9



Notes:

For embedded generation details, please see section 3.2.

This demand forecast includes both Ausnet services distribution load and the load at Loy Yang Power Station. This substation's demand is also included in this report under Morewell Terminal Station. AEMO advises that if an outage of a Loy Yang Power Station unit transformer occurs, approximately 50 MW of additional demand may be drawn from the Morwell Terminal Station.




MBTS66: Mount Beauty Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 18:00 38.8 1.3


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	38.3	1.3	37.5	1.3
15-16	38.4	1.3	37.7	1.3
16-17	38.6	1.3	37.9	1.3
17-18	38.7	1.3	38.0	1.3
18-19	38.8	1.3	38.1	1.3
19-20	38.9	1.3	38.2	1.3
20-21	39.0	1.3	38.4	1.3
21-22	39.1	1.3	38.5	1.3
22-23	39.1	1.3	38.6	1.3
23-24	39.2	1.3	38.7	1.3
24-25	39.3	1.3	38.8	1.3



Winter Demand

2013 MD **MW MVAR**
 25 Jul 2013 01:30 45.5 2.7

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	43.2	2.6	42.3	2.5
2015	43.3	2.6	42.5	2.5
2016	43.5	2.6	42.7	2.6
2017	43.6	2.6	42.9	2.6
2018	43.8	2.6	43.0	2.6
2019	43.9	2.6	43.1	2.6
2020	44.0	2.6	43.3	2.6
2021	44.1	2.6	43.4	2.6
2022	44.2	2.6	43.5	2.6
2023	44.2	2.7	43.6	2.6
2024	44.3	2.7	43.7	2.6



Notes:

For embedded generation details, please see section 3.2.

Forecast demand shown here assumes the Clover Power Station is switched off at the time of maximum demand. Actual previous year summer and winter generation of Clover Power Station at time of maximum demand was zero.




MTS22: Malvern Terminal Station 22 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 28 Jan 2014 17:00 42.3 10.4


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	43.5	10.7	39.8	9.8
15-16	43.6	10.7	39.9	9.8
16-17	44.0	10.8	40.0	9.9
17-18	44.6	11.0	40.7	10.0
18-19	45.3	11.2	40.9	10.1
19-20	45.3	11.2	41.4	10.2
20-21	45.6	11.2	41.7	10.3
21-22	46.0	11.3	42.1	10.4
22-23	46.6	11.5	42.1	10.4
23-24	47.2	11.6	42.7	10.5
24-25	47.5	11.7	43.1	10.6



Winter Demand

2013 MD **MW** **MVAR**
 24 Jun 2013 18:00 32.1 5.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	33.0	5.2	31.2	4.9
2015	33.2	5.3	31.4	5.0
2016	33.3	5.3	31.5	5.0
2017	33.5	5.3	31.7	5.0
2018	33.6	5.3	31.8	5.0
2019	33.7	5.3	31.9	5.1
2020	33.8	5.4	31.9	5.1
2021	33.8	5.3	31.9	5.1
2022	33.7	5.3	31.9	5.1
2023	33.8	5.4	31.9	5.1
2024	34.0	5.4	32.1	5.1



Notes:

For embedded generation details, please see section 3.2.




MTS66: Malvern Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 17:30 183.2 39.7


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	186.7	40.5	165.4	35.8
15-16	188.5	40.9	166.8	36.2
16-17	193.4	41.9	169.9	36.8
17-18	198.7	43.1	175.2	38.0
18-19	205.3	44.5	179.4	38.9
19-20	207.7	45.0	183.4	39.7
20-21	212.0	45.9	187.2	40.6
21-22	216.6	46.9	191.0	41.4
22-23	222.8	48.3	194.1	42.1
23-24	228.5	49.5	199.4	43.2
24-25	233.0	50.5	203.6	44.1



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 18:30 124.0 7.3

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	124.9	7.3	121.8	7.2
2015	127.9	7.5	124.6	7.3
2016	131.1	7.7	127.6	7.5
2017	133.5	7.9	129.9	7.6
2018	136.2	8.0	132.4	7.8
2019	139.0	8.2	135.1	7.9
2020	143.3	8.4	139.2	8.2
2021	145.2	8.5	141.0	8.3
2022	148.1	8.7	143.6	8.5
2023	149.7	8.8	145.1	8.5
2024	153.2	9.0	148.4	8.7



Notes:

For embedded generation details, please see section 3.2.




MTS662266: Malvern T.S. - 66 and 22 kV loads combined 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 17:00 221.5 49.2


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	225.8	50.2	201.3	44.7
15-16	227.8	50.6	202.8	45.1
16-17	233.0	51.8	205.9	45.8
17-18	238.8	53.1	211.9	47.1
18-19	246.1	54.7	216.3	48.1
19-20	248.4	55.2	220.7	49.0
20-21	253.0	56.2	224.8	50.0
21-22	258.0	57.3	228.9	50.9
22-23	264.7	58.8	232.1	51.6
23-24	270.9	60.2	237.8	52.8
24-25	275.6	61.2	242.3	53.8



Winter Demand

2013 MD **MW MVAR**
 23 Jun 2013 18:30 155.5 11.9

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	156.7	12.0	152.3	11.6
2015	160.4	12.2	155.3	11.9
2016	163.8	12.5	158.5	12.1
2017	166.3	12.7	160.9	12.3
2018	169.1	12.9	163.6	12.5
2019	172.1	13.1	166.4	12.7
2020	176.4	13.5	170.4	13.0
2021	178.3	13.6	172.2	13.1
2022	181.2	13.8	174.9	13.3
2023	182.8	14.0	176.3	13.5
2024	186.5	14.2	179.9	13.7



Notes:

For embedded generation details, please see section 3.2.

This includes the 66 kV load plus the 22 kV load at MTS representing the demand through the 220/66 kV transformers.





MWTS66: Morwell Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 17 Jan 2014 15:30 428.1 108.8



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	481.1	122.2	441.4	112.2
15-16	484.4	123.1	444.5	112.9
16-17	487.3	123.8	447.3	113.6
17-18	490.2	124.5	450.0	114.3
18-19	492.1	125.0	451.8	114.8
19-20	493.6	125.4	453.2	115.1
20-21	494.8	125.7	454.3	115.4
21-22	495.8	126.0	455.3	115.7
22-23	496.7	126.2	456.2	115.9
23-24	497.6	126.4	457.1	116.1
24-25	498.4	126.6	457.9	116.3

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD **MW** **MVAR**
 14 Sep 2013 00:00 336.6 18.9

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	398.1	22.3	365.3	20.5
2015	400.9	22.5	367.9	20.6
2016	403.3	22.6	370.2	20.8
2017	405.7	22.7	372.4	20.9
2018	407.3	22.8	373.9	21.0
2019	408.5	22.9	375.1	21.0
2020	409.5	23.0	376.0	21.1
2021	410.3	23.0	376.8	21.1
2022	411.1	23.0	377.6	21.2
2023	411.8	23.1	378.3	21.2
2024	412.5	23.1	378.9	21.2

Load Curve on High Demand Day**Forecast****Notes:**

For embedded generation details, please see section 3.2.

This terminal station supplies Gippsland. Also included in this demand is LY66, which is reported separately in this document. Morwell Power Station and Bairnsdale Power Station are assumed to be switched off at the time of maximum demand in the forecasts, and are not netted off actual previous year summer and winter generation.




PTH220: Point Henry 220 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 15 Dec 2013 14:30 355.1 72.8


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	0.0	0.0	0.0	0.0
15-16	0.0	0.0	0.0	0.0
16-17	0.0	0.0	0.0	0.0
17-18	0.0	0.0	0.0	0.0
18-19	0.0	0.0	0.0	0.0
19-20	0.0	0.0	0.0	0.0
20-21	0.0	0.0	0.0	0.0
21-22	0.0	0.0	0.0	0.0
22-23	0.0	0.0	0.0	0.0
23-24	0.0	0.0	0.0	0.0
24-25	0.0	0.0	0.0	0.0



Winter Demand

2013 MD **MW** **MVAR**
 10 Jul 2013 00:00 356.0 66.8

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	367.5	75.0	367.5	75.0
2015	0.0	0.0	0.0	0.0
2016	0.0	0.0	0.0	0.0
2017	0.0	0.0	0.0	0.0
2018	0.0	0.0	0.0	0.0
2019	0.0	0.0	0.0	0.0
2020	0.0	0.0	0.0	0.0
2021	0.0	0.0	0.0	0.0
2022	0.0	0.0	0.0	0.0
2023	0.0	0.0	0.0	0.0
2024	0.0	0.0	0.0	0.0



Notes:

For embedded generation details, please see section 3.2.

This is a direct-connect customer. Forecast demand shown here assumes the Anglesea Power Station is switched off at the time of maximum demand. Actual previous year summer and winter generation of Anglesea Power Station at time of maximum demand was zero.





RCTS22: Red Cliffs Terminal Station 22 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 08 Feb 2014 16:00 43.4 6.3



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	46.1	24.2	41.5	21.8
15-16	47.3	24.9	42.5	22.4
16-17	48.6	25.5	43.6	22.9
17-18	49.9	26.2	44.7	23.5
18-19	51.3	27.0	45.9	24.1
19-20	52.7	27.7	46.9	24.7
20-21	54.1	28.4	47.9	25.2
21-22	55.6	29.2	48.6	25.6
22-23	57.1	30.0	49.9	26.2
23-24	58.1	30.6	50.5	26.6
24-25	59.7	31.4	51.5	27.1

Load Curve on High Demand Day***Forecast***

Winter Demand

2013 MD **MW MVAR**
 08 Aug 2013 00:00 22.6 5.8

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	21.5	5.2	20.3	4.9
2015	22.0	5.3	20.8	5.0
2016	22.6	5.5	21.3	5.1
2017	22.9	5.5	21.8	5.3
2018	23.4	5.6	22.3	5.4
2019	23.8	5.7	22.7	5.5
2020	24.7	6.0	23.2	5.6
2021	24.6	5.9	23.5	5.7
2022	25.0	6.0	23.8	5.7
2023	25.6	6.2	24.3	5.9
2024	26.5	6.4	24.9	6.0

Load Curve on High Demand Day***Forecast******Notes:***

This includes only the 22 kV demand at RCTS.

For embedded generation details, please see section 3.2.




RCTS66: Red Cliffs Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 16 Jan 2014 14:00 149.1 53.5


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	159.7	56.3	147.7	52.1
15-16	165.4	58.3	152.9	53.9
16-17	171.3	60.4	158.2	55.8
17-18	177.3	62.5	163.7	57.7
18-19	183.4	64.7	169.3	59.7
19-20	189.7	66.9	175.0	61.7
20-21	196.2	69.2	180.9	63.8
21-22	202.8	71.5	186.9	65.9
22-23	209.5	73.9	193.0	68.1
23-24	213.0	75.1	195.8	69.1
24-25	220.2	77.7	202.4	71.4



Winter Demand

2013 MD **MW** **MVAR**
 10 Jul 2013 00:00 90.5 7.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	82.7	0.8	75.8	0.7
2015	85.4	0.8	78.2	0.7
2016	88.1	0.8	80.6	0.7
2017	90.9	0.8	83.0	0.8
2018	93.6	0.9	85.5	0.8
2019	96.5	0.9	88.0	0.8
2020	99.3	0.9	90.5	0.8
2021	102.1	0.9	93.0	0.9
2022	104.9	1.0	95.4	0.9
2023	107.8	1.0	97.9	0.9
2024	107.2	1.0	96.9	0.9



Notes:

For embedded generation details, please see section 3.2.





RTS22: Richmond Terminal Station 22 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 17 Jan 2014 14:00 69.7 28.4



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	69.0	31.3	64.9	29.5
15-16	58.3	26.5	54.0	24.5
16-17	61.1	27.7	56.7	25.7
17-18	62.9	28.5	57.8	26.2
18-19	63.4	28.8	58.3	26.4
19-20	63.2	28.7	58.0	26.3
20-21	61.5	27.9	56.4	25.6
21-22	61.7	28.0	55.9	25.4
22-23	61.4	27.9	55.6	25.2
23-24	60.6	27.5	54.5	24.7
24-25	60.1	27.3	53.8	24.4

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 09:30 57.8 21.6

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	58.9	20.5	56.9	19.8
2015	48.6	16.9	46.5	16.2
2016	37.1	12.9	34.9	12.1
2017	39.0	13.6	36.7	12.8
2018	39.3	13.7	37.0	12.9
2019	38.7	13.4	36.4	12.6
2020	38.2	13.3	35.7	12.4
2021	35.8	12.4	33.3	11.6
2022	34.4	11.9	31.9	11.1
2023	32.9	11.4	30.5	10.6
2024	32.4	11.3	28.7	10.0

Load Curve on High Demand Day**Forecast****Notes:**

This includes only the 22 kV demand at RTS.

For embedded generation details, please see section 3.2 on page 70.




RTS1266: Richmond Terminal Station 1&2 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 17 Jan 2014 14:00 314.5 70.6


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	337.5	112.4	313.3	104.2
15-16	360.4	119.8	331.6	110.1
16-17	363.7	120.9	334.7	111.1
17-18	358.9	121.1	328.8	110.9
18-19	362.3	122.3	331.6	111.9
19-20	360.8	122.0	331.1	111.9
20-21	359.2	121.6	330.1	111.7
21-22	361.4	122.4	329.9	111.7
22-23	367.1	124.4	331.3	112.3
23-24	363.8	123.5	330.3	112.2
24-25	366.5	124.6	330.6	112.4



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 19:00 231.4 29.9

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	255.0	35.8	242.4	34.0
2015	275.7	38.9	262.6	37.0
2016	293.0	41.4	278.5	39.3
2017	297.2	42.0	282.9	39.9
2018	287.5	41.0	275.0	39.2
2019	289.4	41.2	275.0	39.1
2020	290.8	41.4	276.7	39.3
2021	288.4	41.0	275.7	39.1
2022	288.5	41.0	275.2	39.0
2023	289.7	41.1	275.8	39.1
2024	289.9	41.1	274.2	38.8



Notes:

For embedded generation details, please see section 3.2.

This is the demand on buses 1 and 2, fed by transformers B1 and B4. In previous reports, this location was called RTS14 after the transformers, but it has been renamed by the buses for consistency with other locations.




RTS3466: Richmond Terminal Station 3&4 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 17 Jan 2014 15:00 247.1 47.3


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	259.9	85.1	247.3	81.0
15-16	268.3	87.8	255.2	83.6
16-17	277.2	90.8	262.1	85.9
17-18	277.2	92.4	258.2	86.2
18-19	284.5	94.9	261.3	87.3
19-20	287.2	95.8	263.5	88.0
20-21	291.8	97.3	261.9	87.5
21-22	299.6	99.9	265.1	88.6
22-23	307.1	102.5	268.1	89.6
23-24	314.2	104.8	268.8	89.9
24-25	320.7	107.0	270.5	90.5



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 10:00 169.2 5.6

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	188.7	26.3	172.5	24.0
2015	194.2	27.1	177.8	24.8
2016	198.7	27.7	182.2	25.4
2017	201.1	28.0	184.2	25.7
2018	192.4	27.2	175.7	24.8
2019	193.0	27.3	175.6	24.8
2020	193.2	27.3	177.4	25.1
2021	190.3	26.9	172.8	24.4
2022	188.3	26.6	171.1	24.1
2023	186.3	26.3	169.0	23.8
2024	188.0	26.5	170.4	24.0


Notes:

For embedded generation details, please see section 3.2.

This is the demand on buses 3 and 4, fed by transformers B2 and B3. In previous reports, this location was called RTS23 after the transformers, but it has been renamed by the buses for consistency with other locations.




RTS66: Richmond Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 17 Jan 2014 15:00 560.1 96.2


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	598.8	196.6	561.9	184.5
15-16	630.1	206.8	588.1	193.0
16-17	642.4	210.9	598.1	196.3
17-18	637.7	212.7	588.4	196.4
18-19	648.3	216.3	594.3	198.4
19-20	649.6	216.8	596.0	199.1
20-21	652.6	218.0	593.4	198.4
21-22	662.6	221.4	596.4	199.5
22-23	675.9	225.9	600.9	201.1
23-24	679.7	227.4	600.6	201.2
24-25	688.9	230.5	602.7	202.0



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 10:30 398.3 23.3

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	447.2	61.6	418.6	57.6
2015	473.9	65.5	444.2	61.3
2016	495.7	68.6	464.5	64.2
2017	502.4	69.5	471.0	65.1
2018	484.0	67.7	454.6	63.5
2019	486.6	68.0	454.6	63.4
2020	488.3	68.1	458.1	63.9
2021	482.9	67.3	452.4	63.0
2022	481.1	67.0	450.3	62.6
2023	480.4	66.8	448.9	62.3
2024	482.3	67.0	448.8	62.3



Notes:

For embedded generation details, please see section 3.2.

Please see the comments for RTS12 and RTS34. Load will be transferred to the new Brunswick 66 kV Terminal Station in 2018. This transfer has been modelled in this forecast.




RWTS22: Ringwood Terminal Station 22 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 16:30 85.9 24.2


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	89.2	25.2	82.6	23.6
15-16	89.9	25.4	83.2	23.8
16-17	90.8	25.6	83.8	23.9
17-18	91.5	25.7	84.6	24.1
18-19	92.5	25.9	85.1	24.2
19-20	92.6	26.0	85.5	24.3
20-21	92.9	26.0	85.8	24.3
21-22	93.3	26.1	86.1	24.4
22-23	94.7	26.4	86.9	24.5
23-24	95.3	26.5	87.5	24.7
24-25	95.7	26.6	87.9	24.7



Winter Demand

2013 MD **MW MVAR**
 20 Aug 2013 18:30 62.3 13.3

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	68.0	13.3	64.9	12.8
2015	68.4	13.4	65.2	12.9
2016	69.2	13.5	65.9	12.9
2017	69.5	13.5	66.2	13.0
2018	69.6	13.5	66.3	13.0
2019	69.8	13.5	66.5	13.0
2020	70.2	13.6	66.8	13.0
2021	70.1	13.6	66.6	13.0
2022	70.1	13.5	66.6	13.0
2023	70.4	13.6	66.9	13.0
2024	70.6	13.6	67.1	13.0



Notes:

For embedded generation details, please see section 3.2.

This is the 22 kV supply from RWTS, which is not split into bus groups.





RWTS1366: Ringwood Terminal Station 1&3 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 17 Jan 2014 17:30 278.6 72.8



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	287.8	82.8	256.2	73.7
15-16	289.4	83.3	257.5	74.2
16-17	294.0	84.5	260.9	75.1
17-18	298.9	85.8	265.7	76.3
18-19	304.5	87.2	269.6	77.3
19-20	307.4	88.0	273.4	78.3
20-21	310.8	88.9	276.5	79.1
21-22	314.1	89.8	279.3	79.9
22-23	319.2	91.1	282.3	80.7
23-24	322.9	92.1	285.8	81.6
24-25	326.8	93.1	289.4	82.5

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 18:30 203.6 23.8

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	209.8	26.4	193.7	24.0
2015	211.8	26.6	195.5	24.3
2016	213.3	26.8	196.9	24.4
2017	215.2	27.1	198.6	24.6
2018	217.2	27.3	200.4	24.8
2019	219.3	27.5	202.3	25.0
2020	222.4	27.8	205.2	25.3
2021	223.3	27.9	206.0	25.4
2022	224.6	28.1	207.1	25.6
2023	225.7	28.2	208.0	25.7
2024	227.2	28.4	209.4	25.9

Load Curve on High Demand Day**Forecast****Notes:**

For embedded generation details, please see section 3.2 on page 70.

This is the demand on buses 1 and 3, separated out for planning purposes.




RWTS2466: Ringwood Terminal Station 2&4 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 15 Jan 2014 14:30 215.2 63.0


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	219.6	64.3	204.5	59.9
15-16	220.6	64.6	205.4	60.1
16-17	221.5	64.8	206.3	60.4
17-18	222.0	65.0	206.8	60.5
18-19	223.0	65.3	207.6	60.8
19-20	223.8	65.5	208.4	61.0
20-21	224.6	65.7	209.2	61.2
21-22	225.5	66.0	210.0	61.5
22-23	226.4	66.3	210.8	61.7
23-24	227.3	66.5	211.6	62.0
24-25	228.1	66.8	212.4	62.2



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 10:30 166.9 51.9

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	170.5	53.1	158.8	49.4
2015	171.3	53.3	159.5	49.6
2016	172.0	53.5	160.2	49.8
2017	172.4	53.6	160.6	50.0
2018	173.2	53.9	161.3	50.2
2019	173.8	54.1	161.8	50.4
2020	174.4	54.3	162.4	50.5
2021	175.1	54.5	163.1	50.7
2022	175.8	54.7	163.7	50.9
2023	176.5	54.9	164.4	51.1
2024	177.2	55.1	165.0	51.3



Notes:

For embedded generation details, please see section 3.2.

This is the demand on buses 2 and 4, separated out for planning purposes.





RWTS66: Ringwood Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 17:00 485.4 129.3



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	500.7	131.2	454.6	119.2
15-16	503.2	131.9	456.8	119.8
16-17	508.7	133.3	461.0	120.8
17-18	514.1	134.6	466.2	122.1
18-19	520.7	136.3	471.1	123.3
19-20	524.4	137.2	475.6	124.5
20-21	528.7	138.3	479.5	125.5
21-22	532.9	139.3	483.1	126.4
22-23	538.8	140.8	487.0	127.4
23-24	543.4	142.0	491.2	128.4
24-25	548.2	143.2	495.7	129.6

Load Curve on High Demand Day***Forecast***

Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 18:30 350.3 55.2

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	359.3	58.4	333.1	53.7
2015	361.9	58.8	335.5	54.1
2016	364.0	59.2	337.4	54.4
2017	366.2	59.5	339.4	54.7
2018	368.9	59.8	341.9	55.0
2019	371.5	60.2	344.3	55.3
2020	375.1	60.6	347.7	55.7
2021	376.7	60.9	349.0	56.0
2022	378.6	61.2	350.7	56.2
2023	380.2	61.5	352.1	56.5
2024	382.3	61.8	354.0	56.8

Load Curve on High Demand Day***Forecast*****Notes:**

Please see the comments for RWTS13 and RWTS24.

For embedded generation details, please see section 3.2.




SHTS66: Shepparton Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 16:30 275.4 72.0


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	302.6	87.1	279.5	80.5
15-16	309.4	89.1	284.4	81.9
16-17	315.8	90.9	289.6	83.4
17-18	317.3	91.3	291.5	83.9
18-19	342.2	98.5	318.3	91.6
19-20	342.6	98.6	314.8	90.6
20-21	342.0	98.5	313.7	90.3
21-22	346.2	99.7	318.7	91.8
22-23	350.7	101.0	322.1	92.7
23-24	353.8	101.9	322.2	92.8
24-25	356.4	102.6	325.2	93.6



Winter Demand

2013 MD **MW MVAR**
 08 Jul 2013 00:00 191.0 -1.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	184.3	15.6	179.1	15.2
2015	181.6	15.4	176.7	15.0
2016	185.5	15.8	180.4	15.3
2017	187.7	15.9	183.1	15.5
2018	190.4	16.2	185.1	15.7
2019	210.5	17.9	205.5	17.4
2020	212.4	18.0	207.0	17.6
2021	212.5	18.0	207.2	17.6
2022	212.4	18.0	207.1	17.6
2023	213.6	18.1	208.2	17.7
2024	215.1	18.3	208.6	17.7



Notes:

For embedded generation details, please see section 3.2.





SMTS66: South Morang Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 13 Jan 2014 17:00 284.7 62.9



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	291.5	64.7	273.8	61.0
15-16	296.5	66.2	278.4	62.2
16-17	306.9	68.6	288.1	64.6
17-18	317.9	71.1	298.2	66.8
18-19	328.8	73.5	308.2	69.0
19-20	340.1	76.1	318.6	71.4
20-21	351.3	78.6	328.9	73.7
21-22	362.6	81.2	339.7	76.2
22-23	374.7	84.0	350.4	78.6
23-24	385.7	86.5	360.4	80.8
24-25	397.0	89.0	370.5	83.1

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD **MW MVAR**
 14 May 2013 19:00 209.5 25.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	197.7	24.8	186.8	23.7
2015	201.2	25.5	190.3	24.4
2016	208.5	26.5	197.1	25.4
2017	215.8	27.4	204.0	26.2
2018	223.1	28.3	210.8	27.1
2019	230.7	29.3	218.0	28.1
2020	238.3	30.3	225.1	29.0
2021	246.2	31.4	232.5	30.0
2022	254.1	32.4	239.8	31.0
2023	261.4	33.3	246.7	31.8
2024	268.8	34.2	253.6	32.7

Load Curve on High Demand Day**Forecast****Notes:**

For embedded generation details, please see section 3.2.

Somerton Power Station is assumed to be switched off at the time of maximum demand for forecasts, and is not netted off actual previous year summer and winter generation.




SVTS1266: Springvale Terminal Station buses 1&2 66 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 16 Jan 2014 14:00 249.2 55.4


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	257.2	57.2	232.2	51.6
15-16	259.3	57.6	233.8	52.0
16-17	267.6	59.5	239.5	53.2
17-18	276.3	61.4	248.3	55.2
18-19	287.1	63.8	255.5	56.8
19-20	291.8	64.9	262.4	58.3
20-21	294.5	65.5	264.9	58.9
21-22	297.5	66.1	267.0	59.4
22-23	306.5	68.1	271.9	60.4
23-24	310.7	69.1	275.9	61.3
24-25	315.3	70.1	280.4	62.3



Winter Demand

2013 MD **MW** **MVAR**
 09 Aug 2013 12:00 176.3 48.4

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	187.3	51.4	182.6	50.1
2015	173.7	47.7	169.9	46.6
2016	175.2	48.1	171.2	47.0
2017	176.8	48.6	172.7	47.4
2018	178.4	49.0	174.2	47.8
2019	179.3	49.2	174.9	48.0
2020	179.9	49.4	175.4	48.2
2021	179.9	49.4	175.2	48.1
2022	179.7	49.3	174.8	48.0
2023	180.1	49.4	175.1	48.1
2024	182.3	50.1	177.2	48.7


Notes:

For embedded generation details, please see section 3.2.

This is the demand on buses 1 and 2, separated out for planning purposes.




SVTS3466: Springvale Terminal Station buses 3&4 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 18:00 203.6 16.2


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	219.2	33.2	194.8	29.2
15-16	224.2	34.0	198.9	29.8
16-17	234.0	35.4	206.4	30.9
17-18	243.2	36.8	214.9	32.1
18-19	253.2	38.2	221.5	33.0
19-20	258.5	39.0	228.2	33.9
20-21	261.8	39.6	231.0	34.4
21-22	265.2	40.2	233.4	34.8
22-23	273.5	41.4	238.3	35.5
23-24	277.6	42.0	241.9	36.1
24-25	282.2	42.8	246.0	36.7



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 18:00 136.0 5.4

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	146.8	20.8	142.8	20.2
2015	148.0	21.0	144.3	20.4
2016	149.8	21.3	145.9	20.7
2017	150.9	21.4	146.9	20.8
2018	151.1	21.4	147.1	20.8
2019	150.9	21.3	146.6	20.6
2020	150.9	21.3	146.4	20.6
2021	149.8	21.0	145.2	20.3
2022	148.8	20.8	144.1	20.1
2023	148.1	20.7	143.3	19.9
2024	148.6	20.6	143.5	19.9


Notes:

For embedded generation details, please see section 3.2.

This is the demand on buses 3 and 4, separated out for planning purposes.





SVTS66: Springvale Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 18:00 447.4 61.5



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	474.1	90.6	425.1	81.1
15-16	481.1	92.1	430.8	82.2
16-17	499.1	95.5	443.8	84.7
17-18	517.0	98.9	461.1	87.9
18-19	537.8	102.8	475.0	90.5
19-20	547.7	104.7	488.5	93.1
20-21	553.6	105.9	493.7	94.1
21-22	559.9	107.2	498.3	95.0
22-23	577.1	110.4	507.9	96.9
23-24	585.5	112.0	515.5	98.3
24-25	594.6	113.8	524.1	100.0

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 11:00 310.1 54.7

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	329.0	64.1	320.4	62.4
2015	316.7	61.7	309.3	60.3
2016	319.9	62.3	312.2	60.8
2017	322.6	62.9	314.7	61.3
2018	324.6	63.2	316.5	61.6
2019	325.4	63.4	317.0	61.7
2020	326.1	63.5	317.4	61.8
2021	325.3	63.3	316.2	61.6
2022	324.1	63.1	314.9	61.3
2023	324.0	63.1	314.5	61.2
2024	327.1	63.6	317.1	61.7

Load Curve on High Demand Day**Forecast**
Notes:

For embedded generation details, please see section 3.2.




TBTS66: Tyabb Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 17:30 290.0 79.2


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	297.8	81.4	267.8	73.2
15-16	295.4	80.7	265.6	72.6
16-17	302.7	82.7	272.2	74.4
17-18	311.2	85.0	279.8	76.5
18-19	321.9	87.9	289.4	79.1
19-20	325.7	89.0	292.9	80.0
20-21	329.3	90.0	296.1	80.9
21-22	336.2	91.8	302.3	82.6
22-23	345.6	94.4	310.7	84.9
23-24	355.6	97.1	319.8	87.4
24-25	362.7	99.1	326.1	89.1



Winter Demand

2013 MD **MW MVAR**
 09 Jun 2013 18:30 187.0 35.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	204.9	38.5	197.7	37.1
2015	209.7	39.4	202.2	38.0
2016	215.2	40.4	207.4	38.9
2017	220.9	41.5	212.8	40.0
2018	226.3	42.5	217.8	40.9
2019	231.0	43.4	222.2	41.7
2020	235.3	44.2	226.3	42.5
2021	239.5	45.0	230.1	43.2
2022	243.9	45.8	234.3	44.0
2023	249.2	46.8	239.2	44.9
2024	254.5	47.8	244.2	45.9



Notes:

For embedded generation details, please see section 3.2.




TGTS66: Terang Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 17:30 186.4 42.4


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	224.5	58.8	194.6	51.0
15-16	236.7	62.0	205.6	53.9
16-17	242.6	63.6	210.2	55.1
17-18	258.7	67.8	225.0	59.0
18-19	264.1	69.2	229.1	60.0
19-20	269.7	70.7	233.3	61.1
20-21	272.5	71.4	234.6	61.5
21-22	274.8	72.0	235.5	61.7
22-23	276.9	72.5	236.0	61.8
23-24	278.6	73.0	236.1	61.9
24-25	281.2	73.7	237.2	62.1



Winter Demand

2013 MD **MW MVAR**
 08 Jul 2013 00:00 182.3 3.3

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	197.7	25.7	190.4	24.8
2015	194.6	25.3	188.1	24.4
2016	203.4	26.4	196.0	25.5
2017	206.8	26.9	199.4	25.9
2018	219.8	28.6	212.0	27.6
2019	220.5	28.7	212.3	27.6
2020	219.4	28.5	211.4	27.5
2021	213.8	27.8	206.1	26.8
2022	210.0	27.3	201.4	26.2
2023	206.3	26.8	197.4	25.7
2024	201.3	26.2	192.8	25.1



Notes:

For embedded generation details, please see section 3.2.




TSTS66: Templestowe Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 18:00 347.5 101.3


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	363.6	116.0	315.1	100.7
15-16	367.4	117.3	317.8	101.7
16-17	374.8	119.7	322.4	103.2
17-18	382.8	122.3	328.9	105.3
18-19	388.2	124.0	332.0	106.3
19-20	390.5	124.8	335.1	107.3
20-21	393.6	126.0	336.4	107.8
21-22	396.4	126.9	338.2	108.5
22-23	404.2	129.4	341.9	109.7
23-24	407.2	130.5	343.9	110.4
24-25	410.4	131.6	345.9	111.4



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 18:30 244.8 34.8

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	254.7	42.3	240.0	39.8
2015	256.1	42.6	241.9	40.1
2016	259.0	43.1	243.9	40.5
2017	260.9	43.3	245.8	40.7
2018	262.6	43.5	247.5	40.9
2019	263.3	43.5	247.8	40.9
2020	265.1	43.7	249.3	41.0
2021	263.2	43.4	247.0	40.6
2022	262.4	43.2	246.2	40.4
2023	261.7	42.9	245.4	40.1
2024	260.9	42.7	243.9	39.7



Notes:

For embedded generation details, please see section 3.2.




TTS1266: Thomastown Terminal Station 1&2 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 16:00 244.4 15.6


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	248.9	40.8	228.6	37.6
15-16	250.5	40.9	229.7	37.6
16-17	253.9	41.4	232.9	38.1
17-18	256.0	41.6	234.6	38.2
18-19	258.3	41.8	236.5	38.4
19-20	260.9	42.2	238.7	38.6
20-21	263.0	42.4	240.5	38.8
21-22	264.7	42.6	242.4	39.1
22-23	267.1	43.0	244.0	39.3
23-24	269.2	43.2	245.6	39.4
24-25	271.2	43.5	247.1	39.5



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 10:00 182.5 9.9

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	187.1	23.8	175.2	22.6
2015	188.0	23.9	176.0	22.7
2016	190.6	24.2	178.4	23.0
2017	191.9	24.3	179.7	23.0
2018	193.5	24.4	181.1	23.2
2019	195.3	24.6	182.8	23.3
2020	196.7	24.7	184.1	23.5
2021	198.2	24.9	185.5	23.6
2022	199.5	25.0	186.7	23.8
2023	200.8	25.1	187.9	23.8
2024	202.0	25.2	189.0	23.9


Notes:

For embedded generation details, please see section 3.2.

This is the demand on buses 1 and 2, separated out for planning purposes.





TTS3466: Thomastown Terminal Station 3&4 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 15:30 250.3 111.2



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	266.2	124.0	245.6	114.4
15-16	266.6	124.2	244.7	114.0
16-17	258.7	120.6	236.2	110.1
17-18	259.3	120.8	235.7	109.8
18-19	260.0	121.1	235.4	109.7
19-20	261.7	122.0	236.2	110.0
20-21	262.9	122.5	236.3	110.1
21-22	263.6	122.8	237.2	110.5
22-23	266.1	124.0	237.8	110.8
23-24	267.2	124.5	237.4	110.6
24-25	268.2	125.0	237.1	110.5

Load Curve on High Demand Day***Forecast***

Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 10:30 214.3 88.3

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	223.5	91.9	215.9	88.8
2015	222.7	91.6	215.2	88.5
2016	215.0	88.4	207.7	85.4
2017	214.5	88.2	207.2	85.3
2018	214.2	88.1	207.0	85.2
2019	214.9	88.4	207.6	85.4
2020	215.1	88.5	207.8	85.5
2021	215.9	88.8	208.6	85.8
2022	216.4	89.0	209.1	86.0
2023	216.1	88.9	208.8	85.9
2024	215.7	88.8	208.5	85.8

Load Curve on High Demand Day***Forecast******Notes:***

For embedded generation details, please see section 3.2.

This is the demand on buses 3 and 4, separated out for planning purposes.





TTS66: Thomastown Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 16:00 493.2 127.0



Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	511.1	163.6	470.5	150.9
15-16	513.1	163.9	470.8	150.5
16-17	508.7	160.8	465.5	147.1
17-18	511.4	161.3	466.7	146.9
18-19	514.4	161.8	468.4	147.0
19-20	518.6	162.9	471.2	147.6
20-21	521.8	163.7	473.1	147.8
21-22	524.2	164.2	475.9	148.5
22-23	529.1	165.8	478.1	149.0
23-24	532.2	166.5	479.3	148.9
24-25	535.2	167.2	480.4	148.9

Load Curve on High Demand Day**Forecast**

Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 10:00 396.5 98.0

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	407.4	114.9	388.1	110.6
2015	407.5	114.6	388.2	110.3
2016	402.4	111.7	383.2	107.5
2017	403.3	111.6	383.9	107.4
2018	404.6	111.7	385.2	107.5
2019	407.0	112.1	387.4	107.9
2020	408.6	112.3	388.9	108.1
2021	410.9	112.8	391.1	108.6
2022	412.8	113.2	392.8	108.9
2023	413.7	113.1	393.6	108.9
2024	414.5	113.1	394.4	108.8

Load Curve on High Demand Day**Forecast****Notes:**

Please see the comments for TTS12 and TTS34

For embedded generation details, please see section 3.2.




WETS66: Wemen Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 01 Feb 2014 17:00 46.3 7.1


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	51.0	6.6	50.4	6.6
15-16	47.1	6.1	46.5	6.1
16-17	47.2	6.2	46.6	6.1
17-18	47.3	6.2	46.6	6.1
18-19	47.3	6.2	46.7	6.1
19-20	47.3	6.2	46.6	6.1
20-21	47.3	6.2	46.6	6.1
21-22	47.2	6.2	46.5	6.1
22-23	47.1	6.1	46.3	6.0
23-24	43.5	5.7	42.7	5.6
24-25	44.1	5.8	43.3	5.6



Winter Demand

2013 MD **MW MVAR**
 27 Aug 2013 16:00 20.1 -1.2

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	20.9	-3.0	20.2	-2.9
2015	21.2	-3.0	20.4	-2.9
2016	17.5	-2.5	16.6	-2.4
2017	17.7	-2.5	16.8	-2.4
2018	17.9	-2.6	17.0	-2.4
2019	18.1	-2.6	17.2	-2.5
2020	18.2	-2.6	17.3	-2.5
2021	18.4	-2.6	17.4	-2.5
2022	18.4	-2.6	17.4	-2.5
2023	18.5	-2.7	17.4	-2.5
2024	15.1	-2.2	14.0	-2.0



Notes:

For embedded generation details, please see section 3.2.




WMTS22: West Melbourne Terminal Station 22 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 16 Jan 2014 11:30 90.1 45.6


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	93.6	46.4	87.6	43.4
15-16	97.3	48.3	91.1	45.2
16-17	101.0	50.1	94.6	46.9
17-18	104.6	51.9	97.8	48.5
18-19	107.9	53.5	100.9	50.0
19-20	110.8	54.9	103.5	51.3
20-21	113.6	56.3	106.0	52.6
21-22	115.9	57.5	108.0	53.6
22-23	117.5	58.3	109.3	54.2
23-24	118.3	58.7	109.8	54.5
24-25	120.9	60.0	112.1	55.6



Winter Demand

2013 MD **MW MVAR**
 10 Jul 2013 09:30 72.9 29.1

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	87.8	33.7	84.4	32.4
2015	75.7	29.1	72.2	27.7
2016	78.8	30.2	75.1	28.9
2017	81.7	31.4	77.9	29.9
2018	84.5	32.4	80.6	30.9
2019	87.0	33.4	82.9	31.8
2020	89.0	34.2	84.8	32.6
2021	91.0	34.9	86.5	33.2
2022	92.4	35.5	87.8	33.7
2023	93.1	35.7	88.3	33.9
2024	92.9	35.7	87.9	33.8



Notes:

This includes only the 22 kV demand at WMTS.

For embedded generation details, please see section 3.2.




WMTS66: West Melbourne Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 17 Jan 2014 15:30 424.5 86.1


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	500.0	140.3	462.5	129.8
15-16	552.5	155.2	513.4	144.3
16-17	425.2	140.9	388.9	130.1
17-18	358.7	134.8	321.8	123.4
18-19	373.0	139.5	328.9	126.1
19-20	390.3	144.7	333.4	127.7
20-21	402.5	148.5	338.2	129.4
21-22	417.0	153.1	343.4	131.3
22-23	429.6	157.4	349.6	133.8
23-24	440.5	161.2	354.5	135.8
24-25	452.6	165.3	358.1	137.6



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 11:30 318.1 20.6

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	332.0	56.2	319.8	54.2
2015	342.7	57.9	328.2	55.6
2016	382.7	64.2	371.6	62.3
2017	284.0	54.6	275.4	52.9
2018	227.3	49.4	214.3	47.0
2019	229.9	49.9	218.4	47.7
2020	230.8	50.0	221.8	48.2
2021	233.7	50.5	224.6	48.7
2022	235.0	50.7	226.6	49.0
2023	245.9	52.4	227.9	49.2
2024	253.1	53.7	231.7	49.9



Notes:

For embedded generation details, please see section 3.2.

Load will be transferred to the future Brunswick 66 kV Terminal Station in 2017. This transfer has been modelled in this forecast.




WOTS22: Wodonga Terminal Station 22 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 03 Feb 2014 17:00 35.0 5.3


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	36.3	5.5	35.0	5.3
15-16	36.3	5.5	35.1	5.3
16-17	36.4	5.5	35.2	5.3
17-18	36.7	5.6	35.5	5.4
18-19	36.9	5.6	35.6	5.4
19-20	36.9	5.6	35.6	5.4
20-21	36.9	5.6	35.7	5.4
21-22	37.0	5.6	35.7	5.4
22-23	37.0	5.6	35.7	5.4
23-24	37.0	5.6	35.7	5.4
24-25	37.0	5.6	35.7	5.4



Winter Demand

2013 MD **MW** **MVAR**
 18 Oct 2013 07:00 27.1 -0.6

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	28.1	-0.6	27.1	-0.6
2015	28.2	-0.6	27.2	-0.6
2016	28.3	-0.6	27.3	-0.6
2017	28.5	-0.6	27.5	-0.6
2018	28.6	-0.6	27.6	-0.6
2019	28.6	-0.6	27.6	-0.6
2020	28.6	-0.6	27.7	-0.6
2021	28.7	-0.6	27.7	-0.6
2022	28.7	-0.6	27.7	-0.6
2023	28.7	-0.6	27.7	-0.6
2024	28.7	-0.6	27.7	-0.6



Notes:

This includes only the 22 kV demand at WOTS.

For embedded generation details, please see section 3.2.




WOTS66: Wodonga Terminal Station 66 kV bus

Summer Demand

2013-14 MD **MW MVAR**
 03 Feb 2014 16:00 57.8 21.2


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	63.2	23.2	60.8	22.3
15-16	63.5	23.3	61.1	22.4
16-17	63.7	23.4	61.3	22.5
17-18	63.9	23.4	61.5	22.5
18-19	64.0	23.4	61.6	22.6
19-20	64.1	23.5	61.7	22.6
20-21	64.2	23.5	61.8	22.6
21-22	64.2	23.5	61.8	22.7
22-23	64.3	23.6	61.9	22.7
23-24	64.4	23.6	62.0	22.7
24-25	64.5	23.6	62.1	22.7



Winter Demand

2013 MD **MW MVAR**
 24 Jun 2013 18:00 46.9 1.3

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	49.4	1.4	47.6	1.3
2015	49.7	1.4	47.8	1.4
2016	49.8	1.4	48.0	1.4
2017	50.0	1.4	48.1	1.4
2018	50.0	1.4	48.2	1.4
2019	50.1	1.4	48.2	1.4
2020	50.2	1.4	48.3	1.4
2021	50.3	1.4	48.4	1.4
2022	50.3	1.4	48.4	1.4
2023	50.4	1.4	48.5	1.4
2024	50.4	1.4	48.6	1.4



Notes:

For embedded generation details, please see section 3.2.

Hume Power Station is assumed to be switched off at the time of maximum demand for forecasts and is not netted off actual previous year summer and winter generation.




YPS11: Yallourn PS Terminal Station 11 kV bus

Summer Demand

2013-14 MD **MW** **MVAR**
 10 Feb 2014 00:30 13.8 -3.2


Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
14-15	13.8	-3.2	13.8	-3.2
15-16	13.8	-3.2	13.8	-3.2
16-17	13.8	-3.2	13.8	-3.2
17-18	13.8	-3.2	13.8	-3.2
18-19	13.8	-3.2	13.8	-3.2
19-20	13.8	-3.2	13.8	-3.2
20-21	13.8	-3.2	13.8	-3.2
21-22	13.8	-3.2	13.8	-3.2
22-23	13.8	-3.2	13.8	-3.2
23-24	13.8	-3.2	13.8	-3.2
24-25	13.8	-3.2	13.8	-3.2



Winter Demand

2013 MD **MW** **MVAR**
 24 May 2013 15:30 4.7 -1.7

Year	10% POE		50% POE	
	MW	MVAR	MW	MVAR
2014	4.7	-1.7	4.7	-1.7
2015	4.7	-1.7	4.7	-1.7
2016	4.7	-1.7	4.7	-1.7
2017	4.7	-1.7	4.7	-1.7
2018	4.7	-1.7	4.7	-1.7
2019	4.7	-1.7	4.7	-1.7
2020	4.7	-1.7	4.7	-1.7
2021	4.7	-1.7	4.7	-1.7
2022	4.7	-1.7	4.7	-1.7
2023	4.7	-1.7	4.7	-1.7
2024	4.7	-1.7	4.7	-1.7



Notes:

#N/A

For embedded generation details, please see section 3.2.



3. METHODOLOGY

This section describes the methodology used to develop the terminal station demand forecasts. Where relevant, it provides methodology details for specific terminal stations.

The demand forecasts are compiled by AEMO from forecasts provided by Victorian participants (DNSPs and direct-connect customers), and reflect participant expectations of future demand. These forecasts are not developed by AEMO.

3.1 Date ranges and times

Summer 2013–14 is defined as 1 November 2013 to 30 April 2014.

Winter 2013 is defined as 1 May 2013 to 31 October 2013.

Demand values are based on 30-minute energy forecasts. Where an interval time is noted, it refers to the end time of the 30-minute interval.

Time-of-day is Australian Eastern Standard Time (EST). Daylight Saving Time is not used.

3.2 Embedded generation

The actual demands shown for summer 2013–14 and winter 2013 at a connection point represents the total of the following:

- Customer demand connected to the distribution networks.
- Losses in the distribution networks.
- A deduction representing generation from generators embedded in the distribution networks.

The forecasts assume that relatively large embedded generators will be modelled separately, and that they are switched off at times of maximum demand (MD). This applies to the following generators:

- Morwell Power Station units G1-3.
- Clover Power Station.
- Hume Power Station.
- Somerton Power Station.
- Bairnsdale Power Station.
- Anglesea Power Station.

Table 2 describes the treatment of each smaller embedded generator in the forecasts. The final two columns provide the assumed embedded generation at the time of peak demand; the forecast values have been reduced by this amount. Some terminal stations have multiple rows, for example for split bus group locations.

Table 2 Terminal station and bus locations

Location	Location type	Voltage (kV)	Generator	Operating characteristics	Summer forecast load offset (MW)	Winter forecast load offset (MW)
ATS_BLTS	Hybrid	66	Qenos cogenerator	Daily	0.05	21.46
ATS_WEST	Hybrid	66	Boral and Wyndham Landfill and Werribee Treatment Plant	Daily	7.39	5.14
BATS	Entire	66	Challicum Hills Wind Farm	Wind dependent	0.06	0
BATS	Entire	66	Ballarat Hospital cogenerator	Sporadic	0	0
BATS	Entire	66	Charles Piggery	n.a	n.a	n.a
BATS	Entire	66	Smythesdale Tip cogenerator	Daily	0.42	0.49
BATS	Entire	66	Leonard's Hill Wind Farm	Wind dependent	0.00	0.06



Location	Location type	Voltage (kV)	Generator	Operating characteristics	Summer forecast load offset (MW)	Winter forecast load offset (MW)
CBTS	Entire	66	South Eastern Purification Plant	As required by the customer	0	0
ERTS	Entire	66	Berwick Tip	Daily	5.15	5.15
ERTS	Entire	66	Cardinia	Daily	3.8	3.8
ERTS	Entire	66	Hallam Tip	Daily	6.6	6.6
ERTS	Entire	66	Dandenong Hospital (likely to have 5 MW generation during peak demand)	7 AM to 11 PM, Mon to Fri	0	0
ERTS	Entire	66	Dandenong PEP (likely to have 2 MW generation during peak demand)	7 AM to 11 PM, Mon to Fri	0	0
ERTS34	Split Bus	66	Dandenong Hospital (likely to have 5 MW generation during peak demand)	7 AM to 11 PM, Mon to Fri	0	0
ERTS34	Split Bus	66	Dandenong PEP (likely to have 2 MW generation during peak demand)	7 AM to 11 PM, Mon to Fri	0	0
FBTS	Entire	66	Crown Casino	n.a	n.a	n.a
FBTS	Entire	66	ANZ	n.a	n.a	n.a
FBTS	Entire	66	Next DC	n.a	n.a	n.a
GNTS	Entire	66	Lake William Hovell	Seasonal	0.3	1.6
GTS	Entire	66	Corio Tip cogenerator	Daily	0.50	1.0
GTS	Entire	66	Geelong Hospital export	Daily	n.a	n.a
GTS	Entire	66	Breamlea Wind Generator	Wind dependent	n.a	n.a
GTS	Entire	66	Shell Refinery Corio (SRC)	n.a	n.a	n.a
HOTS	Entire	66	Challicum Hills Wind Farm (CHW)	Wind dependant	0.06	0.00
MWTS	Entire	66	Blue Rock Dam	Daily	2.8	2.8
MWTS	Entire	66	Thompson Dam	Daily	7.6	7.6
MWTS	Entire	66	Lake Glenmaggie	Daily	3.8	3.8
MWTS	Entire	66	Toora Wind Farm	Wind related	21	21
MWTS	Entire	66	Wonthaggi Wind Farm	Wind related	12	12
RCTS	Entire	22	Mildura Solar CPV Power Station	Concentrated PV	n.a	n.a
RCTS	Entire	22	Mildura Solar Park #1 (Thurla)	Solar PV	0	0
RTS	Entire	66	St Vincent Hospital	n.a	4.5	3.2
RTS	Entire	66	Alfred Hospital	n.a	4.9	0
RTS12	Split Bus	66	St Vincent Hospital	n.a	4.5	3.2
RTS34	Split Bus	66	Alfred Hospital	n.a	4.9	0
RWTS13	Split Bus	66	Olinda Creek Hydro	Daily	1	1
RWTS13	Split Bus	66	Upper Yarra Hydro	Daily	1	1
RWTS13	Split Bus	66	Silvan Inlet Hydro	Daily	1.8	1.8
SHTS	Entire	66	Tatura Biomass	Biomass	0.52	0
SHTS	Entire	66	Shepparton Wastewater Treatment Facility	Biomass	n.a	n.a
SHTS	Entire	66	Lake Mulwala Hydro	Daily	6.98	1.67
SMTS	Entire	66	Wollert Tip	Daily	4.4	4.4
SMTS	Entire	66	Eildon Pondage	Seasonal	3.8	0
SVTS	Entire	66	Springvale Landfill (likely to have 2 MW generation during peak demand)	7 AM to 11 PM, Mon to Fri	0	0
SVTS	Entire	66	Clayton Landfill (likely to have 5 MW generation during peak demand)	7 AM to 11 PM, Mon to Fri	0	0
SVTS12	Split Bus	66	Springvale Landfill (likely to have 2 MW generation during peak demand)	7 AM to 11 PM, Mon to Fri	0	0



Location	Location type	Voltage (kV)	Generator	Operating characteristics	Summer forecast load offset (MW)	Winter forecast load offset (MW)
SVTS12	Split Bus	66	Clayton Landfill (likely to have 5 MW generation during peak demand)	7 AM to 11 PM, Mon to Fri	0	0
TGTS	Entire	66	Codrington Wind Farm (CWF)	Wind dependant	2.76	2.62
TGTS	Entire	66	Yambuk Wind Farm (YWF)	Wind dependant	2.85	3.35
TGTS	Entire	66	Oakland's Hill Wind Farm (OWF)	Wind dependant	0	4.21
TGTS	Entire	66	Morton's Lane Wind Farm (MLW)	Wind dependant	0	5.04
WMTS	Entire	22	Royal Children's Hospital	n.a	n.a	n.a
WMTS	Entire	22	Royal Melbourne Hospital	n.a	n.a	n.a
WMTS	Entire	22	Channel 7	n.a	n.a	n.a

n.a: not available.

3.3 Capacitance and reactance

Reactive loading forecasts are the reactive loading levels that licensed distribution areas are expected to impose on locations. They incorporate the reactive losses of the distribution network, including any reactors, and are offset by line and cable charging and those capacitors in the distribution network assessed by participants (DNSPs and direct-connect customers) as being in service at the relevant time. Terminal station capacitors, compensators, reactors, and transformation reactive losses are not considered as part of the demand.

3.4 Demand diversity

3.4.1 Terminal station diversity

Where more than one participant connects to a connection point, a participant's MD may not occur at the same time as the connection point as a whole. AEMO refers to this as diversity between participant MD and connection point MD. This diversity is represented by a "terminal station diversity factor", which is a number between zero and one.

AEMO calculates a terminal station diversity factor based on metered historical demand at the connection point. This is then agreed with the participant. To obtain an aggregate demand forecast for each connection point, demand forecasts contributed by participants are multiplied by the terminal station diversity factor before being summed.

Where only one participant connects to a connection point, demand forecasts are presented as provided by the participant.

3.4.2 System diversity

Points of connection typically do not experience MD at the same time. To obtain an aggregate demand forecast for Victoria as a whole, AEMO allows for this diversity between points of connection.

AEMO determines a "system diversity factor" by following a process similar to that for the terminal station diversity factor, but based on historical times of high demand for Victoria as a whole.



4. VICTORIAN MAXIMUM DEMAND FORECASTS

This section compares the aggregate total of the terminal station demand forecasts with AEMO's regional forecasts (summer and winter) for Victoria in the 2014 National Electricity Forecast Report (NEFR).³ This comparison is undertaken for coincident forecasts.

4.1 NEFR forecast

AEMO's NEFR MD forecasts are determined using a "top-down" approach, based on the following factors:

- Historical electricity demand.
- Economic and demographic forecasts.
- Drivers of future changes in demand, such as rooftop photo voltaic (PV) PV and energy efficiency.
- AEMO obtains electricity demand forecasts directly from large industrial customers and TNSPs or DNSPs. Information on the forecasts and the methodology used is available in the NEFR and the Forecasting Methodology Information Paper.⁴

4.2 TSDF system forecast

AEMO derives an overall Victorian forecast from the individual participant forecasts at 10% and 50% POE for summer and winter using the following steps:

1. Multiply each participant's points of connection demand forecasts by the relevant system diversity factor to produce terminal station demand forecasts for the time of system MD (see Section 3, Methodology).
2. Aggregate these system-diversified participant demand forecasts.
3. Eliminate double-counting, such as split bus groups within a single connection point and Loy Yang Switching Station within Morwell Terminal Station.
4. Adjust the overall forecast by adding forecast transmission losses and generator auxiliaries.

4.3 Summer MD


Figure 1 compares TSDF system forecast (as described in section 4.2) and the 2014 NEFR summer MD forecasts at 10% and 50% POE. It shows that summer TSDF forecast demand exceeds the NEFR forecast.

For 10% POE, the difference is an increase from 821 MW (approximately 8% of the NEFR regional total) in 2014–15 to 2,881 MW (approximately 28.1%) in 2024–25.

For 50% POE, the difference is an increase from 1,243 MW (approximately 14% of the NEFR regional total) to 2,824 MW (approximately 32.9%) in 2024–25.

³ AEMO. 2014 National Electricity Forecasting Report
Available at: <http://www.aemo.com.au/Electricity/Planning/Forecasting>. Viewed 17/9/2014.

⁴ AEMO. 2014 Forecasting methodology information paper
Available at: <http://www.aemo.com.au/Electricity/Planning/Forecasting/National-Electricity-Forecasting-Report/NEFR-Supplementary-Information>. Viewed 17/09/2014.

**Figure 1 TSDF and NEFR summer MD forecasts**


4.4 Winter MD

Figure 2 compares TSDF system forecast and NEFR winter MD forecasts at the 10% POE and 50% POE levels. Overall, winter NEFR forecasts is less than the TSDF forecasts.

For 10% POE, the difference is an increase from 70 MW (approximately 0.8% of the NEFR regional total) in 2014 to 439 MW (approximately 5%) in 2024.

For 50% POE, the difference is an increase from 73 MW (approximately 0.9% of the NEFR regional total) in 2014 to 407 MW (approximately 4.9%) in 2024.

Demand is forecast to reduce from winter 2014 due to the closure of Alcoa's Point Henry smelter. The smelter closed on 31 July 2014 and had a capacity of around 370 MW.

**Figure 2 TSDF and NEFR winter MD forecasts**

4.5 Difference between the NEFR and TSDF forecasts

Differences between the NEFR forecasts and the aggregated TSDF forecasts are partly due to the different methods used to develop them.

The NEFR focusses on forecasting total regional demand for each NEM region (including Victoria), whereas the TSDF uses local information to develop forecasts for each connection point. The TSDF is aggregated to a system total for comparative purposes only.

4.5.1 Summer

The TSDF 2014 summer forecast grows at an annual average of 1.6% for 50% POE throughout the forecast horizon. By comparison, the NEFR 50% POE growth rate for the same period is 0.06%. This difference is influenced by different forecasts for rooftop PV, energy efficiency, and economic and demographic assumptions.



4.5.2 Winter

Differences between the NEFR and the TSDF are smaller for winter than for summer. Winter MD levels are generally more stable than summer levels, as they are less subject to extreme weather events. Also, rooftop PV makes no contribution to the NEFR winter MD forecast, because winter MD typically occurs after sunset.

4.6 Reactive demand forecasts

Figure 3 and Figure 4 show the aggregate reactive demand forecasts to be drawn from terminal station points of connection (usually stations' lower voltage terminals) at times of Victorian system maximum summer and winter active power demand. The higher levels of motorised cooling demand in summer are considered mainly responsible for the higher reactive demand in summer compared to winter.

Power factor calculations indicate little change over the forecast horizon, regardless of POE or season.

**Figure 3 Summer MD reactive demand forecast****Figure 4 Winter MD reactive demand forecast**



5. ACTUAL DEMAND AND PREVIOUS FORECAST COMPARISONS

5.1 Summer MD

AEMO assessed the temperature conditions at time of Victorian MD during 2013–14. The highest summer half-hourly demand of 10,313 MW occurred at 4:30 PM Australian EST on Tuesday, 28 January 2014. On that day maximum temperatures in Melbourne reached 42 °C. For more information on the actual summer MD level, see the 2014 NEFR Demand Review.⁵

At the time of this year's MD, the most recent TSDF was the 2013 report, which covers 2013–14 to 2023–24.

Figure 5 and Figure 6 compare the unadjusted MD against the TSDF 2013 forecast demand for summer 2013–14 for each connection point.

For many locations, actual MD was less than the 2013 50% POE forecast. Summer MD rose compared to 2012–13 due to warmer weather. Despite this growth in summer MD, average demand has continued to decline; most likely due to increased energy efficiency standards and greater penetration of rooftop PV.

5.2 Winter MD


AEMO assessed the temperature conditions for the 2013 winter MD, recorded as 7,930 MW at 5:30 PM Australian EST on 24 June 2013.

Figure 7 and Figure 8 compare the unadjusted actual MD against the TSDF 2013 forecast demand for winter 2013 for each connection point.

5.3 Chart notes

For brevity, the following charts present only the “entire station” locations, not their split bus locations (if they exist). In the 2013 TSDF, some of these stations were not forecast as “entire stations”; the forecasts are zero in such cases.

Figure 5 Summer MD actual and forecast comparison by location



⁵ AEMO 2014 NEFR Demand Review

Available at: <http://www.aemo.com.au/Electricity/Planning/Forecasting/National-Electricity-Forecasting-Report/NEFR-Supplementary-Information>. Viewed 17/09/2014.




**Figure 6 Summer MD actual and forecast reactive demand comparison by location****Figure 7 Winter MD actual and forecast comparison by location**

Figure 8 Winter MD actual and forecast reactive demand comparison by location





MEASURES AND ABBREVIATIONS

Units of measure

Abbreviation	Unit of measure
kV	Kilo volt
MW	Megawatt
MWh	Megawatt hour
MVar	Megavolt ampere reactive

Abbreviations

Abbreviation	Expanded name
AEMO	Australian Energy Market Operator
AER	Australian Energy Regulator
COAG	Council of Australian Governments
DNSP	Distribution Network Service Provider
MD	Maximum demand
NEFR	National Electricity Forecast Report
NEM	National Electricity Market
NER	National Electricity Rules
NMI	Network Meter Identifier
NSP	Network Service Provider
POE	Probability of Exceedance
PV	Photovoltaic
RRN	Regional Reference Node
TNI	Transmission Node Identifier
TNSP	Transmission Network Service Provider