



Revised Proposal

Attachment 5.13.M.10

Low Voltage Underground Cable Reactive program CBA summary

January 2019

Attachment 5.13.M.10

Low Voltage Underground Cable Reactive program CBA summary



Introduction

Ausgrid has reviewed the risks associated with low voltage underground cables by undertaking a quantitative risk assessment. This document covers the outcomes of cost benefit analysis and should be reviewed in conjunction with the cost benefit analysis (CBA) modelling methodology report¹.

Scope

This model covers the following RIN categories:

- UNDERGROUND CABLES - ≤ 1 kV

Analysis Outcome

For the low voltage underground cable asset category, Consac and HDPE cables have known condition and inherent design issues and their associated risks which are being addressed through planned replacement programs (refer to Attachment 5.13.M.2). For the remainder of the low voltage underground cable population, there are no additional asset sub-sets which require planned treatment other than a reactive response when failures are identified or occur. Proactively testing all low voltage underground cables to ascertain their condition and to then prioritise replacement is not reasonably practicable due to the size of the asset population and constrained resource availability to perform this testing.

Ausgrid is proposing that the existing strategy of reactive replacement following failure continues for these assets during FY20 to FY24.

The analysis was completed using historical data up to and including FY18. The CBA model forecasts risk from FY19 onwards. The volumes included in FY19 are reflective of Ausgrid's forecast reactive program in this year.


Based on the analysis completed, the model output is forecasting 825 failures resulting in the requirement for reactive replacement by the end of FY24.

Risk Index

The normalised risk index below considers the probability of failure, consequence of failure and the annualised replacement cost.


¹ Attachment 5.13.M.0 – Repex program CBA modelling methodology

ASSET RISK INDEX (2019, 2024 & 2029)



There are no low voltage underground cables which are cost benefit positive.

INHERENT ASSET RISK BY RISK INDEX CATEGORY



Option One – Base case (reactive replacement)

Under a base case (reactive replacement) scenario, Ausgrid forecasts reactive replacement requirements during FY20 to FY24 based on 825 failures (excluding Consac and HDPE). The table below shows the quantity of failures which will result in reactive replacement in the year that they are forecast to fail.

| Financial Year | FY20 | FY21 | FY22 | FY23 | FY24 |
|----------------------|------|------|------|------|------|
| Quantity of failures | 155 | 160 | 165 | 170 | 175 |

Option Two – Replace where cost benefit positive

Given the model shows no low voltage underground cables as cost benefit positive during FY20 to FY24, this option is not considered as supported.

Option Three – Replace all cost benefit positive by the end of the period

Given the model shows no low voltage underground cables as cost benefit positive during FY20 to FY24, this option is not considered as supported.

Data input

| | | Data Source |
|---|-------------------------|----------------------|
| Population | 4,908 km | GIS – Asset Register |
| Object Types | LV cable | GIS – Asset Register |
| Conditional & Functional Failures / Time Period | 768 failures 5 years | SAP – Defect Records |
| Asset standard life | 52.07 years | RAB life |
| WACC | 3.90% | Regulated Rate |

Planned Replacement Cost

A weighted average for the period per asset was used in this model.

| Cost | Data Source |
|----------|---|
| \$33,200 | Calculated average reactive replacement cost (FY19 real direct costs) |

Crow-AMSAA parameters

The Crow-AMSAA parameters have been developed by applying asset age to failure correlation using Ausgrid historical data relating to failures and assets.

| | | | | | |
|----------------------------|--------|--------------------------|--------|-----------------------|-----|
| β_{good} | N/A | β_{average} | 2.0931 | β_{poor} | N/A |
| λ_{average} | 0.0003 | | | | |

Adjustments factors

| | |
|----------------------------------|--|
| Probability of Failure (PoF) | <ul style="list-style-type: none"> Actual Failure Data Age |
| Probability of Consequence (PoC) | <ul style="list-style-type: none"> Nil |

Model calculated failures

| | 2020 | 2021 | 2022 | 2023 | 2024 |
|----------|------|------|------|------|------|
| Failures | 155 | 160 | 165 | 170 | 175 |

Sensitivity

Sensitivity analysis in regard to gross disproportionality factors was not undertaken due to the intent to continue with the existing reactive replacement strategy for these assets.

Modelled inherent incident consequences

Safety

Due to this model being for reactive replacement, analysis of safety probability of consequence factors including incident conversion rate and probability of severity was not undertaken.

Fire

Due to this model being for reactive replacement, analysis of fire probability of consequence factors including incident conversion rate and probability of severity was not undertaken.

Environment

Due to this model being for reactive replacement, analysis of environmental probability of consequence factors including incident conversion rate and probability of severity was not undertaken.

Loss of supply

Ausgrid's failure data has been reviewed to estimate the proportion of failures resulting in unserved energy and reasonable switching / restoration times.

| Outage Type | LV | Data Source |
|---|-----------------|-------------------|
| Proportion of failures resulting in unserved energy | 90% | SAP - defect data |
| VCR | \$40.73/kWh | AEMO / AER |
| Average kWh lost per failure | 266 | Metering data |
| Switching time/Proportion load | 5.04 hrs / 100% | OMS Data |
| Time without supply | 5.04 hrs | Calculated |

Average **loss of supply** consequence per asset: \$10,805 per event.

Finance

| | | Data Source |
|---|-----------------|----------------------|
| Annual deferral benefit of reactive | \$0 | N/A |
| Repair cost | \$0 | N/A |
| Proportion replaced | 100% | SAP – Defect records |
| Weighted replacement/repair cost | \$33,200 | Calculated |
| Maintenance original asset per annum | \$0 | N/A |
| Maintenance replacement asset per annum | \$0 | N/A |
| Maintenance benefit per asset per annum | \$0 | Calculated |

Average **financial** consequence/benefit per asset: \$33,200 per event.

AVERAGE TOTAL CONSEQUENCE per asset: \$44,005 (including POC x C(\$))