

# Distribution Category Analysis RIN, 2017-18

**Basis of Preparation** 

# CONTACT

This document is the responsibility of the Strategic Asset management Group within Tasmanian Networks Pty Ltd (ABN 24 167 357 299). Please contact the indicated owner of the document with any queries or suggestions.

#### RESPONSIBILITIES

#### Document Owner

Regulation Leader Tasmanian Networks Pty Ltd 1 – 7 Maria Street Lenah Valley TAS 7008 email: revenue.reset@tasnetworks.com.au

#### **Document Management**

Strategy Asset Management Group

# Introduction

TasNetworks (Tasmanian Networks Pty Ltd, ABN 24 167 357 299) is the owner and operator of the electricity distribution network in Tasmania.

This Basis of Preparation (**BoP**) forms part of the response of TasNetworks to the Regulatory Information Notice (**RIN**) issued in March 2014 by the Australian Energy Regulator (**AER**), under Division 4 of Part 3 of the National Electricity (Tasmania) Law, for the purposes of collecting information for category analysis.

The information and explanatory material included in this BoP relate to TasNetworks' activities as Tasmania's licensed Distribution Network Service Provider (**DNSP**) during the 2017-18 Regulatory Year (referred to throughout this document as the current reporting period).

# **AER's Instructions**

The AERs instructions in completing the category analysis RIN is to provide a BoP that demonstrates how the information provided in response to the RIN request complies with the requirement of the RIN. The minimum requirements of the BoP as per schedule 2 of the notice are set out in

# Table 1 - AER Requirements of the BoP

1.2 (a)	demonstrate how the information provided is consistent with the requirements of the notice.
(b)	explain the source from which we obtained the information provided.
(c)	explain the methodology we applied to provide the required information, including any assumptions made.
(d)	<ul> <li>explain, in circumstances where we cannot provide input for a variable using actual information and therefore must provide input using estimated information:</li> <li>(i) why an estimate was required, including why it was not possible to use actual information;</li> <li>(ii) the basis for the estimate, including the approach used, assumptions made and reasons why the estimate is our best estimate, given the information sought in the notice.</li> </ul>

# Definitions and interpretation

Aurora	Aurora Energy Pty Ltd, acting in its capacity as the licensed DNSP in Tasmania prior to 1 July 2014
CAM	Cost Allocation Method
DM	TasNetworks' Electronic Document Management System
Gentrack	TasNetworks' Electronic Document Management System
GTech	Distribution Network Service Provider
OTTER	Office of the Tasmanian Economic Regulator
POW	Programme of Work
SAIDI	System Average Interruption Duration Index
SAIFI	System Average Interruption Frequency Index
SCS	Standard Control Services
SDW	Spatial Data Warehouse
SOM	TasNetworks' Service Order Management system
WASP	TasNetworks' program-of-work management system (Works, Assets, Solutions and People)
UG	Underground (cable )
Telecommunications	Encompasses any telecommunications related asset
Secondary Systems	Encompasses protection systems, SCADA and Network Control
Substations Primary Systems	Encompasses power transformers, switchbays, transmission cables and reactive plant
Transmission Lines	Encompasses towers, support structures and conductors
TasNetworks	Refers to Tasmanian Networks Pty Ltd, acting in its capacity as a licensed Distribution Network Service Provider in the Tasmanian jurisdiction of the National Electricity Market.
AER	Australian Energy Regulator
DNSP	Distribution Network Service Provider
RIN	Regulatory Information Notice
UMS	Unmetered Supply

# **Table of Contents**

Introduction1			
AER's Instructions1			
Definitions ar	d interpretation	2	
Table of Conten	ts	4	
Template 2.1	Expenditure summary & reconcilliation	5	
Table 2.1.	1: Standard control services capex	5	
Table 2.1.	2: Standard control services opex	5	
Table 2.1.	3: Alternative control services capex	5	
Table 2.1.	4: Alternative control services opex	5	
Table 2.1.	5: Dual function assets capex	5	
Table 2.1.	6: Dual functions assets opex	5	
Template 2.2	Repex	6	
Table 2.2.	1: Replacement expenditure, volumes and asset failures by asset category	<i>.</i> 6	
Table 2.2.	2: Selected assets characteristics	10	
Template 2.3	Augex project data	13	
Table 2.3.	<ol> <li>Augex asset data – Subtransmission substations, switching stations and 13</li> </ol>	zone substations	
Table 2.3.	2: Augex asset data – Subtransmission lines	13	
Table 2.3.	3: Augex data HV/LV feeders and distribution substations	14	
Table 2.3.	4: Augex data – Total expenditure	14	
Template 2.5	Connections	16	
Table 2.5.	1: Descriptor metrics	16	
Table 2.5.	2: Cost metrics by connection classification	18	
Template 2.6	Non-network expenditure	20	
Table 2.6.	1: Non-network expenditure	20	
Table 2.6.	2: Annual descriptor metrics – IT and communications expenditure	20	
Table 2.6.	3: Annual descriptor metrics – Motor vehicles	21	
Template 2.7	Vegetation management	22	
Table 2.7.	1: Descriptor metrics by zone	22	
Table 2.7.	2: Expenditure metrics by zone	27	
Table 2.7.	3: Descriptor metrics across all zones – Unplanned vegetation events	28	
Template 2.8	Maintenance	29	
Table 2.8.	1: Descriptor metrics for routine and non-routine maintenance	29	
Table 2.8.	2: Cost metrics for routine and non-routine maintenance	33	
Template 2.9	Emergency response	34	
Table 2.9.	1: Emergency response expenditure (opex)	34	
Template 2.10	Overheads	36	

Table 2.10.1: Network overheads expenditure	36
Table 2.10.2:         Corporate overheads expenditure	36
Template 2.11 Labour	38
Table 2.11.1:         Cost metrics per annum	38
Table 2.11.2: Descriptor metrics	
Template 2.12 Input tables	40
Table 2.12: Input tables	40
Template 4.1 Public lighting	41
Table 4.1.1: Descriptor metrics over the current reporting period	41
Table 4.1.2: Descriptor metrics annually	41
Table 4.1.3:   Cost metrics	42
Template 4.2 Metering	44
Table 4.2.1: Metering descriptor metrics	44
Table 4.2.2:   Cost metrics	44
Template 4.3 Ancillary services – Fee-based services	46
Table 4.3.1: Cost metrics for fee-based services	46
Template 4.4 Ancillary services – Quoted services	47
Table 4.4.1: Cost metrics for quoted services	47
Template 5.2 Asset age profile	49
Table 5.2.1: Asset age profile	49
Template 5.3 Maximum demand at network level	54
Table 5.3.1: Raw and weather corrected coincident MD at network level	54
Template 5.4 Maximum demand at network level	55
Table 5.4.1: Non-coincident and coincident maximum demand	55
Template 6.3 Sustained interruptions to supply	56
Table 6.3.1: Sustained interruptions to supply	56

# Template 2.1Expenditure summary & reconcilliation

Table 2.1.1:	Consistency of information with the requirements of the RIN
Standard control services capex	<ul> <li>Information has been presented for the expenditure summary and reconciliation in accordance with the definitions and requirements of the RIN.</li> </ul>
	• Total expenditure for capex and opex has been reported on an 'as-incurred' basis.
Table 2.1.2: Standard control services opex	• TasNetworks has reconciled total capex and opex with the sum of capex and opex line items in the 'balancing item' row of each table in Template 2.1 using a balancing item which has been calculated in line with the instructions set out in paragraph 2.3 of Appendix E to the RIN.
Table 2.1.3:	Source of information
control services	• The summary information reported about standard control services capex in Table 2.1.1 was sourced from tables 2.2 Repex, 2.3 Augex, 2.5 Connections data and 2.10 Overheads capitalised. The balancing lines include items sourced from the regulatory accounts that have not been included in the above tables.
Table 2.1.4: Alternative control services	• The information in Table 2.1.2 Standard control services opex by category was sourced from templates 2.7 Vegetation, 2.8 Maintenance, 2.9 Emergency Response, 2.6 Non-network data and Table 2.10 Overheads capitalised. The balancing lines include items sourced from the regulatory accounts that have not been included in the above tables.
opex Table 2.1.5:	• The information in Table 2.1.3 Alternative control services capex was sourced from templates 4.1 Metering and 4.2 Public lighting. The balancing items in Table 2.1.3 include alternative control services capitalised overheads identified during the process of responding to Template 2.10 (but not reported in that template).
Dual function assets capex	• The data reported in Table 2.1.4 Alternative control services opex by category has been sourced from templates 4.1 Metering, 4.2 Public Lighting and 4.3 Fee-based Services. The balancing items in Table 2.1.4 include alternative control operating overheads identified during the process of responding to template 2.10 (but not reported in that template).
Table 2.1.6: Dual functions assets opex	Metering expenditure is included as part of overhead expenditure (as per AER instructions) and the balancing items have been reduced to take this into account.
	Methodology and assumptions made
	<ul> <li>In relation to Tables 2.1.5 and 2.1.6, TasNetworks has no dual function assets and, therefore, has reported no expenditure in these tables.</li> </ul>
	<ul> <li>The expenditure reported in Template 2.6 Non-network has been included in operating overhead expenditure as well as non-network and, therefore, has been reduced in the balancing items.</li> </ul>
	Use of estimates
	No estimates have been used in the collation and presentation of this information.

# Template 2.2 Repex

Table 2.2.1: Replacement expenditure, volumes and asset failures by asset category

# Consistency of information with the requirements of the RIN

Information has been presented for repex in accordance with the definitions and requirements of the RIN in that:

- Where TasNetworks has provided asset sub-categories corresponding to the prescribed asset categories in Table 2.2.1, the asset replacement / asset failure volumes of these sub-categories reconcile with the higher level asset category
- Expenditure for each of the sub-categories is determined through prescribed unit rates, determined for each of the sub-categories
- In instances where the asset group categories and the sub-categorisation provisions set out in Table 2.2.1 do not account for an asset on TasNetworks' distribution system, TasNetworks has inserted additional rows below the relevant asset group to account for this and provided a corresponding age profile in regulatory template 5.2
- Replacement volumes by asset group are equal to the applicable replacement volumes provided in Table 2.2.2, with the exception of sub transmission assets. Subs transmission asset categories do not fall into any of the asset group metrics specified in Table 2.2.2
- Asset replacements reflect the quantity of store data from TasNetworks' financial systems for the current reporting period

# Source of information

Data was obtained from SAP, WASP, TasNetworks' financial systems, data stored in the Spatial Data Warehouse. TasNetworks' outage management system (InService) was also used to source information relating to outages.

# Methodology and assumptions made

# General

• TasNetworks identified the applicable Work Categories used in WASP **or SAP** that best represented Repex activities. Jobs falling into those Work Categories were then analysed within the various works tools, including WASP, InService, TasNetworks' financial systems and WASP Outages.

# Poles

- For pole replacements (i.e. renewals) and refurbishments, sources of data included:
  - o all completed condition related pole renewals
  - o pole refurbishments recorded in WASP or in SAP
- The quantity reported for pole renewals and pole refurbishments are based on actual materials allocated through identified Repex work categories in TasNetworks' financial systems. Each piece of material used that correlates to an asset category has been classified as such, enabling the pole replacements arising as a result from other Repex drivers to be identified and counted, for inclusion in the count of replacements.
- For pole refurbishments, the staking of wooden poles and the reinstatement of steel / steel and concrete poles has been included. Steel and concrete pole reinstatements have been classified as concrete poles for the purposes of reporting.
- TasNetworks records tasks against each pole that requires renewal or refurbishment, and the data provided reflects tasks recorded in WASP, for any work under the Repex work categories.
- The condition-based replacement of poles is not deemed to constitute an asset failure, based upon the definition provided.
- TasNetworks records pole failures in its risk database, and a tabular record of

Asset Inspector's Pole Failure Inspection Reporting for each unassisted pole failures is also stored in TasNetworks' document management system. Unassisted pole failures are annually reported but are not reported in WASP or SAP as each suspected unassisted failure pole is forensically inspected by an Asset Inspector who then submits a Pole Failure Inspection Report that is risk reviewed and then recorded in the Document Management System. The annual summary is submitted in RIN Supporting References . The annual tally of unassisted pole failures is an important internal and internetwork benchmark for risk comparison, and for identifying dynamics in risk trends in pole failure in the population.

## Pole top structures

- TasNetworks has a capex task defined within WASP or SAP for pole top hardware replacement principally cross-arms. TasNetworks has reported all pole-top hardware replacement tasks completed during the current reporting period.
- TasNetworks has reported outages where pole top hardware has failed and requires replacement.
- The outage categories reported as pole-top asset replacement/failures are:
  - o Cross Arm Bent
  - Cross arm Broken
  - o Pole Top Fire
- It is assumed a large majority of pole top hardware is changed at the time a defect is addressed; therefore all outages have been counted.
- It is also assumed that all transformer outages are at a LV level and all other outages relate to the voltage of the relevant feeder (HV).

#### **Overhead conductors**

- A summary of stores data has been extracted from TasNetworks' financial systems, and then linked to the relevant work categories in WASP . **or SAP** As there is no reliable link between asset data and works data, the route length and number of phases involved with each work package cannot be easily attained. For the relevant work packs, the total of the conductor lengths has been used to calculate the length in the Repex table, and the values divided by 3 and converted to km to determine the total km installed. These values have been distributed across voltages matching that for the poles system voltage rating , and ratio of multiphase ,single phase and SWER.
- Conductors are repaired in the majority of cases, and then programmed for replacement if required as part of a program for replacement (Copper and Galvanised Iron conductor (GI )). The types of failures reported are:
  - o Conductor clashing due to wind long span
  - o Conductor clashing due to wind slack span
  - o Conductor Bare Wire Broken
  - o Conductor low Incorrect clearance
- The total conductor used from TasNetworks' stores system has been divided by three to calculate the total kilometres installed, based on the assumption that all overhead conductor installations are three phase.
- It is assumed that the majority (≈87.5%) of installations are 22 kV, with a smaller proportion (≈12.0%) being 11 kV conductors and a very small number being LV (≈0.05%). This proportion is based broadly upon voltage distribution across the state where this work has taken place. From a pole top/construction perspective, voltage makes very little difference in terms of the materials used, as the same components are used for both 22 kV

and 11 kV voltages.

- For conductor failures, it has been assumed that all transformer outages are at LV conductor level; that others relate to voltage of feeder (HV); and conductor replacements with no recorded voltage level involve 22kV conductors, on the basis that a large majority are 22kV.
- Kilometres of Overhead Line Inspected in 2017/18 is assumed the TasNetworks overhead line supports (poles) inspected multiplied by 0.1km average span, plus overhead line kilometres covered by aerial inspection by helicopter patrol.

# Underground cables

- The approach used for Repex work of underground cables is to use a summary of store data extracted from TasNetworks' financial systems, and then based on material description is allocated to the appropriate RIN category.
  - Underground cable replacement volumes are in kilometres.
- Cables are repaired in the majority of cases, and then programmed for replacement if required as part of a program for replacement. The number of failures reported are:
  - o UG Cable Failure
  - o UG Joint Failure
  - UG Cable Termination Failure(s)
- All transformer outages are at LV level, whilst others relate to the voltage of the feeder.

# Service lines

- TasNetworks does not have a specific replacement program in place for service lines. Instead, it has work rules that require the service fitting and service line to be replaced if they meet certain parameters, specifically the type of fitting/service. TasNetworks does not record the details of the arrangement, make or model of service connection assets and is unable to provide a breakdown of service line replacements and/or failures on the basis of actual data.
- From the failure data, it is assumed that firstly all service fuses and service lines are replaced on failure. Where an insulated service/service fuse has failed, a large majority have both items replaced with new.
  - The reported task list for service connections failures includes the following, which assumes that all service fuse outages are at Installation Conductor Failure Insulated
  - o Switchgear Service Fuse Failure
- Voltage relates to feeder (HV) and is not relevant. 'Blank' will be included in the total count.
- Residential / Commercial and Industrial split is assumed to be 85/15, based on the ratio of customer types.
- TasNetworks has no other services connection types at other voltages, as they are deemed part of the network, or relate to consumer mains (private).

# Transformers

- TasNetworks has a replacement program for transformers, HV and LV switchgear and substations. The data provided in this section is for the functional areas relating to those replacement programs.
- A summary of warehouse data has been extracted from TasNetworks' financial systems, and then linked to the relevant RIN categories, based on the asset material description.
- Failure reported in this category includes failed transformers, ground mounted switchgear

and substations.

 The feeder voltage is provided for the voltage breakdown. For transformer failures, the voltage is determined from the material description for the asset in TasNetworks' financial systems.

# Switchgear

- TasNetworks has specific programs for the replacement of ground mounted and overhead switchgear units. For replacement activities the data is sourced from TasNetworks' financial systems, and allocated to the appropriate switchgear type, based on the financial systems description.
- Where ground mounted switchgear is replaced and the solution is a complete kiosk substation, although the kiosk also contains a transformer, all the expenditure is accrued on the switchgear replacement REPEX program. This is because the replacement equipment is a singular unit and the expenditure could not be split up and distributed over several REPEX programs.
- For failed units, the data is sourced from Inservice, where the outage cause is classified as switchgear and allocated to switchgear type, based on the GIS asset description. This count will include all asset component failures, but does not necessarily attribute the failure to the correct asset group, as this information is not recorded at the time that the unit is replaced. This count does not differentiate between an asset failure that would result in a capex asset replacement or an asset component failure that would result in opex such as replacing a fuse tube. It also does not allow for attribution of failures into the correct RIN asset categories as this information is not recorded at the time that the unit is replaced. Changes to the outage management systems will allow the correct attribution of these units in the next reporting period.

### Public lighting

• Public lighting data has been sourced from stores data for materials recorded in TasNetworks financial systems. The data from the financial systems was assigned to the relevant public lighting categories for faults and replacements. Volumes of faults in table 2.2.1 are not a subset of total replacements in the same table.

#### SCADA, network control and protection systems

- The estimated financial data in Table 2.2.1 has been apportioned across categories using financial information for that year and the volumes of replacements.SCADA devices include Zone Substation Gateways , pole mounted reclosers and sectionalisers.
- Replacement of SCADA and protection systems are not formally recorded as these programs of work are normally combined with larger primary asset replacement projects.

# Use of estimates

Unless specified below, no estimates have been used in the collation and presentation of this information.

#### Poles

• For the breakdown of voltages for poles replaced by other drivers for Repex, an estimation of the voltage has been assumed based on the ratio of other poles. There is no detail available to provide actual data.

# Pole top structures

• A process of capitalisation of the opex costs for materials against this fault work is undertaken monthly as a way to capitalise the replacement of failed components with

rded as these eplacement projects. oss categories using nd requirements of
nd requirements of

### Poles

- Feeders have been classified for the purposes of Table 2.2.2 as per the classification of feeders undertaken for TasNetworks' response to the current Annual Reporting RIN, specifically Table 3a Feeder Reliability.
- Feeders were classified by applying the AER's feeder categorisation rules of:
  - Urban: Maximum demand of the feeder divided by the total length of the feeder is greater than 0.3 MVA/km
  - Short Rural: Maximum demand of the feeder divided by the total length of the is less than or equal to 0.3 MVA/km and the total length of the feeder is less than or equal to 200 km
  - Long Rural: Maximum demand of the feeder divided by the total length of the feeder is less than or equal to 0.3 MVA/km and the total length of the feeder is greater than 200 km
- Feeders for which there was no maximum demand available were manually assessed for classification based on their location and the classification of other feeders connected to the same substation.
- The asset volumesreported for table 2.2.1 have then been split by feeder classification (as per the AER's definitions) based on the feeder associated with each pole. Poles with no recorded feeder attribute have been distributed proportionally across feeder categories.
- The AER has made no provision in the RIN template for sub-transmission poles. Therefore, the total volume of poles reported in Table 2.2.2 will be less than the total number of poles reported in Template 5.2 Asset Age Profile.
- The asset volumes currently in commission have been determined through spatial analysis, where feeders were attributed to all poles. Poles with no recorded feeder attribute were distributed proportionally across feeder categories.

# Overhead conductors by feeder type

- Overhead conductor replacement volumes are determined from the values submitted in Table 2.2.1. The asset volumes currently in commission have been provided principally from Template 5.2 Asset Age Profile.
- In the case of HV feeders, asset volumes have then been split by feeder classification (as per the AER's definitions) based on the feeder associated with each conductor.
   TasNetworks does not record a feeder attribute for LV conductors. Therefore, in the case of low voltage conductors, and any high voltage conductors with no recorded feeder attribute, those conductors have been distributed proportionally across feeder categories based on the classification of high voltage conductors.
- This template does not allow for sub-transmission feeders, meaning that high voltage conductor volumes do not reconcile with those reported in Template 5.2.

#### Overhead conductors by material type

- HV overhead conductors were split by material based on the conductor material recorded in GTech **or SAP**. However, TasNetworks' Geographic Information System (GIS) does not currently record the material of low voltage conductors. Therefore, the split of low voltage conductors between materials was based on an extrapolation of records of low voltage conductor type connected to poles in WASP **or SAP**. The number of low voltage spans was assumed to be the number of poles minus 1. The average span length was then applied to the conductor materials to estimate the total length of low voltage conductors by conductors by woltage spans with no conductor material were proportionally distributed across the low voltage conductor population.
- Template 2.2.2 does not allow for the reporting of copper conductor, so asset volumes will

vary between conductor volumes by feeder classification and conductor volumes by material.

## Underground cables

- Underground cable replacement volumes are as submitted in Table 2.2.1. The asset volumes currently in commission have been provided principally from Template 5.2 Asset Age Profile.
- High voltage underground cables asset volumes have then been split by feeder classification (as per the AER's definitions) based on the feeder associated with each underground cable. TasNetworks does not record a feeder attribute for low voltage underground cables. Therefore, in the case of low voltage cables, and any high voltage underground cables with no recorded feeder attribute, those cables have been distributed proportionally across feeder categories based on the classification of high voltage cables.
- This template does not allow for sub-transmission feeders, meaning that high voltage cable volumes do not reconcile with those reported in Template 5.2.

## Transformers

- Transformer replacement volumes are as submitted in Table 2.2.1. The asset volumes currently in commission have been provided principally from Template 5.2 Asset Age Profile.
- •

# Use of estimates

Unless specified below, no estimates have been used in the collation and presentation of this information.

#### Tranformers

• TasNetworks does not record the nameplate ratings of transformers on disposal. Therefore, the capacity of transformers disposed during the current reporting period was estimated on the basis of 10 per cent of the transformers replaced during the current reporting period.

# Template 2.3 Augex project data

Table 2.3.1:	Consistency of information with the requirements of the RIN
Augex asset data – Subtransmission substations.	Information has been presented for augmentation projects in accordance with the definitions and requirements of the RIN.
switching stations	
and zone	Source of information
substations	WASP or SAP
	TasNetworks financial systems
	Schematic diagrams of TasNetworks substations
	Project scope documents
	Methodology and assumptions made
	<ul> <li>Project expenditure has been reported in the regulatory year nominal dollars.</li> </ul>
	<ul> <li>Zone substation development utilise the work category codes CAZNC, CAZSU, LANDZ and EASEZ. Work programs relating to subtransmission work specifically is extracted from these codes and removed from the zone substation specific data.</li> </ul>
	• This data is examined for jobs exceeding \$5 million completed in the regulatory year.
	• Any jobs completed for a total cost less than \$5 million are reported as non-material.
	• Any jobs which do not have a project close date but have costs incurred against them under these work category codes are listed as non-material forecast.
	Use of estimates
	No estimates have been used in the collation and presentation of this information.
Table 2.3.2:	Consistency of information with the requirements of the RIN
Subtransmission	Information has been presented for augmentation projects in accordance with the definitions and requirements of the RIN.
	Source of information
	TasNetworks program of works management system
	TasNetworks financial systems
	Schematic diagrams of TasNetworks substations
	Project scope documents
	Methodology and assumptions made
	• Project expenditure has been reported in the regulatory year nominal dollars.
	• Subtransmission augmentations utilise the work category codes CAZNC, CAZSU, LANDZ and EASEZ. Work programs relating to subtransmission work specifically is extracted from these codes.
	• This data is examined for jobs exceeding \$5 million completed in the regulatory year.
	• Any jobs completed for a total cost less than \$5 million are reported as non-material.
	Use of estimates
	NO ESTIMATES HAVE DEED USED IN THE CONTROL OF AND DESENTATION OF THIS INFORMATION.

Table 2.3.3:	Consistency of information with the requirements of the RIN
Augex data HV/LV feeders and distribution	Information has been presented for augmentation projects in accordance with the definitions and requirements of the RIN.
substations	Source of information
	• The data reported in Tables 2.3.3.1 and 2.3.3.2 has been sourced from TasNetworks' financial and Works Management systems.
	• The numbers of circuit kilometres and distribution transformers added during the reporting period have been obtained from TasNetworks' financial and Works Management systems.
	Methodology and assumptions made
	<ul> <li>No information relating to gifted assets has been included.</li> </ul>
	<ul> <li>Information regarding augmentation (capital) expenditure has been reported on an as incurred basis and in nominal dollars</li> </ul>
	<ul> <li>information regarding the circuit line lengths of HV and LV feeders and the number of substations added has been provided on an as incurred basis.</li> </ul>
	<ul> <li>Data was extracted from the source systems based on specified Work Categories and identified by Overhead and Underground project types</li> </ul>
	<ul> <li>Data was summarised based on High and Low voltage conductor types and Substation types based on the data extract.</li> </ul>
	• Expenditure recorded in Table 2.3.3.2 includes all projects undertaken during the regulatory year, not just completed jobs. The assets added or in service as an outcome of projects that were not complete as at the end of the current reporting period have not been included in the totals reported in Table 2.3.3.1.
	• The total cost thresholds applied to delineate between material and non-material high voltage and low voltage feeder augmentation projects are \$500k and \$50k respectively. The thresholds have been applied against the total cumulative expenditure over the life of the project, inclusive of any indirect costs. Expenditure reported in Table 2.3.3.2, however, excludes overheads.
	Lise of estimates
	No estimates have been used in the collation and presentation of this information.
Table 2.3.4:	Consistency of information with the requirements of the RIN
Augex data – Total	Information has been presented for augmentation projects in accordance with the definitions and requirements of the RIN in that:
expenditure	<ul> <li>Information regarding augmentation expenditure has been reported on an as incurred basis and in nominal dollars</li> </ul>
	• Expenditure relating to land purchases and easements associated with augmentation works on high voltage feeders, low voltage feeders and distribution substations has only been provided in Table 2.3.4
	<ul> <li>expenditure recorded in the 'Land and easements' rows of Table 2.3.4 has not been included in the augmentation expenditure reported in relation to the corresponding asset groups in the same table.</li> </ul>
	Source of information



• TasNetworks financial systems (SAP)

# Methodology and assumptions made

- TasNetworks' augmentation expenditure has been extracted from TasNetworks' financial systems by relevant work category, and aggregated to the corresponding asset groups.
- The expenditure reported in Table 2.3.4 in relation to Subtransmission Substations, Switching Stations, Zone Substations and Subtransmission Lines is as incurred, whereas expenditure reported in tables 2.3.1. and 2.3.2 is consistent with requirement to report expenditure on a project close basis.

# Use of estimates

No estimates have been used in the collation and presentation of this information.

# Template 2.5 Connections

Table 2.5.1:	Consistency of information with the requirements of the RIN
Descriptor metrics	Information has been presented for connections in accordance with the definitions and requirements of the RIN in that:
	<ul> <li>No information relating to gifted assets has been included;</li> </ul>
	<ul> <li>Information regarding augmentation (capital) expenditure has been reported on an as incurred basis and in nominal dollars (of the relevant regulatory year);</li> </ul>
	<ul> <li>Information regarding the circuit line lengths of HV and LV feeders and the number of substations added is provided on an as incurred basis;</li> </ul>
	The GSL data provided pertains to Customer Charter payments made to residential customers only
	Source of information
	Augmentation (all sub categories)
	The information regarding augmentation in Table 2.5.1 has been sourced from WASP and SAP and the Managing Customer Connections (MACCs) database.
	Connection volumes (residential connections)
	All annual residential connection volumes provided in Table 2.5.1 were sourced from Bravo (SOM).
	Underground and overhead connection volumes (residential connections)
	The volumes of underground and overhead connections were determined on the basis of information stored in the Bravo (SOM) system or Spatial Data Warehouse <b>or SAP.</b>
	Distribution Substation Installed (residential connections)
	Distribution substations MVA added and number installed have been calculated by extracting the transformer size and quantities from the TasNetworks' financial system (SAP) quantities that were extracted for residential augmentation HV and LV.
	Distribution Substation Installed (residential connections)
	Expenditure data has been sourced from TasNetworks' financial system and reconciled to the Annual Reporting RIN.
	Mean days to connect residential customer with LV single phase connection (residential connections)
	The mean days taken to connect residential customers requiring a low voltage single phase connection was derived using a combination of service order information originating from the Bravo (SOM) system.
	GSL breaches for residential customers (residential connections)
	The volumes and values of payments made under the customer charter applying in the current reporting period to connections to customers who received a standard of service below that set out in the charter have been derived from records kept in the Charter Payment Tool, which is part of TasNetworks' customer complaint management systems.
	Volume of customer complaints relating to connection services (residential connections)
	The volume of complaints applying in the current reporting period to connections to customers who made a complaint to TasNetworks have been derived from records kept in the Customer Advocacy

Tool, which is TasNetworks' customer complaint management tool.

#### GSL payments (residential connections)

The number and value of payments made to customers who received a standard of service below that set out in the customer charter in the current reporting period have been derived from records kept in the Charter Payment Tool, which is part of TasNetworks' customer complaint management systems.

## Commercial / Industrial Connections

All annual Commercial connection volumes provided in Table 2.5.1 were sourced from Bravo (SOM).

### Subdivision connections

The data reported in Tables 2.5.1 and 2.5.2 has been sourced from TasNetworks' financial and Works Management systems.

#### Embedded generation connections

The data reported in Tables 2.5.1 and 2.5.2 has been sourced from TasNetworks' financial and Works Management systems.

# Methodology and assumptions made

#### General

- Expenditure on all types of connection related activities reported in Table 2.5.1 has been allocated to the different classifications and subcategories using the work categories in TasNetworks' financial systems.
- Information regarding the circuit line lengths of HV and LV feeders and the number of substations added on an as incurred basis
- Connections for which the type of connection has not been recorded have been determined by extracting information from the associated connection Service Order, or failing that, querying the GIS database for the NMIs connection details;
- 'Net circuit km added' refers to the net addition of circuit line length resulting from augmentation work.;
- TasNetworks is not obliged under a jurisdictional scheme to make payments to customers for connections. The amounts reported are voluntary payments made by TasNetworks in recognition of a breach of our customer charter.

### **Connection volumes**

Connections for which the type (underground or overhead) has not been recorded have been determined by extracting information from the associated connection Service Order, or failing that, querying the GIS database for the NMIs connection details.

### Distribution substation installed

Expenditure has been allocated to the different classifications and subcategories using the work categories in TasNetworks' financial systems. Where the RIN further breaks down the information into more detailed subcategories than TasNetworks' financial systems; volumes relating to these sub categories have been used for allocation purposes.

### Mean days to connect residential customers with LV single phase connection

The mean days to connect residential customers with a low voltage single phase connection has been derived using Brave Service Order Management records of the date on which service orders

for connections of this type are received in the field and the corresponding job completion dates. The service orders are generated by SOM and exported into TasNetworks' field tool, which is also used to gather the completion date for each job as part of standard operating procedure.

# Augmentation (all subcategories)

- Augmentation volumes were sourced from WASP and SAP under the following work categories:
  - Residential connections
  - o Commercial/industrial connections
  - o Subdivisions
- Embedded generation SOLAR connections projects were identified in Gentrack and the MACCs database.
- •
- The number of high voltage embedded generator projects have been identified by the relevant TasNetworks' Asset Manager.

# Use of estimates

Unless specified below, no estimates have been used in the collation and presentation of this information.

# GSL payments (residential connections)

The data sources which record the customers who have received payments under TasNetworks' customer charter do not consistently contain NMIs, meaning that residential customers that receive payments are not able to be identified with absolute certainty.

In order to apportion customer charter payments between residential and non residential customers, a sample of approximately 200 general charter payment recipients for whom NMIs were recorded has been cross-referenced with the network tariff history stored for those NMIs in TasNetworks' distribution billing system in order to identify the primary network tariff (and customer status) applying at the time each payment was made. The findings from this analysis have then been applied to customer charter payments made during the current reporting period, with the result that 85 per cent of payments, both by value and number, have been apportioned to residential customers.

This methodology was chosen because it was based on objective data sources and the ratio of residential to non-residential NMIs identified using this technique has been shown to be consistent with that of the wider customer base.

The source data for the complaints is not apportioned as we can filter out the business related complaints, this data is captured against the complaint case.

# **Overhead / Underground Connections**

Where this information has not been provided, the null or blank values will be proportioned to the OH/UG categories based on percentages of the known values.

Table 2.5.2:	Consistency of information with the requirements of the RIN		
Cost metrics by connection	Information has been presented for connections in accordance with the definitions and requirements of the RIN in that:		
classification	<ul> <li>TasNetworks has reported expenditure data as gross amounts, and has not subtracted customer contributions from the connections expenditure data</li> </ul>		
	• TasNetworks has applied the definitions of complex connections in Appendix F of the RIN to provide guidance on the type of work which is to be reported as connection services for the purposes of Table 2.5.2, as opposed to augmentation (reported under Template 2.3)		
	Only augmentation expenditure relating to connections provided in response to customer		

connection requests has been reported in regulatory Template 2.5

 The costs associated with the provision of connection services has been reconciled to the Annual Reporting RIN.

# Source of information

- The costs associated with the provision of connection services have been sourced from TasNetworks' financial systems and reconciled to the Annual Reporting RIN.
- The volume data reported in Tables 2.5.2 has been sourced from TasNetworks' financial and Works Management systems.

# Methodology and assumptions made

# Financial

In relation to the provision of connection services, TasNetworks' financial systems does not distinguish between the connection classifications used in Table 2.5.2 (i.e. simple and complex LV or HV connections).

In order to report the costs associated with each type of connection classification stipulated in Table 2.5.2, the total cost of providing connection services in the current reporting period has been apportioned between the classifications in Table 2.5.2 on the basis of unit rates developed specifically for the purposes of weighting the connection volumes reported in Table 2.5.2.

### **Residential – Simple Connection LV**

This is the balance after deducting the values for Complex Connections LV and HV below from the total of Residential Underground and Overhead in table 2.5.1

#### Commercial/Industrial – Simple Connection LV

This is the balance after deducting all values for Complex Connections HV below from the total of Commercial/Industrial Underground and Overhead in table 2.5.1

#### **Embedded Generation – Simple Connection LV**

This is the balance after deducting all values for Complex Connections HV below from the total of Embedded Generation Underground and Overhead in table 2.5.1

# Use of estimates

No estimates have been used in the collation and presentation of this information.

# Template 2.6Non-network expenditure

-	
Table 2.6.1:	Consistency of information with the requirements of the RIN
Non-network	Information has been presented for non-network expenditure in accordance with the definitions
expenditure	and requirements of the RIN.
	Source of information
	TasNetworks financial systems
	AusFleet
	Annual Reporting Rin data
	Methodology and assumptions made
	IT and Communications
	<ul> <li>Client device expenditure is expenditure that relates to a hardware device that accesses services made available by a server. Items included in this category are the costs associated with our IT service provider, plus all capital expenditure associated with the purchase of desktop computers, laptops, tablets etc.</li> </ul>
	<ul> <li>Recurrent expenditure is expenditure that relates to items that occur on a regular on-going basis and would include the operating labour costs of the IT department, plus all costs associated with landlines, mobile phone charges, software, data communications etc.</li> </ul>
	<ul> <li>Non-recurrent expenditure is expenditure that relates to items that occur on a non-recurring basis.</li> </ul>
	Motor vehicles
	• All motor vehicles are split into the relevant RIN category per the category number generated from the Fleet Management System. Costs are then allocated on a proportionate basis per the number of vehicles within each category for determining opex expenditure. Capex expenditure is the value of additions within the regulatory year, split into the relevant motor vehicle category.
	Use of estimates
	No estimates have been used in the collation and presentation of this information.
Table 2.6.2:	Consistency of information with the requirements of the RIN
Annual descriptor metrics – IT and	<ul> <li>Information has been presented for non-network expenditure in accordance with the definitions and requirements of the RIN.</li> </ul>
communications	Source of information
expenditure	The descriptor metrics relating to TasNetworks' IT and Communications expenditure has been
	sourced from TasNetworks' Human Resources system at the time of the Financial Year End. The numbers provided are as per the TasNetworks' published accounts.
	Methodology and assumptions made
	Employee numbers represent total TasNetworks employee numbers as published in the annual accounts.
	Use of estimates

	No estimates have been used in the collation and presentation of this information.
Table 2.6.3:	Consistency of information with the requirements of the RIN
Annual descriptor metrics – Motor	Information has been presented for non-network expenditure in accordance with the definitions and requirements of the RIN.
vehicles	Source of information
	<ul> <li>TasNetworks financial systems</li> <li>AusFleet</li> </ul>
	Methodology and assumptions made
	Kilometres travelled
	The opening and closing odometer readings for each vehicle were used to calculate the kilometres travelled in the current reporting period, with the mileages then sorted by category of vehicle and aggregated.
	Number purchased
	The number of vehicles purchased by TasNetworks during the current reporting period was extracted from AusFleet.
	Proportion of expenditure
	• The proportion of fleet expenditure was derived by:
	<ul> <li>gathering motor vehicle expenditure for each vehicle from AusFleet</li> </ul>
	<ul> <li>allocating each motor vehicle to the appropriate category (e.g. Light Commercial, Passenger, Trailer)</li> </ul>
	<ul> <li>calculating the total expenditure for each category of motor vehicle</li> </ul>
	<ul> <li>splitting out the cost of each category of vehicle into prescribed and non-prescribed expenditure</li> </ul>
	<ul> <li>calculating the Regulatory Percentage by dividing prescribed expenditure by total expenditure</li> </ul>
	Use of estimates
	No estimates have been used in the collation and presentation of this information.

# Template 2.7Vegetation management

Table 2.7.1:	Consistency of information with the requirements of the RIN
Descriptor metrics by	Information has been presented for vegetation management in accordance with the definitions and requirements of the RIN.
zone	
	Vegetation management zones
	Under paragraph 12.1 in section 12 of Appendix E to the RIN (Principles and Requirements), TasNetworks is required to nominate one or more vegetation management zone(s) across the geographical area of TasNetworks' distribution network.
	TasNetworks has nominated two vegetation management 'zones' in accordance with Appendix E. In doing so, TasNetworks has taken into consideration the areas where bushfire mitigation costs are imposed by legislation, regulation or Ministerial order, as well as areas of the network where other recognised drivers affect the costs of performing vegetation management work.
	TasNetworks is required to provide, on separate A4 sheets, maps showing each vegetation management zone and the total network area with the borders of each vegetation management zone. Those maps have been provided as required, and are also reproduced below.
	For each vegetation management zone identified, TasNetworks has provided details of any regulations that impose a material cost on performing vegetation management works, including, but not limited to, bushfire mitigation regulations.
	Details of the self-imposed standards from TasNetworks' vegetation management program which apply to each nominated vegetation management zone have also been provided as part of this Basis of Preparation document.
	Operationally, TasNetworks' entire network is managed as a single vegetation management zone, which reflects the fact that the entire distribution network is covered by TasNetworks' normal trimming cycle. Within that zone, however, a High Bushfire Consequence Area has been defined to identify the area of TasNetworks' network where bushfire mitigation is a recognised driver of additional vegetation management work.
	TasNetworks carries out an annual pre-summer vegetation inspection and cutting program in the High Bushfire Consequence Area to ensure required clearances are achieved prior to the onset of the annual bushfire season.
	Tree-trimming costs have been split between zones in the vegetation expenditures table (Table 2.7.2).
	The definition of the High Bushfire Consequence Area is flexible, however, and can change between years, in that TasNetworks has the option of extending the area covered by its pre-summer inspection and cutting program if conditions leading into the bushfire season pose sufficient risk to warrant additional work being undertaken. Such risks and additions to the program are developed in consultation with the Tasmania Fire Service and the Bureau of Meteorology.





# Legislation with a material impact on vegetation management work

The following legislation requires TasNetworks to implement programmes relating to vegetation management:

- Electricity Supply Industry Act 1995 (ESI Act)
- Electricity Industry Safety and Administration Act 1997 (ESI&A Act)
- The Tasmanian Electricity Code (TEC)

TasNetworks' normal trimming cycle across the state are driven by compliance with the ESI Act, the ESI&A Act and Chapter 8A of the TEC. TasNetworks uses the principles and approaches contained within Chapter 8A of the TEC as its basis for managing the vegetation within TasNetworks' statutory easements.

# Electricity Supply Industry Act 1995

The ESI Act exists to:

- promote efficiency and competition in the electricity supply industry
- establish and maintain a safe and efficient system of electricity generation, transmission, distribution and supply
- establish and enforce proper standards of safety, security, reliability and quality in the electricity

supply industry

protect the interests of consumers of electricity

The ESI Act covers safety aspects at a fairly high level and is implicit regarding vegetation management risks.

#### Electricity Industry Safety and Administration Act 1997

The EIS&A Act exists to establish safety standards for electrical articles, to provide for the investigation of accidents in the electricity industry and for related purposes. The ESI&A Act covers:

- Powers of entry and inspection
- Powers to order rectification
- Powers to order disconnection
- Emergency powers relevant to TasNetworks vegetation management activities

#### Tasmanian Electricity Code (TEC)

The TEC provides, inter alia, a statement of the relevant technical standards of the electricity supply industry, an access regime to facilitate new entry, guidance on price setting methodologies, a means of resolving disputes, and establishes advisory committees to assist the Regulator. There has been on-going development and refinement of the TEC to ensure that it best meets the needs of the Tasmanian electricity supply industry and customers.

Chapter 8A of the TEC includes a framework for the management of vegetation around distribution powerlines. This framework is explicit regarding works requirements and practices in various fire hazard categories.

TasNetworks has the regulatory responsibility to manage trees growing near power lines and mitigate risks associated with trees coming into contact with power lines. The minimum standard to which TasNetworks must achieve is compliance with Chapter 8A of the TEC.

#### Self-imposed Vegetation Management Standards

Vegetation management works in the High Bushfire Consequence Area include the standard cyclic cuttings undertaken in the rest of the State, as well as a more rigorous annual pre-summer vegetation inspection and cutting programme to ensure required clearances are achieved prior to the onset of each annual bushfire season.

The High Bushfire Consequence Area was developed as part of Aurora Energy's 2012 Bushfire Mitigation Strategy (which has been adopted by TasNetworks), where leading experts from Melbourne University and the Tasmanian Parks and Wildlife Service were engaged (in consultation with the Tasmanian Fire Service) to utilise the industry accepted Phoenix Rapid-fire modelling tool to determine areas of fire loss consequence. This methodology has been utilised by other DNSPs following the findings of the Victorian Bushfire Royal Commission.

The level of exposure to bushfire risk has been determined based on the number of maintenance spans located in the bushfire loss consequence areas.

TasNetworks has the option of extending the area covered by the pre-summer vegetation inspection and cutting programme if conditions leading into the bushfire season pose sufficient risk to warrant additional work being undertaken. Risk and additions to the programme are discussed in liaison with the Tasmania Fire Service and the Bureau of Meteorology.

# Source of information

Number of maintenance spans

The number of maintenance spans data is sourced from the vegetation management system and data provided by vegetation management service providers.

# Total length of maintenance spans

Total length of maintenance spans data is sourced from the vegetation management system (data populated by vegetation management service providers), the distribution span model and the spatial data warehoused.

# Length of vegetation corridors

Length of vegetation corridors data is sourced from TasVeg spatial vegetation community data, TasNetworks' Spatial Data Warehouse and specialist consultant tree density analysis.

# Average number of trees per maintenance span

Average number of trees per maintenance span data is sourced from the the vegetation management system (data populated by vegetation management service providers) and the distribution span model.

# Average frequency of cutting cycle

Average frequency of cutting cycle data is sourced from the the vegetation management system (data populated by vegetation management service providers)

# Methodology and assumptions made

## General

Only spans within TasNetworks' network that were subject to active vegetation management in the current reporting period have been included.

## Route line length within zone

- the length of each span has been considered only once in calculating route line length, regardless of the number of circuits it contains
- the distances between line and cable segments do not reflect vertical components such as sag
- Changes in height are ignored
- Multiple circuits counted only once.

#### Number of maintenance spans

- TasNetworks' primary vegetation management service providerssubmits the number of spans cleared and trees actioned within each span via electronic data capture and upload to TasNetworks' vegetation management system during the scoping and cutting phase of works.
- For the purpose of providing this data, TasNetworks has defined a maintenance span as "a span within TasNetworks' network that is subject to active vegetation management practices..."

#### Total length of maintenance spans

Each span identified for work can be linked via a specific span ID back to the Spatial Data Warehouse and Distribution Span Model providing the distance of each individual span.

#### Length of vegetation corridors

Vegetation corridor lengths have been estimated using spatial analysis by overlaying TasNetworks' network span model with recognised and modelled vegetation data.

### Average number of trees per maintence span

TasNetworks' primary vegetation management contractor submits the number of spans cleared and trees actioned within each span via electronic data capture and uploads to TasNetworks' vegetation

management system during the scoping and cutting phase of works.

# Use of estimates

Unless specified below, no estimates have been used in the collation and presentation of this information.

# Number of maintenance spans

- While TasNetworks' primary vegetation management service providers records the number of spans cleared electronically, other contractors, responsible for approximately 5% of work, do not yet provide the required data directly.
- The number of spans maintained where data are available (from the primary contractor) has been divided by expenditure to calculate an average rate (vegetation management productivity) per maintenance span. Expenditure where data is unavailable has been applied at this average rate to estimate the additional number of spans under management.
- Where mechanical clearing techniques have been utilised, an average rate of \$4,000 per kilometre
  has been applied (based upon historical data) to determine kilometres covered. An average span
  distance of 0.0828km (from known span data within the vegetation management system (VMS)
  has been applied to the total kilometres to determine spans cleared.
- The primary vegetation management service providersoperate a large and diverse number of teams, through a wide variety of vegetation areas throughout the state. It has been assumed that the average vegetation management productivity of TasNetworks' Primary vegetation management service providersis constant across all contractors The effects of individual efficiency and progress rates through different areas are thus averaged to determine an overall aggregate rate.

# Total length of maintenance spans

- While vegetation pool contractors and mechanical clearing contractors report the number of spans cleared, they do not currently identify the exact spans cleared, meaning that an estimate of the total length of maintenance spans is required.
- Data based upon the number and length of spans maintained where data are available has been provided.
- Estimates have been derived based upon expenditure where data is unavailable and added to the known data.
- It has been assumed that the average vegetation management productivity of TasNetworks' Primary vegetation management contractor is constant across all contractors.
- The average span length is considered to be relatively accurate given the large number of spans in each feeder. Vegetation programs for a given year also generally follow a single feeder, mitigating the effects of outlying long or short spans.

# Length of vegetation corridors

- TasNetworks has provided estimated vegetation corridor lengths because actual spatial vegetation corridor records were not kept through the current reporting period.
- The TasVeg database was used to assign a vegetation 'community' to every network span from the Spatial Data Warehouse. A specialist consultant was engaged to analyse these communities and assign appropriate densities for vegetation that may interfere with overhead lines. Any line within a vegetation community (tree density > 0) was considered part of a vegetation corridor.
- It has been assumed that the vegetation community data is sufficiently detailed and accurate on the scale of overhead spans.
- An objective, state-wide vegetation model is required to make meaningful comparisons and decisions when scheduling and prioritising vegetation work. While more accurate assessments could be made on a local scale, this would likely distort the system-view of vegetation corridors.

	Average number of trees per maintence span
	• While TasNetworks' primary vegetation management contractor records the numbers of trees cleared per span, other contractors, responsible for approximately 11% of work, do not yet provide the required data directly.
	<ul> <li>It has been assumed that the average vegetation management productivity of TasNetworks' Primary vegetation management contractor is constant across all contractors.</li> </ul>
	<ul> <li>Where mechanical clearing techniques have been utilised, trees removed are measured by the number of metres squared cleared rather than by numbers of trees. This has resulted in the necessity to convert the number of metres squared cleared into the AER's definition of 'trees'.</li> </ul>
	• Where mechanical clearing techniques have been utilised, an average rate of \$4,000 per kilometre has been applied (based upon historical data) to determine kilometres covered. An average span distance of 0.0828km (from known span data within the VMS) has been applied to the total kilometres to determine spans cleared.
	• Where mechanical clearing techniques have been utilised, a further assumption has been made that the average width of cleared easement is 8 metres. This width is derived from the average total easement width of 12 metres and subtracting 4 metres for allowance for roads and tracks within the easement.
	• It is assumed (based upon sampling) that 50% of mechanical clearing m2 are populated with trees greater than 3m in height (as per AER's definition of 'trees').
	• The primary vegetation management service providersoperate a large and diverse number of teams, through a wide variety of vegetation areas throughout the state. The effects of individual efficiency and progress rates through different areas are thus averaged to determine an overall aggregate rate.
Table 2.7.2:	Consistency of information with the requirements of the RIN
Expenditur e metrics by zone	Information has been presented for vegetation management in accordance with the definitions and requirements of the RIN in that the costs associated with vegetation management work have been reported for each of TasNetworks' two nominated vegetation management zones.
	Source of information
	Expenditure data reported in Table 2.7.2 has been sourced from TasNetworks' financial systems , which recognises each vegetation management zone as a separate vegetation management cost centre.
	Methodology and assumptions made
	• TasNetworks does not split its vegetation zones into Northern, Central and Southern Regions. Rather, reporting is prepared on two nominated vegetation management zones.
	<ul> <li>Cyclic cutting costs have been apportioned between Tree Trimming and Vegetation Corridor Clearance based on the length of vegetation corridors in each zone as a percentage of the rural route line length recorded for each zone.</li> </ul>
	• TasNetworks' does not identify trees as hazards to be treated differently from any other trees located in the vicinity of power lines. Therefore, the cells in Table 2.7.2 relating to hazard tree cutting have not been disclosed.
	• Ground clearance works are not recorded separately and the associated costs are included in tree trimming expenditure.
	TasNetworks does not record expenditure on inspections of vegetation separately.
	• TasNetworks does not capture expenditure on audits of vegetation management work separately.
	• Contractor liaison expenditure has been sourced from TasNetworks' financial systems and reflects the number of FTEs specifically engaged in managing TasNetworks' vegetation management

	programme, in terms of the associated labour costs, labour on-costs and vehicle costs. TasNetworks has reported no tree replacement costs because trees pear powerlines which are
	removed as part of vegetation management work are not replaced.
	Use of estimates
	No estimates have been used in the collation and presentation of this information.
Table 2.7.3:	Consistency of information with the requirements of the RIN
Descriptor metrics across all	Information has been presented for vegetation management in accordance with the definitions and requirements of the RIN.
zones –	Source of information
Unplanned vegetation events	The data reported in Tables 2.7.3 has been sourced from WASP (01 July 2017 to 30 April 2018) and In Service (01May 2018 to 30 June 2018). Software updates (due to SAP implementation) have resulted in two separate information sources.
	Methodology and assumptions made
	<ul> <li>The data regarding fires started by vegetation blow-ins and fall-ins was extracted from TasNetworks' distribution-outage database within WASP and In Service.</li> </ul>
	• TasNetworks does not generally categorise vegetation related fire starts as either caused by 'grow- ins' or caused by 'blow-ins or fall-ins'. TasNetworks has made an assumption that 'grow-ins' relate to trees inside the clearance space, whilst 'blow-ins or fall ins' relate to trees outside the clearance space
	Use of estimates
	No estimates have been used in the collation and presentation of this information.

# Template 2.8 Maintenance

Table 2.8.1:	Consistency of information with the requirements of the RIN
Descriptor	Information has been presented for maintenence in accordance with the definitions and
metrics for	requirements of the RIN in that it includes costs incurred for the simultaneous inspection of assets
routine and non-	and vegetation and costs associated with access track maintenance. As we had no dual function
routine	assets throughout the current reporting period, we have included no descriptor metrics for this asset class in table 2.8.1.
maintenance	
	Source of information
	Pole top, overhead line & service line
	The volume of overhead service wires installed was sourced from GTech; and Pole top and overhead line information was sourced from GTech
	Pole inspection and treatment
	Pole inspection and treatment information was sourced from GTech.
	Overhead Asset Inspection
	Overhead asset inspection information was sourced from GTech.
	Network underground cable
	Asset data from GTech and SAP
	Distribution substation
	Asset data sourced from SAP
	<ul> <li>'Ground Mounted Substations - Live Asset Records 30 June 2018' which is a live link to the</li> </ul>
	spatial data warehouse; and
	Distribution Substation Asset management Plan;
	Zone substation
	Asset data sourced from SAP; and
	Zone Substation Asset management Plan;
	Public lighting
	Public lighting quantities have been sourced from TasNetworks' Market Data Management System (GenTrack) and the volumes of public lighting inspection and maintenance activity have been sourced from TasNetworks' financial systems, based on the quantities of materials issued for this work category.
	SCADA & network control
	• Wherever possible, asset information has been sourced from WASP, SAP, data pertaining to the Telstra mobile phone accounts which enable remote communications, site audit information, test reports stored in TasNetworks' intranet 'The ZoNe', or documentary records such as asset management plans.
	Ground clearance - access tracks
	All data regarding access tracks has been sourced from:
	<ul> <li>TasNetworks' Spatial Data Warehouse and GTech; and</li> </ul>

• TasNetworks' distribution 'Span Model' – a database of pairs of geographic coordinates

that correspond to poles with at least one connecting conductor circuit. The Span Model has been derived from spatial conductor data in the Spatial Data Warehouse specifically to meet the AER's definition of Route Line Length:

 TasNetworks has a service level agreement with the Tasmanian Department of Primary Industries, Parks, Water and Environment for the Land Titles Office to supply up-to-date GIS transport information sourced from the Land Information System Tasmania (The LIST). This includes details of public highways, streets and known private off-road trails.

# Other (metering transformers)

- The volume of metering transformers and age data was sourced from TasNetworks' Market Data Management System (Gentrack); and
- Metering transformer inspection data was sourced from SOM.

# Methodology and assumptions made

# Service line maintenance

• Other than visual inspections undertaken as part of TasNetworks' pole inspection programme, no service wires were inspected during the current reporting period as part of a programme of service line inspection. As TasNetworks had no specific inspection cycle for service wires, TasNetworks has reported no activity in relation to the testing of service lines.

# Pole top and overhead line; Pole inspection and treatment

- The number of poles has been derived by taking a count of the poles recorded in GTech filtered by date installed and grouped by different pole owners in order to exclude privately owned poles from the count.
- The pole count (i.e. number of pole ids) and pole owners were extracted from TasNetworks' Spatial Data Warehouse, as were pole installation dates, with poles and installation dates being matched on the basis of each pole's unique asset identifier.
- The number of pole inspections conducted during the current reporting period was derived by taking a count of completed work tasks in WASP, filtered by date completed to return only inspections carried out in the current reporting period.
- Pole inspections were defined as including only work tasks classified as either Pole Inspect (DAIS) (Task Code 1PID) and Inspect Pole Special Inspections (Task Code 5OP7) with a status of Closed(c) or Completed (Z).
- The average age of poles is calculated from the base of asset age profile reported on Category Analysis RIN 5.2.1.

# **Overhead Asset Inspection**

• The line patrolled value was calculated by multiplying the value of conductor length in service by the number of poles inspected divided by the total number of poles.

# Network underground cable maintenance by voltage; Network underground cable maintenance by location; Distribution substation equipment and Property maintenance;, Zone substation equipment maintenance; Zone substation property maintenance

- The number reported for Distribution substation includes only pad mounted and ground mounted distribution transformers. The pole mounted distribution substations are reported under 'other';
- Asset volumes were sourced from the spatial data warehouse, and SAP;
- Maintenace volumes were soureced from WASP and SAP;

- Average age is calculated by summing the ages of all assets and dividing by the volume for each asset class;
- Inspection and maintenance cycles are sourced from the appropriate management plan. Where varying frequencies exist the tasks with the highest cost has been used as the frequency. Historically, as there are several maintenance frequencies for some tasks, a weighted average has been applied;
- Zone substation volumes and maintenance frequencies were sourced from TasNetworks asset management plan;
- Rural zone substations (22kV) were clasified as distribution substations.
- Average age data for zone substations was calculated using information relative to each Zone substation where:
  - Average age of transformer = total age for all transformers / number of items
  - Average age of switchgear = total age for all switchgear/number of items

# Public lighting maintenance

- TasNetworks has limited data relating to the installation date of individual lights. Age data for lights with no install date was estimated using procurement records or by interviewing employees involved historically with the installation of lighting assets.
- Inspection and maintenance cycles for major and minor lights are based on the average expected life of lamp and photo-electric (PE) cell.

# SCADA & network control maintenance

- SCADA & network control systems form part of:
  - o Reclosers
  - Load break switches
  - Sectionalisers
  - Zone substations (in terms of a complete SCADA system per zone substation).
- Distribution substations are not included as they do not have SCADA systems associated with them.
- Protection systems form part of:
  - Distribution substations (in terms of a complete protection system per distribution substation)
  - Zone substations (in terms of a complete protection system per zone substation).
- Reclosers, load break switches and sectionalisers are not included as protection systems.
- Average age is based on the average installation age of the protection or SCADA systems.
- Less than 5 per cent of the population of Recloser, LBS and sectionaliser devices had no installation dates and were not included in the average age calculation.
- Maintenance of protection and SCADA systems is performed every 5 years as stated in the distribution protection and control asset management plan.
- Inspection of protection and SCADA systems is performed yearly for CBD ground mounted substations and 4 monthly for zone substations as stated in the relevant asset management plans.

# Ground clearance - access tracks

- The inspection and maintenance cycle for access tracks is the same as the pole inspection cycle in order to ensure access to assets for inspectors for the purposes of inspecting poles.
- The average age of access tracks is assumed to be the same as that of the overhead/pole

assets to which they provide access, on the basis that the tracks would have been established around the same time the assets were installed.

• Spans only containing LV circuits are not included in the current iteration of the Span Model. TasNetworks' current program of 'active' vegetation management is based on the Span Model and LV-only spans are not actively managed.

# Other (metering current transformers)

- The volume of metering current transformers was sourced from TasNetworks' Market Data Management System (Gentrack). Due to the way some third party metering providers provide meter standing data (including metering current transformers) to the NEM, TasNetworks is unable to provide data for metering current transformers where TasNetworks is not the metering provider.
- Metering current transformer inspection data was sourced from Gentrackas a count of completed service orders;
- The ten year maintenance cycle is per the asset management plan for metering current transformers and is designed to comply with the requirements of Chapter seven of the National Electricity Rules for metering installations.
- Age data for metering current transformers was sourced from Gentrack, based on the first recorded connection dates of installations with metering current transformers.

#### Pole mounted distribution substation

- The volume of pole mounted distribution susbstations was sourced from GTech. SAP was not used due to the conflicting install dates of the transformers.
- Transformers were only included if they had a construction type of 'SINGLE POLE' or 'DOUBLE POLE' and were owned by TasNetworks
- The maintenance cycles for polemounted distribution substations is based off the transformer earth maintenance schedule.

# Use of estimates

Unless specified below, no estimates have been used in the collation and presentation of this information.

### Pole top, overhead line & service line maintenance

TasNetworks does not maintain records of installation dates for service wires and so age data for poles was used to estimate the age of service wires.

# Public lighting maintenance

Where actual age data for specific lights is not avaiable, the age data for lights was estimated by applying a flat age profile for each make / model of light over the period each particular light was purchased according to purchasing contract records.

#### SCADA & network control maintenance

- Protection system for distribution substations have been estimated as the same installation date of the complete substation.
- SCADA systems for Reclosers, LBS and sectionalisers have been estimated as the same installation date as the Recloser, LBS or sectionaliser.

# Sub-transmission asset maintenance

• TasNetworks had no dual function assets and, therefore reported no descriptor metrics for the maintenance of dual function assets.

	Ground clearance - access tracks
	<ul> <li>TasNetworks does not currently maintain a separate record of access track clearance activity, with ground clearance activities and costs currently being captured under the broader activity of 'Pole top, overhead line &amp; service line maintenance'.</li> </ul>
	<ul> <li>The length of access tracks cleared in the current reporting period has, therefore, been estimated, by dividing the route length of TasNetworks' distribution network which requires non-standard vehicle access (as reported in TasNetworks' response to the Economic Benchmarking RIN for the current reporting period) by the length of the inspection cycle for access track.</li> </ul>
	• The sections of TasNetworks' distribution network requiring non-standard vehicular access have been identified using GTech to identify spans located more than 25 metres from the nearest private off-road trail, public highway or street. Trails explicitly flagged '4WD only' have been excluded as a recognised transport element. After excluding trails explicitly flagged '4WD only', the reported length of the distribution network not within 25m of any transport element is taken to represent the component requiring non-standard vehicular access and, therefore, ground clearance.
	<ul> <li>Data from the previous reporting period has been escalated in proportion to route line length increases to represent data for the current regulatory period.</li> </ul>
	Other
	<ul> <li>Actual install dates for metering current transformers is not available. Age data was estimated based on the first connection date of installations with metering current transformers</li> </ul>
	<ul> <li>TasNetworks is establishing an asset database for metering current transformers to record this information.</li> </ul>
Table 2.8.2:	Consistency of information with the requirements of the RIN
Cost metrics for routine and non- routine	Information has been presented for maintenence in accordance with the definitions and requirements of the RIN.
maintenance	Source of information
	• WASP
	TasNetworks Financial Systems
	Methodology and assumptions made
	• The routine and non-routine maintenance expenditure reported in Table 2.8.2 has been extracted on the basis of work category codes, which represents the manner in which TasNetworks captures routine and non-routine maintenance expenditure.
	Use of estimates
	No estimates have been used in the collation and presentation of this information.

# Template 2.9 Emergency response

Table 2.9.1:	Consistency of information with the requirements of the RIN
Emergency	Information has been presented for emergency response in accordance with the definitions and
response	requirements of the RIN in that:
expenditure (opex)	Emergency response expenditure attributable to major events has been identified using a specific cost code for major events;
(	Emergency response expenditure attributable to major event days has been compiled by identifying the daily operating expenditure incurred on each MED and summing the expenditure for each event; and
	Any major storm days identified during the current regulatory year include only tropical cyclones of category 1 or above.
	Source of information
	WASP
	TasNetworks Financial Sysytems
	Methodology and assumptions made
	<ul> <li>TasNetworks' Regulatory Accounts have been used to reconcile the data</li> </ul>
	• The cyclone history on the Bureau of Meteorology website has been used to confirm if any have occurred during the year.
	<ul> <li>Major Event Days throughout the period have been identified with reference to MED System Average Interruption Duration Index thresholds calculated using the method prescribed by the AER.</li> </ul>
	<ul> <li>The information contained in Table 2.9.1 has been filtered by work category code and cross referenced against the Major Event Days table. In the interests of accuracy, emergency response expenditure data has been extracted with reference to transaction dates (i.e. 'document dates'), which correspond to MEDs, rather than the posting dates recorded in TasNetworks' finance system.</li> </ul>
	<ul> <li>TasNetworks' emergency response expenditure includes expenditure captured in TasNetworks' financial systems in relation to the following types of emergency response activities:</li> </ul>
	<ul> <li>Emergency &amp; Unscheduled Power System Response &amp; repairs (EMRES)</li> </ul>
	<ul> <li>Emergency Management - Customer damage to TasNetworks' Asset (EMDAA)</li> </ul>
	<ul> <li>Emergency Response - Major Event (EMMAJ)</li> </ul>
	• The emergency response expenditure shown in Table 2.9.1 under (b) includes expenditure incurred in responding to all faults that occur on MEDs. The emergency response expenditure totals shown in Table 2.9.1 under(c) include only the costs relating to emergency responses to major events on major event days (EMMAJ). These costs have been taken directly from the network system ledger, meaning that the costs reported for individual days will include capitalised expenditure, but not all overheads and CAM adjustments as they are done on a monthly or end of year basis. The difference between the total EMMAJ category extracted from the network service ledger and what is included in the Annual Reporting RIN has been reconciled.
	<ul> <li>None of the costs of responding to faults and emergencies reported in Table 2.9.1 include the costs associated with the standing down of field crews, as far as they relate to events involving faults and damaged TasNetworks' assets.</li> </ul>
	<ul> <li>Emergency response expenditure attributable to major events has been identified using a specific cost code for major events</li> </ul>
	<ul> <li>Emergency response expenditure attributable to major event days has been compiled by</li> </ul>

 Emergency response expenditure attributable to major event days has been compiled by identifying the daily operating expenditure incurred on each MED and summing the expenditure for each event

• Emergency response expenditure data has been extracted with reference to transaction dates (i.e. 'document dates'), which correspond to MEDs, rather than the posting dates recorded in TasNetworks' finance system.

# Use of estimates

No estimates have been used in the collation and presentation of this information.

# Template 2.10 Overheads

Table 2.10.1:	Consistency of information with the requirements of the RIN
Network	Information has been presented for overheads in accordance with the definitions and
overheads	requirements of the RIN in that it includes expenditure for each of the mandatory
expenditure	subcategories discussed in the RIN.
Table 2.10.2:	<ul> <li>There have been no material changes in reported expenditures as a result of changes in TasNetworks' capitalisation policy.</li> </ul>
Corporate	Source of information
overheads	
expenditure	Association of the second systems (now SAP)
	Annual Reporting RIN
	Methodology and assumptions made
	Network Overheads Expenditure – to all services (total costs including capitalised portion)
	<ul> <li>This information has been derived on the basis of a combination of Network Management and Network Services cost pools. Network Management and Network Services cost pools have been populated from TasNetworks' Annual Reporting RIN;</li> </ul>
	<ul> <li>Network operating costs reported under Network Management costs have been allocated between the six subcategories of overhead expenditure set out in Table 2.10.1 based on the type of work performed, and then allocated to the forms of control; and</li> </ul>
	• The Network operating costs attributed to Network Services in each year were extracted from TasNetworks' financial system General Ledger Overheads Applied code by work category code, and then allocated to the forms of control. These were then allocated to the six subcategories based on the actual percentage spend of all the overheads departments from the financial system, based on the type of work performed.
	Network Overheads Expenditure – to capitalised overheads for only Standard Control Services
	<ul> <li>This information has been derived from an aggregate of relevant Network Management and Network Services cost pools. The Network Management costs that have been allocated to capital works have been extracted from TasNetworks' financial systems. Network Services costs that have been allocated to capital works (capex jobs only) have also been drawn from TasNetworks' financial systems;</li> </ul>
	<ul> <li>Network operating costs relating to Network Management amounts that have been capitalised were allocated to the six subcategories based on the allocation of departmental overheads. They were then allocated to the forms of control based on actual percentage to only capital jobs and the split of the type of work performed; and</li> </ul>
	<ul> <li>Network operating costs relating to Network Services cost recovery against jobs were sourced from TasNetworks' financial system and based on costs that were coded to the General Ledger Overheads Applied code. They were then broken down in each year by work category code to the allocated forms of control as per below. The costs allocated to each form of control were then allocated between the six subcategories in template 2.10 based on the actual percentage spend of all the overheads departments on each type of work performed.</li> </ul>
	Corporate Overheads Expenditure – to all services (total costs including capitalised portion) and capitalised overheads for Standard Control Services
	Corporate Overheads have been populated using the costs allocated in accordance with TasNetworks' Cost Allocation Model which are in line with the Indirect Cost Allocation Model

utilised in prior years. Allocation to forms of control The allocation of Network Overheads between the different forms of control has been based on two methodologies, both of which are in accordance with TasNetworks' approved CAM: Network Management costs have been allocated between the forms of control based on the percentage spend of the total program of work costs driver of forms of control; and Network Services costs have been automatically allocated between forms of control according to the type of work (e.g. work category code), with each type of work allocated directly in TasNetworks' ledger to the relevant form of control. Corporate Overheads Expenditure – to all services (total costs including capitalised portion) The allocation of Corporate Overheads has been split between Network Management and Network Services on the basis of actual spend, and then allocated to a subcategory. The allocation of expenditure within each subcategory between the forms of control has been undertaken using different methodologies for Network Management and Network Services in accordance with the allocation described in Network Overheads Expenditure. Corporate Overheads Expenditure - to capitalised overheads for only Standard Control form of control Corporate overheads expenditure has been calculated on the same basis as the network operating costs relating to Network Services. Use of estimates No estimates have been used in the collation and presentation of this information.

# Template 2.11 Labour

Table 2.11.1:	Consistency of information with the requirements of the RIN
Cost metrics per annum	Information has been presented for labour in accordance with the definitions and requirements of the RIN in that:
Table 2.11.2:	<ul> <li>only labour costs allocated to the provision of standard control services have been reported</li> </ul>
Descriptor	labour data has been broken down into the Classification Levels in template 2.11
metrics	TasNetworks has not separately reported labour sourced through labour hire contracts
	• Average Staffing Levels (ASLs) for each Classification Level reflect the average paid FTEs for each Classification Level over the course of a given year
	<ul> <li>stand down periods have been reported against the relevant classification level in the table containing the relevant labour</li> </ul>
	Source of information
	TasNetworks Financial Systems
	TasNetworks Payroll System
	Methodology and assumptions made
	General
	• Field staff often need to stand-down and when this occurs they include this information in the time which they charge to a job. When entered into TasNetworks' financial systems the jobs used include 'STANDDOWN' in the job description to identify this time. TasNetworks' financial systems jobs were identified and transactions were extracted for these jobs so that occurrences could be counted.
	<ul> <li>Productive work hours have been determined using the available working days per year, adjusted for assumptions developed for budgeting purposes about the average amount of leave (Annual, sick leave and public holidays) taken per FTE.</li> </ul>
	• Office based corporate employees have been assumed to work a standard week, that is 37.5 hours, this extends for the year, reduced by estimated leave per FTE, as follows:
	<ul> <li>average of 20 days annual leave taken per FTE</li> </ul>
	<ul> <li>average of 6 days sick leave per FTE</li> </ul>
	<ul> <li>actual Public holidays per annum (10)</li> </ul>
	<ul> <li>average of 5 additional other days (carers leave and LSL)</li> </ul>
	The labour data was categorised into normal time and overtime.
	• The average productive normal time hourly rate has been determined by taking actual labour costed to standard control services and dividing that cost by the actual labour hours that have been worked for standard control services per classification type.
	• The average productive overtime hourly rate reflects the average of the hourly overtime rates applied to each labour class of employees.
	Corporate overheads (Average Staffing Levels)
	<ul> <li>Reported total FTE numbers are as at 30th June of the current reporting periodr, as provided in TasNetworks' staffing report;</li> </ul>
	• Employee job titles as per TasNetworks' Payroll System (TasNetworks' classification) were categorised into the AER's required classifications as per the RIN instructions; and

• To determine the ASL per labour classification level, the FTE numbers in each RIN labour category were multiplied by the relevant standard control services percentage in accordance with TasNetworks' CAM.

#### Corporate overheads (Total Labour costs)

Total labour costs are reflective of the actual corporate labour costs that have been charged to distribution services plus the labour costs associated with the corporate functions (i.e. the finance and regulatory functions).

# Network overheads (Average Staffing Levels)

Average ASLs for each labour classification type have been determined using actual FTE data and the total labour costs.

#### Network overheads (Total Labour costs)

Total labour costs are reflective of the actual labour costs that have been charged against individual network services and network jobs within TasNetworks' job ledger.

### Total direct network labour (Average Staffing Levels)

The ASL for each labour classification type that has been allocated to standard control services has been determined using the actual number of FTEs per each classification type.

# Total direct network labour (Total Labour costs)

Allocated to standard control services based on actual labour costs captured against standard control services categories as per costing in TasNetworks' financial system for each year.

# Use of estimates

No estimates have been used in the collation and presentation of this information.

# Template 2.12 Input tables

Consistency of information with the requirements of the RIN
The information provided is consistent with the requirements of the RIN.
Source of information
• WASP
• SAP
• Table 2.2 – 2.9 of the RIN
• Table 4.1 – 4.3 of the RIN
Methodology and assumptions made
Actual job costs are directly captured in TasNetworks' financial system as labour, materials, contract costs and/or 'other' costs, in line with Template 2.12 where possible. However, in cases where unit rates have been used to allocate costs to a job, for the purposes of Table 2.12, the associated expenditure on those jobs has been apportioned between the above cost categories based on the expenditure in each category recorded in the Network Services ledger as a percentage of the total.
Use of estimates
No estimates have been used in the collation and presentation of this information.

# Template 4.1 Public lighting

-	
Table 4.1.1:	Consistency of information with the requirements of the RIN
Descriptor	Information has been presented for public lighting in accordance with the definitions and
metrics over the	requirements of the RIN in that:
current reporting period	<ul> <li>The data provided reconciles to internal planning models used in generating TasNetworks' proposed revenue requirements;Public lighting volumes and costs have been recorded on an incurred basis;</li> </ul>
	<ul> <li>Lighting types have been reported in a manner which is consistent with the RIN definitions of major and minor lighting;</li> </ul>
	Customer contributions have not been subtracted from the amounts reported; and
	<ul> <li>No information relating to gifted assets has been included.</li> </ul>
	Source of information
	The population of each public lighting type for the current reporting period was sourced from Gentrack. This system is the master record for public lighting.
	Methodology and assumptions made
	The lighting volumes were reported based on install date information from Gentrack and Unmetered Supply (UMS) audits. These volumes are consistent with the volumes used for the purposes of retailer billing and are consistent with the volumes assumed for the purposes of asset management.
	Use of estimates
	No estimates have been used in the collation and presentation of this information.
Table 4.1.2:	Consistency of information with the requirements of the RIN
Descriptor metrics annually	Information has been presented for public lighting in accordance with the definitions and requirements of the RIN in that:
	Costs have been recorded on an as incurred basis; and
	Costs have been classified as either:
	<ul> <li>replacement</li> </ul>
	$\circ$ installation
	• maintenance expenditure
	• The quality of supply data describes the voluntary 'GSL' payments made in relation to public lighting under TasNetworks' Customer Charter
	Source of information
	TasNetworks Financial Sysytems (now SAP)
	• GTech
	Gentrack
	Service Order Managament (SOM)
	Customer Complaint Management Systems – Customer Advocacy Tool (CAT)
	Methodology and assumptions made
	Cost

	regulatory accounts; and
	<ul> <li>Costs relating to private lights have been excluded through apportioning total costs against the volume of public and private lights as at year end.</li> </ul>
	Volumes
	<ul> <li>Volumes of public lighting materials for lamps and luminaires installed during the current reporting period were sourced from the TasNetworks' financial systems;</li> </ul>
	<ul> <li>Volumes of dedicated public lighting poles were sourced from GTech;</li> </ul>
	<ul> <li>Materials are classified into major or minor public lighting categories according to the type of asset. Luminaires up to and including 100 watts are classified as minor lights and over 100 watts are major lights; and</li> </ul>
	<ul> <li>When materials are issued from the warehouse they are assigned to a work pack that corresponds to the type of task being performed, e.g. install new light, fault response or replacement.</li> </ul>
	Mean days to rectify
	Calculation of the mean days taken to rectify or replace public lighting assets was based on a count of business days between the creation and completion dates recorded for each service order relating to public lighting faults in SOM.
	Quality of supply
	<ul> <li>Data relating to complaints from customers about public lighting was sourced from a TasNetworks' complaint management system known as the Customer Advocacy Tool (CAT).</li> </ul>
	• The volumes and values of payments made to customers who received a standard of service below that set out in the charter in the current reporting period have been derived from records kept in the Charter Payment Tool, which is part of TasNetworks' customer complaint management systems.
	Use of estimates
	No estimates have been used in the collation and presentation of this information.
Table 4.1.3:	Consistency of information with the requirements of the RIN
Cost metrics	Information has been presented for public lighting in accordance with the definitions and requirements of the RIN.
	Source of information
	TasNetworks Financial Systems
	Methodology and assumptions made
	<ul> <li>The volumes of public lighting materials for lamps and luminaries' installed were sourced from the TasNetworks' finance system.</li> </ul>
	Cost data has been reconciled to the Annual Reporting RIN.
	<ul> <li>Materials have been classified into major and minor public light categories according to the type of asset.</li> </ul>
	<ul> <li>When materials are issued from the warehouse they are assigned to a work pack that corresponds to the type of task being performed (e.g. install new light, fault repair or</li> </ul>

replacement etc).
<ul> <li>Public lighting costs are, however, captured for the entire lighting suite, rather than specific to particular lighting types.</li> </ul>
• Light replacement and light maintenance have been sourced from TasNetworks' financial systems and combined with calculated unit rates to derive average cost by lighting type.
Use of estimates
No estimates have been used in the collation and presentation of this information.

# Template 4.2 Metering

•	
Table 4.2.1:	Consistency of information with the requirements of the RIN
Metering descriptor metrics	Information has been presented for metering in accordance with the definitions and requirements of the RIN.
	Source of information
	Gentrack
	• SOM
	Methodology and assumptions made
	The Gentrack query is run on the first working day of each month and the resultant data is saved so that a total of installed meters at the start of each month is recorded.
	The volumes were sourced from a snapshot from Gentrack of all basic meters. This was analysed to define the types of meters for each RIN category.
	Use of estimates
	No estimates have been used in the collation and presentation of this information.
Table 4.2.2:	Consistency of information with the requirements of the RIN
Cost metrics	Information has been presented for metering in accordance with the definitions and requirements of the RIN in that it includes expenditure incurred in relation to all non-contestable, regulated metering services.
	Source of information
	TasNetworks Financial Systems
	• SOM
	Gentrack
	Methodology and assumptions made
	• Actual expenditure (excluding overheads) is as per TasNetworks' financial systems.
	<ul> <li>Volumes (except Meter purchase and Scheduled meter reading) are sourced from SOM data of the financial year.</li> </ul>
	<ul> <li>The Work Category Codes used to extract metering costs from the financial systems capture the costs associated with: Meter Reads and special meter reads (MDSMR), Meter Replacement, (MEREP) Meter Testing (AIMET), Meter Maintenance and Investigations (ARMER) and Meter Installations (MENIN).</li> </ul>
	• The costs of purchasing meters has been determined by applying the unit rate against the volume of meters purchased, which were sourced from Gentrack.
	<ul> <li>Meter Reads split costing is based on individual job numbers that capture special and scheduled reads on the Network Services side as other labour costs applied after intercompany transfer have apportioned labour and overhead costs based on the actual in Network Services.</li> </ul>
	• Scheduled Meter Reading numbers are extracted from monthly conformance reports (total reads).

• Every meter inspection involves removing the seal to assess the meter. Resealing the meter is counted as maintenance, therefore every inspection involves the meter being maintained regardless of the repair amount. All meter maintenance involves an investigation first, therefore the volumes of the service subcategories are the same.

# Use of estimates

- TasNetworks does not capture the cost of conducting metering investigations, with metering investigation costs captured under the broader expenditure category of Meter Maintenance and Investigations. In order to provide the requested metering investigation costs, expenditure on meter maintenance has been apportioned between Meter Investigations and Meter Maintenance on the basis of a 20/80 percentage split. The split between meter maintenance and investigations represents an estimate by the relevant Asset Manager that seeks to average the significant variation in investigative effort involved across a wide range of meter maintenance jobs.
- The split between meter maintenance and investigations represents an estimate by the relevant Asset Manager that seeks to average the significant variation in investigative effort involved across a wide range of meter maintenance jobs.

Template 4	Ancillary services – Fee-based services
Table 4.3.1:	Consistency of information with the requirements of the RIN
Cost metrics for fee-based	<ul> <li>Information has been presented for ancillary services – fee based services in accordance with the definitions and requirements of the RIN; and</li> </ul>
services	<ul> <li>Section 15.3 of the RIN requires TasNetworks to provide a description of each fee based service listed in regulatory Template 4.3 that explains the purpose of each service and details the activities which comprise each service. That information is available in the <u>Ancillary Services – Fee Based Services Guide</u> available on our website.</li> </ul>
	Source of information
	TasNetworks Financial Sysytems
	• SOM
	Gentrack
	Methodology and assumptions made
	<ul> <li>The costs associated with the provision of fee-based services have been reconciled to the Annual Reporting RIN;</li> </ul>
	<ul> <li>Volume data relating to fee-based services was sourced from SOM based on service orders with an overall status of 'complete';</li> </ul>
	<ul> <li>All miscellaneous fee-based services volumes were sourced from SOM based on service orders with an overall status of 'complete'.</li> </ul>
	<ul> <li>All annual energisation, de-energisation and re-energisation volumes were sourced from Gentrack.</li> </ul>
	<ul> <li>All costs incurred in the provision of fee-based service are captured against the same cost code in TasNetworks' finance system. For the purpose of Table 4.3.1, total fee-based service costs have been apportioned across fee-based service sub-categories on the basis of Regulated Prices and activity volumes.</li> </ul>
	<ul> <li>All annual energisation, de-energisation and re-energisation volumes were sourced from Gentrack.</li> </ul>
	Basic Connection Services are not included in the Fee-Based Services volumes.
	• The installation of pulse outputs are included in tariff alterations.
	Use of estimates
	No estimates have been used in the collation and presentation of this information.

# Template 4.4Ancillary services – Quoted services

Table 4.4.1:	<b>Consistency of informat</b>	ion with the requirements of	the RIN	
Cost metrics for quoted services	<ul> <li>Information has been presented for ancillary services – quoted services in accordance with the definitions and requirements of the RIN in that:</li> </ul>			
	• TasNetworks has not distinguished between standard or alternative control services when reporting expenditure for quoted services, as per paragraph 15.4;			
	<ul> <li>TasNetworks has not reported on quoted</li> </ul>	t differentiated between capex or or services, as per paragraph 15.5;	bex in relation to the expenditure	
	<ul> <li>the capture of costs for quoted services provided in Template 4.4 is consistent with the definition of quoted services given in Appendix F of the RIN;</li> </ul>			
	<ul> <li>Section 15.1 states that the data provided in relation to quoted services must reconcile to internal planning models used in generating TasNetworks' proposed revenue requirements. The information provided for the current reporting period has been based on actual data and reconciles with the data provided in response to the Annual Regulatory Information Notice for the same year;</li> </ul>			
	<ul> <li>Section 15.2 is not a TasNetworks' annua</li> </ul>	pplicable to TasNetworks, as quoted I tariff proposal; and	services are not listed in	
	<ul> <li>Section 15.3 requires regulatory template which comprise each</li> </ul>	s TasNetworks to provide a descripti 4.4 that explains the purpose of eac n service. That information is provid	on of each quoted service listed in h service and details the activities ed in the following table:	
	Service	Purpose	Activities	
	Relocation/Removal - Poles	To capture expenditure on customer driven pole relocations/removals	Pole relocation and removal in its entirety	
	Relocation/Removal - Substations	To capture expenditure on customer driven substations relocations/removals	Relocation and removal of substation in entirety or components, eg door way removed or building design mortifications	
	Relocation/Removal - Transformers	To capture expenditure on customer driven transformers relocations/removals	Transformers removal and relocation in its entirety	
	Relocation/Removal - Overhead	To capture expenditure on customer driven overhead assets relocations/removals	Relocation or removal of overhead components including; low voltage wire, high voltage wire , service wire, fibre, conductors, switches/fuses	
	Relocation/Removal - Underground	To capture expenditure on customer driven underground assets relocations/removals	Relocation or removal of underground components including; low voltage cables, high voltage cable, cabinets, turrets	
	Services of higher standard - Substation	To capture expenditure on customer driven above standard substation works	Modifications to substation for customer needs, including; building design modifications	
	Services of higher standard -	To capture expenditure on customer driven above	Modifications to transformer design for customer	
	Services of higher standard - Overhead	To capture expenditure on customer driven above standard overhead asset works	Modifications to overhead asset design for customer needs, including; overhead wires both low voltage and high voltage, service wire, conductors etc	
	Services of a non standard nature - Connections	To capture expenditure on customer driven service connection and metering works	Disconnects, reconnections, metering upgrades, new mains connections Could encompassed both overhead and	
	Services of a non standard nature - Subdivisions	To capture expenditure on customer driven subdivision overhead and underground works	components, looks at activities directly related to subdivisions as requested by developers Modifications to line designs for customer needs	
	Services of higher standard - Poles Services of a non standard nature -	above standard pole works. To capture expenditure on customer driven	including the installation of additional poles Modifications to cable designs for customer needs	
	Underground	underground works.	including cable size and location	
	Source of information			
	<ul><li>TasNetworks Financi</li><li>WASP</li></ul>	ial Systems		
	Methodology and assum	nptions made		
	<ul> <li>Data has been obtain</li> </ul>	ned directly from TasNetworks' finar	ncial systems for the direct work	
	costs associated with	n quoted services work. These costs	have then had the overhead	

component removed and reconciled back to the Opex Allocation Model.
<ul> <li>Data was extracted from WASP for all projects relating to quoted services (i.e. Work Level = QUOT). This data details the Service Sub-Category relating to project costs. In instances where the Service Sub-Category field was blank, the project details were manually checked in TasNetworks' financial systems to determine the nature and, therefore, the applicable Service Sub-Category.</li> </ul>
• Data was also extracted from WASP for the work category CIMIX, which is used to apportion costs to projects that relate to multiple service types.
• Information related to corporate overheads and shared services costs were sourced from the Annual Regulatory Information Notice – Opex Allocation Model.
<ul> <li>Quoted services project data from WASP was summarised into Work Categories and Design Project Types with associated total costs and volumes. Design Project Types have been mapped to a RIN Service Subcategory to enable direct population of Table 4.4.1.</li> </ul>
• The following assumptions were applied to the data:
<ul> <li>where a Work Category links directly to a type of service, all volumes and costs for that Work Category were applied to that service e.g. the work category QUSCO is 100 per cent allocated to the service "Services of a non standard nature – Connections"</li> </ul>
<ul> <li>the Design Project Type was used to classify projects across service types e.g. where 'pole' has been recorded as the project description, it was assumed that the project related to poles</li> </ul>
<ul> <li>When assumptions 1 or 2 could not be applied, information about the service type was manually sourced from WASPby referencing customer letters, project notes or directly from the scope.</li> </ul>
<ul> <li>in relation to volumes data, a 'one project for one service' relationship was assumed for all service types (i.e. volume = 1 for each project) except for pole relocation and removal.</li> </ul>
<ul> <li>For the 'Relocation/Removal – Poles' service category, volumes were derived using a unit rate per pole against the cost of the project. The unit rate was built up by a business expert. The volume derived for each project has not been rounded or truncated to arrive at the overall annual total.</li> </ul>
Use of estimates
No estimates have been used in the collation and presentation of this information.

# Template 5.2 Asset age profile

 Table 5.2.1:
 Consistency of information with the requirements of the RIN

 Asset age profile
 Information has been presented for asset age profile in accordance with the definitions and requirements of the RIN in that:

 •
 the asset subcategories in Table 5.2.1 correspond with the prescribed asset categories in Table 2.2.1

- the information reflects total volumes of assets currently in commission
- The information provided in relation to SCADA, Network Control and Protection Systems is consistent with the definition provided in the RIN notice.

## Source of information

• Spatial Data Warehouse

### SCADA & network control

 Wherever possible, asset information has been sourced from SAP, site audit information, test reports stored in TasNetworks' intranet 'The ZoNe', or documentary records such as asset management plans.

# Methodology and assumptions made

#### General

- TasNetworks reported asset age profile was reported on a calendar year basis up until 2015/2016 and from 2016/2017 it is reported on a financial year basis and which all asset categories are affected by the change;
- The economic lives for TasNetworks' assets are sourced from TasNetworks' Regulated Asset Base, other than public lighting assets where asset lives have been taken from TasNetworks' public lighting annuity model; and
- The standard deviation for the economic life of TasNetworks' assets has been estimated as the square root of the mean, as discussed on page 51 of the AER's explanatory statement for the RIN.

#### Poles

- Pole data is captured either through in-field work processes, or by pole inspectors
  operating under a five year inspection cycle, delays of over 12 months may be experienced
  in the data capture process. Rules applying to the recording of new poles in TasNetworks'
  GIS also require that poles can only be added to the database when they have been
  assigned a Pole Tag ID and their installation has been confirmed. If no confirmation is
  received from the field of a pole having been erected, a record of the new pole may not be
  added until the pole is next inspected, which may not occur for another five years under
  TasNetworks' current inspection regime;
- An extract of pole asset data was taken from TasNetworks' spatial data warehouse. Attributes that were extracted included: pole material, pole staking status, voltage, and installation date. Only poles owned by TasNetworks and a small number of poles with unknown or null owners were included. All poles dedicated to public lighting were excluded from this data set; and
- Poles were categorised by material and by voltage.

#### **Overhead conductors**

As discussed in estimated information section below.

# Underground cables

As discussed in estimated information section below.

# Service lines

As discussed in estimated information section below.

# Transformers

- An extract of transformer asset data was taken from TasNetworks' spatial data warehouse. The attributes that were extracted included:
  - Asset owner
  - Voltage
  - Transformer size
  - HV and LV switchgear
  - Phase count
  - Construction type
  - Year installed.
- Transformers were categorised by construction type as either pole mounted, kiosk mounted (including pad-mounted transformers) or ground outdoor/chamber mounted.
- Transformers with a recorded phase count of 0, 1 or 2 have been classified as single phase transformers.

#### Switchgear

- An extract of HV and LV switchgear asset data was taken from TasNetworks' spatial data warehouse, including:
  - switchgear installed in substations/switching stations (i.e. ground mounted switchgear)
  - overhead switchgear
- A list of zone substations and the number of breakers at each site were extracted (feeder switchgear)
- All switchgear was categorised by voltage and type into required categories for the RIN as advised by subject matter experts, and then consolidated into the RIN template.

# Public lighting

- This section does not cover public lighting lamps
- TasNetworks interprets a public lighting bracket which is dedicated to public lighting and owned by TasNetworks.
- TasNetworks interprets a public lighting pole/column as a pole dedicated to public lighting, owned by TasNetworks, irrespective of whether the Un-Metered Supply (UMS) type is 'public' or 'private'. This is not the same definition that is used for the Economic Benchmarking RIN.
- An extract of UMS data was taken from TasNetworks' spatial data warehouse. The query linked UMS that were supported by a pole to a pole tag, which enabled the pole material, installation date and owner of that pole to be retrieved.
- Poles were classified as columns if the pole material attribute was 'Steel-Other', otherwise they were classified as poles.
- Un-Metered Supplies were classified as major if the wattage of the lamp/luminaire was greater than 100W, otherwise they were classified as minor.

• Where no additional information was available, poles with no recorded material, voltage or installation date were distributed proportionally across the population of poles of the same type and installation date.

# SCADA, network control and protection systems

- A 'field device' is defined to include the following devices as per RIN instructions:
  - o Relays
  - Remote Terminal Unit
  - Program Logic Controllers
  - Data storage
  - o communication interfaces
  - local master stations
- Data provided pertains to TasNetworks' zone substation assets only, which are the 33/11 kV substations.
- Field device numbers relate to the number of protection and control devices in zone substations which are mostly protection relays. The corresponding device numbers have been sourced from the most recent audit of zone substation secondary equipment. Volumes includes the protection relays located at upstream terminal substations for associated sub-transmission protection.
- Communications site infrastructure is assumed to be the same as communications network assets.
- Communication network asset volumes are based on one Remote Terminal Unit and one Ethernet switch per zone substation as well as one AVR per transformer and HMI units at the applicable zone substation sites. There are an unknown number of other devices.
- Communications linear assets are based on the number of fibre optic links between the zone substation and its upstream substation, which corresponds with the number of transformers at the zone substation. AFLC is assumed to denote Audio Frequency Load Control assets, of which TasNetworks has none.
- 'Terminal Station' is defined by TasNetworks as the upstream substation supplying the associated zone substation. Terminal stations supplying zone substations all have 33 kV sub-transmission links. Accordingly, some distribution protection assets are located within the terminal stations supplying zone substations. The terminal station assets are split in accordance with the number of power transformers in each zone substation. These devices are then added to the total device count for each zone substation.
- Previous RIN submissions hadn't included SCADA and protection system replacements that had occurred at Sandy Bay zone substation. These replacement numbers have been updated for the 2013/2014 financial year.
- The asset categories used for the asset age profile differ from the asset categories used in the maintenance tables (2.8). Hence the total number of SCADA and protection systems cannot be reconciled between these tables.

# Use of estimates

- Unless specified below, no estimates have been used in the collation and presentation of this information;
- TasNetworks distribution asset installation date is capture in full date format since 2010.
   Prior to 2010, only the year values are stored in the database. Where there is no full installation date the quantity of the asset is weighted between the financial years based on the install year date; and
- TasNetworks has not captured installation dates of some asset categories until recently. In these circumstances, estimates of those assets' ages have been made for the purposes of asset age profiling.

# Poles

- Where there is no voltage and no material information, the poles are distributed across the RIN categories based on the proportion of poles in the RIN categories for which this information is known. Where no voltage information was available, those poles were categorised by voltage in proportion with the breakdown of poles with the same pole material. All poles in the system have been allocated to a RIN category.
- For poles where the age information is not available, the age of these poles are distributed proportionally across the population according to the volumes of poles where age is known, for each RIN category.
- The volume of poles for which age information must be estimated is approximately 7 per cent of the total population of poles.

# **Overhead conductors**

TasNetworks' implemented a project to better estimate the age of the HV conductors in the distribution network. A schema was developed in the Spatial Data Warehouse to store the information of estimated age, through live connections to GIS data. Where possible, the age of conductors are assigned the values of the age of the poles, to which they are connected. Where age data cannot be calculated through this method, these conductors are proportionally assigned the ages of conductor populations whose ages are known.

## Underground cables

- TasNetworks does not have reliable historical records of the installation date of HV or LV cables. TasNetworks' implemented a project to better estimate the age of the HV cables in the distribution network;
- For HV cables, a spreadsheet was developed that uses GIS connectivity traces to determine the physical asset, to which the cable is connected. The age of the cable is assumed to be equal to the age of the asset, to which it is connected;
- For LV cables, TasNetworks' developed a low voltage connectivity model to create a vegetation span model. This model is also used to determine the connectivity of LV cables, where possible, to the transformers to which they are connected. The age of LV cables is approximated as the age of the transformer from which the cable is supplied; and
- Where ages of these assets are not known, cables are assigned ages proportionally, from the population of cables, whose age is known.

#### Service lines

- Recorded asset information regarding LV services is limited. TasNetworks currently captures whether a line is located overhead or underground and its voltage, but does not include size, material, type or installed date. While installation dates from TasNetworks' NMI records would be TasNetworks' preferred proxy for the installation date of a service line, this information could not be used for the purposes of this RIN due to issues with installation dates requiring validation. Therefore, the age of the pole to which a service line is connected was deemed an acceptable substitute methodology until NMI installation dates become available;
- Geomedia was used to undertake spatial analysis and return the age of the pole and the number of LV services that were close to that pole;
- A query of TasNetworks' NMI installation data was used to determine the proportion of residential NMIs, commercial and industrial NMIs;
- Services associated with poles for which no installation date (year) was available were distributed proportionally across the rest of the population. The proportions of residential versus commercial/industrial were then applied to the age profile to give values for each

type of installation;

- LV services are assumed to be the same age as the nearest pole;
- LV service numbers are a count of the number of services, not the length of those services;
- All services are <= 11 kV and are simple connections; and
- The proportion of service lines supplying residential customers as opposed to commercial and industrial services is deemed to be the same as indicated by the proportion of NMIs associated with each broad customer category.

### Transformers

• Where no information is on record regarding the attributes of a transformer such as voltage and transformer size, those transformers have been distributed across the population of transformers consistent with the age profile of transformers of the same type and similar installation dates.

# Switchgear

• Asset information regarding overhead switchgear is limited. It has been assumed that the installation date of switchgear is the same as the transformer/site installation date. Pole installation dates have been used as a proxy for site date for overhead switchgear sites. Any residual volumes were evenly distributed across the population of switchgear of that category.

### Public lighting

- TasNetworks has limited data relating to the installation date of individual luminaires. Age
  data for lights with no install date was estimated using procurement records or by
  interviewing employees involved historically with the installation of lighting assets. The
  volumes of lights installed in each year was given a flat profile for the period each
  particular light was purchased by TasNetworks;
- To identify public lighting brackets, TasNetworks' public lighting pole data was queried to identify all UMSs that are installed on poles that do not have unique pole tags. This count was distributed proportionally across the population of poles of the same type and installation date where no additional information was available; and
- Public lighting brackets are assumed to be the same age as the pole.

#### SCADA, network control and protection systems

• Local network wiring assets, due to lack of details in TasNetworks' historical asset records, have been assumed to be the same as the estimated number of field devices.

Other

# Template 5.3Maximum demand at network level

-		
Table 5.3.1:	Consistency of information with the requirements of the RIN	
Raw and	The information provided about the maximum demand at network level in Table 5.3.1 Raw and	
weather	weather corrected coincident MD at network level is consistent with the requirements of the RIN in that:	
coincident MD at network level	<ul> <li>the coincident raw system annual maximum demands are the actual unadjusted summation of actual raw demands for the transmission connection point, at the time when the summation is greatest;</li> </ul>	
	<ul> <li>weather correction has also been applied to unadjusted raw demand data to calculate weather corrected 50% POE and 10% POE maximum demands;</li> </ul>	
	<ul> <li>the maximum demand data reported in Table 5.3.1 is presented on a regulatory year basis; and</li> </ul>	
	<ul> <li>all non-scheduled embedded generation data for embedded generators over 0.5MW are included and is the net export to the network at the connection point.</li> </ul>	
	Source of information	
	<ul> <li>Raw demand data has been sourced from National Electricity Market metering and TasNetworks' SCADA data retrieving tool (eDNA) at connection points; and</li> </ul>	
	Bureau of Meterorology weather data.	
	Methodology and assumptions made	
	<ul> <li>the coincident raw system annual maximum demands are the actual unadjusted summation of actual raw demands for the transmission connection point, at the time when the summation is greatest</li> </ul>	
	<ul> <li>The weather correction process involves temperature sensitivity analysis at each connection point to determine the demand response to a change in temperature of one degree. The linear variation of daily maximum demand of each season against daily average temperature is taken as demand sensitivity to temperature. The process then determines the relationship between the temperature on the highest demand day and the average long term temperature at the site to determine the relativity to the 50 POE or 10 POE scenarios</li> </ul>	
	<ul> <li>50 and 10 POE temperatures are derived from long term seasonal minimum daily average temperatures.</li> </ul>	
	• The difference between the average temperature of the maximum demand day and POE temperature is multiplied by the temperature sensitivity and added to recorded maximum demand to derive temperature corrected maximum demand.	
	• Power factor is calculated as the average of all the half hourly measurements and applied across the whole year when converting MW to MVA.	
	Use of estimates	
	No estimates have been used in the collation and presentation of this information.	

# Template 5.4 Maximum demand at network level

Table 5.4.1:
Non-coincident
and coincident
maximum
demand

# Consistency of information with the requirements of the RIN

The information provided about the non-coincident and coincident maximum demands for the zone substations in Table 5.4.1 Non-coincident & Coincident Maximum Demand at network level is consistent with the requirements of the RIN, in that:

- the coincident raw system annual maximum demands are the unadjusted summation of actual raw demands for the transmission connection point, at the time when the summation is greatest
- weather correction has also been applied to raw demand data to calculate weather corrected 50 POE and 10 POE maximum demands
- the maximum demand data reported in Table 5.4.1 is presented on a regulatory year basis
- all non-scheduled embedded generation data for embedded generators over 0.5MW are included and is the net export to the network at the connection point

# Source of information

- Raw demand data is sourced from National Electricity Market metering and eDNA at connection points.
- Bureau of Meterorology weather data

# Methodology and assumptions made

- The coincident raw system annual maximum demands are the unadjusted summation of actual raw demands for the transmission connection point, at the time when the summation is greatest.
- The weather correction process involves temperature sensitivity analysis at each connection point to determine the demand response to a change in temperature of one degree. Raw unadjusted MD has been used in the weather correction process. The linear variation of daily maximum demand of each season against daily average temperature is taken as demand sensitivity to temperature.
- The process then determines the relationship between the temperature on the highest demand day and the average long term temperature at the site to determine the relativity to the 50 POE or 10 POE scenarios. 50 and 10 POE temperatures are derived from long term seasonal minimum daily average temperatures.
- The difference between the average temperature of the maximum demand day and POE temperature is multiplied by the temperature sensitivity and added to recorded maximum demand to derive temperature corrected maximum demand.
- The substation and transformer MVA ratings provided are based on 'cyclic rating' as required by the RIN. This applies to substation normal and emergency ratings as well as individual transformer ratings. Substation ratings are typically based on nameplate rating from the equipment manufacturer. As TasNetworks does not currently have thermal models of the transformer loading capacity the cyclic ratings provided are a 30% increase of nameplate continuous rating.
- Power factor is calculated as the average of all the half hourly measurements and applied across the whole year when converting MW to MVA.

# Use of estimates

No estimates have been used in the collation and presentation of this information.

# Template 6.3Sustained interruptions to supply

Table 6.2.1.	Consistency of information with the requirements of the DIN	
	Consistency of information with the requirements of the Rin	
Sustained	Information has been presented for sustained interruptions to supply in accordance with the	
supply	e interruptions have been defined as less of electricity supply to a sustemer associated with	
շտրիւչ	<ul> <li>Interruptions have been defined as loss of electricity supply to a customer associated with an outage of any part of the electricity supply network, including generation facilities and transmission networks, of more than 0.5 seconds, including outages affecting a single premises;</li> </ul>	
	<ul> <li>the customer interruption starts when recorded by equipment such as SCADA or, where such equipment does not exist, at the time of the first customer call relating to the network outage. An interruption may be planned or unplanned, momentary or sustained. Subsequent interruptions caused by network switching during fault finding are not recorded as additional outages. An interruption ends when supply is restored to the customer;</li> </ul>	
	<ul> <li>Feeder and Community SAIDI and SAIFI are calculated in accordance with TEC section 8.6.11; and</li> </ul>	
	• The Major Event Day threshold calculated in accordance with the 2.5ß methodology defined in with TEC section 8.6.11.	
	Source of information	
	Inservice	
	• r NOCS	
	Methodology and assumptions made	
	<ul> <li>All reliability performance indices (SAIDI and SAIFI) have been calculated using disconnected customers and customer duration at the time of the outage.</li> </ul>	
	<ul> <li>Outage data from WASP was migrated into Inservice and used in the outage calculations. The dataset ranges from 1<sup>st</sup> July 2017 to the 27<sup>th</sup> April 2018 due to migration across to new systems</li> </ul>	
	• All outages for the current reporting period on mainland Tasmania (i.e. excluding UMS and Bass Strait Islands) have been captured, with the outages' impact measured on the basis of disconnected customers and customer duration as per the RIN requirements.	
	• The data was then cleansed to ensure completeness of customers disconnected and customer durations. All outages were manually inspected to identify issues and information sourced from Inservice. Where a customer was connected to a transformer that bordered on two reliability areas, the reliability area of highest customer count was chosen (e.g. urban over high density rural).	
	• TasNetworks' outage categories were then mapped to the AER's categories and applied to the outage data.	
	<ul> <li>An extract of Major Event Days was taken from the current Annual Reporting RIN response and cross referenced with outage data to determine the outages that occurred on major event days.</li> </ul>	
	<ul> <li>Momentary interruptions are not recorded for all feeders and TasNetworks is unable to determine the causes of many momentary interruptions.</li> </ul>	
	<ul> <li>Momentary interruptions caused by reclosers are automatically captured by TasNetworks' automatic download process for devices where communications are available. Momentary interruptions on circuit breakers are extracted from NOCS on a quarterly basis.</li> </ul>	
	<ul> <li>A query was run to extract all momentary outages on TasNetworks' distribution network for the current reporting period with the outage impact measured by disconnected kVA</li> </ul>	

and customers, in line with TasNetworks' STPIS reporting requirements and Category RIN reporting requirements. Disconnected kVA and customers are based on network configuration at the time of running the query, not the configuration at the time of the interruption as the MAIFI calculation relies on TasNetworks' protection zone model, which is refreshed each day and does not store changes.
• MAIFI for each reliability classification was calculated by customers interrupted divided by the total number of customers in each reliability area.
<ul> <li>All momentary outages have been assumed to be unknown causes and have no duration associated with them as they are less than 1 minute in duration.</li> </ul>
<ul> <li>MAIFI by feeders was calculated from number of customers disconnected divided by total customers of that feeder category in AER – RIN CA EB AR Reliability Stats, MAIFI Data</li> </ul>
• Events were grouped by day, time, feeder number and feeder classification.
Use of estimates
No estimates have been used in the collation and presentation of this information.

