




# ElectraNet Transmission Network Revised Revenue Proposal

Appendix G ElectraNet, Revised Connection  
Point Demand Forecasts,  
December 2012





# ELECTRANET TRANSMISSION NETWORK REVISED REVENUE PROPOSAL

Appendix G – ElectraNet Revised 2012 Demand Forecasts



The following table presents ElectraNet’s revised demand forecast for the majority of grouped connection points in South Australia. These forecasts are a result of adjusting the 2012 SA Power Networks 10 per cent PoE forecast for extra embedded generation and curtailed load.

## J-1: ElectraNet’s metropolitan and country meshed connection point forecasts

| Connection Point        | Units | 11/12 | 12/13 | 13/14 | 14/15 | 15/16 | 16/17 | 17/18 | 18/19 | 19/20 | 20/21 | 21/22 | 22/23 | 23/24 | 24/25 | 25/26 | 26/27 | 27/28 | 28/29 | 29/30 | 30/31 | 31/32 |
|-------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Year from Base          |       | 0     | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10    | 11    | 12    | 13    | 14    | 15    | 16    | 17    | 18    | 19    | 20    |
| EASTERN SUBURBS         | MW    | 221   | 224   | 227   | 230   | 233   | 244   | 247   | 250   | 254   | 257   | 260   | 263   | 267   | 270   | 273   | 277   | 280   | 284   | 287   | 291   | 295   |
|                         | PF    | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  |
| ADELAIDE CENTRAL REGION | MW    | 722   | 733   | 789   | 801   | 814   | 835   | 848   | 862   | 875   | 889   | 903   | 917   | 931   | 946   | 960   | 975   | 990   | 1005  | 1020  | 1035  | 1051  |
|                         | PF    | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.96  | 0.96  | 0.96  |
| SOUTHERN SUBURBS        | MW    | 708   | 771   | 747   | 761   | 727   | 743   | 757   | 772   | 786   | 801   | 816   | 832   | 847   | 863   | 879   | 895   | 912   | 929   | 946   | 963   | 981   |
|                         | PF    | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  |
| WESTERN SUBURBS         | MW    | 461   | 469   | 521   | 530   | 539   | 548   | 558   | 568   | 578   | 588   | 598   | 608   | 619   | 629   | 640   | 651   | 662   | 673   | 685   | 696   | 708   |
|                         | PF    | 0.99  | 0.99  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.95  | 0.95  |
| NORTHERN SUBURBS        | MW    | 364   | 374   | 341   | 350   | 360   | 370   | 380   | 391   | 402   | 413   | 424   | 436   | 448   | 460   | 473   | 486   | 500   | 513   | 527   | 542   | 557   |
|                         | PF    | 0.99  | 0.99  | 1.00  | 1.00  | 1.00  | 1.00  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.98  | 0.98  | 0.98  | 0.98  | 0.97  | 0.97  | 0.97  | 0.97  | 0.96  | 0.96  |
| PORT PIRIE SYSTEM       | MW    | 80    | 81    | 82    | 83    | 84    | 85    | 85    | 87    | 88    | 89    | 90    | 91    | 92    | 93    | 94    | 96    | 97    | 98    | 99    | 102   | 103   |
|                         | PF    | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  |

The following table presents ElectraNet’s revised demand forecast for the remainder of connection points in South Australia. These forecasts are based on SA Power Networks 2012 10 per cent PoE for connections points that are ETC Category 2 and above and SA Power Networks 2012 medium scenario peak demand forecasts for Category 1 connection points. Of these connection points only Dorrien and Whyalla have been adjusted for extra embedded generation and curtailed load.

**ELECTRANET TRANSMISSION NETWORK REVISED REVENUE PROPOSAL**

Appendix G – ElectraNet Revised 2012 Demand Forecasts



**J- 2: ElectraNet’s country connection point forecasts**

| Connection Point | Units | 11/12 | 12/13 | 13/14 | 14/15 | 15/16 | 16/17 | 17/18 | 18/19 | 19/20 | 20/21 | 21/22 | 22/23 | 23/24 | 24/25 | 25/26 | 26/27 | 27/28 | 28/29 | 29/30 | 30/31 | 31/32 |
|------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Year from Base   |       | 0     | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10    | 11    | 12    | 13    | 14    | 15    | 16    | 17    | 18    | 19    | 20    |
| ANGAS CREEK      | MW    | 20.8  | 21.4  | 22.0  | 22.6  | 23.3  | 23.9  | 24.6  | 25.3  | 26.0  | 26.7  | 27.4  | 28.2  | 29.0  | 29.8  | 30.6  | 31.5  | 32.3  | 33.2  | 34.1  | 35.1  | 36.0  |
|                  | PF    | 0.93  | 0.92  | 0.92  | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.89  | 0.89  | 0.89  | 0.89  |
| ARDROSSAN WEST   | MW    | 14.2  | 14.7  | 15.1  | 15.7  | 16.2  | 16.7  | 17.3  | 17.8  | 18.4  | 19.0  | 19.7  | 20.3  | 21.0  | 21.7  | 22.4  | 23.1  | 23.9  | 24.6  | 25.4  | 26.3  | 27.1  |
|                  | PF    | 0.90  | 0.90  | 0.90  | 0.92  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.89  | 0.89  |
| BAROOTA          | MW    | 8.7   | 8.8   | 8.8   | 8.9   | 9.0   | 9.1   | 9.2   | 9.3   | 9.3   | 9.4   | 9.5   | 9.6   | 9.7   | 9.8   | 9.9   | 9.9   | 10.0  | 10.1  | 10.2  | 10.3  | 10.4  |
|                  | PF    | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.95  | 0.95  | 0.95  |
| BERRI            | MW    | 91.1  | 94.2  | 95.3  | 96.5  | 97.6  | 98.7  | 99.9  | 101.0 | 102.1 | 103.3 | 104.4 | 105.6 | 106.7 | 107.8 | 109.0 | 110.1 | 111.2 | 112.3 | 113.4 | 114.5 | 115.6 |
|                  | PF    | 0.98  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  |
| BLANCHE          | MW    | 37.3  | 35.6  | 41.4  | 42.3  | 43.2  | 44.2  | 45.2  | 46.1  | 47.2  | 48.2  | 49.3  | 50.3  | 51.5  | 52.6  | 53.7  | 54.9  | 56.1  | 57.4  | 58.6  | 59.9  | 61.2  |
|                  | PF    | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.89  | 0.89  | 0.89  |
| BRINKWORTH       | MW    | 5.6   | 5.6   | 5.7   | 5.7   | 5.7   | 5.7   | 5.7   | 5.8   | 5.8   | 5.8   | 5.8   | 5.8   | 5.9   | 5.9   | 5.9   | 5.9   | 5.9   | 5.9   | 6.0   | 6.0   | 6.0   |
|                  | PF    | 0.96  | 0.96  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.94  | 0.94  |
| CLARE NORTH      | MW    | 13.3  | 13.7  | 14.1  | 14.5  | 14.9  | 15.3  | 15.8  | 16.2  | 16.7  | 17.2  | 17.7  | 18.2  | 18.7  | 19.2  | 19.7  | 20.3  | 20.9  | 21.5  | 22.1  | 22.7  | 23.3  |
|                  | PF    | 0.92  | 0.92  | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  | 0.91  | 0.92  | 0.91  | 0.91  | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  |
| DALRYMPLE        | MW    | 8.6   | 8.9   | 9.2   | 9.5   | 9.8   | 10.1  | 10.4  | 10.7  | 11.0  | 11.4  | 11.7  | 12.1  | 12.5  | 12.9  | 13.3  | 13.7  | 14.1  | 14.5  | 14.9  | 15.4  | 15.8  |
|                  | PF    | 0.92  | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.92  | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.89  | 0.89  | 0.89  |
| DAVENPORT WEST   | MW    | 30.8  | 31.3  | 31.7  | 32.1  | 32.5  | 32.9  | 33.4  | 33.8  | 34.2  | 34.7  | 35.1  | 35.5  | 36.0  | 36.4  | 36.9  | 37.3  | 37.7  | 38.2  | 38.6  | 39.1  | 39.5  |
|                  | PF    | 0.98  | 0.98  | 0.98  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  |
| DORRIEN          | MW    | 62.9  | 64.7  | 66.4  | 68.3  | 70.2  | 72.1  | 74.1  | 76.1  | 78.2  | 80.3  | 82.5  | 84.8  | 87.1  | 89.5  | 92.0  | 94.5  | 97.0  | 99.7  | 102.4 | 105.2 | 108.0 |
|                  | PF    | 0.94  | 0.94  | 0.93  | 0.93  | 0.93  | 0.93  | 0.92  | 0.92  | 0.92  | 0.92  | 0.91  | 0.91  | 0.92  | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  |
| HUMMOCKS         | MW    | 14.6  | 15.3  | 16.0  | 16.7  | 17.5  | 18.3  | 19.2  | 20.1  | 21.0  | 22.0  | 23.0  | 24.1  | 25.2  | 26.4  | 27.6  | 28.9  | 30.3  | 31.7  | 33.2  | 34.7  | 36.4  |
|                  | PF    | 0.93  | 0.92  | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.89  | 0.89  | 0.92  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  |
| KADINA EAST      | MW    | 26.8  | 28.0  | 29.3  | 30.6  | 32.0  | 33.4  | 34.9  | 36.5  | 38.1  | 39.8  | 41.6  | 43.5  | 45.4  | 47.5  | 49.6  | 51.8  | 54.1  | 56.6  | 59.1  | 61.7  | 64.5  |
|                  | PF    | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.91  | 0.90  | 0.90  | 0.90  | 0.89  | 0.89  | 0.89  | 0.89  |
| KANMANTOO        | MW    | 1.8   | 1.9   | 2.0   | 2.2   | 2.3   | 2.5   | 2.7   | 2.9   | 3.1   | 3.3   | 3.6   | 3.8   | 4.1   | 4.4   | 4.7   | 5.0   | 5.4   | 5.8   | 6.2   | 6.7   | 7.1   |
|                  | PF    | 0.93  | 0.93  | 0.92  | 0.92  | 0.91  | 0.91  | 0.90  | 0.96  | 0.95  | 0.94  | 0.94  | 0.93  | 0.93  | 0.92  | 0.92  | 0.92  | 0.94  | 0.94  | 0.93  | 0.93  | 0.92  |
| KEITH            | MW    | 24.8  | 25.2  | 25.6  | 26.0  | 25.8  | 24.3  | 23.2  | 22.2  | 22.1  | 22.6  | 23.0  | 23.5  | 24.0  | 30.5  | 30.9  | 31.4  | 31.9  | 32.4  | 33.0  | 33.5  | 34.0  |
|                  | PF    | 0.94  | 0.94  | 0.94  | 0.94  | 0.93  | 0.93  | 0.93  | 0.93  | 0.94  | 0.94  | 0.94  | 0.94  | 0.94  | 0.94  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  |
| KINCRAIG         | MW    | 22.9  | 23.6  | 24.4  | 25.2  | 26.0  | 26.8  | 27.6  | 28.5  | 29.4  | 30.3  | 31.3  | 32.3  | 33.3  | 34.3  | 35.4  | 36.5  | 37.7  | 38.8  | 40.1  | 41.3  | 42.6  |

**ELECTRANET TRANSMISSION NETWORK REVISED REVENUE PROPOSAL**

Appendix G – ElectraNet Revised 2012 Demand Forecasts



| Connection Point      | Units | 11/12 | 12/13 | 13/14 | 14/15 | 15/16 | 16/17 | 17/18 | 18/19 | 19/20 | 20/21 | 21/22 | 22/23 | 23/24 | 24/25 | 25/26 | 26/27 | 27/28 | 28/29 | 29/30 | 30/31 | 31/32 |
|-----------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Year from Base        |       | 0     | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10    | 11    | 12    | 13    | 14    | 15    | 16    | 17    | 18    | 19    | 20    |
| LEIGH CREEK SOUTH     | PF    | 0.90  | 0.90  | 0.90  | 0.91  | 0.91  | 0.90  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.89  | 0.89  | 0.89  | 0.89  | 0.89  | 0.88  |
|                       | MW    | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   | 1.7   |
|                       | PF    | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  |
| MANNUM                | MW    | 13.8  | 13.9  | 13.9  | 13.9  | 13.9  | 14.0  | 14.0  | 14.0  | 14.0  | 14.1  | 14.1  | 14.1  | 14.1  | 14.1  | 14.1  | 14.1  | 14.1  | 14.1  | 14.1  | 14.0  | 14.0  |
|                       | PF    | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.92  | 0.92  | 0.92  | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  |
| MOBILONG              | MW    | 41.3  | 42.8  | 44.3  | 45.8  | 47.4  | 49.1  | 50.8  | 52.6  | 54.4  | 56.3  | 58.3  | 60.3  | 62.4  | 64.6  | 66.9  | 69.2  | 71.6  | 74.1  | 76.7  | 79.3  | 82.1  |
|                       | PF    | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.89  | 0.89  | 0.89  |
| MT BARKER             | MW    | 100.0 | 104.6 | 109.4 | 114.5 | 119.8 | 125.3 | 131.1 | 137.2 | 143.5 | 150.2 | 157.1 | 164.4 | 172.0 | 179.9 | 188.2 | 196.9 | 206.0 | 215.5 | 225.5 | 235.9 | 246.8 |
|                       | PF    | 1.00  | 1.00  | 0.99  | 0.99  | 0.99  | 0.98  | 0.98  | 0.98  | 0.97  | 0.97  | 0.97  | 0.96  | 0.96  | 0.97  | 0.97  | 0.97  | 0.96  | 0.96  | 0.97  | 0.97  | 0.96  |
| MT GAMBIER            | MW    | 23.9  | 24.2  | 19.6  | 19.8  | 20.1  | 20.4  | 20.6  | 20.9  | 21.2  | 21.5  | 21.7  | 22.0  | 22.3  | 22.6  | 22.9  | 23.1  | 23.4  | 23.7  | 24.0  | 24.3  | 24.5  |
|                       | PF    | 0.92  | 0.92  | 0.94  | 0.94  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.92  | 0.92  | 0.92  | 0.92  | 0.92  | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  |
| MT GUNSON             | MW    | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   | 0.4   |
|                       | PF    | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  |
| NEUROODLA             | MW    | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   | 1.0   |
|                       | PF    | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  |
| NORTH WEST BEND       | MW    | 26.1  | 26.2  | 26.3  | 26.4  | 26.6  | 26.7  | 26.8  | 26.9  | 27.1  | 27.2  | 27.3  | 27.4  | 27.6  | 27.7  | 27.8  | 28.0  | 28.1  | 28.2  | 28.3  | 28.5  | 28.6  |
|                       | PF    | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  |
| PENOLA WEST           | MW    | 12.4  | 12.7  | 12.9  | 13.2  | 13.4  | 13.7  | 13.9  | 14.2  | 14.5  | 14.7  | 15.0  | 15.3  | 15.6  | 15.9  | 16.2  | 16.5  | 16.8  | 17.1  | 17.5  | 17.8  | 18.1  |
|                       | PF    | 0.90  | 0.90  | 0.93  | 0.92  | 0.92  | 0.92  | 0.92  | 0.92  | 0.92  | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  |
| PORT LINCOLN TERMINAL | MW    | 39.5  | 40.6  | 41.8  | 43.0  | 44.2  | 45.5  | 46.8  | 48.1  | 49.5  | 50.9  | 52.3  | 53.8  | 55.3  | 56.9  | 58.5  | 60.1  | 61.8  | 63.5  | 65.3  | 67.1  | 69.0  |
|                       | PF    | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  |
| SNUGGERY INDUSTRIAL   | MW    | 35.0  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  | 27.5  |
|                       | PF    | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  | 0.95  |
| SNUGGERY RURAL        | MW    | 17.2  | 17.9  | 18.7  | 19.5  | 20.4  | 21.3  | 22.2  | 23.2  | 24.2  | 25.3  | 26.4  | 27.5  | 28.7  | 30.0  | 31.3  | 32.7  | 34.1  | 35.6  | 37.2  | 38.8  | 40.5  |
|                       | PF    | 0.92  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.91  | 0.90  | 0.91  | 0.91  | 0.91  | 0.91  | 0.94  | 0.94  | 0.93  | 0.93  | 0.93  | 0.92  | 0.92  | 0.92  | 0.91  |
| STONY POINT           | MW    | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   | 0.6   |
|                       | PF    | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  |
| TAILEM BEND           | MW    | 23.0  | 23.1  | 23.2  | 23.3  | 23.4  | 23.5  | 23.5  | 23.6  | 23.7  | 23.8  | 23.9  | 24.0  | 24.0  | 24.1  | 24.2  | 24.3  | 24.3  | 24.4  | 24.5  | 24.5  | 24.6  |
|                       | PF    | 0.94  | 0.94  | 0.94  | 0.94  | 0.94  | 0.94  | 0.94  | 0.94  | 0.94  | 0.94  | 0.94  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  |
| TEMPLERS              | MW    | 34.2  | 35.7  | 37.2  | 38.7  | 40.3  | 42.0  | 43.7  | 45.6  | 47.5  | 49.4  | 51.5  | 53.6  | 55.9  | 58.2  | 60.6  | 63.1  | 65.8  | 68.5  | 71.4  | 74.3  | 77.4  |
|                       | PF    | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.90  | 0.89  | 0.89  | 0.89  |

**ELECTRANET TRANSMISSION NETWORK REVISED REVENUE PROPOSAL**

Appendix G – ElectraNet Revised 2012 Demand Forecasts



| Connection Point | Units | 11/12 | 12/13 | 13/14 | 14/15 | 15/16 | 16/17 | 17/18 | 18/19 | 19/20 | 20/21 | 21/22 | 22/23 | 23/24 | 24/25 | 25/26 | 26/27 | 27/28 | 28/29 | 29/30 | 30/31 | 31/32 |
|------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Year from Base   |       | 0     | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10    | 11    | 12    | 13    | 14    | 15    | 16    | 17    | 18    | 19    | 20    |
| WATERLOO         | MW    | 11.5  | 11.8  | 12.1  | 12.4  | 12.7  | 13.0  | 13.4  | 13.7  | 14.0  | 14.4  | 14.7  | 15.1  | 15.5  | 15.9  | 16.2  | 16.6  | 17.0  | 17.4  | 17.9  | 18.3  | 18.7  |
|                  | PF    | 0.92  | 0.92  | 0.92  | 0.91  | 0.91  | 0.91  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  | 0.90  | 0.91  | 0.90  | 0.90  | 0.90  | 0.91  | 0.91  | 0.90  | 0.90  | 0.90  |
| WHYALLA TERMINAL | MW    | 81.7  | 82.3  | 83.0  | 83.8  | 84.5  | 85.2  | 86.0  | 86.7  | 87.5  | 88.3  | 89.1  | 89.9  | 90.7  | 91.5  | 92.4  | 93.2  | 94.1  | 95.0  | 95.9  | 96.8  | 97.8  |
|                  | PF    | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.93  | 0.92  | 0.92  | 0.92  | 0.92  | 0.92  |
| WHYALLA LMF      | MW    | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  | 13.2  |
|                  | PF    | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  |
| WUDINNA          | MW    | 16.6  | 16.8  | 17.1  | 17.3  | 17.5  | 17.8  | 18.0  | 18.2  | 18.5  | 18.7  | 19.0  | 19.2  | 19.4  | 19.7  | 19.9  | 20.2  | 20.4  | 20.7  | 20.9  | 21.2  | 21.4  |
|                  | PF    | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.98  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.97  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.96  | 0.95  |
| YADNARIE         | MW    | 9.5   | 9.7   | 9.8   | 10.0  | 10.1  | 10.3  | 10.4  | 10.6  | 10.7  | 10.9  | 11.1  | 11.2  | 11.4  | 11.5  | 11.7  | 11.9  | 12.0  | 12.2  | 12.4  | 12.5  | 12.7  |
|                  | PF    | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 1.00  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.99  | 0.98  | 0.98  | 0.98  | 0.98  |

## ELECTRANET TRANSMISSION NETWORK REVISED REVENUE PROPOSAL

Appendix G – ElectraNet Revised 2012 Demand Forecasts



The customer connection point load forecast is sourced from the transmission customers connected directly to the transmission network at the respective connection points. These forecasts have been aggregated to protect customer confidentiality, as required by the Rules.

### J- 3: Combined direct connect customer load forecast (MW)

|                | 11/12 | 12/13 | 13/14 | 14/15 | 15/16 | 16/17 | 17/18 | 18/19 | 19/20 | 20/21 | 21/22 |
|----------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Year From Base | 0     | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     | 10    |
| TOTAL*         | 276.7 | 300.3 | 345.8 | 365.9 | 386.0 | 406.0 | 406.1 | 406.2 | 406.3 | 406.3 | 406.4 |

\* Excludes the power station house supply loads