




ElectraNet Transmission Network Revised Revenue Proposal

Appendix P

ElectraNet, Capex Replacement and Maintenance Decision Framework, January 2013





Capex Replacement and Maintenance Decision Framework

January 2013



ElectraNet Corporate Headquarters

52-55 East Terrace, Adelaide, South Australia 5000 • PO Box, 7096, Hutt Street Post Office, Adelaide, South Australia 5000
Tel: (08) 8404 7966 • Fax: (08) 8404 7104 • Toll Free: 1800 243 853

Copyright and Disclaimer

Copyright in this material is owned by or licensed to ElectraNet. Permission to publish, modify, commercialise or alter this material must be sought directly from ElectraNet.

Reasonable endeavours have been used to ensure that the information contained in this report is accurate at the time of writing. However, ElectraNet gives no warranty and accepts no liability for any loss or damage incurred in reliance on this information.

Contents

CONTENTS	III
1. PURPOSE.....	4
2. DEFINITIONS	4
3. DECISION FRAMEWORK.....	4
3.1 BACKGROUND	4
3.2 MEASURES OF ASSET CONDITION	5
3.3 ASSET MAINTENANCE / REPLACEMENT DECISION FRAMEWORK.....	5
3.4 ASSET CONDITION INFORMATION	6
3.5 ASSET REPLACEMENT THRESHOLD.....	7
3.6 CORRECTIVE MAINTENANCE THRESHOLD	9
3.7 REFURBISHMENT PLANS	9
3.8 OPTIMISE ROUTINE MAINTENANCE.....	10
4. SUMMARY.....	10
APPENDIX A OPEX REFURBISHMENT PROJECT ANALYSIS AND PRIORITISATION	12
APPENDIX B ASSET REPLACEMENT COST/BENEFIT METHODOLOGY	17

1. Purpose

The purpose of this note is to summarise the decision making framework for network asset replacement decisions and for developing maintenance plans.

2. Definitions


Asset refurbishment is defined as additional planned maintenance required outside the specified routine maintenance programme – generally applied to an asset in order to return it to a condition where routine maintenance will be effective (i.e. applied where routine maintenance by itself will not prevent unacceptable deterioration of safety/ environment impact or availability/ reliability).

3. Decision Framework

3.1 Background

As an asset moves through its lifecycle the relative effectiveness of maintenance on the asset changes. Therefore, maintenance decisions change in response to asset condition changes as represented in Figure 3-1 below.

Figure 3-1: Asset Lifecycle Maintenance and Replacement



With reference to Figure 3-1, the following asset management processes are applied:

- **Start-up to midlife** – Routine maintenance is applied as appropriate to the asset and its environment in order to maintain asset performance within acceptable limits of safety, environmental impact, reliability and availability.

During this time condition inspection is undertaken to track the rate of change of condition of the asset in order to assess the adequacy of routine maintenance (for the purposes of optimisation of routine maintenance) and to predict the requirement for future asset refurbishment.
- **Midlife onwards** – Routine maintenance including condition inspection continues however based on condition and performance monitoring the requirement for asset refurbishment may be identified. This additional effort is based on determining the lowest cost option of maintaining the working life of the asset in preference to replacement.
- **Asset end of life** – Asset end of life is characterised by entering a phase of operation where it is no longer possible to predict key aspects of the asset behaviour (one or a combination of safety performance, asset capability or asset health). The uncertain behaviour is reflected in deteriorating asset reliability and availability performance.

3.2 Measures of Asset Condition


All asset maintenance plans are based on collection and analysis of asset lifecycle condition which allows the current and future performance of the asset to be efficiently managed using the following frameworks:

- System Condition and Risk (SCAR) has been developed to systematically and consistently describe asset condition and risk. SCAR coding of all asset failure modes and associated risk/ response is designed to limit unplanned corrective maintenance by allocating asset defects to more efficient longer term planned routine, refurbishment and replacement streams where possible. Unplanned corrective maintenance is applied only where safety/ environmental or significant operational or asset risk is present (for more information please refer ElectraNet, SCAR Framework, January 2013 document).
- Transmission Asset Life Cycle (TALC) has been developed to provide a framework for systematically identifying where an asset is in its life cycle, and more importantly when it is likely to reach end of life in order to make the most effective asset replacement investment decisions (for more information please refer ENET184 Transmission Asset Life Cycle document - A Framework for Understanding the Lifecycle of Transmission Assets).

3.3 Asset Maintenance / Replacement Decision Framework

The asset maintenance / replacement decision framework is set out in Figure 3-2 below; the key decision points are highlighted and discussed in detail in the following sections.

Figure 3-2: Asset Maintenance/ Replacement Decision Framework



3.4 Asset Condition Information


In order to manage the full lifecycle of the asset, specific information is required from each part of the asset lifecycle. The main elements used to describe the transmission asset life cycle are shown below.

In a framework where an asset manager does not have access to reliable and consistent information from each part of the asset cycle, the ability to effectively manage the asset is limited to responding to asset defects as they occur with the worst case becoming a reactive maintenance environment where long term performance of the asset is impossible to predict.

Collection of asset condition information is based on the need to have adequate information to make economic decisions, the only question being what and how much information for each category is economically justified. In this case the minimum level of information collection is determined by the need to have adequate information to assess asset P-F intervals in order to determine unacceptable failure modes and performance. Without this information the ability to potentially delay asset replacement (with the significant benefit of capital expenditure delay) is substantially reduced.

It should be noted that choosing not to collect asset condition information and rely solely on a maintenance management approach in which assets are repaired or replaced when they fail would be inconsistent with modern day asset management practices.

Figure 3-3: Asset Lifecycle Information Categories



3.5 Asset Replacement Threshold

In the transmission network, asset replacement may be justified when the performance of the asset is such that it:

- is unsafe to operate;
- is environmentally unacceptable; or
- is unpredictable and economic assessment shows that the cost of unserved energy exceeds the cost of replacement.

In order to assess asset performance and behaviour TALC and SCAR information is used to determine the position of assets on the lifecycle curve and asset risk respectively. Where unacceptable performance against the above criteria is identified (indicating end of asset life), asset replacement is recommended.

The threshold for replacement is based on evidence that the asset has reached a stage where it is no longer possible to manage one or more of its key aspects (safety/environment impact, reliability and availability), and it is unsafe to continue in service or will have an unacceptable impact on unserved energy.

An example of the sensitivity of the value of lost load to asset availability is shown in the following typical example where the relative unavailability of an asset deteriorates over a number of years shown in Figure 3-4.

In the case where asset unavailability affects the ability to supply load, the relative change in unavailability may be related to the value of lost load shown in Figure 3-5 below. For a typical 132kV substation node the relative change in average unavailability shown would result in the value of lost load exceeding the cost of replacement in the future as indicated. At this point replacement of the asset could be economically justified.

Figure 3-4 Change in Asset Average Unavailability





Figure 3-5 Value of Lost Load and Replacement Cost



ElectraNet conducts cost/benefit analysis of forecast site replacements taking into account customer benefits through improved reliability outcomes and reduced maintenance costs compared with the capital and ongoing costs of a replacement site. This analysis takes into account multiple factors including the expected reliability of a connection point, actual reliability/outage values and trends, corrective cost profile, load at risk and load growth, and residual asset value for multiple replacement timing scenarios. Refer Appendix B – Asset Replacement Cost/Benefit Methodology for description of input assumptions and methodology.

Conversely where TALC indicates overall asset performance is not unmanageable, asset replacement may be delayed, potentially deferring large capital replacement projects into future regulatory periods

3.6 Corrective Maintenance Threshold

The asset manager is required to manage asset defects by:

- Understanding all reasonably probable failure modes
- Identifying risk and consequence of all failure modes
- Responding on the basis of the risk analysis
- Ensuring that for unacceptable failures, inspection and response time is within the P-F interval (time between commencement of failure and actual failure)

Corrective maintenance thresholds have been set based on risk / response analysis set out in SCAR Coding (for more information please refer ElectraNet, SCAR Framework, January 2013 document).

The corrective maintenance threshold is set based on unacceptable failures with short P-F intervals. Note that unacceptable failures are those failures that are related to safety / environment impact, assets with unacceptable reliability/ availability and are likely to immediately impact network performance, or asset defect which have unacceptable consequences.

3.7 Refurbishment Plans

Asset refurbishment plans are developed by considering all asset defect profiles where possible by plant group (in order to be able to group and package work to maximise efficiency).

Prioritisation of each refurbishment plan is then undertaken based on:

- TALC profile of the assets
- SCAR profile of the assets
- Network Impact

Projects are categorised as follows:

- High Priority – where a direct impact on safety/ environment or asset availability / reliability is identified
- Medium Priority – where an impact on asset availability / reliability is identified (but response may be delayed and asset condition monitored)
- Low Priority – where a possible impact on asset availability/ reliability is identified but further information or monitoring is required

A summary of refurbishment projects analysis is shown in Appendix A. Note that only high priority operational refurbishment projects have been recommended for implementation.

3.8 Optimise Routine Maintenance

Routine maintenance plans are characterised by long maintenance cycles (typically in the order of 5 to 8 years). The maintenance plans currently in place have been developed using reliability centred maintenance techniques and are in the following stages of implementation:

- Substations – completion of first maintenance cycle
- Transmission Lines – full implementation during current regulatory period, completion of first maintenance cycle during next regulatory period

A systematic review of all substation maintenance plans will be conducted during the next regulatory period in order to identify opportunity for optimising scope and frequency.

4. Summary

The overall asset management framework is designed to:

- Assess asset lifecycle using TALC – based on the need to for a comprehensive framework to identify asset replacement thresholds and those asset replacements that may be delayed without affecting network performance and lifecycle cost.
Benefit: Delay substantial capital expenditure by only replacing assets where safety / environment impact or unreliability cost is unacceptable.
- Identify asset failure modes and risk using SCAR – based on the requirement to identify unacceptable failure modes and respond with corrective maintenance accordingly. All other defects are allocated to more efficient planned maintenance, refurbishment or monitor / review work streams.
Benefit: Minimise corrective maintenance expenditure by only responding to asset condition where safety / environment impact or unreliability cost is unacceptable, or where asset defects have unacceptable consequences.
- Assess and develop opex refurbishment projects using TALC and SCAR – based on the requirement to ensure asset availability/ reliability that will affect network performance is maintained during the life of the asset, allocate all other defects to monitor / review.

Benefit: Minimise Opex Refurbishment and Asset Replacement expenditure by only responding to asset condition where safety/ environment impact or unreliability cost is unacceptable, or where asset defects have unacceptable consequences.

Thresholds for reliability are set by assessing the risk and associated likelihood of each asset failure mode (resulting in decreased levels of safety or availability) that will directly affect network performance and associated value of lost load.

CAPEX REPLACEMENT AND MAINTENANCE DECISION FRAMEWORK

January 2013

Appendix A OPEX Refurbishment Project Analysis and Prioritisation

Project	Work Category	TALC											SCAR		Network					Risk				Decision			
		Safety	Model	Environment	Security	Maintainability	Operability	Spares	Training	Support	Corrective	Condition	Standards	Coding	Rating	Configuration	Reliability	Capability	Safety	Network	SCAR	TALC	Risk Score	Risk Driver	Risk Category	Response	
Subs Plant Isolator Refurb	Plant OH	4	3	5	2	2	1	3	4	4	1	2	3	O-ABED	5	5	1	1	4	3	1	2.7	1	SCAR	High	OPEX Refurb	
Sub Civil Site Remediation Pri 1	Subs	4	3	5	5	3	3	5	5	5	1	1	3	R-ABED	5	5	5	5	4	5	2	3.5	2	SCAR	High	Defer	
Sub Civil Site Remediation Pri 2	Subs	4	3	5	5	3	3	5	5	5	1	1	3	R-NSO	5	5	5	5	4	5	3	3.5	3.0	SCAR	Medium	Defer	
Sub Civil Site Remediation Pri 3	Subs	4	3	5	5	3	3	5	5	5	1	1	3	R-NSO	5	5	5	5	4	5	3	3.5	3.0	SCAR	Medium	Defer	
GIS Refurbishment	Plant OH	4	3	4	2	2	4	2	3	4	1	3	3	R-ABED	5	5	5	5	4	5	2	2.8	2	SCAR	High	OPEX Refurb	
Structure and Footing Repair	Subs	3	3	5	5	2	3	5	5	5	1	2	3	R-ABED	5	5	5	5	3	5	2	3.5	2	SCAR	High	OPEX Refurb	
Sub Plant TF Minor Refurb	Subs	4	3	3	5	3	5	5	5	5	2	2	3	R-ABED	5	5	5	5	4	5	2	3.7	2	SCAR	High	OPEX Refurb	
TIPS Under/Over Stn Removal	Subs	4	3	5	2	3	3	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	3	3	TALC	Medium	Defer	
Subs Surge Arrestor Earthing Mods	Subs	5	5	5	5	5	5	5	5	5	5	5	3	NA	5	5	5	5	5	5	5	4.8	4.8	TALC	Low	Delete	
Strategic CVT Replacement	CAPEX Unit Asset	2	3	5	5	2	5	5	5	5	1	2	3	R-ABED	5	5	5	5	2	5	2	3.7	2	Safety	High	CAPEX	
H209 Site Drainage Refurb & Asphalt Hardstand	Subs	5	3	3	5	3	3	5	5	5	2	2	3	R-ABED	5	5	5	5	5	5	2	3.5	2	SCAR	High	OPEX Refurb	
H209 Gantry Footings CA Investigation	Subs	4	3	5	5	3	5	5	5	5	3	2	3	R-NSO	5	5	5	5	4	5	3	4	3	SCAR	Medium	Monitor	
H209 Stormwater Culvert Replacement	Subs	5	5	3	5	5	5	5	5	5	2	2	3	R-MR	5	5	5	5	5	5	4	4	4	SCAR	Low	Delete	
H209 Internal Access Road Hardstand Bituminising	Subs	5	5	3	5	5	5	5	5	5	2	2	3	R-MR	5	5	5	5	5	5	4	4.1	4	SCAR	Low	Delete	
Subs Pumping Stn 3.3kV VT Replacement	Subs	5	3	5	5	4	5	5	5	5	3	2	2	R-MR	5	5	5	5	5	5	4	4	4	SCAR	Low	CAPEX	
T211 Hold-Down Bolt Refurb	Subs	3	1	5	5	1	2	1	5	5	1	1	1	R-ABED	5	5	5	5	3	5	2	2.5	2	SCAR	High	Delete	
TF Seismic Restraint Investigation	Subs	5	1	5	5	5	5	5	5	5	5	3	1	NA	5	5	5	5	5	5	5	4.1	4.09091	TALC	Low	Monitor	
H403 Site Drainage Refurb & Asphalt Hardstand	Subs	5	3	3	5	3	3	5	5	5	2	2	3	R-ABED	5	5	5	5	5	5	2	3.5	2	SCAR	High	OPEX Refurb	
TF Bunds Refurb - Plate Separators Replacement	Subs	4	3	2	5	1	1	3	4	4	1	2	3	R-NSO	5	5	5	5	4	5	3	2.6	2.63636	TALC	High	OPEX Refurb	
TF Bunds Refurb - Design/Construct	Subs	4	3	2	5	1	1	3	4	4	1	2	3	R-NSO	5	5	5	5	4	5	3	2.6	2.63636	TALC	High	OPEX Refurb	
TF Bunds Refurb - U/G Oil/Water Separation Tank Sample Poi	Subs	4	3	2	5	1	1	3	4	4	1	2	3	R-NSO	5	5	5	5	4	5	3	2.6	2.63636	TALC	High	OPEX Refurb	
Site Stormwater Run-off Sample Point Install	Subs	5	5	3	5	5	3	5	5	5	5	5	3	R-MR	5	5	5	5	5	5	4	4.45455	4	SCAR	Low	Monitor	
H255 TIPS-A Stormwater Culvert Replacement	Subs	5	5	3	5	5	5	5	5	5	2	2	3	R-MR	5	5	5	5	5	5	4	4.09091	4	SCAR	Low	Delete	
H161 Para Stormwater Culvert Replacement	Subs	5	5	3	5	5	5	5	5	5	2	2	3	R-MR	5	5	5	5	5	5	4	4.09091	4	SCAR	Low	Delete	
H209 Fire Hydrant Refurbishment	Subs	4	3	5	5	5	5	5	5	5	1	2	3	R-ABED	5	5	5	5	4	5	2	4	2	SCAR	High	OPEX Refurb	
Fire water Tank & Pump Replacement	Subs	4	3	5	5	5	5	5	5	5	1	2	3	R-ABED	5	5	5	5	4	5	2	4	2	SCAR	High	OPEX Refurb	
H220 Fire water Tank Replacement	Subs	4	3	5	5	5	5	5	5	5	1	2	3	R-ABED	5	5	5	5	4	5	2	4	2	SCAR	High	Delete	
H209 Fire water Tank Replacement	Subs	4	1	5	5	1	1	1	5	5	1	1	1	R-NSO	5	5	5	5	4	5	3	2.45455	2.45455	TALC	High	Delete	
Battery Charger Upgrades - Pri 1	Subs	5	2	5	2	3	3	3	4	4	1	2	3	R-NSO	5	5	5	5	5	5	3	2.9	2.90909	TALC	High	OPEX Refurb	
Battery Charger Upgrades - Pri 2	Subs	5	2	5	5	2	4	2	2	3	3	3	R-NSO	5	5	5	5	5	5	3	3	3	SCAR	Medium	Defer		
Porcelain Surge Arrestor Replacement	Subs	4	3	5	5	5	5	5	5	5	5	5	3	R-MR	5	5	5	5	4	5	4	4.63636	4	Safety	Low	Monitor	
TIPS De-Energised 66kV U/G Oil-filled Cable Removal	Subs	5	3	3	5	5	5	5	5	5	5	5	3	R-MR	5	5	5	5	5	5	4	4.45455	4	SCAR	Low	Delete	
TF Bunds Refurb - Oil Blocking System Replace	Subs	4	1	2	5	2	2	1	1	1	1	2	3	R-ABED	5	5	5	5	4	5	2	1.9	1.90909	TALC	High	OPEX Refurb	
TF Bunds Refurb - Oil Separator Install	Subs	4	1	2	5	2	2	1	1	1	1	2	3	R-ABED	5	5	5	5	4	5	2	1.9	1.90909	TALC	High	OPEX Refurb	
TF Bunds Refurb - Design/Construct	Subs	5	5	3	5	5	5	5	5	5	5	5	3	NA	5	5	5	5	5	5	5	4.63636	4.63636	TALC	Low	Delete	
TF Bunds Refurb - U/G Oil/Water Separation Tank Sample Poi	Subs	5	5	3	5	5	5	5	5	5	5	5	3	NA	5	5	5	5	5	5	5	4.63636	4.63636	TALC	Low	Delete	
Asset Online CA Monitoring Equipment Replacement	CAPEX Unit Asset	5	2	5	5	1	2	1	2	2	1	2	3	R-NSO	5	5	5	5	5	5	3	2.36364	2.36364	TALC	High	CAPEX	
Review and Application of LDC to Isolated Connection Points	Sec Sys	5	5	5	5	5	5	5	5	5	5	5	5	NA	5	5	3	3	5	4	5	5	4	Network	Low	Monitor	

CAPEX REPLACEMENT AND MAINTENANCE DECISION FRAMEWORK

January 2013

Project	Work Category	TALC											SCAR		Network				Risk				Decision				
		Safety	Model	Environment	Security	Maintainability	Operability	Spares	Training	Support	Corrective	Condition	Standards	Coding	Rating	Configuration	Reliability	Capability	Safety	Network	SCAR	TALC	Risk Score	Risk Driver	Risk Category	Response	
Load Indices	Sec Sys	5	5	5	5	5	5	5	5	5	5	5	5	5	NA	5	5	3	2	5	3.75	5	5	3.75	Network	Medium	Defer
Substation Computer Based Local Control Facilities (HMI) Rep	Sec Sys	4	2	5	5	1	1	1	2	2	1	3	2	NA	5	4	1	1	4	2.75	5	2.27273	2.27273	TALC	High	OPEX Refurb	
conductor (sample & Test)	Tx Lines	4	3	5	5	3	3	3	4	4	2	3	R-NSO	5	5	5	5	4	5	3	3.36364	3	SCAR	Medium	Defer		
F1836/1837/1833 conductor CA	Tx Lines	4	3	5	5	3	3	3	4	4	1	2	R-ABED	5	5	5	5	4	5	2	3.27273	2	SCAR	High	OPEX Refurb		
structures (Climbing Inspection)	Tx Lines	4	4	5	5	4	4	4	4	4	3	4	R-MR	5	5	5	5	4	5	4	4.09091	4	Safety	Low	Delete		
insulators (Volt-drop testing)	Tx Lines	4	4	5	5	4	4	4	4	4	3	4	R-MR	5	5	5	5	4	5	4	4.09091	4	Safety	Low	Delete		
foundations (NDT & Field validation)	Tx Lines	4	4	5	5	4	4	4	4	4	3	4	R-MR	5	5	5	5	4	5	4	4.09091	4	Safety	Low	Delete		
Stobie groundline pole inspection	Tx Lines	4	4	5	5	4	4	4	4	4	3	4	R-MR	5	5	5	5	4	5	4	4.09091	4	Safety	Low	Delete		
CA Analysis (Eng support)	Tx Lines	5	5	5	5	5	5	5	5	5	5	5	R-ABED	5	5	5	5	5	5	2	5	2	SCAR	High	OPEX Refurb		
insulator testing (Lab destructive testing)	Tx Lines	5	4	5	5	4	4	4	4	4	3	4	R-MR	5	5	5	5	5	5	4	4.09091	4	SCAR	Low	Monitor		
Tx Line Mid-Span Joint Testing Baseline	Tx Lines	3	3	5	5	2	2	3	2	2	2	2	R-NSO	5	5	5	5	3	5	3	2.81818	2.81818	TALC	High	OPEX Refurb		
Tower earthing & assessment	Tx Lines	3	3	5	5	2	2	3	2	2	2	2	R-NSO	5	5	5	5	3	5	3	2.81818	2.81818	TALC	High	OPEX Refurb		
Line component testing (conductor & joints)	Tx Lines	3	3	5	5	2	2	3	2	2	2	2	R-NSO	5	5	5	5	3	5	3	2.81818	2.81818	TALC	High	OPEX Refurb		
Tx line thermography 3yr cycle	Tx Lines	3	3	5	5	2	2	3	2	2	2	2	R-ABED	5	5	5	5	3	5	2	2.81818	2	SCAR	High	OPEX Refurb		
access track refurb	Tx Lines	4	5	3	5	3	3	5	5	5	3	3	R-MR	5	5	5	5	4	5	4	4.09091	4	Safety	Low	Monitor		
joint reinforcement HBFRA	Tx Lines	4	3	5	5	3	5	5	5	3	3	NA	5	5	5	5	4	5	5	4.09091	4	Safety	Low	Delete			
Low span CDR/SAE	Tx Lines	5	5	5	5	5	5	5	5	5	5	5	NA	4	4	2	1	5	2.75	5	5	2.75	Network	High	Delete		
Str/Ins photos	Tx Lines	5	5	5	5	5	5	5	5	5	5	5	NA	5	4	5	5	5	4.75	5	5	4.75	Network	Low	Delete		
Line schedule data audit	Tx Lines	4	3	5	5	3	3	3	4	4	1	2	NA	5	5	5	5	4	5	5	3.27273	3.27273	TALC	Medium	Monitor		
Aerial Hazard ID (over/under line xing markers)	Tx Lines	2	2	5	5	2	1	5	4	4	1	1	NA	5	5	5	5	2	5	5	2.81818	2	Safety	High	OPEX Refurb		
Undercrossing fix	Tx Lines	4	5	5	5	5	5	5	5	5	5	2	NA	5	5	5	5	4	5	5	4.72727	4	Safety	Low	Monitor		
ERS - training	Tx Lines	2	5	5	5	5	5	5	5	5	5	5	R-NSO	5	5	5	5	2	5	3	5	2	Safety	High	OPEX Refurb		
bog mats	Tx Lines	5	5	5	5	5	5	5	5	5	5	5	R-MR	5	5	5	5	5	5	4	5	4	SCAR	Low	Delete		
F1812/57 footing fix pri 1	Tx Lines	3	3	5	4	1	2	1	5	5	1	2	R-NSO	5	5	5	5	3	5	3	2.72727	2.72727	TALC	High	OPEX Refurb		
F1830 removal	Tx Line Removal	3	3	5	4	1	2	1	5	5	1	2	R-NSO	5	5	5	5	3	5	3	2.72727	2.72727	TALC	High	OPEX Refurb		
pt river xing removal	Tx Lines	4	4	5	5	4	4	5	4	4	3	3	R-MR	5	5	5	5	4	5	4	4	4	Safety	Low	Monitor		
F1808 xing Low Span fix	Tx Lines	4	4	5	5	4	4	5	4	4	3	3	R-MR	5	5	5	5	4	5	4	4	4	Safety	Low	Delete		
F1808/1809 Gulf xing footing refurb	Tx Lines	4	4	5	5	4	4	5	4	4	3	3	R-MR	5	5	5	5	4	5	4	4	4	Safety	Low	Delete		
EPL insulator replace	Tx Lines	3	1	5	4	1	2	5	5	5	1	2	R-ABED	5	5	5	5	3	5	2	3	2	SCAR	High	OPEX Refurb		
Individual spun concrete pole replace	Tx Lines	4	4	5	5	4	4	4	4	4	4	4	R-MR	5	5	5	5	4	5	4	4.09091	4	Safety	Low	Defer		
Std Tx Line component repair guideline	Tx Lines	5	5	5	5	5	5	5	5	5	5	5	NA	5	5	5	5	5	5	5	5	5	Safety	Low	Monitor		
fly-ash pond bypass	Tx Lines	4	4	5	5	4	4	4	4	4	3	3	R-MR	5	5	5	5	4	5	4	4	4	Safety	Low	Monitor		
Twr Rusty Nut & Bolt Refurb	Tx Lines	3	3	5	4	2	3	5	4	4	1	2	R-ABED	5	5	5	5	3	5	2	3.27273	2	SCAR	High	OPEX Refurb		
F1802 xing refurb	Tx Lines	5	3	5	4	4	5	5	5	3	3	3	R-MR	5	5	5	5	5	5	4	4.09091	4	SCAR	Low	Monitor		
"safety valve" xarm assess/fix	CAPEX Re-Insulati	2	2	5	5	2	3	1	2	2	1	2	R-ABED	5	5	5	5	2	5	2	2.36364	2	Safety	High	CAPEX		
F1836 footing fix	Tx Lines	3	3	5	4	1	2	1	5	5	1	2	R-NSO	5	5	5	5	3	5	3	2.72727	2.72727	TALC	High	Delete		
F1837 footing fix	Tx Lines	3	3	5	4	1	2	1	5	5	1	2	R-NSO	5	5	5	5	3	5	3	2.72727	2.72727	TALC	High	Delete		
F1910 Brinkworth-Davenport Re-Insulation	CAPEX Re-Insulati	3	1	5	4	1	2	5	5	5	1	2	R-ABED	5	5	5	5	3	5	2	3	2	SCAR	High	CAPEX		
F1911 Para-Brinkworth Re-Insulation	CAPEX Re-Insulati	3	1	5	4	1	2	5	5	5	1	2	R-ABED	5	5	5	5	3	5	2	3	2	SCAR	High	CAPEX		
F1864 Penola West-South East Re-Insulation	CAPEX Re-Insulati	3	1	5	4	1	2	5	5	5	1	2	R-ABED	5	5	5	5	3	5	2	3	2	SCAR	High	CAPEX		
xarm refurb/replace F1846/1866 (TB xarm ???)	Tx Lines	5	4	5	5	4	5	5	5	5	3	3	R-MR	5	5	5	5	5	5	4	4.27273	4	SCAR	Low	Monitor		
tower earthing refurb	Tx Lines	5	4	5	5	4	5	5	5	5	3	3	R-MR	5	5	5	5	5	5	4	4.27273	4	SCAR	Low	Defer		
Stobie pole plating/replace	Tx Lines	5	4	5	5	4	5	5	5	5	3	3	R-MR	5	5	5	5	5	5	4	4.27273	4	SCAR	Low	Monitor		

CAPEX REPLACEMENT AND MAINTENANCE DECISION FRAMEWORK

January 2013

Project	Work Category	TALC											SCAR		Network				Risk				Decision				
		Safety	Model	Environment	Security	Maintainability	Operability	Spares	Training	Support	Corrective	Condition	Standards	Coding	Rating	Configuration	Reliability	Capability	Safety	Network	SCAR	TALC	Risk Score	Risk Driver	Risk Category	Response	
Vegetation Management Analysis Tools	Tx Lines	5	5	5	5	5	5	5	5	5	5	5	5	NA	5	4	1	1	5	2.75	5	5	2.75	Network	High	CAPEX	
Easement GIS Mngt (Google Earth Licence)	Tx Lines	5	5	5	5	5	5	5	5	5	5	5	5	NA	5	5	5	5	5	5	5	5	5	Safety	Low	Delete	
F1938/F1945 Lightning Performance Improvement	Tx Lines	5	5	5	5	5	5	5	5	5	5	5	5	R-MR	5	5	5	5	5	5	4	5	4	SCAR	Low	Delete	
F1912 "safety valve" xarm change-out	Tx Lines-OH	2	2	5	5	2	3	1	2	2	1	2	1	R-ABED	5	5	5	5	2	5	2	2.36364	2	Safety	High	Monitor	
F1808 xing Removal	Tx Line Removal	4	3	5	5	3	3	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	3.27273	3.27273	TALC	Medium	Monitor	
High Crossing Twr Climbing Inspection	Tx Lines	4	3	5	5	3	3	3	4	4	1	2	3	R-ABED	5	5	5	5	4	5	2	3.27273	2	SCAR	High	OPEX Refurb	
Insulator Testing for Z-Code Replacement	Tx Lines	3	5	5	5	3	3	5	5	5	3	3	3	R-ABED	5	5	5	5	3	5	2	4.09091	2	SCAR	High	OPEX Refurb	
F1807 Insulator Testing for Z-Code Replacement	Tx Lines	3	5	5	5	3	3	5	5	5	3	3	3	R-NSO	5	5	5	5	3	5	3	4.09091	3	Safety	Medium	Delete	
F1818 Insulator Testing for Z-Code Replacement	Tx Lines	3	5	5	5	3	3	5	5	5	3	3	3	R-NSO	5	5	5	5	3	5	3	4.09091	3	Safety	Medium	Delete	
F1846 Insulator Testing for Z-Code Replacement	Tx Lines	3	5	5	5	3	3	5	5	5	3	3	3	R-ABED	5	5	5	5	3	5	2	4.09091	2	SCAR	High	Delete	
F1847,1849,1853 Insulator Testing for Z-Code Replacement	Tx Lines	3	5	5	5	3	3	5	5	5	3	3	3	R-NSO	5	5	5	5	3	5	3	4.09091	3	Safety	Medium	Delete	
NDT Foundation CA	Tx Lines	4	2	5	5	2	3	3	2	2	1	2	2	R-MR	5	5	5	5	4	5	4	2.63636	2.63636	TALC	High	OPEX Refurb	
F1853 Foundation CA	Tx Lines	4	2	5	5	2	3	3	2	2	1	2	2	R-MR	5	5	5	5	4	5	4	2.63636	2.63636	TALC	High	Delete	
F1912 Foundation CA	Tx Lines	4	2	5	5	2	3	3	2	2	1	2	2	R-MR	5	5	5	5	4	5	4	2.63636	2.63636	TALC	High	Delete	
TIPS De-Energised 66kV U/G Oil-filled Cable Removal	Tx Line Removal	4	3	5	5	3	3	3	4	4	1	2	3	R-ABED	5	5	5	5	4	5	2	3.27273	2	SCAR	High	OPEX Refurb	
F1827 Tallem Bend-Keith No2 Re-Insulation	CAPEX Re-Insulati	3	1	5	4	1	2	5	5	5	1	2	2	R-ABED	5	5	5	5	3	5	2	3	2	SCAR	High	CAPEX	
F1804 Brinkworth-Mintaro Re-Insulation	CAPEX Re-Insulati	3	1	5	4	1	2	5	5	5	1	2	2	R-ABED	5	5	5	5	3	5	2	3	2	SCAR	High	CAPEX	
F1905 Magill-Happy Valley Re-Insulation	CAPEX Re-Insulati	3	1	5	4	1	2	5	5	5	1	2	2	R-ABED	5	5	5	5	3	5	2	3	2	SCAR	High	CAPEX	
F1844 Cultana-Stoney Point Re-Insulation	CAPEX Re-Insulati	3	1	5	4	1	2	5	5	5	1	2	2	R-ABED	5	5	5	5	3	5	2	3	2	SCAR	High	CAPEX	
F1808/F1809 Connect Electrically	Tx Line Removal	5	5	5	5	5	5	5	5	5	5	5	5	NA	5	1	1	4	5	2.75	5	5	5	2.75	Network	High	Monitor
F1836 Decommission & Remove	Tx Line Removal	3	3	5	4	1	2	1	5	5	1	2	1	R-NSO	5	5	5	5	3	5	3	2.72727	2.72727	TALC	High	CAPEX	
F1837 Decommission & Remove	Tx Line Removal	3	3	5	4	1	2	1	5	5	1	2	1	R-NSO	5	5	5	5	3	5	3	2.72727	2.72727	TALC	High	CAPEX	
F1819 Re-energise	CAPEX Uprate	3	3	5	4	1	2	1	5	5	1	2	1	R-NSO	5	5	5	5	3	5	3	2.72727	2.72727	TALC	High	CAPEX	
Tx Line Dead-End Joint Testing Baseline	Tx Lines	3	5	5	5	3	3	5	5	5	3	3	3	R-NSO	5	5	5	5	3	5	3	4.09091	3	Safety	Medium	Monitor	
F1838/1839 Insulator Testing for Z-Code Replacement	Tx Lines	3	5	5	5	3	3	5	5	5	3	3	3	R-ABED	5	5	5	5	3	5	2	4.09091	2	SCAR	High	Delete	
F1903 Insulator Testing for Z-Code Replacement	Tx Lines	4	3	5	5	3	3	4	4	1	2	3	R-ABED	5	5	5	5	4	5	2	3.27273	2	SCAR	High	Delete		
Comms Tower CA	Comms	3	3	5	5	5	5	5	5	5	3	3	4	R-ABED	5	5	5	5	3	5	2	4.36364	2	SCAR	High	OPEX Refurb	
Comms Towers Fall Arrester Replace	Comms	2	3	5	2	3	3	3	4	4	3	2	3	R-NSO	5	5	5	5	2	5	3	3.18182	2	Safety	High	OPEX Refurb	
Comms Towers Remediation Stage 5	Comms	5	4	5	5	4	4	4	4	4	4	3	3	R-MR	5	5	5	5	5	5	4	4	4	SCAR	Low	Monitor	
Frequency Rationalisation	Comms	5	3	5	5	3	3	3	5	5	5	5	3	R-ABED	5	5	5	5	5	5	2	4.09091	2	SCAR	High	Delete	
Network Management Enhancement	Comms	5	5	5	5	5	5	5	5	5	5	5	NA	5	4	1	1	5	2.75	5	5	2.75	Network	High	Delete		
ACMA Program Radio Replacement	Comms	5	3	5	5	3	3	3	4	4	3	3	1	R-ABED	5	5	5	5	5	5	2	3.36364	2	SCAR	High	Delete	
Building CA Investigation	Buildings	5	5	5	5	3	3	3	4	4	3	3	3	R-MR	5	5	1	1	5	3	4	3.72727	3	Network	Medium	Monitor	
H114 Building Refurb	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete	
H403 Synch Condensor Removal & Building Refurbishment	Sync Cond Remov	5	2	5	5	3	3	3	3	3	2	2	2	R-NSO	5	5	5	5	5	5	3	3	3	SCAR	Medium	Defer	
H408 Synch Condensor Removal & Building Refurbishment	Sync Cond Remov	5	2	5	5	3	3	3	3	3	2	2	2	R-NSO	5	5	5	5	5	5	3	3	3	SCAR	Medium	Defer	
C007 Crafers Radio Site BUILDING - BRICK (BD01) Building Sec	Comms	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete	
C016 Mt Charles Radio Site BUILDING - CONCRETE HUT (BD01)	Comms	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete	
C021 The Bluff (Port Pirie) Radio Site BUILDING - BRICK (BD01)	Comms	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete	
C023 Manacon Tank (Hut) Refurb	Comms	4	4	5	4	4	4	4	4	4	4	3	4	R-MR	5	5	5	5	4	5	4	4	4	Safety	Low	Delete	
C027 Manacon Tank (Hut) Refurb	Comms	4	4	5	4	4	4	4	4	4	4	3	4	R-MR	5	5	5	5	4	5	4	4	4	Safety	Low	Delete	
C029 Manacon Tank (Hut) Refurb	Comms	4	4	5	4	4	4	4	4	4	4	3	4	R-MR	5	5	5	5	4	5	4	4	4	Safety	Low	Delete	
C030 Manacon Tank (Hut) Refurb	Comms	4	4	5	4	4	4	4	4	4	4	3	4	R-MR	5	5	5	5	4	5	4	4	4	Safety	Low	Delete	
C031 Williamstown Radio site BUILDING - CONCRETE HUT (BD01)	Comms	4	4	5	4	4	4	4	4	4	4	3	4	R-MR	5	5	5	5	4	5	4	4	4	Safety	Low	Delete	

CAPEX REPLACEMENT AND MAINTENANCE DECISION FRAMEWORK

January 2013

Project	Work Category	TALC											SCAR		Network				Risk				Decision			
		Safety	Model	Environment	Security	Maintainability	Operability	Spares	Training	Support	Corrective	Condition	Standards	Coding	Rating	Configuration	Reliability	Capability	Safety	Network	SCAR	TALC	Risk Score	Risk Driver	Risk Category	Response
H396 Bungama BUILDING - BRICK (BD01) Refurb - Major	Buildings	4	3	5	5	2	2	3	5	5	1	2	3	R-MR	5	5	5	5	4	5	4	3.27273	3.3	TALC	Medium	Defer
T399 Control Building Refurb/Replace	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
H161 Para BUILDING - BRICK (BD01) Removal	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Monitor
CC02 BUCC Building Refurb/Replace	Comms	4	3	5	2	2	2	3	4	4	1	2	2	R-NSO	5	5	5	5	4	5	3	2.72727	2.72727	TALC	High	Delete
T399 Berri BUILDING - BRICK (BD01) Building Security Hardening	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T339 Blanche BUILDING - BRICK (BD01) Building Security Hardening	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
H207 Cherry Gardens BUILDING - BRICK (BD02) Building Security Hardening	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
H426 Davenport BUILDING - BRICK (BD01) Building Security Hardening	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
U284 Dry Creek Power Station BUILDING - BRICK (BD01) Building Security Hardening	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T135 Snuggery BUILDING - BRICK (BD01) Building Security Hardening	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
H114 Taillem Bend BUILDING - BRICK (BD02) Building Security Hardening	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T134 Whyalla Terminal BUILDING - BRICK (BD01) Building Security Hardening	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T440 Leigh Creek South BUILDING - TRANSPORTABLE (BD01) Refurb - Major	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T400 North West Bend BUILDING - BRICK (BD01) Refurb - Medium	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
H161 Para BUILDING - METAL (BD04) Refurb - Medium	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
H404 Playford A & B Power Station BUILDING - BRICK (BD01) Refurb - Major	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T188 Port Lincoln Terminal BUILDING - BRICK (BD01) Refurb - Minor	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T153 Templers BUILDING - BRICK (BD01) Refurb - Medium	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
H255 Torrens A Power Station BUILDING - BRICK (BD03) Refurb - Major	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T262 Yadrarie BUILDING - BRICK (BD01) Refurb - Medium	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T438 Angas Creek BUILDING - TRANSPORTABLE (BD01) Refurb - Major	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T399 Berri BUILDING - BRICK (BD04) Refurb - Minor	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T525 Dorrien BUILDING - TRANSPORTABLE (BD01) Refurb - Minor	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T140 Keith BUILDING - BRICK (BD01) Refurb - Minor	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T452 Leigh Creek Coalfield BUILDING - TRANSPORTABLE (BD01) Refurb - Major	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T440 Leigh Creek South BUILDING - TRANSPORTABLE (BD02) Refurb - Major	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T514 Middleback BUILDING - TRANSPORTABLE (BD01) Refurb - Major	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
H161 Para BUILDING - BRICK (BD02) Refurb - Minor	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
H215 Robertstown BUILDING - BRICK (BD01) Refurb - Minor	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
T363 Stony Point BUILDING - TRANSPORTABLE (BD01) Refurb - Major	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
H254 Torrens B Power Station BUILDING - TRANSPORTABLE (BD01) Refurb - Major	Buildings	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
C032 LeFevre Tower 7 Radio site BUILDING - CONCRETE HUT (BD01) Refurb - Major	Comms	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
C033 Torrens Island Tower 8 Radio site BUILDING - CONCRETE HUT (BD01) Refurb - Major	Comms	4	2	5	2	2	2	3	4	4	1	2	3	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	Delete
H161 BUILDING - BRICK (BD01) Refurb - Medium	Buildings	4	3	5	5	2	2	3	5	5	1	2	3	R-MR	5	5	5	5	4	5	4	3.27273	3.3	TALC	Medium	Defer
U/G HV Cable Oil Plant Workshop & Test Facility	CAPEX Building	3	3	5	5	3	3	3	4	4	3	3	NA	5	5	5	5	3	5	5	3.54545	3	Safety	Medium	CAPEX	
Substation Building Security Hardening & Refurb	Buildings	4	3	5	2	3	3	3	2	2	1	2	R-MR	5	5	5	5	4	5	4	2.54545	2.5	TALC	High	OPEX Refurb	
Communications Building Security Hardening & Refurb	Buildings	4	2	5	2	2	2	3	4	4	1	2	R-MR	5	5	5	5	4	5	4	2.72727	2.72727	TALC	High	OPEX Refurb	
T399 Berri BUILDING - BRICK (BD01) Refurb - Major	Buildings	4	3	5	2	3	3	3	2	2	1	2	R-MR	5	5	5	5	4	5	4	2.54545	2.5	TALC	High	OPEX Refurb	

CAPEX REPLACEMENT AND MAINTENANCE DECISION FRAMEWORK

January 2013

Project	Work Category	TALC											SCAR	Network			Risk				Decision					
		Safety	Model	Environment	Security	Maintainability	Operability	Spares	Training	Support	Corrective	Condition	Standards	Coding	Rating	Configuration	Reliability	Capability	Safety	Network	SCAR	TALC	Risk Score	Risk Driver	Risk Category	Response
Joint PD CA	U/G Cables	4	3	5	5	3	3	3	4	4	1	2	3	R-ABED	5	5	5	5	4	5	2	3.27273	2	SCAR	High	CAPEX
F1914 Pit construction (Pit O & K)	CAPEX Unit Asset	4	2	5	4	2	1	1	1	1	1	2	2	R-NSO	5	5	5	5	4	5	3	2	2	TALC	High	CAPEX
link box refurb	U/G Cables	4	2	5	4	2	1	1	1	1	1	2	2	R-NSO	5	5	5	5	4	5	3	2	2	TALC	High	OPEX Refurb
Aux plant refurb/upgrade	U/G Cables	4	2	5	4	2	1	1	1	1	1	2	2	R-NSO	5	5	5	5	4	5	3	2	2	TALC	High	OPEX Refurb
U/G HV Cable Oil Plant Workshop & Test Facility	U/G Cables	5	3	5	5	3	3	3	4	4	1	2	3	R-MR	5	5	5	5	5	5	4	3.27273	3.27273	TALC	Medium	Monitor
F1914 Inst Upgrade - East Tce End Construction	CAPEX Unit Asset	4	2	5	4	2	1	1	1	1	1	2	2	R-NSO	5	5	5	5	4	5	3	2	2	TALC	High	CAPEX
CA Investigation	Weather Stns	5	4	5	5	4	4	5	4	4	3	3	4	R-MR	5	5	5	5	5	5	4	4.09091	4	SCAR	Low	Monitor
Obsolete Weather sensor replace	Weather Stns	5	4	5	5	4	4	5	4	4	3	3	4	R-MR	5	5	5	5	5	5	4	4.09091	4	SCAR	Low	Delete
Solar Flare Impact	R&D	5	5	5	5	5	5	5	5	5	5	5	5	NA	5	5	1	5	5	4	5	5	4	Network	Low	Delete
Climate Change - increased lightning	R&D	5	5	5	5	5	5	5	5	5	5	5	5	NA	5	5	1	5	5	4	5	5	4	Network	Low	Monitor
Climate Change - increased dust pollution	R&D	5	5	5	5	5	5	5	5	5	5	5	5	NA	5	5	1	5	5	4	5	5	4	Network	Low	Monitor
Conductor Corrosion Identification	R&D	5	5	5	5	5	5	5	5	5	5	5	5	NA	5	5	1	5	5	4	5	5	4	Network	Low	Monitor
Insulation Destructive Testing	R&D	5	5	5	5	5	5	5	5	5	5	5	5	NA	5	5	1	5	5	4	5	5	4	Network	Low	Monitor
Veg ID & Mngt Tool Investigation	R&D	5	5	5	5	5	5	5	5	5	5	5	5	NA	5	4	1	1	5	2.75	5	5	2.75	Network	High	OPEX Refurb

Note: High priority projects shown as deleted have been combined grouped into common project packages.

Appendix B Asset Replacement Cost/Benefit Methodology

The inputs, assumptions and methodology described below are for a radial single transformer 132kV site. In this example it is assumed that the substation is at the end of its economic life.

Assumptions:

- Options compare replacement now to replacement in 5 years and 10 years (notionally next and following regulatory control periods)
- PV analysis is undertaken in \$real
- Base level corrective maintenance costs are assumed 30 per cent of routine maintenance costs up to start of current data set
- Connection point outage rates are determined from historical outage data for the particular site using a current day 6 year moving average of historical data
- End of life corrective maintenance costs and therefore the cost of customer supply outages are inflated by a common growth factor until the substation scenario replacement date

Input Parameters – Example Site

Base level reliability calculations are below.

Note: Failure rate and value of customer reliability data is consistent with data used by AEMO (for example in review of Electricity Transmission Code reliability standards for ESCOSA)

CAPEX REPLACEMENT AND MAINTENANCE DECISION FRAMEWORK

January 2013

Category	Failure Rate (Failures/Year)	Downtime (Hours)	Number of Units	Failures /year	Failure Downtime hrs/yr	Maintenance Frequency (Years)	Maintenance Downtime (Hours)	Maintenance Downtime Hours/Year
Protection Equipment	0.0002	5	4	0.0008	0.0040	4.0	0.0	0.00
Circuit Breakers	0.0036	8	1	0.0036	0.0288	4.0	8.0	2.00
Instrument Transformers	0.025	24	3	0.075	1.8000	4.0	4.0	3.00
Cables	0.00613	19	0	0	0.0000	4.0	4.0	0.00
Cable Terminations	0.0001	3.8	0	0	0.0000	4.0	4.0	0.00
Disconnectors	0.0061	3.6	3	0.0183	0.0659	5.0	4.0	2.40
Transformers	0.0033	192	1	0.0033	0.6336	6.0	16.0	2.67
Distribution Supply Point	2.0000	2	0	0	0.0000	4.0	4.0	0.00
Total				0.1	2.5			10.07

Annualised Performance	Estimate	Unit
MTTF	9.90	Years
MTTR (Forced Outage)	2.53	Hours
Maintenance (Planned Outage)	10.07	Hours
Total Outage	12.60	Hours
Availability	99.856%	
Unavailability	0.144%	


Availability = $MTTF / (MTTF + MTTR)$ where:
 MTTF is the Mean Time to Fail (1/failure rate)
 MTTR is the Mean Time to Repair (loss time)

Unavailability = (1-Availability)


(Circuit 1 OR Circuit 2) = $(P(C1) + P(C2)) - (P(C1) * P(C2))$

(Circuit 1 AND Circuit 2) = $P(C1) * P(C2)$

Single Line Diagram



The base level reliability is compared against actual outage data for the site. This provides the base customer outage rates (hours per annum) and an indicative trend.




CAPEX REPLACEMENT AND MAINTENANCE DECISION FRAMEWORK

January 2013

The base level routine maintenance costs are then calculated (\$ million per annum) given the primary plant arrangement and size of site.

The corrective effort expected for the site is compared against the actual recorded data together with indicative trend indication.



The lost load (MW) and load growth (MW per annum) is taken from ElectraNet's demand forecast.

Finally these parameters are used in the cost benefit analysis together with other financial parameters.

A typical input parameter listing is shown below.

Example Substation Replacement - Cost Benefit Analysis Inputs	
Data input	
Capital cost (\$m)	\$ 17.5
Asset life (years)	40
Discount rate	7.43%
WACC	7.11%
Routine maintenance costs (\$m pa)	\$ 0.012
Corrective maint. costs (% of routine)	30%
Base customer outage rate (hours pa)	80
Base customer outage rate - new sub (hours pa)	22.5
End of life customer outage rate multiplier	1
Growth in customer outage rate (pa)	10%
Lost load (MW)	4.5
Load growth (pa)	3%
Value of customer reliability (\$/ MWh)	\$ 44,300
Growth in customer outage rate (pa) - Replacement	12%

A significantly lower value of customer reliability has been assumed for SA Water pumping station loads.