

4 February 2013

Australian Energy Regulator
GPO Box 520
Melbourne VIC 3001

Dear Sir,

Performance Incentive Scheme Report for 2012 Calendar Year

Herewith I submit ElectraNet's annual Service Targets Performance Incentive Scheme (STPIS) report for the 2012 calendar year, which has been prepared in accordance with the applicable guidelines and revenue determination.

ElectraNet is required to report actual performance for the period 1 January to 31 December 2012 against the performance measures determined by the AER in ElectraNet's revenue cap decision 2008-2013 and the subsequent Market Impact Parameter (MIP) decision of December 2010 and to provide:

- A list of events that ElectraNet believes should be excluded from the performance measures for the period, and for each event a description of the event and its impact, quantification of the impact and the reasons for the exclusion request; and
- The calculation of the financial incentive as per the revenue cap decision applying to the period.

These requirements are satisfied in the attached templates.

The STPIS is based on service standard measures that are common to all TNSPs. However, the ACCC recognised in its November 2003 decision on service standards that there must be flexibility in how these performance measures are implemented for each TNSP. In particular, the importance of measuring performance consistently over time was emphasised. The STPIS is based on the assumption that performance measurement will be consistent with the way in which historical performance was derived for target setting.

On 11 March 2010, the Australian Energy Market Commission approved the addition of clause 11.32 of the Electricity Rules which enabled the early application of a MIP.

On 1 October 2010, ElectraNet Pty Ltd (ElectraNet) applied to the AER for the early application of the MIP. Subsequently the AER approved the early application of the MIP to ElectraNet commencing on 1 January 2011 with a target of 1862 dispatch intervals.

Separate templates have been provided with this report covering the service component parameters and the MIP respectively.

Discussion of specific exclusions

Major project outages of more than 14 days

In 2004 ElectraNet applied for the exclusion of major line outages for the rebuilding of the Para - Waterloo 132kV transmission line. The ACCC's auditor Sinclair Knight Merz (SKM) recommended that the ACCC accept ElectraNet's exclusion as it was consistent with the definitions used for target setting for the STPIS. However, the ACCC decided that, as the work was included in the revenue cap it should not be excluded from the performance incentive, but that it would be appropriate that the time associated with the event be capped at 14 days in aggregate in calculating ElectraNet's transmission circuit availability figure. The AER subsequently incorporated this cap into the STPIS that has applied to ElectraNet since 1 July 2008.

During the 2012 ElectraNet managed a number of significant projects which each exceeded the 14 day cap provision. The treatment of these capped exclusions is detailed in the attached template.

Third party events – non customer

In 2009 ElectraNet sought to exclude a number of access related outages requested by third parties to facilitate road widening and high vehicle transport that occurred in the 2008 calendar year. ElectraNet maintained that these outages were clearly of a third party nature and satisfied the exclusion requirement in the definitions. The auditor, Parsons Brinckerhoff (PB), maintained that these outages did not satisfy the definition as the third party concerned was not a customer of ElectraNet subject to a transmission connection agreement (TCA). The AER subsequently granted these exclusions and stated that such outages would be assessed on a case by case basis in the future. ElectraNet has sought no exclusions of this kind for the 2012 calendar year.

Third party events – customer

For the 2009, 2010 and 2011 calendar years ElectraNet sought and received exclusions for a number of transmission line outages that were required to enable access by third parties to the transmission network. These works were:

- Required solely due to the obligations under clauses 5.2.3.(d)(1) and 6A.1.3 of the Rules and clause 4 of the Electricity Transmission Licence for ElectraNet to grant access to third parties to the transmission network;
- Conducted in accordance with TCA's between the customers and ElectraNet which were established following a customer access request;
- Minimised and coordinated in accordance with clauses 3.2 and 3.3 of the Electricity Transmission Code so as to reduce any consequent transmission service interruptions or restrictions.

There were no such outages during the period.

The attachment lists all outages which are excluded by definition from the parameters and which the AER has nonetheless required ElectraNet to report and request exclusions for.

Coordinated generator outages in accordance with Connection Agreements

Between 28 May 2012 and 7 June 2012 the Clements Gap Windfarm was connected to the network via a temporary arrangement to avoid the necessity to constrain the generator to zero output in accordance with its connection agreement during construction works at the Bungama substation.

The temporary arrangement was pursued to enable a level of output to be achieved by the windfarm.

Please refer to the supporting evidence "FW: Endorsement – ElectraNet efforts for transmission availability" in which the customer, Pacific Hydro, expresses its support for ElectraNet's efforts to maximise dispatch during the outage.

As coordinated generator outages are excluded from the scheme ElectraNet seeks the exclusion of the associated dispatch intervals.

Force majeure events

Friday, 30 November 2012 - Davenport – Brinkworth 275kV line

On Friday, 30 November 2012 at 16:53, the Davenport - Brinkworth 275kV line tripped and locked out after an extreme weather event passed through the line. In the aftermath of high winds and storm activity, it was observed that tower numbers 57, 58, 59, 60, 61 and 62 had collapsed and structure 63 remained standing but with visible structural damage. At the other end, tower 56 remained standing with no visible damage. From the recorded weather data and field observations, localised high intensity winds caused the structural damage. Weather station recorded winds in excess of 127km/h, this is exceeded the design parameters that applied when the line was built in 1960.

As discussed with AER staff due to the nature and timing of the event and the subsequent restoration an event investigation report is currently being developed and will be provided in the near future.

The event was unforeseeable and its impact extraordinary. Structure failures in service are rare and, absent negligence on the part of the TNSP, would satisfy any reasonable definition of force majeure.

ElectraNet could not have prevented the event but worked to effectively control the impact of the event and used all available resources to expedite the replacement of the structures.

Monday 5 November 2012 - Templers West 275/132kV transformer

On Monday 5 November 2012 at 18:46 a catastrophic internal failure of the Templers West 275/132kV transformer occurred. This resulted in the Templers - Dorrien 132kV line being de-energised for the duration of the transformer replacement.

The Templers West-Dorrien line connects the low voltage side of Templers West TF2 to Dorrien. This line remained out of service for the duration of the transformer replacement because the transformer is the singular point of connection. The Templers West-Dorrien line was returned to service at 13:07 on 12 December 2012. The replacement Templers West 275/132kV transformer was loaded at 11:10 on 13 Dec 2012. Notwithstanding the

transformer outage the transmission line remained available for return to service at all times.

The failed transformer has been returned to the manufacturer for assessment.

The event was unforeseeable and its impact extraordinary. Catastrophic infantile transformer failures in service are rare and, absent negligence on the part of the TNSP, would satisfy any reasonable definition of force majeure. ElectraNet has not experienced an event of this nature before.

ElectraNet could not have prevented the event but worked to effectively control the impact of the event and used all available resources to expedite the replacement of the transformer.

As discussed with AER staff due to the nature and timing of the event and the subsequent restoration a confidential investigation report is currently being developed. ElectraNet will liaise with AER staff with respect the provision of additional evidence to support this claim of force majeure.

Calculation of Incentive

ElectraNet's actual performance against the conventional STPIS parameters and the MIP respectively are shown in the attached AER Templates (Attachments 1 and 2) that summarise actual performance against each performance measure, including calculation of the S factors and the applicable revenue bonus/ penalty for the 2012 calendar year.

Calculations are presented with and without exclusions as required by the guideline and consistent with previous discussions with AER officers.

Audit of Performance

In its final decision with respect to 2011 calendar performance the AER reiterated the need for supporting evidence to be provided with the annual report. Following discussions with AER staff ElectraNet has endeavoured to provide a reasonable level of supporting information with this submission.

Full access to all relevant systems and reports to support this application will be made available to the auditor if appointed by the AER. In the event that a face to face audit is not progressed the use of ElectraNet's web based video conferencing system is proposed.

Please do not hesitate to contact Bill Jackson on (08) 8404 7969 should you require clarification of any of the information provided in this report.

Yours sincerely,



Simon Appleby
Senior Manager Regulatory Affairs

**ATTACHMENT 1 – AER PROFORMA FOR CALCULATION OF S FACTOR AND INCENTIVE
CONVENTIONAL PARAMETERS**

TEMPLATE EXPLANATION



This template must be used by the TNSP to report service performance information for the previous calendar year.

Yellow worksheets (**'Inputs - Performance'** and **'Inputs - Exclusions'**) are for inputs, including performance and exclusion information. The TNSP only needs to enter data on these worksheets.

Purple worksheets **'S1' to 'S6'** are the s-factor results based on the performance inputs from the 'Inputs - Performance' worksheet.

Blue worksheet **'Revenue Calculation'** quantifies the appropriate revenue to be applied to the s-factor results adjusted for CPI.

Red worksheet **'Outcomes'** shows the total performance, s-factor and financial incentive results based on the TNSP's performance in 'Inputs-Performance' and 'Revenue Calculation' worksheets.

Orange worksheet **'Exclusion Definitions'** are the defined exclusions for each TNSP which should form the basis of exclusion requests under 'Inputs-Exclusions' worksheet.

ElectraNet - SERVICE STANDARDS PERFORMANCE

<i>Performance Inputs</i>							
S	Performance parameter	Collar	Target	Cap	Revenue at Risk	Performance (Without exclusions)	Performance (With exclusions)
S1	Total transmission circuit availability	99.10%	99.47%	99.63%	0.30%	97.806323%	98.463696%
S2	Critical circuit availability – peak	98.52%	99.24%	99.51%	0.20%	98.820141%	99.621571%
S3	Critical circuit availability – non-peak (zero weighting)	98.88%	99.62%	99.95%	0.00%	98.907912%	99.721376%
S4	Loss of supply event frequency (>0.05 system minutes)	11	8	6	0.10%	8	6
S5	Loss of supply event frequency (>0.2 system minutes)	6	4	2	0.20%	6	5
S6	Average outage duration (minutes)	119	78	38	0.20%	431	122

<i>Revenue Determination Inputs</i>	
TNSP:	ElectraNet
STPIS version:	January, 2007
Regulatory Determination	2008/09 - 2012/13
Base Year Allowed Revenue	\$ 229,990,000
Base Year	2008–09
X-factor	-5.93%
Commencement of regulatory year	01-Jul-08

<i>Other inputs</i>	
Assessment Period	2012
Financial year to affect revenue:	2013/14
Date prepared:	11 January 2013
Revision date:	

Number of critical circuits	19 April 1900
Number of non-critical circuits	21 January 1900

Other Inputs

<i>Annual revenue adjusted for C</i>	Mar-08	Mar-09	Mar-10	Mar-11	Mar-12	Mar-13
CPI	162.2	166.2	171.0	176.7	179.5	

NOTE:

Pink cells - Performance without exclusions input cells

Orange cells - Performance with exclusions input cells

Green cells - Other inputs

Blue cells - Inputs sourced from the revenue determination

Performance is based on a calendar year or the proportion of a calendar year that applies in each regulatory period.

Table 1.3.2 - Summary of network events

Table with columns: Event ID, Event category, Event description, Cause of the event, Start date, End date, Risk level, Criticality affected, Resolution status, Duration, Reason for resolution request, Further information, Customer request. The table contains numerous rows detailing network incidents, their causes, and resolutions.

Customer Request column details for various events, including references to investigation reports, technical reports, and specific customer inquiries.

Yellow sidebar area containing 'Critical Peak Start' and 'Critical Peak End' labels, along with a list of customer names and their associated event IDs.

ElectraNet - S1 - Total transmission circuit availability

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Total transmission circuit availability	99.80%	99.10%	99.47%	99.63%	99.80%
Weighting	-0.30%	-0.30%	0.00%	0.30%	0.30%

Performance Formulae	Formulae				Conditions	S- Calc 1	S- Calc 2
Performance	=	-0.003000			Availability < 99.10%	-0.003000	-0.003000
	=	0.810811	x	Availability +	99.10% ≤ Availability ≤ 99.47%	-0.013489	-0.008159
	=	1.875000	x	Availability +	99.47% ≤ Availability ≤ 99.63%	-0.031194	-0.018868
	=	0.003000			99.63% < Availability	0.003000	0.003000

Performance Outcomes	Performance (Without Exclusions)	Performance (Exclusions)
Total transmission circuit availability	= 97.806323%	98.463696%
S-Factor	= -0.300000%	-0.300000%


NOTE: This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



ElectraNet - S2 - Critical circuit availability – peak

Performance Targets	Graph start	Collar	Target	Cap	Graph end
critical circuit availability – peak	98.50%	98.52%	99.24%	99.51%	99.70%
Weighting	-0.20%	-0.20%	0.00%	0.20%	0.20%

Performance Formulae	Formulae				Conditions	S- Calc 1	S- Calc 2
Performance	=	-0.002000			When: Availability < 98.52%	-0.002000	-0.002000
	=	0.277778	x	Availability +	98.52% ≤ Availability ≤ 99.24%	-0.001166	0.001060
	=	0.740741	x	Availability +	99.24% ≤ Availability ≤ 99.51%	-0.003110	0.002826
	=	0.002000			99.51% < Availability	0.002000	0.002000

Performance Outcomes	Performance (Without Exclusions)	Performance (Exclusions)
critical circuit availability – peak	= 98.820141%	99.621571%
S-Factor	= -0.116627%	0.200000%


NOTE: This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



ElectraNet - S3 - Critical circuit availability – non-peak (zero weighting)

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Circuit availability – non-peak (zero Weighting)	98.70%	98.88%	99.62%	99.95%	100.20%
	0.00%	0.00%	0.00%	0.00%	0.00%

Performance Formulae	Formulae				Conditions		S- Calc 1	S- Calc 2
Performance	=	0.000000			When:	Availability < 98.88%	0.000000	0.000000
	=	0.000000	x	Availability + 0.000000		98.88% ≤ Availability ≤ 99.62%	0.000000	0.000000
	=	0.000000	x	Availability + 0.000000		99.62% ≤ Availability ≤ 99.95%	0.000000	0.000000
	=	0.000000				99.95% < Availability	0.000000	0.000000

Performance Outcomes		Performance (Without Exclusions)	Performance (Exclusions)
Circuit availability – non-peak (zero S-Factor)	=	98.907912%	99.721376%
	=	0.000000%	0.000000%


NOTE: This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



ElectraNet - S4 - Loss of supply event frequency (>0.05 system minutes)

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Loss of supply event frequency (>0.05 system minutes)	13	11	8	6	-
Weighting	-0.10%	-0.100%	0.00%	0.100%	0.10%

Performance Formulae	Performance	=	Formulae	Conditions	S- Calc 1	S- Calc 2
		=	-0.001000	11 < No. of events	-0.001000	-0.001000
		=	-0.000333	x No. of events + 0.002667	8 ≤ No. of events ≤ 11	0.000000 0.000667
		=	-0.000500	x No. of events + 0.004000	6 ≤ No. of events ≤ 8	0.000000 0.001000
		=	0.001000	No. of events < 6	0.001000	0.001000

Loss of supply event frequency (>0.05 system minutes)	=	Performance (Without Exclusions)	Performance (Exclusions)
Loss of supply event frequency (>0.05 system minutes)	=	8	6
S-Factor		0.000000%	0.100000%


NOTE: This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



ElectraNet - S5 - Loss of supply event frequency (>0.2 system minutes)

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Loss of supply event frequency (>0.2 system minutes)	0	6	4	2	0
Weighting	-0.20%	-0.200%	0.00%	0.200%	0.20%

Performance Formulae	Formulae					Conditions	S- Calc 1	S- Calc 2	
Performance	=	-0.002000				6 < No. of events	-0.002000	-0.002000	
	=	-0.001000	x	No. of events	+	0.004000	4 ≤ No. of events ≤ 6	-0.002000	-0.001000
	=	-0.001000	x	No. of events	+	0.004000	2 ≤ No. of events ≤ 4	-0.002000	-0.001000
	=	0.002000				No. of events = 2	0.002000	0.002000	

Loss of supply event frequency (>0.2 system minutes)	=	Performance (Without Exclusions)	Performance (Exclusions)
Loss of supply event frequency (>0.2 system minutes)	=	6	5
S-Factor	=	-0.200000%	-0.100000%


NOTE: This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



ElectraNet - S6 - Average outage duration (minutes)

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Average outage duration (minutes)	319	119	78	38	-
Weighting	-0.20%	-0.200%	0.00%	0.200%	0.20%

Performance Formulae	Formulae					Conditions		S- Calc 1	S- Calc 2
Performance	=	-0.002000				119	< Duration	-0.002000	-0.002000
	=	-0.000049	x	Duration	+	0.003805	78 ≤ Duration ≤ 119	-0.017211	-0.002168
	=	-0.000050	x	Duration	+	0.003900	38 ≤ Duration ≤ 78	-0.017641	-0.002222
	=	0.002000					Duration < 38	0.002000	0.002000

Average outage duration (minutes)	=	Performance (Without Exclusions)	Performance (Exclusions)
Average outage duration (minutes)	=	430.816327	122.441860
S-Factor	=	-0.200000%	-0.200000%


NOTE: This sheet will automatically update based on data in input sheets

Blue cells show the TNSP's performance targets and weightings

Yellow/Green cells show the TNSP's performance formulae and related formula conditions based on performance targets and weightings

Pink cells show the TNSP's performance outcomes without any events excluded from performance data

Orange cells show the TNSP's performance outcomes with events excluded from performance data



ElectraNet - Revenue Calculation

X-factor from AER final decision

<i>Revenue cap information</i>	2008-09 to 2009-10
Base year allowed revenue (2008-09)	\$229,990,000
Base year	2008-09
X-factor	-5.93%
Commencement of regulatory period	01-Jul-08

X-factor after approval of Munno Para contingent project

<i>Revenue cap information</i>	2010-11 to 2012-13
Base year allowed revenue (2010-11)	\$272,077,206
Base year	2010-11
X-factor	-5.95%
Commencement of regulatory period	01-Jul-08

<i>Annual revenue adjusted for CPI</i>	Mar-08	Mar-09	Mar-10	Mar-11	Mar-12	Mar-13
CPI	162.2	166.2	171.0	176.7	179.5	-

Nominal annual revenue	2008-09	2009-10	2010-11	2011-12	2012-13
Allowed Revenue	\$229,990,000	\$249,636,506	\$272,077,206	\$297,818,430	\$320,478,165

<i>Calendar year revenue</i>	2008	2009	2010	2011	2012	2013
Revenue	\$114,995,000	\$239,813,253	\$260,856,856	\$284,947,818	\$309,148,298	

NOTE:

This sheet will automatically update based on data on input sheets.

Grey cells show calendar year revenue

Green cells are for formula

ElectraNet - Performance outcomes

Revenue calendar year

\$309,148,298

S	Performance parameter	Target	Performance without exclusions			Performance with exclusions			Impact of exclusions
			Performance	S-Factor	Final Incentive	Performance	S-Factor	Final Incentive	
S1	Total transmission circuit availability	99.47%	97.806323%	-0.300000%	-\$927,445	98.463696%	-0.300000%	-\$927,445	0.000000%
S2	Critical circuit availability – peak	99.24%	98.820141%	-0.116627%	-\$360,552	99.621571%	0.200000%	\$618,297	0.316627%
S3	Critical circuit availability – non-peak (zero weighting)	99.62%	98.907912%	0.000000%	\$0	99.721376%	0.000000%	\$0	0.000000%
S4	Loss of supply event frequency (>0.05 system minutes)	8	8	0.000000%	\$0	6	0.100000%	\$309,148	0.100000%
S5	Loss of supply event frequency (>0.2 system minutes)	4	6	-0.200000%	-\$618,297	5	-0.100000%	-\$309,148	0.100000%
S6	Average outage duration (minutes)	78	431	-0.200000%	-\$618,297	122	-0.200000%	-\$618,297	0.000000%
TOTALS				-0.816627%	-\$2,524,590		-0.300000%	-\$927,445	0.516627%

NOTE:

This sheet will automatically update based on data in input sheets.

Grey cell shows relevant calendar year revenue

Green cells show performance measure targets

Pink cells show performance, s-factor results and financial incentive without exclusions

Orange cells show performance, s-factor results and financial incentive with exclusions

Blue cells show the impact of exclusions on revenue

Aggregate outcome	
S-factor	-0.300000%
Financial Incentive	-\$927,445
Financial year affected by financial incentive	2013/14

ElectraNet - Defined exclusions

No. Parameter 1 - Transmission circuit availability		
Defined exclusions	Further description of exclusion	Reference
1.1 Unregulated transmission assets		Appendix C Revenue cap decision
1.2 3rd party outages	Any outages shown to be caused by a 'third party system'—eg. intertrip signals, generator outage, customer installation, customer request or AEMO direction.	Appendix C Revenue cap decision
1.3 Outages to control voltages	Outages to control voltages within required limits, both as directed by AEMO and where AEMO does not have direct oversight of the network (in both cases only where the element is available for immediate energisation if required).	Appendix C Revenue cap decision
1.4 Circuit opening for operational purposes	The opening of only one end of a transmission line where the transmission line remains energised and available to carry power.	Appendix C Revenue cap decision
1.5 Capped outages	The number of interrupted hours related to a single transmission line redevelopment project or substation redevelopment project is capped at 336 hours (14 days).	Appendix C Revenue cap decision
1.6 Force majeure		Appendix D First proposed STPIS
No. Parameter 2 - Critical circuit availability – peak		
Defined exclusions	Further description of exclusion	Reference
2.1 Unregulated transmission assets		Appendix C Revenue cap decision
2.2 3rd party outages	Any outages shown to be caused by a 'third party system'—eg. intertrip signals, generator outage, customer installation, customer request or AEMO direction.	Appendix C Revenue cap decision
2.3 Outages to control voltages	Outages to control voltages within required limits, both as directed by AEMO and where AEMO does not have direct oversight of the network (in both cases only where the element is available for immediate energisation if required).	Appendix C Revenue cap decision
2.4 Circuit opening for operational purposes	The opening of only one end of a transmission line where the transmission line remains energised and available to carry power.	Appendix C Revenue cap decision
2.5 Capped outages	the number of interrupted hours related to a single transmission line redevelopment project or substation redevelopment project is capped at 336 hours (14 days).	Appendix C Revenue cap decision
2.6 Force majeure		Appendix D First proposed STPIS
Parameter 3 - Loss of supply event frequency (>0.2 system minutes)		
Defined exclusions	Further description of exclusion	Reference
3.1 Successful reclose events (<1 min duration)		Appendix C Revenue cap decision
3.2 Unregulated transmission assets		Appendix C Revenue cap decision
3.3 3rd party outages	Any outages shown to be caused by a 'third party system'—e.g. intertrip signals, generator outage, customer installation, customer request or AEMO direction.	Appendix C Revenue cap decision
3.4 Planned outages		Appendix C Revenue cap decision
3.5 Interconnector outages	For supply outages resulting from an interconnector outage, the period of the interruption is capped at half an hour. This is done to include the impact of automatic under-frequency load shedding, but to exclude the impact of any market failure to respond and restore load within required timeframes (ie. excluding factors outside of ElectraNet's control).	Appendix C Revenue cap decision
3.6 Pumping station supply interruptions	Pumping station supply interruptions were excluded from historical data due to the highly irregular nature of these loads, which makes accurate estimation of load profiles unreliable.	Appendix C Revenue cap decision
3.7 Force majeure		Appendix D First proposed STPIS
3.8 ElectraNet protection operates incorrectly ahead of third party protection	Where ElectraNet protection operates incorrectly ahead of third party protection, the portion of customer load that would have been lost had ElectraNet protection not operated is removed from the total lost load.	Appendix C Revenue cap decision
3.9 ElectraNet protection operates correctly due to a fault on a third party system	Where ElectraNet protection operates correctly due to a fault on a third party system no lost load is recorded.	Appendix C Revenue cap decision
Parameter 4 - Loss of supply event frequency (>1.0 system minutes)		
Defined exclusions	Further description of exclusion	Reference
4.1 Successful reclose events (<1 min duration)		Appendix C Revenue cap decision
4.2 Unregulated transmission assets		Appendix C Revenue cap decision
4.3 3rd party outages	Any outages shown to be caused by a 'third party system'—e.g. intertrip signals, generator outage, customer installation, customer request or AEMO direction.	Appendix C Revenue cap decision
4.4 Planned outages		Appendix C Revenue cap decision
4.5 Interconnector outages	For supply outages resulting from an interconnector outage, the period of the interruption is capped at half an hour. This is done to include the impact of automatic under-frequency load shedding, but to exclude the impact of any market failure to respond and restore load within required timeframes (ie. excluding factors outside of ElectraNet's control).	Appendix C Revenue cap decision
4.6 Pumping station supply interruptions	Pumping station supply interruptions were excluded from historical data due to the highly irregular nature of these loads, which makes accurate estimation of load profiles unreliable.	Appendix C Revenue cap decision
4.7 Force majeure		Appendix D First proposed STPIS
4.8 ElectraNet protection operates incorrectly ahead of third party protection	Where ElectraNet protection operates incorrectly ahead of third party protection, the portion of customer load that would have been lost had ElectraNet protection not operated is removed from the total lost load.	Appendix C Revenue cap decision

4.9	ElectraNet protection operates correctly due to a fault on a third party system	Where ElectraNet protection operates correctly due to a fault on a third party system no lost load is recorded.	Appendix C Revenue cap decision
Parameter 5 - Average outage duration			
	Defined exclusions	Further description of exclusion	Reference
5.1	Successful reclose events (<1 min duration)		Appendix C Revenue cap decision
5.2	Unregulated transmission assets		Appendix C Revenue cap decision
5.3	3rd party outages	any outages shown to be caused by a 'third party system'—eg intertrip signals, generator outage, customer installation, customer request or AEMO direction	Appendix C Revenue cap decision
5.4	Planned outages		Appendix C Revenue cap decision
5.5	Interconnector outages supply interruptions	For supply outages resulting from an interconnector outage, the duration is capped at half an hour. This is done to include the impact of automatic under-frequency load shedding, but to exclude the impact of any market failure to respond and restore load within required timeframes (i.e. excluding factors outside of ElectraNet's control).	Appendix C Revenue cap decision
5.6	Force majeure		Appendix D First proposed STPIS
5.7	ElectraNet protection operates correctly due to a fault on a third party system	Where ElectraNet protection operates correctly due to a fault on a third party system no lost load is recorded.	Appendix C Revenue cap decision

No. Critical circuit availability – non-peak (zero weighting)			
	Defined exclusions	Further description of exclusion	Reference
6.1	Unregulated transmission assets		Appendix C Revenue cap decision
6.2	3rd party outages	Any outages shown to be caused by a 'third party system'—eg intertrip signals, generator outage, customer installation, customer request or AEMO direction.	Appendix C Revenue cap decision
6.3	Outages to control voltages	Outages to control voltages within required limits, both as directed by AEMO and where AEMO does not have direct oversight of the network (in both cases only where the element is available for immediate energisation if required).	Appendix C Revenue cap decision
6.4	Circuit opening for operational purposes	The opening of only one end of a transmission line where the transmission line remains energised and available to carry power.	Appendix C Revenue cap decision
6.5	Capped outages	The number of interrupted hours related to a single transmission line redevelopment project or substation redevelopment project is capped at 336 hours (14 days).	Appendix C Revenue cap decision
6.6	Force majeure		Appendix D First proposed STPIS (January 2007)

Service Target Performance Incentive Scheme - Definition of Force Majeure

Definition of Force Majeure	Reference
<p>For the purpose of applying the <i>service target performance incentive scheme</i>, force majeure events means any event, act or circumstance or combination of events, acts and circumstances which (despite the observance of good electricity industry practice) is beyond the reasonable control of the part affected by any such event, which may include, without limitation, the following:</p> <ul style="list-style-type: none">- fire, lightning, explosion, flood, earthquake, storm, cyclone, action of the elements, riots, civil commotion, malicious damage, natural disaster, sabotage, act of a public enemy, act of God, war (declared or undeclared), blockage, revolution, radioactive contamination, toxic or dangerous chemical contamination or force of nature.- action or inaction by a court, government agency (including denial, refusal or failure to grant any authorisation, despite timely best endeavour to obtain same)- strikes, lockouts, industrial and/or labour disputes and/or difficulties, work bans, blockades, picketing- acts or omissions (other than failure to pay money) of a party other than the TNSP, which party either is connected to or uses the high voltage grid or is directly connected to or uses a system for the supply of electricity that in turn is connected to the high voltage grid- where those acts or omissions affect the ability of the TNSP to perform its obligation under the service standard by virtue of that direct or indirect connection to or use of the high voltage grid <p>In determining what force majeure events should be excluded the AER will consider the following:</p> <ul style="list-style-type: none">- was the event unforeseeable and its impact extraordinary, uncontrollable and not manageable?- does the event occur frequently? If so, how did the impact of the particular event differ?- could the TNSP, in practice, have prevented the impact (not necessarily the event itself)?- could the TNSP have effectively reduced the impact of the event by adopting better practices?	<p>Service Target Performance Incentive Scheme (January 2007) p. 31</p>

**ATTACHMENT 2 – AER PROFORMA FOR CALCULATION OF S FACTOR AND INCENTIVE
MARKET IMPACT PARAMETER**

EXCEL TEMPLATE EXPLANATION



This reporting template is for each TNSP to report its service performance against the market impact parameter of the service target performance incentive scheme.

It only applies to the TNSP for the calendar year set out in the Input Performance worksheet of the TNSPs current regulatory period. The TNSP will need to submit raw data in a clear layout for validation (either in database or csv).

DATABASE TEMPLATE EXPLANATION

Below is an example of a database table format suitable for verification by the AER.

The table lists ALL binding constraints that are used to manage TNSP's XYZ equipment on a 5 minute resolution. The TNSP is able to enter the exclusion clause number in the 'EXCLUSION CLAUSE' field and provide comment . If the outage should be included in the benchmark, the TNSP simply leave the exclusion field blank.

NOTE: All dispatch intervals with a marginal value greater than \$10/MWh, classified as an OUTAGE and has no exclusion clause entered, will be used to calculate the TNSP's Market Impact Parameter.

DATABASE NAME: TNSP XYZ

TABLE NAME: TNSP XYZ Service Performance data

DATA:

SOURCE	SETTLEMENTDATE	CONSTRAINTID	EQUIPMENTNAME	EFFECTIVEDATE	VERSIONNO	MARGINAL VALUE	CLASSIFICATION	EXCLUSION CLAUSE	COMMENTS
TNSP XYZ	1/01/2007 12:30 PM	X>X-22_LK 1	LINE 22	1/01/2007	1	12	OUTAGE		
TNSP XYZ	1/01/2008 12:35 PM	X>X-NIL_RU		1/01/2006	2	120	SYSTEM NORMAL		
TNSP XYZ	1/01/2008 12:35 PM	X>>X-54	LINE 54	1/01/2004	1	200	OUTAGE	6	Line out of service to provide greater network capacity
TNSP XYZ	1/01/2008 12:55 PM	X>X_NSA_01	LINE 33	1/02/2004	1	5000	OUTAGE	7	Network Support constraint
TNSP XYZ	1/01/2007 12:30 PM	X>Y-22_LK 1	LINE 22	1/01/2007	1	12	OUTAGE		TNSP YYY is also responsible for this outage


ElectraNet - SERVICE STANDARDS PERFORMANCE SUMMARY

SERVICE TARGET PERFORMANCE INCENTIVE SCHEME DATA						
Year	Month	Market impact parameter count (DI) (without exclusions)	Market impact parameter count (DI) (with exclusions)	Non-market impact parameter count (DI)	Market impact paramters (Hrs)	Non-market impact paramters (Hrs)
2012	January	773	0	60762	0.00	5063.50
	February	338	0	54878	0.00	4573.17
	March	1156	29	64929	2.42	5410.75
	April	1738	49	64190	4.08	5349.17
	May	1184	11	64474	0.92	5372.83
	June	1603	279	59979	23.25	4998.25
	July	918	69	55740	5.75	4645.00
	August	2134	583	113706	48.58	9475.50
	September	2634	1072	57482	89.33	4790.17
	October	1804	740	64446	61.67	5370.50
	November	1997	626	66115	52.17	5509.58
	December	1931	1029	123168	85.75	10264.00
Total		18210	4487	849869	373.92	70822.42

NOTES:
 Yellow cells - Enter market impact parameter performance data
 Note: Performance is measured on a calendar year basis.

Summary

Date	Marginal value > \$10/MWh	Marginal value < \$10/MWh	Market impact paramters (Hrs)	Non-market impact paramters (Hrs)
2012	4487	849869	373.92	70822.42



Revenue Determination Inputs	
TNSP:	ElectraNet
STPIS version:	January, 2007
Regulatory Determination	2008/09 - 2012/13
Base Year Allowed Revenue	\$ 229,990,000
Base Year	2008-09
X-factor	-5.93%
Commencement of regulatory year	01-Jul-08

Other inputs	
Assessment Period	2012
Financial year to affect revenue:	2012/13
Date prepared:	
Revision date:	
Target	1862

Other Inputs						
Annual reven	Mar-08	Mar-09	Mar-10	Mar-11	Mar-12	Mar-13
CPI	162.2	166.2	171.0	176.7	179.5	

ElectraNet - Market Impact parameter s-factor

Performance Targets	Graph start	Target	Cap	Graph end
market impact parameter	3000	1862	0	0
Parameter weighting	0.00%	0.00%	2.00%	2.00%

Performance Formulae	Formulae				Conditions	S- Calc 1	S- Calc 2
Performance	=	0.000000			When: 1862 < No of dipatch intervals	0.000000	0.000000
	=	-0.000011	x	no of dispatch intervals	+ 0.020000 1862 ≤ No of dipatch intervals < 0	-0.175596	-0.028195
	=	0.020000			No of dipatch intervals = 0	0.020000	0.020000

Performance Outcomes		Performance (Without Exclusions)	Performance (Exclusions)
number of dispatch intervals	=	18210	4487
S-Factor	=	0.0000%	0.0000%


NOTES:

Blue cells show Transgrid's performance target and maximum financial incentive.

Yellow/Green cells show Transgrid's performance formula and related formula conditions based on performance targets and the maximum financial incentive

Pink cells show TNSP performance outcomes without any events excluded from performance data

Orange cells show TNSP's performance outcomes with events excluded from performance data



ElectraNet - Revenue calculation

X-factor from AER final decision

<i>Revenue cap information</i>	2008-09 to 2009-10
Base revenue	\$229,990,000
Base year	2008-09
X-factor	-5.93%
Commencement of regulatory period	01-Jul-08

X-factor after approval of Munno Para contingent project

<i>Revenue cap information</i>	2010-11 to 2012-13
Base year allowed revenue (2010-11)	\$272,077,206
Base year	2010-11
X-factor	-5.95%
Commencement of regulatory period	01-Jul-08

<i>Annual revenue adjusted for CPI</i>	Mar-08	Mar-09	Mar-10	Mar-11	Mar-12	Mar-13
CPI	162.2	166.2	171.0	176.7	179.5	-

	2008-09	2009-10	2010-11	2011-12	2012-13
AR	\$229,990,000	\$249,636,506	\$272,077,206	\$297,818,430	\$320,478,165

<i>Calendar year revenue</i>	2008	2009	2010	2011	2012	2013
Revenue	\$114,995,000	\$239,813,253	\$260,856,856	\$284,947,818	\$309,148,298	

NOTES:
 Grey cells show calendar year revenue
 Green cells are for formula
 .

ElectraNet - Market impact parameter performance outcomes

Revenue calendar year **\$309,148,298**

Performance parameter	Target (six months)	Performance without exclusions			Performance with exclusions			Impact of exclusions
		Performance	S-Factor	Final Incentive	Performance	S-Factor	Final Incentive	
Market impact parameter	1,862	18210	0.000000%	\$0	4487	0.000000%	\$0	0.000000%

NOTE:
This sheet will automatically update based on data in input sheets.

Grey cell shows relevant calendar year revenue

Green cells show performance targets

Pink cells show performance, s-factor results and financial incentive without exclusions

Orange cells show performance, s-factor results and financial incentive with exclusions

Blue cells show the impact of exclusions on revenue

Aggregate outcome	
S-factor	0.000000%
Bonus for market impact parameter	\$0
Financial year to affect revenue	2012/13

Exclusions for Service Target Performance Incentive Scheme

Exclusion Number	Defined Exclusion	Further description	Reference
1	Force majeure	As defined in the Force Majeure definition worksheet and Appendix E of the Service Target Performance Incentive Scheme (March 2008) p. 51	Service Target Performance Incentive Scheme (March 2008) p. 51
2	Credible contingency events	Any network constraints that are invoked to manage the reclassification of non-credible contingency events to credible contingency events as per clause 4.2.3 (f) of the NER	Service Target Performance Incentive Scheme (March 2008) p. 46
3	3rd party outage	Any outages shown to be caused by a fault or other event on a '3rd party system' e.g. intertrip signal, generator outage, customer installation	Service Target Performance Incentive Scheme (March 2008) p. 46
4	Non-prescribed transmission services	Any outages on assets that are not providing prescribed transmission services	Service Target Performance Incentive Scheme (March 2008) p. 46
5	Safety reasons	Any outages for personal safety that are not related to the activity of owning or operating a transmission network	Service Target Performance Incentive Scheme (March 2008) p. 46
6	Operational security	Any outages that are only for the purpose of assisting with operational security, for example where a lower voltage parallel circuit is taken out of service to assist with transfers across an interconnector	Service Target Performance Incentive Scheme (March 2008) p. 46
7	Network support services	Any network constraints related to network support services in accordance with clause 5.6.2 of the NER	Service Target Performance Incentive Scheme (March 2008) p. 46
8 (a)	Others	Dispatch intervals (for a network outage constraint) that are affected by:	Service Target Performance Incentive Scheme (March 2008) p. 46
8 (b)		(a) a manifestly incorrect input to the dispatch algorithm as determined by AEMO under clause 3.9.2B of the NER)	
8 (c)		(b) a constraint applied by AEMO that does not accurately reflect or is otherwise inconsistent with that network capability that the TNSP advised AEMO	
8 (d)		(c) a scheduling error	
8 (e)		(d) mandatory restrictions under clause 3.12A if the NER	
8 (f)		(e) AEMO declaring the spot market suspended under clause 3.14.3 of the NER, or (f) an administered price cap under clause 3.14.2 of the NER	

Service Target Performance Incentive Scheme - Definition of Force Majeure

Definition of Force Majeure	Reference
<p>For the purpose of applying the <i>service target performance incentive scheme</i>, force majeure events means any event, act or circumstance or combination of events, acts and circumstances which (despite the observance of good electricity industry practice) is beyond the reasonable control of the part affected by any such event, which may include, without limitation, the following:</p> <ul style="list-style-type: none">- fire, lightning, explosion, flood, earthquake, storm, cyclone, action of the elements, riots, civil commotion, malicious damage, natural disaster, sabotage, act of a public enemy, act of God, war (declared or undeclared), blockage, revolution, radioactive contamination, toxic or dangerous chemical contamination or force of nature.- action or inaction by a court, government agency (including denial, refusal or failure to grant any authorisation, despite timely best endeavour to obtain same)- strikes, lockouts, industrial and/or labour disputes and/or difficulties, work bans, blockades, picketing- acts or omissions (other than failure to pay money) of a party other than the TNSP, which party either is connected to or uses the high voltage grid or is directly connected to or uses a system for the supply of electricity that in turn is connected to the high voltage grid- where those acts or omissions affect the ability of the TNSP to perform its obligation under the service standard by virtue of that direct or indirect connection to or use of the high voltage grid <p>In determining what force majeure events should be excluded the AER will consider the following:</p> <ul style="list-style-type: none">- was the event unforeseeable and its impact extraordinary, uncontrollable and not manageable?- does the event occur frequently? If so, how did the impact of the particular event differ?- could the TNSP, in practice, have prevented the impact (not necessarily the event itself)?- could the TNSP have effectively reduced the impact of the event by adopting better practices?	<p>Service Target Performance Incentive Scheme (March 2008) p. 51</p>

Month	Marginal Value > \$0 (DI)		Marginal Value > \$10 (DI)	Inclusion Count (DI)		Exclusion Count (DI)	Market Impact Parameters (Hrs)	Inclusion Count (Hrs)	Excluded Count (Hrs)	OUTAGE EXCLUSIONS	MITC CHECKED Dis
2012-01	60762	59989	773	0		773	2.68	0	2.68	160	773
2012-02	54878	54540	338	0		338	1.17	0	1.17	100	338
2012-03	64929	63773	1156	29		1127	4.01	0.1	3.91	381	1156
2012-04	64190	62452	1738	49		1689	6.03	0.17	5.86	1000	1738
2012-05	64474	63290	1184	11		1173	4.11	0.04	4.07	739	1184
2012-06	59979	58376	1603	279		1324	5.57	0.97	4.6	330	1603
2012-07	55740	54822	918	69		849	3.19	0.24	2.95	92	918
2012-08	113706	111572	2134	583		1551	7.41	2.02	5.39	748	2134
2012-09	57482	54848	2634	1072		1562	9.15	3.72	5.42	102	2634
2012-10	64446	62642	1804	740		958	6.26	2.57	3.33	226	1804
2012-11	66115	64118	1997	626		1371	6.93	2.17	4.76	828	1997
2012-12	123168	121237	1931	1029		902	6.7	3.57	3.13	673	1931
Total	849869		18210	4487		13617	63.21	15.57	47.27	5379	18210

Constraint ID	Constraint Description	Marginal Value > \$0 (DI)	Marginal Value > \$10	Inclusion Count (DI)	Exclusion Count (DI)	Market Impact Parameters	Inclusion Count (Hrs)	Excluded Count (Hrs)	OUTAGE EXCLUSIONS	MITC CHECKED Dis
#R006175_010_RAMP_V	Soft Ramping constraint for constraint	3	0	0	0	0	0	0	0	0
#R006175_011_RAMP_F	Hard Ramping constraint for constraint	8	1	0	1	0	0	0	0	1
#R006175_011_RAMP_V	Soft Ramping constraint for constraint	3	0	0	0	0	0	0	0	0
#R006209_002_RAMP_F	Hard Ramping constraint for constraint	6	3	0	3	0.01	0	0.01	0	3
#R006209_002_RAMP_V	Soft Ramping constraint for constraint	2	0	0	0	0	0	0	0	0
#R006241_006_RAMP_V	Soft Ramping constraint for constraint	3	0	0	0	0	0	0	0	0
#R006241_007_RAMP_F	Hard Ramping constraint for constraint	9	8	0	8	0.03	0	0.03	0	8
#R006241_008_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006241_013_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006255_005_RAMP_F	Hard Ramping constraint for constraint VS_250,	2	0	0	0	0	0	0	0	0
#R006255_005_RAMP_V	Soft Ramping constraint for constraint VS_250,	1	0	0	0	0	0	0	0	0
#R006257_016_RAMP_F	Hard Ramping constraint for constraint VS_250,	2	0	0	0	0	0	0	0	0
#R006257_016_RAMP_V	Soft Ramping constraint for constraint VS_250,	3	0	0	0	0	0	0	0	0
#R006259_002_RAMP_F	Hard Ramping constraint for constraint	6	0	0	0	0	0	0	0	0
#R006259_002_RAMP_V	Soft Ramping constraint for constraint	3	0	0	0	0	0	0	0	0
#R006267_006_RAMP_F	Hard Ramping constraint for constraint	6	0	0	0	0	0	0	0	0
#R006267_006_RAMP_V	Soft Ramping constraint for constraint	5	0	0	0	0	0	0	0	0
#R006267_007_RAMP_F	Hard Ramping constraint for constraint	6	4	0	4	0.01	0	0.01	0	4
#R006267_007_RAMP_V	Soft Ramping constraint for constraint	3	0	0	0	0	0	0	0	0
#R006268_006_RAMP_F	Hard Ramping constraint for constraint	6	0	0	0	0	0	0	0	0
#R006271_006_RAMP_F	Hard Ramping constraint for constraint	4	0	0	0	0	0	0	0	0
#R006271_006_RAMP_V	Soft Ramping constraint for constraint	3	0	0	0	0	0	0	0	0
#R006289_007_RAMP_F	Hard Ramping constraint for constraint	8	3	0	3	0.01	0	0.01	0	3
#R006289_007_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006289_008_RAMP_V	Soft Ramping constraint for constraint	2	0	0	0	0	0	0	0	0
#R006289_013_RAMP_F	Hard Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006292_004_RAMP_F	Hard Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006292_004_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006297_002_RAMP_V	Soft Ramping constraint for constraint	6	0	0	0	0	0	0	0	0
#R006298_010_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006298_011_RAMP_F	Hard Ramping constraint for constraint	2	0	0	0	0	0	0	0	0
#R006298_011_RAMP_V	Soft Ramping constraint for constraint	3	0	0	0	0	0	0	0	0
#R006298_012_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006301_002_RAMP_F	Hard Ramping constraint for constraint	7	3	0	3	0.01	0	0.01	0	3
#R006301_002_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006334_004_RAMP_F	Hard Ramping constraint for constraint	3	2	0	2	0.01	0	0.01	0	2
#R006334_004_RAMP_V	Soft Ramping constraint for constraint	7	2	0	2	0.01	0	0.01	0	2
#R006334_005_RAMP_V	Soft Ramping constraint for constraint	4	0	0	0	0	0	0	0	0
#R006335_005_RAMP_V	Soft Ramping constraint for constraint	4	1	0	1	0	0	0	0	1

#R006335_006_RAMP_F	Hard Ramping constraint for constraint	8	4	0	4	0.01	0	0.01	0	4
#R006335_006_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006350_004_RAMP_F	Hard Ramping constraint for constraint	12	12	0	12	0.04	0	0.04	0	12
#R006350_004_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006350_005_RAMP_V	Soft Ramping constraint for constraint	3	3	0	3	0.01	0	0.01	0	3
#R006350_006_RAMP_V	Soft Ramping constraint for constraint	2	0	0	0	0	0	0	0	0
#R006350_011_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006363_010_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006363_016_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006363_020_RAMP_F	Hard Ramping constraint for constraint	11	6	0	6	0.02	0	0.02	0	6
#R006363_020_RAMP_V	Soft Ramping constraint for constraint VN::DDMS,	1	0	0	0	0	0	0	0	0
#R006382_012_RAMP_V	Soft Ramping constraint for constraint	4	0	0	0	0	0	0	0	0
#R006382_013_RAMP_F	Hard Ramping constraint for constraint	6	0	0	0	0	0	0	0	0
#R006384_013_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006384_014_RAMP_F	Hard Ramping constraint for constraint	3	0	0	0	0	0	0	0	0
#R006386_018_RAMP_F	Hard Ramping constraint for constraint	4	0	0	0	0	0	0	0	0
#R006386_018_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006386_020_RAMP_F	Hard Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006386_020_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006391_020_RAMP_F	Hard Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006391_020_RAMP_V	Soft Ramping constraint for constraint	4	0	0	0	0	0	0	0	0
#R006395_005_RAMP_V	Soft Ramping constraint for constraint VS_250,	3	0	0	0	0	0	0	0	0
#R006400_007_RAMP_V	Soft Ramping constraint for constraint	4	0	0	0	0	0	0	0	0
#R006400_008_RAMP_V	Soft Ramping constraint for constraint	3	0	0	0	0	0	0	0	0
#R006400_013_RAMP_V	Soft Ramping constraint for constraint	4	0	0	0	0	0	0	0	0
#R006400_014_RAMP_V	Soft Ramping constraint for constraint	4	0	0	0	0	0	0	0	0
#R006400_015_RAMP_F	Hard Ramping constraint for constraint VS_250,	4	0	0	0	0	0	0	0	0
#R006400_015_RAMP_V	Soft Ramping constraint for constraint VS_250,	4	0	0	0	0	0	0	0	0
#R006413_004_RAMP_F	Hard Ramping constraint for constraint	5	5	0	5	0.02	0	0.02	0	5
#R006413_004_RAMP_V	Soft Ramping constraint for constraint	2	0	0	0	0	0	0	0	0
#R006413_005_RAMP_F	Hard Ramping constraint for constraint	5	5	0	5	0.02	0	0.02	0	5
#R006413_005_RAMP_V	Soft Ramping constraint for constraint	2	0	0	0	0	0	0	0	0
#R006413_006_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006441_004_RAMP_F	Hard Ramping constraint for constraint	7	7	0	7	0.02	0	0.02	0	7
#R006441_004_RAMP_V	Soft Ramping constraint for constraint	1	1	0	1	0	0	0	0	1
#R006441_005_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006441_010_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006441_011_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006447_006_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006447_007_RAMP_F	Hard Ramping constraint for constraint	7	5	0	5	0.02	0	0.02	0	5
#R006447_007_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006447_008_RAMP_F	Hard Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006447_008_RAMP_V	Soft Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006447_019_RAMP_F	Hard Ramping constraint for constraint VS_250,	1	0	0	0	0	0	0	0	0
#R006447_019_RAMP_V	Soft Ramping constraint for constraint VS_250,	2	0	0	0	0	0	0	0	0
#R006456_017_RAMP_F	Hard Ramping constraint for constraint	2	0	0	0	0	0	0	0	0
#R006460_007_RAMP_F	Hard Ramping constraint for constraint	6	0	0	0	0	0	0	0	0
#R006460_007_RAMP_V	Soft Ramping constraint for constraint	5	0	0	0	0	0	0	0	0
#R006467_011_RAMP_F	Hard Ramping constraint for constraint	1	0	0	0	0	0	0	0	0
#R006467_011_RAMP_V	Soft Ramping constraint for constraint	4	0	0	0	0	0	0	0	0
#R006467_016_RAMP_V	Soft Ramping constraint for constraint	2	0	0	0	0	0	0	0	0
#R006467_017_RAMP_F	Hard Ramping constraint for constraint	5	0	0	0	0	0	0	0	0
#R006467_017_RAMP_V	Soft Ramping constraint for constraint	2	0	0	0	0	0	0	0	0
#R006467_020_RAMP_F	Hard Ramping constraint for constraint	3	0	0	0	0	0	0	0	0
#R006467_020_RAMP_V	Soft Ramping constraint for constraint	2	0	0	0	0	0	0	0	0
#R006470_010_RAMP_F	Hard Ramping constraint for constraint	3	0	0	0	0	0	0	0	0
#R006470_010_RAMP_V	Soft Ramping constraint for constraint	6	0	0	0	0	0	0	0	0
#R006470_011_RAMP_F	Hard Ramping constraint for constraint	4	0	0	0	0	0	0	0	0

#V-SA_RAMP_E_F	V-SA <= MAX(126, InitialFlow - 30) (Wt=20)	5	1	0	1	0	0	0	0	1
#V-SA_RAMP_E_F	V-SA <= MAX(134, InitialFlow - 30) (Wt=20)	3	0	0	0	0	0	0	0	0
#V-SA_RAMP_E_F	V-SA <= MAX(145, InitialFlow - 30) (Wt=20)	3	0	0	0	0	0	0	0	0
#V-SA_RAMP_E_F	V-SA <= MAX(15, InitialFlow - 30) (Wt=20)	4	0	0	0	0	0	0	0	0
#V-SA_RAMP_E_F	V-SA <= MAX(155, InitialFlow - 30) (Wt=20)	10	0	0	0	0	0	0	0	0
#V-SA_RAMP_E_F	V-SA <= MAX(185, InitialFlow - 30) (Wt=20)	10	1	0	1	0	0	0	0	1
#V-SA_RAMP_E_F	V-SA <= MAX(188, InitialFlow - 30) (Wt=20)	3	0	0	0	0	0	0	0	0
#V-SA_RAMP_E_F	V-SA <= MAX(20, InitialFlow - 30) (Wt=20)	4	0	0	0	0	0	0	0	0
#V-SA_RAMP_E_F	V-SA <= MAX(22, InitialFlow - 30) (Wt=20)	2	0	0	0	0	0	0	0	0
#V-SA_RAMP_E_F	V-SA <= MAX(230, InitialFlow - 30) (Wt=20)	2	0	0	0	0	0	0	0	0
#V-SA_RAMP_E_F	V-SA <= MAX(250, InitialFlow - 30) (Wt=20)	8	8	0	8	0.03	0	0.03	0	8
#V-SA_RAMP_E_F	V-SA <= MAX(50, InitialFlow - 30) (Wt=20)	4	0	0	0	0	0	0	0	0
#V-SA_RAMP_E_F	V-SA <= MAX(53, InitialFlow - 30) (Wt=20)	6	2	0	2	0.01	0	0.01	0	2
#V-SA_RAMP_E_F	V-SA >= MIN(165, InitialFlow + 50) (Wt=20)	1	0	0	0	0	0	0	0	0
#V-SA_RAMP_I_F	V-SA <= MAX(-1, InitialFlow - 30) (Wt=20)	3	0	0	0	0	0	0	0	0
#V-SA_RAMP_I_F	V-SA <= MAX(-105, InitialFlow - 30) (Wt=20)	9	0	0	0	0	0	0	0	0
#V-SA_RAMP_I_F	V-SA <= MAX(-33, InitialFlow - 30) (Wt=20)	4	0	0	0	0	0	0	0	0
#V-SA_RAMP_I_F	V-SA <= MAX(-50, InitialFlow - 30) (Wt=20)	3	0	0	0	0	0	0	0	0
#V-SA_RAMP_I_F	V-SA <= MAX(-57, InitialFlow - 30) (Wt=20)	3	0	0	0	0	0	0	0	0
#V-SA_RAMP_I_F	V-SA <= MAX(-80, InitialFlow - 30) (Wt=20)	12	7	0	7	0.02	0	0.02	0	7
#V-SA_RAMP_I_F	V-SA <= MAX(-92, InitialFlow - 30) (Wt=20)	4	0	0	0	0	0	0	0	0
#V-SA_RAMP_I_F	V-SA >= MIN(-10, InitialFlow + 50) (Wt=20)	4	0	0	0	0	0	0	0	0
#V-SA_RAMP_I_F	V-SA >= MIN(-122, InitialFlow + 50) (Wt=20)	5	1	0	1	0	0	0	0	1
#V-SA_RAMP_I_F	V-SA >= MIN(-128, InitialFlow + 50) (Wt=20)	4	3	0	3	0.01	0	0.01	0	3
#V-SA_RAMP_I_F	V-SA >= MIN(-43, InitialFlow + 50) (Wt=20)	5	4	0	4	0.01	0	0.01	0	4
#V-SA_RAMP_I_F	V-SA >= MIN(-61, InitialFlow + 50) (Wt=20)	4	2	0	2	0.01	0	0.01	0	2
#V-SA_RAMP_I_F	V-SA >= MIN(-70, InitialFlow + 50) (Wt=20)	10	6	0	6	0.02	0	0.02	0	6
#V-SA_RAMP_I_F	V-SA >= MIN(-80, InitialFlow + 50) (Wt=20)	6	0	0	0	0	0	0	0	0
#V-SA_RAMP_I_F	V-SA >= MIN(-85, InitialFlow + 50) (Wt=20)	5	0	0	0	0	0	0	0	0
#V-SA_RAMP_I_F	V-SA >= MIN(-86, InitialFlow + 50) (Wt=20)	3	3	0	3	0.01	0	0.01	0	3
#V-SA_RAMP_I_F	V-SA >= MIN(-90, InitialFlow + 50) (Wt=20)	6	0	0	0	0	0	0	0	0
#V-SA_RAMP_I_F	V-SA >= MIN(-91, InitialFlow + 50) (Wt=20)	4	0	0	0	0	0	0	0	0
#V-S-MNSP1_I_E	V-S-MNSP1.ENERGY * -1 = 31 (Wt = 20)	23	0	0	0	0	0	0	0	0
#V-S-MNSP1_I_E	V-S-MNSP1.ENERGY * -1 = 50 (Wt = 20)	9	9	0	9	0.03	0	0.03	0	9
@OSBTOA_3	Eff = 02/11/2012 ; RHS = 380 ; Op = "<=" ; Wt =	26	18	18	0	0.06	0.06	0	0	18
@OSBTOA_3	Eff = 03/11/2012 ; RHS = 380 ; Op = "<=" ; Wt =	245	136	136	0	0.47	0.47	0	0	136
@OSBTOA_3	Eff = 04/11/2012 ; RHS = 425 ; Op = "<=" ; Wt =	9	3	3	0	0.01	0.01	0	0	3
@OSBTOA_3	Eff = 05/11/2012 ; RHS = 380 ; Op = "<=" ; Wt =	258	158	158	0	0.55	0.55	0	0	158
@TIPSA_ET_TRANSF	Eff = 02/11/2012 ; RHS = 450 ; Op = "<=" ; Wt =	10	10	0	10	0.03	0	0.03	10	10
CA_MQS_3FA51EAC_01	Constraint Automation, O/L OSBTOA_3	88	63	0	63	0.22	0	0.22	63	63
CA_MQS_3FAAB8EA_01	Constraint Automation, O/L N_W_B_TRANSF	354	3	0	3	0.01	0	0.01	3	3
CA_MQS_3FC98EBF_01	Constraint Automation, O/L TABKEI_1	6	6	0	6	0.02	0	0.02	0	6
CA_SPS_3EF2F2EF_01	Constraint Automation, O/L DDTS_TRANSF	2	2	0	2	0.01	0	0.01	0	2
DATASNAP	Reference Constraint to check measurement;	576	0	0	0	0	0	0	0	0
DATASNAP_DPTX_1	Compare Armidale, Tamworth Total load and	576	0	0	0	0	0	0	0	0
DATASNAP_NILQ1	Test - NEVER TO BIND. Out = NIL, prevent	465	0	0	0	0	0	0	0	0
DATASNAP_NILQ2	Test - NEVER TO BIND. Out = NIL, prevent	177	0	0	0	0	0	0	0	0
DATASNAP_NILQ2	Test - NEVER TO BIND. Out = NIL, prevent	288	0	0	0	0	0	0	0	0
DATASNAP_NILQ3	Test - NEVER TO BIND. Out = NIL, prevent	288	0	0	0	0	0	0	0	0
DATASNAP_NILQ3	Test - NEVER TO BIND. Out = NIL, prevent	177	0	0	0	0	0	0	0	0
DATASNAP_NILQ4	Test - NEVER TO BIND. Out = NIL, prevent	465	0	0	0	0	0	0	0	0
DATASNAP_NILS1	Test - NEVER TO BIND. Out = NIL, prevent	288	0	0	0	0	0	0	0	0
DATASNAP_NILS1	Test - NEVER TO BIND. Out = NIL, prevent	177	0	0	0	0	0	0	0	0
DATASNAP_NILS2	Test - NEVER TO BIND. Out = NIL, prevent	177	0	0	0	0	0	0	0	0
DATASNAP_NILS2	Test - NEVER TO BIND. Out = NIL, prevent	288	0	0	0	0	0	0	0	0
DATASNAP_NILS3	Test - NEVER TO BIND. Out = NIL, prevent	177	0	0	0	0	0	0	0	0
DATASNAP_NILS4	Test - NEVER TO BIND. Out = NIL, prevent	177	0	0	0	0	0	0	0	0
DATASNAP_NILV1	Test - NEVER TO BIND. Out = NIL, prevent	177	0	0	0	0	0	0	0	0

S>>V_NIL_NIL_MNWT	Out= Nil, avoid O/L Mintaro to Waterloo (1)	576	0	0	0	0	0	0	0	0	0
S>>V_NIL_NIL_MW4RB	Out= Nil, avoid O/L Morgan Whyalla 4 to	576	0	0	0	0	0	0	0	0	0
S>>V_NIL_PWSE_KHSG	Out= Nil, avoid O/L Keith - Snuggery 132 kV line	576	0	0	0	0	0	0	0	0	0
S>>V_NIL_RBTX_MW4RB	Out= Nil, avoid O/L Morgan Whyalla 4 to	576	0	0	0	0	0	0	0	0	0
S>>V_NIL_RBTXW_RBTX1	Out=Nil: limit SA to Vic on Murraylink and SA	66	9	0	9	0.03	0	0.03	0	9	0
S>>V_NIL_RBTXW_RBTX1	Out=Nil: limit SA to Vic on Murraylink and SA	1088	205	0	205	0.71	0	0.71	0	205	0
S>>V_NIL_RBTXW_RBTX2	Out=Nil: limit SA to Vic on Murraylink and SA	580	4	0	4	0.01	0	0.01	0	4	0
S>>V_NIL_SETX_SETX	Out= Nil, avoid overloading a South East 275/132	5902	4187	0	4187	14.54	0	14.54	0	4187	0
S>>V_NIL_TBSE_KHSG	Out= Nil, avoid O/L Keith - Snuggery 132 kV line	576	0	0	0	0	0	0	0	0	0
S>>V_NIL_WTTP_WEMW4	Out= Nil, avoid O/L Waterloo East to Morgan	577	1	0	1	0	0	0	0	1	0
S>>V_RBTU_N-2_RBTX1	Out= Nil; avoid O/L Robertstown transformer #1	45	11	0	11	0.04	0	0.04	0	11	0
S>>V_RBTX_DRTW_WEMW4	Out= One Robertstown 275/132kV transformer	1	1	0	1	0	0	0	1	1	0
S>>V_SETB_N-2_TBKH2	Prior outage= Nil; avoid O/L Keith to Tailem Bend	18	0	0	0	0	0	0	0	0	0
S>>V_SETB_SETB_TBKH1	Out= one South East to Tailem Bend 275kV line,	2	2	2	0	0.01	0.01	0	0	2	0
S>>V_SETX_SGKH_SETX	Out = South East one transformer; Prevent	5	4	4	0	0.01	0.01	0	0	4	0
S>>V_TBTU_N-2_MOTB	Prior Outage= Nil; Avoid O/L Mobilong - Tailem	1	0	0	0	0	0	0	0	0	0
S>>V_TU_W_BUS_TUTB_3	Out= Tungkillo 275kV west bus (i.e.	203	0	0	0	0	0	0	0	0	0
S>>V_TU_W_BUS_TUTB_4	Out= Tungkillo 275kV west bus (i.e.	203	0	0	0	0	0	0	0	0	0
S>>V_TU_W_BUS_TUTB_5	Out= Tungkillo 275kV west bus (i.e.	203	0	0	0	0	0	0	0	0	0
S>BGCB6243_BGPT_HUWT	Out = Bungama 132 kV circuit breaker CB6243; to	92	92	0	92	0.32	0	0.32	92	92	0
S>BRDV_BRTW_MNWT	Out= Brinkworth - Davenport 275 kV line, avoid	288	0	0	0	0	0	0	0	0	0
S>MYTX2_MYTX1	Out = Mayura 132/33 kV transformer #2 with the	49	49	0	49	0.17	0	0.17	49	49	0
S>NIL_BGPA_BRTW	Out= Nil, avoid O/L Brinkworth 275 to Templers	576	0	0	0	0	0	0	0	0	0
S>NIL_BRTW_MNWT	Out= Nil, avoid O/L Mintaro to Waterloo (1) on trip	576	0	0	0	0	0	0	0	0	0
S>NIL_CGTB_TUTB	Out= Nil, avoid O/L Tungkillo to Tailem Bend 275	607	17	0	17	0.06	0	0.06	0	17	0
S>NIL_DVBG_BRTW	Out= Nil, avoid O/L Brinkworth 275 to Templers	576	0	0	0	0	0	0	0	0	0
S>NIL_HUWT_STBG	Out = Nil; Limit Snowtown WF generation to avoid	659	83	0	83	0.29	0	0.29	0	83	0
S>NIL_NIL_MYSG-T	Out = NIL; Limit LB2 and LB3 generation to avoid	730	130	0	130	0.45	0	0.45	0	130	0
S>NIL_NIL_STST-T	Out = Nil; Limit Snowtown WF generation to avoid	576	0	0	0	0	0	0	0	0	0
S>NIL_NOTI_NOTI	Out = NIL; Limit generation to avoid OL Torrens	586	9	0	9	0.03	0	0.03	0	9	0
S>NIL_PL_GENMAX	Out = Nil, Maximum generation at Port Lincoln	576	0	0	0	0	0	0	0	0	0
S>NIL_PL_GENMAX_YDMD	Out = Nil, Maximum generation at Port Lincoln	576	0	0	0	0	0	0	0	0	0
S>NIL_TBSE_TBKH1	Out= Nil, avoid O/L Tailem Bend 132 to Keith 132	582	1	0	1	0	0	0	0	1	0
S>S_6162_MTSE_SGKH	Out = South East CB6162; avoid O/L of Snuggery-	16	16	16	0	0.06	0.06	0	0	16	0
S>S_SNTX3A	Out=Snuggery #3 132/33 kV transformer, prevent	39	39	0	39	0.14	0	0.14	39	39	0
S>S_SNTX3B	Out=Snuggery #3 132/33 kV transformer, prevent	13	13	0	13	0.05	0	0.05	13	13	0
S>SE132CB_SETX_SGKH	Out= South East 132 kV CB6160 or CB6162,	265	265	0	265	0.92	0	0.92	265	265	0
S>SETX_SETX_SGKH	Out= One South East 275/132kV transformer,	719	719	701	18	2.5	2.43	0.06	18	719	0
S>V_CB6021+6225_TX1	Out= North West Bend_CB6021 and CB6225; limit	436	91	91	0	0.32	0.32	0	0	91	0
S>V_CB6021+6225_TX1	Out= North West Bend_CB6021 and CB6225; limit	156	0	0	0	0	0	0	0	0	0
S>V_CB6024+6023_TX2	Out= North West Bend_CB6024 and CB6023; limit	1534	646	646	0	2.24	2.24	0	0	646	0
S>V_NIL_HYTX_HYTX	Out= Nil, limit SA to Vic to avoid OL the remaining	675	19	0	19	0.07	0	0.07	0	19	0
S>V_NIL_NIL_HYTX1	Out= Nil, limit SA to Vic to avoid OL Heywood	578	0	0	0	0	0	0	0	0	0
S>V_NIL_NIL_HYTX2	Out= Nil, limit SA to Vic to avoid OL Heywood	576	0	0	0	0	0	0	0	0	0
S>V_NIL_NIL_RBNW	Out = Nil, avoid overloading North West Bend to	1408	184	0	184	0.64	0	0.64	0	184	0
S>V_NWRB_RBMWP3	Out=NWB - Robertstown 132kV line, Limit	53	16	16	0	0.06	0.06	0	0	16	0
S>V_NWRB2_RBNW1	Out = North West Bend to Robertstown No2 line,	184	35	35	0	0.12	0.12	0	0	35	0
S>V_X_6021+6022_TX2	Out= North West Bend CB6021 & CB6022; limit	2204	433	433	0	1.5	1.5	0	0	433	0
S>VML_NWCB6023_TX2	Out= North West Bend_CB6023; limit SA to	40	36	0	36	0.13	0	0.13	36	36	0
S>VML_NWCB6024+25	Out= North West Bend_CBs 6024 and 6025; limit	159	45	45	0	0.16	0.16	0	0	45	0
S>VML_NWCB6033_TX2	Out= North West Bend_CB6033; limit SA to	2484	413	413	0	1.43	1.43	0	0	413	0
S>VML_NWCB6225_TX1	Out= North West Bend_CB6225; limit SA to	3	0	0	0	0	0	0	0	0	0
S>VMLMHNW2	Out=MNSH_NW # 2, SA-V on ML, avoid overload	145	27	27	0	0.09	0.09	0	0	27	0
S>X_BRMN_DRTP_1	Out= Brinkworth to Clare North to Mintaro 132kV	32	32	0	32	0.11	0	0.11	32	32	0
SA_HYSE1	SA / Eastern separation between Heywood and	2	2	0	2	0.01	0	0.01	2	2	0
S-LB2_0	Discretionary upper limit for Lake Bonney 2	17	17	0	17	0.06	0	0.06	15	17	0
S-SG_0	Snuggery 132KV Turbine Bus out of service.	1	1	0	1	0	0	0	1	1	0
S-SNWWF_0	Discretionary upper limit for Snowtown WF	470	470	78	392	1.63	0.27	1.36	392	470	0

V^S_PACP_MAXG	Out = Para capacitor bank; Vic to SA Long Term	43	6	0	6	0.02	0	0.02	6	6
V^S_PAVC_MAXG	Out= Para one SVC; Vic to SA Long Term Voltage	174	69	69	0	0.24	0.24	0	0	69
V^S_PWSE_MAXG	Out= Penola West - South East 132 kV line; Vic to	25	0	0	0	0	0	0	0	0
V^S_SETX_MAXG	Out = One South East 275/132 kV transformer; Vic	142	38	38	0	0.13	0.13	0	0	38
V^S_SEVC_MAXG	Out= South East one SVC; Vic to SA Long Term	50	0	0	0	0	0	0	0	0
V^S_X_MSTU_MBMO	Out= Mt Barker South-Tungkillo 275kV line and Mt	30	4	4	0	0.01	0.01	0	0	4
V^S_HYCP	Outage = Nil, limit Vic to SA to avoid voltage	576	0	0	0	0	0	0	0	0
V^SML_NIL_3	Out = Nil, avoid voltage collapse for loss of	577	0	0	0	0	0	0	0	0
V^SML_NIL_3	Outage = Nil, limit Vic to SA on Murraylink to avoid	1	1	0	1	0	0	0	0	1
V^SML_NSWRB_2	Out = NSW Murraylink runback scheme, avoid	632	48	0	48	0.17	0	0.17	48	48
V^SML_NSWRB_2	Outage = NSW Murraylink runback scheme, limit	83	45	0	45	0.16	0	0.16	45	45
V_HYML1_2	Out = Heywood to Moorabool No. 1 500 kV line,	100	1	0	1	0	0	0	1	1
V_HYML1_4	Out = Heywood to Moorabool No. 1 500 kV line,	103	4	0	4	0.01	0	0.01	4	4
V_HYML1_5	Out = Heywood to Moorabool No. 1 500 kV line,	99	0	0	0	0	0	0	0	0
V_HYMO2_1	Out = Heywood to Mortlake No. 2 500 kV line, limit	125	29	0	29	0.1	0	0.1	29	29
V_HYMO2_2	Out = Heywood to Mortlake No. 2 500 kV line, limit	92	0	0	0	0	0	0	0	0
V>>N_DDMS_2	Out = Dederang to Murray 330 kV line, avoid O/L	77	15	0	15	0.05	0	0.05	15	15
V>>N_SMHTX_1	Out = South Morang H1 or H2 330/220 kV txfmr,	128	6	0	6	0.02	0	0.02	6	6
V>>N_SMTXF2	Outage = South Morang 500/330kV (F2)	7	0	0	0	0	0	0	0	0
V>>N_SMTXF2A	Outage = South Morang 500/330kV (F2)	1	1	0	1	0	0	0	1	1
V>>N_UTYS_BH_15M	Out = Upper Tumut -Yass(2), avoid Murray to	120	0	0	0	0	0	0	0	0
V>>N-LTMS_1	Out= Lower Tumut-Murray(66), avoid Murray to	18	15	0	15	0.05	0	0.05	15	15
V>>N-LTMS_4	Out= LowerTumut-Murray(66), avoid Murray to	1	1	0	1	0	0	0	1	1
V>>N-NIL_HA	Out = Nil, avoid Murray to Upper Tumut(65) O/L on	687	37	0	37	0.13	0	0.13	0	37
V>>N-NIL_HB	Out = Nil, avoid Murray to Lower Tumut(66) O/L on	576	0	0	0	0	0	0	0	0
V>>N-NIL_HG	Out = Nil, avoid Murray to Upper Tumut(65) O/L on	591	11	0	11	0.04	0	0.04	0	11
V>>N-NIL_HH	Out = Nil, avoid Murray to Lower Tumut(66) O/L on	576	0	0	0	0	0	0	0	0
V>>S_APDH2_1	Out = Heywood to APD No. 2 500 kV line section,	8	0	0	0	0	0	0	0	0
V>>S_APDH2_3	Out = Heywood to APD No. 2 500 kV line section	1	1	0	1	0	0	0	1	1
V>>S_BGPA_RBTU_N-2_1	Out= Bungama - Para 275 kV line, avoid O/L	3	1	0	1	0	0	0	1	1
V>>S_BGPA_RBTU_N-2_3	Out= Bungama-Para 275kV line; avoid O/L	1	1	0	1	0	0	0	1	1
V>>S_BP_RBTU-2_WEWT	Out= Brinkworth - Templers West line; avoid O/L	4	3	0	3	0.01	0	0.01	3	3
V>>S_BP_RBTU-2_WTTP	Out= Brinkworth - Templers West line; avoid O/L	3	3	0	3	0.01	0	0.01	3	3
V>>S_CGTB_TBTU_TBMO	Out= Cherry Gardens - Taillem Bend 275 kV line,	280	79	79	0	0.27	0.27	0	0	79
V>>S_CGTB_TBTU_TBMO	Prior Outage = Cherry Gardens - Taillem Bend 275	15	0	0	0	0	0	0	0	0
V>>S_DB_RBTU-2_WEWT	Out= Davenport - Brinkworth line; avoid O/L	100	90	0	90	0.31	0	0.31	90	90
V>>S_HYML_1	Out = Heywood - Moorabool - APD 500 kV line,	1231	41	0	41	0.14	0	0.14	41	41
V>>S_HYML_1	Out = One Heywood 500/275 kV txfmr in service	239	1	0	1	0	0	0	1	1
V>>S_HYML_2	Out = Heywood - Moorabool - APD 500 kV line,	525	2	0	2	0.01	0	0.01	2	2
V>>S_HYML_2	Out = One Heywood 500/275 kV txfmr in service	302	78	0	78	0.27	0	0.27	78	78
V>>S_HYML_3	Out = One Heywood 500/275 kV txfmr in service	191	0	0	0	0	0	0	0	0
V>>S_HYML_4	Out = One Heywood 500/275 kV txfmr in service	833	203	0	203	0.7	0	0.7	203	203
V>>S_KHKN_SETB_SGKH	Out = Keith - Kincaig 132 kV line; avoid Snuggery	358	185	185	0	0.64	0.64	0	0	185
V>>S_KNPW_NIL_SGKH	Out = Kincaig - Penola West 132 kV line; avoid	2	0	0	0	0	0	0	0	0
V>>S_KNPW_SETB_SGKH	Out = Kincaig - Penola West 132 kV line; avoid	20	0	0	0	0	0	0	0	0
V>>S_NIL_DVBG_DVBR	Out= Nil, avoid O/L Davenport 275 to Brinkworth	576	0	0	0	0	0	0	0	0
V>>S_NIL_KHTB1_KHTB2	Out = Nil. Prevent Keith - Taillem Bend #2 line OL	678	52	0	52	0.18	0	0.18	0	52
V>>S_NIL_KHTB2_KHTB1	Out = Nil. Prevent Keith - Taillem Bend #1 line OL	627	6	0	6	0.02	0	0.02	0	6
V>>S_NIL_NIL_KHTB1	Out = Nil. Prevent Keith - Taillem Bend #1 line OL	576	0	0	0	0	0	0	0	0
V>>S_NIL_NIL_SGKHC	Out= Nil, Limit all other generators except LB3 to	754	67	0	67	0.23	0	0.23	0	67
V>>S_NIL_PWKN_SGKH	Out= Nil, avoid O/L Snuggery - Keith 132 kV line	576	0	0	0	0	0	0	0	0
V>>S_NIL_SETB_KHTB	Out = Nil; Prevent Keith - Taillem Bend #1 line OL	738	45	0	45	0.16	0	0.16	0	45
V>>S_NIL_SETB_PWKN	Out = Nil; Prevent Penola West - Kincaig OL for	576	0	0	0	0	0	0	0	0
V>>S_NIL_SETB_SGKH	Out= Nil, avoid O/L Snuggery - Keith 132 kV line	576	0	0	0	0	0	0	0	0
V>>S_NIL_SGBL_SGKH	Out= Nil, avoid O/L Snuggery Keith 132 kV line on	576	0	0	0	0	0	0	0	0
V>>S_RBTU_N-2_WEWT	Out= Nil; avoid O/L Waterloo East-Waterloo	63	27	0	27	0.09	0	0.09	0	27
V>>S_SETX_NPS_SETX	Out = One South East Transformer. Prevent	57	52	52	0	0.18	0.18	0	0	52
V>>S_TU_W_BUS_TURB_1	Out= Tungkillo 275kV west bus (i.e.	203	0	0	0	0	0	0	0	0

V>>S_TU_W_BUS_TURB_2	Out= Tungkillo 275kV west bus (i.e.	203	0	0	0	0	0	0	0	0	0	0
V>>S_TU_W_BUS_TUTB_6	Out= Tungkillo 275kV west bus (i.e.	203	0	0	0	0	0	0	0	0	0	0
V>>S_TU_W_BUS_TUTB_7	Out= Tungkillo 275kV west bus (i.e.	203	0	0	0	0	0	0	0	0	0	0
V>>S_TU_W_BUS_TUTB_8	Out= Tungkillo 275kV west bus (i.e.	203	0	0	0	0	0	0	0	0	0	0
V>>S_TX1_SGBL_SGTX4	Out= Snuggery T1 transformer , avoid O/L	4	0	0	0	0	0	0	0	0	0	0
V>>S_X_CGTB_TBKH1_3	Out= Cherry Gardens - Taillem Bend 275 kV line	169	6	6	0	0.02	0.02	0	0	0	0	6
V>>SML_BAML1_4	Out = Moorabool to Ballarat No. 1 220 kV line,	23	22	0	22	0.08	0	0.08	22	22	0	22
V>>SML_BESH_1	Out = Bendigo to Shepparton 220 kV line, avoid	8	7	0	7	0.02	0	0.02	7	7	0	7
V>>SML_BESH_2	Out = Bendigo to Shepparton 220 kV line, avoid	2	1	0	1	0	0	0	1	1	0	1
V>>SML_DDG_N	Out = Dederang to Glenrowan No.1 or No.3 220kV	288	0	0	0	0	0	0	0	0	0	0
V>>SML_NIL_1	Out = Nil, avoid O/L Ballarat to Moorabool No.1	311	18	0	18	0.06	0	0.06	0	18	0	18
V>>SML_NIL_1	Out = Nil, avoid O/L Ballarat to Moorabool No.1	298	3	0	3	0.01	0	0.01	0	3	0	3
V>>SML_NIL_1	Out = Nil, avoid O/L Ballarat to Moorabool No.1	7	7	0	7	0.02	0	0.02	0	7	0	7
V>>SML_NIL_1_5M	Out = Nil, avoid O/L Ballarat to Moorabool No.1	288	0	0	0	0	0	0	0	0	0	0
V>>SML_NIL_2	Out = Nil, avoid pre-contingent O/L of the	576	0	0	0	0	0	0	0	0	0	0
V>>SML_NIL_3	Out = Nil, avoid O/L the Bendigo to Fosterville to	576	0	0	0	0	0	0	0	0	0	0
V>>SML_NIL_7A	Out = Nil, avoid O/L Ballarat North to Buangor	660	40	0	40	0.14	0	0.14	0	40	0	40
V>>SML_NIL_7A	Out = Nil, avoid O/L on the Ballarat North to	79	10	0	10	0.03	0	0.03	0	10	0	10
V>>SML_NIL_7B	Out = Nil, avoid O/L Buangor to Arrarat 66kV line	577	1	0	1	0	0	0	0	1	0	1
V>>SML_NIL_7B	Out = Nil, avoid O/L on the Buangor to Arrarat	32	0	0	0	0	0	0	0	0	0	0
V>>SML_NIL_7C	Out = Nil, avoid O/L Arrarat to Stawell 66kV line for	576	0	0	0	0	0	0	0	0	0	0
V>>SML_NIL_8	Out = Nil, avoid O/L Ballarat to Bendigo 220 kV	291	0	0	0	0	0	0	0	0	0	0
V>>SML_NIL_8	Out = Nil, avoid O/L Ballarat to Bendigo 220 kV	288	0	0	0	0	0	0	0	0	0	0
V>>SML_NIL_8_5M	Out = Nil, avoid O/L Ballarat to Bendigo 220 kV	288	0	0	0	0	0	0	0	0	0	0
V>>S-SEVC_SETB_SETX	Prior Outage = South East SVC with bus tie CB;	2	0	0	0	0	0	0	0	0	0	0
V>>V_CBTS_TX_2B_R	Outage = Cranbourne 500/220kV transformer, limit	41	0	0	0	0	0	0	0	0	0	0
V>>V_DDTX_A	Out = Dederang H2 or H3 330/220kV txfmr, avoid	23	6	0	6	0.02	0	0.02	6	6	0	6
V>>V_HWTS_TX3_3-5MOD	Out = Hazelwood #3 or #4 500/220kV transformer,	60	12	0	12	0.04	0	0.04	12	12	0	12
V>>V_KTS_TX_A2_2B_R	Out = Keilor A2 or A4 500/220 kV txfmr, avoid pre-	2	0	0	0	0	0	0	0	0	0	0
V>>V_LTMS_1	Out= LowerTumut-Murray(66), avoid Dederang to	81	19	0	19	0.07	0	0.07	19	19	0	19
V>>V_MLSY1_1A	Out = Either Sydenham-Moorabool 500 kV line,	182	0	0	0	0	0	0	0	0	0	0
V>>V_MLSY1_1B	Out = Either Sydenham-Moorabool 500 kV line,	182	0	0	0	0	0	0	0	0	0	0
V>>V_MLTS_TX_2_P	Out = Moorabool A1 or A2 500/220kV transformer,	104	0	0	0	0	0	0	0	0	0	0
V>>V_NIL_1A	Out = Nil, avoid O/L Dederang to Murray No.1	576	0	0	0	0	0	0	0	0	0	0
V>>V_NIL_1B	Out = Nil, avoid O/L Dederang to Murray No.2	664	73	0	73	0.25	0	0.25	0	73	0	73
V>>V_NIL_2_P	Out = Nil, avoid pre-contingent O/L of the South	116	0	0	0	0	0	0	0	0	0	0
V>>V_NIL_2A_R	Out = Nil, avoid pre-contingent O/L of South	1063	4	0	4	0.01	0	0.01	0	4	0	4
V>>V_NIL_2A_R	Out = Nil, avoid pre-contingent O/L of the South	249	0	0	0	0	0	0	0	0	0	0
V>>V_NIL_2B_R	Out = Nil, avoid pre-contingent O/L of South	1675	11	0	11	0.04	0	0.04	0	11	0	11
V>>V_NIL_2B_R	Out = Nil, avoid pre-contingent O/L of the South	17	0	0	0	0	0	0	0	0	0	0
V>>V_NIL_3	Out = Nil, avoid O/L either Dederang to South	580	4	0	4	0.01	0	0.01	0	4	0	4
V>>V_NIL_4A	Out = Nil, avoid pre-contingent O/L of the	577	1	0	1	0	0	0	0	1	0	1
V>>V_NIL_4B	Out = Nil, avoid pre-contingent O/L of the	576	0	0	0	0	0	0	0	0	0	0
V>>V_NIL_4C	Out = Nil, avoid pre-contingent O/L of the	576	0	0	0	0	0	0	0	0	0	0
V>>V_NIL_5	Out = Nil, avoid O/L either Dederang to Mount	661	44	0	44	0.15	0	0.15	0	44	0	44
V>>V_NIL_6A_R	Out = Nil, avoid O/L South Morang F2 500/330 kV	576	0	0	0	0	0	0	0	0	0	0
V>>V_NIL_6B_R	Out = Nil, avoid O/L South Morang F2 500/330 kV	576	0	0	0	0	0	0	0	0	0	0
V>>V_NIL1A_R	Out = Nil, avoid O/L a Dederang to South Morang	79	0	0	0	0	0	0	0	0	0	0
V>>V_NIL1A_R	Out = Nil, avoid O/L either Dederang to South	1059	17	0	17	0.06	0	0.06	0	17	0	17
V>>V_ROTSTX_2B_R	Out= Rowville A1 or A2 500/220 kV txfmr, avoid	18	0	0	0	0	0	0	0	0	0	0
V>>V_ROTSTX_2B_R	Outage = Rowville 500/220kV transformer, limit	86	0	0	0	0	0	0	0	0	0	0
V>>V_ROTT_R_1B	Out= Rowville to Thomastown 220 kV line, avoid	89	84	0	84	0.29	0	0.29	84	84	0	84
V>>V_SMSY_KTSM_1A_R	Outage = One South Morang-Sydenham line;	182	0	0	0	0	0	0	0	0	0	0
V>>V_SMSY_KTSM_1B_R	Outage = One South Morang-Sydenham line;	196	19	0	19	0.07	0	0.07	19	19	0	19
V>>V_SMSY_SMSY_1A_R	Outage = Either South Morang-Sydenham line;	182	0	0	0	0	0	0	0	0	0	0
V>>V_SMSY_SMSY_1B_R	Outage = Either South Morang-Sydenham line;	182	0	0	0	0	0	0	0	0	0	0
V>>V_SMTT1_2	Out = South Morang to Thomastown No. 1 220 kV	9	0	0	0	0	0	0	0	0	0	0
V>>V_SMTT1_2	Out= South Morang to Thomastown No. 1 220 kV	107	20	0	20	0.07	0	0.07	20	20	0	20

V>>V_SMTT2_2	Out = South Morang to Thomastown No. 2 220 kV	5	0	0	0	0	0	0	0	0
V>>V_SMTT2_2	Out= South Morang to Thomastown No. 2 220 kV	114	33	0	33	0.11	0	0.11	33	33
V>S_460	VIC to SA on Heywood upper transfer limit of 460	754	5	0	5	0.02	0	0.02	0	5
V>S_NIL_HYTX_HYTX	Out = NIL, limit VIC to SA on Heywood to avoid OL	1145	45	0	45	0.16	0	0.16	0	45
V>S_NIL_NIL_HYTX1	Out = Nil, avoid O/L Heywood M1 500/275 kV	582	0	0	0	0	0	0	0	0
V>S_NIL_NIL_HYTX2	Out = Nil, avoid O/L Heywood M2 500/275 kV	940	3	0	3	0.01	0	0.01	0	3
V>SML_BUDP_2	Out = Buronga to Balranald to Darlington Pt. (X5)	378	101	0	101	0.35	0	0.35	101	101
V>SML_BUDP_3	Out = Buronga to Balranald to Darlington Pt. (X5)	2	2	0	2	0.01	0	0.01	2	2
V>SML_NIL_8	Outage = Nil, limit Vic to SA on Murraylink to avoid	1	1	0	1	0	0	0	0	1
V>SML_NSWRB_10	Out = NSW Murraylink runback scheme, avoid O/L	576	0	0	0	0	0	0	0	0
V>SML_NSWRB_9	Out = NSW Murraylink runback scheme, avoid O/L	576	0	0	0	0	0	0	0	0
V>SML_NWCB6024+25	Out= North West Bend_CBs 6024 and 6025; limit	4	3	3	0	0.01	0.01	0	0	3
V>SML_NWCB6033_TX2	Out= North West Bend_CB6033; limit Victoria to	1	0	0	0	0	0	0	0	0
V>SML_NWCB6225_TX1	Out= North West Bend_CB6225; limit Victoria to	1	0	0	0	0	0	0	0	0
V>SMLBAHO1	Out = Ballarat to Horsham, or Bendigo to Kerang	55	11	0	11	0.04	0	0.04	11	11
V>SMLBAHO4	Out = Ballarat to Horsham or Bendigo to Kerang	2	0	0	0	0	0	0	0	0
V>SMLBAHO4	Out = Ballarat to Horsham or Bendigo to Kerang	141	7	0	7	0.02	0	0.02	7	7
V>SMLKGRC1	Out = Kerang to Redcliffs 220kV line, avoid	1	0	0	0	0	0	0	0	0
V>SMLMHNW1	Out = Monash to North West Bend # 1 132kV line,	6	0	0	0	0	0	0	0	0
VN::DDMS	Out = Dederang to Murray 330kV line, avoid	8	0	0	0	0	0	0	0	0
VS_250	Victoria to SA on Heywood upper transfer limit of	732	23	0	23	0.08	0	0.08	23	23
VS_420	Victoria to SA on VicSA upper transfer limit of 420	53	26	0	26	0.09	0	0.09	0	26
VS_HYTS_TX	Victoria to SA on VicSA upper transfer limit based	1206	305	0	305	1.06	0	1.06	0	305
VSML_000	Vic to SA on ML upper transfer limit of 0 MW	360	12	4	8	0.04	0.01	0.03	8	12
VSML_220	Vic to SA on ML upper transfer limit of 220 MW	637	19	0	19	0.07	0	0.07	0	19
VSML_VFRB_OFF	Out=Nil, Vic to SA on Murraylink <=10 for	576	0	0	0	0	0	0	0	0
		849869	18210	4487	13617	62.98	15.54	47.06	5379	18210