: HV Overhead Switchgear : Asset Class Plan

Mains Assets

October 2022





•	
•	
•	
•	Version control
•	
•	
•	
•	

Version	Date	Comments
1.1	20/10/2022	Initial release

HV Overhead Switchgear Asset Class Plan



•	Co	nto	nte
•			1113

•	Ver	sion control	2
•	1.	Executive Summary	5
•	2.	Overview	6
•		2.1 Purpose	6
•		2.2 Scope	7
	3.	Asset Portfolio	8
		3.1 Asset Function	8
		3.2 Asset Population	9
	4.	Asset Performance	10
		4.1 Asset Utilisation	12
		4.2 Safety	14
		4.3 Reliability	16
		4.4 Network Resilience	18
		4.5 Bushfire	20
		4.6 Financial	22
		4.7 Environmental	23
	5.	Asset Lifecycle	24
		5.1 Acquisition	24
		5.2 Operations	24
		5.3 Maintenance	26
		5.4 Disposal	27
	6.	Intervention Options	28
		6.1 Non-Network Based Interventions	29
		6.2 Condition Based Interventions	29
		6.3 Risk Based Interventions	31
	7.	Forecasts	32
		7.1 Cost	32

HV Overhead Switchgear Asset Class Plan



7.2 Risk	33
 8. Asset Management Systems 	34
 8.1 Standards, Guidelines & Policies 	35
8.2 Asset Management Tools	36
 Appendix A – Cost of Consequence 	37
Safety	37
Reliability	38
Bushfire	39
Appendix B – Weibull Parameters	40
Conditional Weibull Parameters	40
Functional Weibull Parameters	44

HV Overhead Switchgear Asset Class Plan



1. Executive Summary

A 10-year strategy for HV Overhead (OH) Distribution Switchgear has been defined driven by the risk associated with the aging population of the asset class. The forecasted risk, strategy cost breakdown, and performance metrics are outlined below and include Air Break Switches, Under Slung Links, Drop Out Fuses, and Load Break Switches.

Risk Forecast

The failure of HV OH Switchgear may lead to Safety, Reliability, Financial, or Bushfire consequences.

These consequences are quantified in \$'s and coupled with statistical modelling to determine the risk associated with the fleet of in-service HV Overhead Switchgear.

As the age of these assets age, the risk associated with their failure also increase and this is geographically represented.

Strategy and Cost

The selected intervention option to address the risk associated with HV OH Switchgear 26.6M includes a mix of reactive replacement and proactive replacement.

Continued maintenance is also to be applied however the cost associated with this cannot be broken down to this level at this stage.

The total cost of this strategy for the 2023-2029 period is \$26.6M and is categorised based on the intervention type.



TOTAL RISK



9.6M

1.9M

Key Performance Indicators

HV OH Switchgear performance is defined based on the following performance categories and objectives.

For all asset types, the targets for these objectives are either already met, or cannot currently be measured. In these cases, monitoring systems are to be setup to allow for appropriate data collection to determine if objectives are being achieved.

All objectives are forecasted to be improved or achieved based on the 10-year strategy proposed in this asset class plan.

Performance Category	Objective	Status		
Asset Utilisation	Optimise use and penetration of assets in the network to decrease management costs, improve utilisation and inform future network standards	•		
Safety	Reduce the number incidents (excluding general hazards)			
Reliability	Reduce the number of unplanned outages associated with functional failures			
	Monitor the average number of customers impacted during an unplanned outage	—		
Resilience	Monitor the average number of customers impacted during a planned outage	—		
	Reduce need / risk associated with manual switching	•		
Bushfire	Maintain the percentage of fire starts as a proportion of the asset base	•		



2. Overview

2.1 Purpose

The purpose of this document is to outline previous, current and proposed asset management practices for HV Overhead (OH) Distribution Switchgear and define a 10-year strategic plan for the asset class based on the asset's risk and cost.

The 10-year plan seeks to use all current knowledge of the asset in context with the whole network to establish Key Performance Indicators (KPI) to assist in understanding and monitoring the ongoing performance of the asset. The adopted levels of service for HV OH Distribution Switchgear are based on risk / benefit trade-offs versus cost options, legislative requirements, customer expectations, and strategic goals set by Endeavour Energy.

This document is intended to function as part of the "Performance Monitoring and Review Process" as established in the Asset Management System (AMS) outlined in Section 8 of this report. The document plays a key role in ensuring:

- A continuous feedback loop is established between the performance of the individual assets and the performance of the more macro level Asset Class
- Monitoring of the performance of the asset class against Key Performance Indicator (KPI's) set
- Changes in the performance or risk (positive or negative) are identified as early as possible
- Communicating the historic, current and proposed balance of risk and cost (as shown via the number of asset replacements caused by functional failures, conditionbased replacements and risk based replacements).

The document will highlight and discuss historical trends and future forecasts for three primary asset management strategies:

- Risk Based asset replacements (e.g. those proposed to be completed on a risk / cost justification basis)
- Condition Based asset replacements (e.g. asset triggered for replacement due to a inspection and/or maintenance program)
- Functional asset failures (e.g. assets replaced post an asset failure whilst in service)

The forecasted "outcome" risk projections (for safety, reliability, resilience, bushfire etc) throughout this document are based on the optimal investment profiles proposed in the Case for Investments (CFI's) as well as the continuation of the existing maintenance strategies. The "baseline" risks outlined through out this document represent the natural increase in risk without an asset replacement program.





This report covers all Endeavour Energy owned HV OH Distribution Switchgear which includes the following highlighted assets:





3. Asset Portfolio

3.1 Asset Function

HV OH Switchgear currently perform two primary functions, allowing current to flow and isolation / segmentation of the network for the following purposes:

- 1. To facilitate re-energisation of the network, post a fault event (e.g. restore supply to customers).
- 2. Facilitate isolation for faulted sections of the network or for planned outages and maintenance/repair of equipment.
- 3. Automatic and centralised operation of switchgear (through replacement of retired ABS & USL assets with SCADA enabled LBS), to promote operational efficiency.

The current role and minimum performance measures for OH switchgear in the distribution network is underpinned by Company Policy 9.2.5 Network Asset Design. This policy states:

"Isolation points must be installed at appropriate locations in the network to facilitate the effective operation, maintenance, fault isolation, supply restoration and repair of the network so as to reduce the duration and the area of planned and unplanned interruption of supply to customers."

The policy also specifies design parameters for the number of substations or amount of load allowed between isolation points. The procedure to implement and achieve this policy is outlined in MDI 0026.

As the capability of switches (and supporting infrastructure such as ADMS) become more advanced (e.g. load break capability, network fault detection, communications and the introduction of "Fault location, isolation, and service restoration" (FLISR), the functionality and purpose of HV OH switches will continue to change and mature. This asset class will increase in significance / importance in the performance of the network as these technologies are gradually introduced into the network and the maturity of systems develop.

The breakdown of risks that are attributed to this asset class are shown in section 4 to illustrate performance measures and key drivers.



Asset Population 3.2

Endeavour has approximately 22,600 HV Overhead Switches in service in the distribution network.

The total number of assets in the network is relatively consistent over the previous 10 years as most network extensions are in the underground network. A continued overall reduction in the number of assets in this class is expected in years to come (and can already be witnessed) due to further undergrounding of the distribution systems and a shift to automated switches resulting in the need for less switches overall.

A decrease in ABS's and USL's is expected in the coming regulatory period(s) as asset utilisation is assessed and these components are removed from service or replaced by LBS's.



Note: this age profile includes DOF's dedicated for transformer protection. These assets are not reflected in the Annual Population graph shown on the right.

Annual Population





4. Asset Performance

This section quantifies the risks and asset performance measures associated with the fleet of HV OH Switchgear. The weighting for different risk categories illustrates the areas of focus for managing the maintenance, life cycle and intervention options for this asset class. These are further broken down into performance measures that enable clear relationships to be drawn between risk and the asset performance.

The level of risk (by risk category) is determined for each individual asset, based on its location in the network and probability of failure (as per the risk based replacement review). The following table summarises the risk categories and provides an overview of the average risk contribution made by each risk category (e.g. safety, reliability bushfire etc), this illustrates the primary risk drivers for the asset class.

The largest risk by for this asset class is associated with reliability.

Risk Category	Risk Category Consequence	
Safety	 Damaged insulators falling to the ground during switching striking operators Faulty insulation creating tracking currents Combustible gas creating debris from explosive failures which may strike operators 	20%
Reliability	Reliability - Damaged insulators causing faults and loss of supply on the HV network - Misaligned or jammed contacts prohibiting switching and extending outages or network maintenance	
Bushfire	- Arcing of live contacts and damaged insulation may create sparks and initiate a bushfire	5%
Environmental	 No significant environmental consequences have been experienced or are anticipated and are therefore not considered a risk to be managed Switches using SF6 gas may impose environmental risks in the future, however this is dependent on carbon tax laws 	0%
Financial	- Not replacing the asset before a failure may lead to capital expenditure related to reactive replacement	15%



The table below summarises the asset performance service level and objectives across the fleet of HV OH Switchgear.

Performance Category	Objective	Performance Measure	Asset	Current	Performance	Status	Trend
			Туре	Performance	Target	_	
		ABS 64%		•			
	Optimise use and penetration of assets in the	% of switches with at least 1 operation	USL	47%	Stable or	•	
Asset Utilisation	improve utilisation and inform future network	over 10 years	DOF	15%	Increasing	•	_
	standards		LBS	66%		•	
		Number of switches per km OH line	All	0.98 / per km	Stable	•	_
			ABS	2.0		•	_
			USL	1.4		•	_
Safety	Reduce the number incidents (excluding general hazards)	5-year rolling average of total incidents (excluding general bazards)	DOF	2.2	Reduce in line	•	_
	general hazarday	(choldaling general hazarae)	LBS	0.2	with forecasts	•	_
			All	5.8		•	_
			ABS	28.6		•	_
	Reduce the number of unplanned outages associated with functional failures	5-year rolling average of unplanned outages	USL	26.4	Reduce in line with forecasts	•	_
Reliability			DOF	17.0		•	_
······			LBS	3.6		•	_
			All	75.6		•	_
	Monitor the average number of customers impacted during an unplanned outage	Average number of customers disconnected during an unplanned outage (post utilisation of ALBS's)	A II	210			
			All	customers	wonitor	_	_
Resilience	Monitor the average number of customers	Average number of customers	ΔII	333	Marsitan		
	impacted during a planned outage	disconnected during a planned outage	7 \	customers	WOHILOI		_
	Reduce need / risk associated with manual switching	Percent of total switching operations performed remotely	All	22%	Increase	•	
			ABS	4.2		•	—
			USL	2.0	.	•	▼
Bushfire	Maintain the percentage of fire starts as a proportion of the asset base	5-year rolling average of fire starts	DOF	1.6	Reduce in line with forecasts	•	•
			LBS	0.0		•	_
			All	7.8		•	_



•

4.1 Asset Utilisation

4.1.1. Objective

To monitor and understand asset utilisation across each asset type and network wide to inform topology standards and maximise the utilisation of the existing asset base.

4.1.2. Performance

Utilisation of HV OH Switchgear is defined by the frequency of switching events (open or close of a switch). However, as the primary function of switches is to provide network isolation during network faults, augmentation, maintenance and load transfers, the non-operation of an asset in any one year (or over a short period) should not be considered as under-utilisation.

Both a yearly and rolling 10-year window are monitored for the utilisation of HV OH switches and this data illustrates that the utilisation of each asset type as well as the asset group is continuing to improve. The short term (i.e. yearly) utilisation of LBS's is significantly higher than any other asset type, this is predominantly due the locations in the network they have been installed and their capability to switch line current (which other asset types within this class do not have).

No formal utilisation targets have been established for HV OH Switchgear; however, in line with our objective we want to maximise the value provided by existing assets and only install new assets where the increased level of service they provide justifies the whole of life cost. We aim to maintain or increase the annual utilisation of assets.





Performance Category	Objective	Performance Measure	Asset Type	Current Performance	Performance Target	Status	Trend
		% of switches with at least 1 operation over 10 years	ABS	64%		•	
	Optimise use and penetration of assets in the network to decrease management costs, improve utilisation and inform future network standards		USL	47%	Stable or Increasing	•	
Asset Utilisation			DOF	15%		•	_
			LBS	66%		•	
		Number of switches per km OH line	Total	0.98 / per km	Stable	•	_

4.1.3. Gap

Value of Utilisation, total network risk is increasing so the value of network isolation is expected to increase over the next 20 years, increasing the reliability value of HV OH Switchgear. These switches contribute to our level of service; however, negatively impact traditional KPIs for utilisation. Improved performance measures need to be developed to accurately reflect the value of these assets and set appropriate targets.

4.1.4. Response

Utilisation of HV OH switches have not traditionally been monitored and the establishment of KPI's will help ensure the ongoing performance of the asset class. All current KPI's indicate that the network topology described in MDI 0026 is effective and being implemented appropriate to allow an increase in asset utilisation of HV OH switches.



- •

4.2 Safety

4.2.1. Objective

Stabilise, monitor, and maintain safety risk across the asset base over the next 10-years.

4.2.2. Performance

Safety incidents are categorised by severity and include general hazards, near misses, minor injuries, major injuries, and fatalities.

The current asset management strategy is expected to improve safety performance across the fleet of assets as assets at higher risk of failure, which are utilised more often are prioritised for intervention.

The proposed asset strategies (refer to Section 6) are expected to decrease both the frequency of events as well as the total organisational safety risk associated with the asset class.

The Safety Risk Concentration indicates that at present particular areas of the network have a higher normalised safety risk profile, the proposed program (refer to Section 6) will facilitate balancing the normalised safety risk across the network.





Performance Category	Objective	Performance Measure	Asset Type	Current Performance	Performance Target	Status	Trend
	Safety Reduce the number incidents (excluding general hazards)	5-year rolling average of total incidents (excluding general hazards)	ABS	2.0		•	-
			USL	1.4	Poduco in	•	_
Safety			DOF	2.2	line with forecasts	•	_
			LBS	0.2		•	_
			All	5.8		•	_

4.2.3. Gap

Previous investment strategies were unable to separate out safety as an individual risk. Whilst safety makes up a relatively small portion of the overall risk associated with HV OH switches, it is forecast to reduce (improve) based on the current proposed strategy.

4.2.4. Response

Safety risk will continue to be monitored and risk modelling reviewed as new external factors are identified / occur to improve future forecasts.



•

4.3 Reliability

4.3.1. Objective

Maintain the level of network reliability risk and number of outages caused by unassisted asset failures associated with HV OH Switches

4.3.2. Performance

The number of functional failures associated with HV OH switches has been relatively stable over the past 10 years, the move to an asset level understanding of both probability of failure and reliability risk is expected to create a step change (improvement) in the number of functional failures, however overall reliability risk is expected to remain relatively steady. This steady reliability risk profile is a significant advancement considering the asset bases increasing probability of failure.

The normalised risk concentration across the network is not currently uniform, however is expected to improve over the coming regulatory period.



Performance Category	Objective	Performance Measure	Asset Type	Current Performance	Performance Target	Status	Trend
			ABS	28.6		•	_
	Reduce the number of unplanned outages associated with functional failures		USL	26.4	Reduce in line with forecasts	•	_
		5-year rolling average of unplanned outages	DOF	17.0		•	_
Reliability			LBS	3.6		•	_
			All	75.6		•	_
	Reduce the assets contribution to SAIDI	5-year rolling average of SAIDI contribution	-	-	-	-	-
	Reduce the assets contribution to SAIFI	5-year rolling average of SAIFI contribution	-	-	-		-

4.3.3. Gap

No Gaps are currently identified in the reliability risk associated with HV OH switchgear

4.3.4. Response

The current proposed asset management strategy indicates a steady risk profile, with a decline in the number of functional failures. Continued monitoring of both metrics will be performed to ensure this continues to hold true.



4.4 Network Resilience

4.4.1. Objective

To monitor the network wide installation of automated load break switches across the network and ensure the asset levels decisions being made are reflected once viewed from the network perspective.

4.4.2. Performance

The primary purpose of HV OH switches is to allow switching of the network to allow isolation of faults and/or access to the network for augmentation / maintenance. Network Resilience can significantly be impacted (positively or negatively) by the number, location, and functionality of HV OH switches across the network.

The performance of HV OH Switchgear is determined by the impact it has on outage management, during unplanned and planned interruptions and how efficiently field services can complete network switching activities. At present the number of customers impacted for unplanned outages remains steady, whilst the number of customers for planned outages appears to be increasing. With the low volumes of ALBS's within the network this is expected, however needs to be continued to be monitored.

Average Number of Customers Interrupted by Outage Type

Percentage of Total Switching Operations Performed Remotely





Performance Category	Objective	Performance Measure	Asset Type	Current Performance	Performance Target	Status	Trend
	Monitor the average number of customers impacted during an unplanned outage	Average number of customers disconnected during an unplanned outage (post utilisation of ALBS's)	Total	210 customers	monitor	Ι	
	Monitor the average number of customers impacted during a planned outage	Average number of customers disconnected during a planned outage	Total	333 customers	monitor		-
Resilience	Reduce need / risk associated with manual switching	Percent of total switching operations performed remotely	All	22%	increasing	•	
	Monitor operational performance	Average time to isolate customers (time needed by district operators to perform a switching plan)	Total	-		٠	_

4.4.3. Gap

Whilst the asset level replacement decision framework is sound, measurable impacts cannot yet be seen at the asset class level. This is expected to be driven by two primary factors:

- The current low volumes of ALBS's across the network and the short period of time they have been present.
- Current KPI's / measurements not specifically designed to monitor network resilience and the improvements to customers from automated switching capability

4.4.4. Response

Continued work on developing new KPI's / measurements to better quantify the network wide impacts of automated switching capability.



Bushfire 4.5

4.5.1. Objective

To reduce the number of functional failures and therefore the likelihood component of bushfire risk associated with HV OH switches.

4.5.2. Performance

Bushfire performance is measured by monitoring the quantity and severity of fire starts that are initiated by asset failures across our network. Fire starts caused by HV OH Switchgear remained stable with an average of 9 fire starts per annum. Limitations in the fire start data prevent further analysis to determine the severity of these fire starts, however anecdotal experience over this period indicated no major events have occurred, which is reflective of the relatively low proportion of bushfire risk attributed to HV OH switches.

The proposed asset management strategy is forecasting a reduction in failure events / fire starts, however overall bushfire risk with HV OH switches is forecast to increase by approximately 20% over the next regulatory period. This increase is predominantly driven by an increased likelihood of asset failure and a forecasted increase in high fire danger weather events.





Performance Category	Objective	Performance Measure	Asset Type	Current Performance	Performance Target	Status	Trend
Bushfire	Maintain the percentage of fire starts as a proportion of the asset base	5-year rolling average of fire starts	ABS	4.2		•	_
			USL	2.0	Roduco in	•	•
			DOF	1.6	line with	•	•
			LBS	0.0	forecasts	•	_
			All	7.8		•	_

4.5.3. Gap

Bushfire performance, as monitored by fire starts is expected to remain stable as older, higher risk assets are replaced under existing replacement programs. Although firestarts remain stable, the severity of these starts is not adequately monitored to align real world events with the organisation's bushfire risk model.

4.5.4. Response

To further minimise controllable bushfire risk, HV OH Switchgear will consider possible improvements in the capture of data associated with actual network fire events (e.g the comparison of the actual consequence with modelled consequence).

Bushfire risk will also be monitored at a network wide level to ensure investment is conducted in the most appropriate areas to ensure appropriate investment / prioritisation decisions are made



- •
- •

- •
- •

4.6 Financial

Not applicable to this asset class.

Only reactive replacement costs associated with functional failures of HV OH switches are considered.





4.7 Environmental

Not applicable to this asset class.



5. Asset Lifecycle

This section discusses HV OH Switchgear throughout the asset lifecycle and brings to light key factors that currently (or may) impact the asset class performance.

5.1 Acquisition

The location and type of HV OH Switchgear is determined by the isolation requirements currently defined in MDI 0026. Historically, a mix of technologies (e.g. DOF's, USL's, ABS's, LBS's etc) and different network configurations have been utilised across the network, resulting in wide spread of asset utilisation levels and network capability.

The introduction of LBS's (in approximately 2010) and ALBSs (in 2020) as a new technology options has significantly improved the network capability (in the areas they are introduced) as well as allowed for the number of switches overall to start declining.

The continued monitoring of the asset class will allow further refinement of technology mix and network configurations options being implemented.

The current technical criteria for this asset class are defined in Equipment Technical Specifications (ETS) as listed in Section 8.1. Asset types have largely been defined based on the technology type, however as performance data indicated the current asset types will continue to be further subdivided.

5.2 **Operations**

The operation (e.g. switching needs) of HV OH Switchgear is generally driven by network requirements (e.g. asset maintenance, asset failures, network augmentation etc). Currently most switches are not rated to break load (e.g. USL's and ABS's) and should only be used for equipment / line isolation and not for breaking continuous current.

Additionally, most assets are manual switches and require staff to attend site to operate the asset. With the introduction of automated switches, the networks need for switches across the network has been re-evaluated (as per MDI 0026) and an increase in automated and nonautomated LBS's is expected with a decrease in other switch types as they are replaced and/or made redundant.

Overall, this should see an increase in asset utilisation (e.g. switching frequency per switch), with an overall reduction in the total number of switches per line length.

The historical installation / operation of assets not adequately rated to break load (e.g. ABS's) being used for such operations (due to a lack of suitable alternative technologies) have led to an increase in the deterioration of some assets. With the introduction of LBS's (due to an increased reduction in their costs) this limitation is beginning to be removed from the network.

Reducing manual operation of the switchgear fleet also reduces the safety risk associated with the asset class as switching operators are not physically exposed in the event of a failure resulting from falling parts.



I he following table lists the	operational restrictions and	l location of use for each switch.

Asset Group	Operational Restrictions	Location & Use
ABS	 Not rated for breaking fault or load current Not to be installed in coastal locations due to corrosion issues 	11kV and 22kV networkStand-alone equipment (mid-pole or pole-top mounted)
USL	 Not to be used as isolation points on distribution transformers (due to the risk of ferroresonance leading to failure of distribution transformers) Each phase is singly operated using a link stick 	 Single phase units that may be configured for 1, 2 or 3 phase isolations Stand-alone equipment (mid-pole or pole-top mounted) With Reclosers With Regulators
DOF	Not indented for interrupting nominal system load currents.	 11kV network with low fault levels High fault level 11kV areas all 22kV (incl. SWER) areas
LBS	 Not to be used or operated when low-gas indicator has been raised. 	 11kV and 22kV network Stand-alone equipment (mid-pole or pole-top mounted)



- •
- •

5.3 Maintenance

An overview of the current maintenance activities being performed on HV OH Switchgear are summarised below. These maintenance activities result in the current asset performance (e.g. risk and number of unassisted / conditional asset failures). The shift to an asset level risk-based replacement strategy is expected to provide a step change (improvement) in risk during the FY25-FY29 regulatory period, however the underlying risk will continue based on the following maintenance strategy.

5.3.1. Inspections & Preventative Maintenance

The following table summarises the frequency of different inspection programmes and preventative maintenance applicable to overhead switches.

		Programme Name	Interval (Years)	ABS	USL	DOF	LBS	Reference
	OLI/GLI ¹		5.5	~	✓	✓	~	SMI 101 MMI 0001
	T 11	Non-Critical Feeders	5	✓			✓	MMI 0001
	I LI	Critical Feeder	3	✓			✓	MMI 0012
ions	PSBI ²		1	~	✓	✓	~	SMI 101 MMI 0034
ect	Transmiss	ion ABS Inspection	0.5	✓	✓			SMI 100
Inspe	Recloser Inspection ³		0.5					SMI 100 SMI 207 MMI 0001
	Thermovision ⁴		3	~	~	~	~	SMI 100 SMI 101 MMI 0032
(D)	-	All ABS's	-	✓				
nance	∆BS lajor erhaul	Problematic ABS's ≥ <i>5km coast</i> ⁵	8	~				SMI 101
lainte	4 ≥ ¥ O	Problematic ABS's < 5km coast ⁵	4	✓				51011 204
tive N	Earth Resistance Tests		10				~	SMI 101 EDI 0005
reventat	Recloser Battery Check		4					SMI 100 SMI 102 PMI 4120
ш.	LBS Minor Overhaul		4				\checkmark	SMI 207

1. Applicable to only distribution assets

2. Applicable to only assets that fall within the defined bushfire prone area

3. Only applicable to reclosers associated with ZS and TS

4. Typically applied to the first seven switches out from the zone or transmission substation

5. Applicable to specific manufacturer model ABS's identified as problematic (Essante HS641, Taplin D571 and AK Power A24)



•

5.3.2. Essential Spares

The requirement for an essential spare's strategy is governed by the criticality of the equipment's function in the network and is dependent on the lead time for acquisition.

Given the availability of various suppliers, the ease of procuring items and the level of inventory maintained for overhead switches there is no existing essential spares strategy for overhead switches.

Endeavour Energy's procurement and logistics section is responsible for the on-going sourcing strategy of overhead switches including its supply chain security.

5.4 Disposal

There are no unique requirements governing the disposal of the majority of the HV OH Switchgear asset class, with the exception of the LBS asset type as these contain SF6. The number of LBS replacements at this point are very low (due to their age), however all SF6 from replaced assets is captured and recycled.

Metrics for the monitoring of SF6 holdings, leakage and disposal are currently being created to support the organisations objectives associated with environmental management.



6. Intervention Options

A range of options have been considered as possible intervention options to address the risk presented by HV Overhead Switchgear. These options are initially considered as an asset type / class level to determine if they are technically feasible and/or practical. Intervention options deemed to be a viable options are then considered at an asset level to determine the most appropriate option for each individual asset.

Intervention Type	Option	Assessment of effectiveness	Credibility
Non-Network Based	-	Due to the substantial load that each switch carries on a continual basis and the asset's primary functionality being to isolate / switch the network, there are no credible non-network solutions which could replace their functionality.	Not A Feasible Solution
		Air Break Switch - A maintenance program, which was initially introduced in 2005, has had negligible effect on the defect rate for ABS's. Since 2015 maintenance of the general population ABS's was ceased whereas maintenance on problematic ABS's has currently continued. However, given that the primary causes of failure are age related or problematic insulator designs (both of which cannot be addressed via maintenance), re-introducing maintenance on the general population or funding additional maintenance on the problematic population will not be effective in managing risk or extending asset life.	
Condition Based	Additional maintenance to extend the life of the existing asset	d Load Break Switch - Routine inspections are currently performed on all LBS's (manual and automated) via the OLI, TLI, PSBI and thermovision programs. Whilst these inspection programs are effective in identifying assets close to end of life, few options currently existing to maintain or refurbish load break switches.	
		Under Slung Links and Drop Out Fuses - USLs and DOFs do not have any scheduled maintenance activities dedicated purely to the asset. Inspection of these assets are carried out as part of other inspection programs such as the OLI program, PSBI, and thermovision. The frequencies of these inspection programs range from yearly to every 5 years. However, given that the primary causes of failure are on-event failures (e.g. failure when switching is attempted) (which cannot be adequately identified via maintenance), funding additional maintenance on the population will not be effective in managing risk.	
	Reduce the load on the asset through network reconfiguration, network automation or demand management	The risk of failure is independent of load. A minor reduction in the consequences of failure could be achieved by transferring load from any one substation / feeder to another, however this is not a practical option in reality and would result in little if any positive benefit. The primary function of this asset class is to facilitate flexibility in switching of the overhead distribution network to minimise the extent of customer outages and the duration of outages during planned and unplanned works on the network. Load transfers would ultimately reduce this flexibility and provide a negative results to customers in the medium to long term.	Not A Feasible Solution
Risk Based	Implementing operational controls such as limiting access, remote switching protocols etc	Operating controls are already in place for the operation of all HV Overhead Switches. These controls are in place to limit the safety risks presented by this equipment to workers, but the principal risk that drives the need for intervention is reliability, which is not affected by practicable controls.	Controls only safety risk for workers
	Staged removal or replacement of HV Overhead Switchgear.	On replacement, risk associated with a switch will be reduced to the risk associated with the replacement option. On removal, risk associated with a switch will be effectively illuminated as any operating risks are no longer present.	Feasible Option



6.1 Non-Network Based Interventions

No non-network based interventions have been identified to replace the primary function of this asset class (e.g. switching capability in the network).

6.2 Condition Based Interventions

The inspections and preventative maintenance programs outlined in 5.3 Asset Maintenance results in the following condition-based repairs, replacements and defects on HV Overhead Switchgear. The objective of the condition-based maintenance is to identify functional asset failures prior to them occurring, however as close as possible to the assets technical / economic end of life.

Defects are directly linked to an asset's failure mode(s) and aim to identify issues with the defect that will result in it being unable to perform its primary intended function. Defects are currently prioritised based on a qualitative assessment of the likelihood the defect will result in a functional failure.

Endeavour Energy determines what constitutes a defect based on Failure Modes Effects and Criticality Analysis (FMECA). FMECA is an analytical process that is derived from an assessment of an asset's ability to sustain technical functionality and relies on information relating to failure modes, their probability and consequences of failure.

MMI 0002 and SMI 124 provide further detail on what is to be recorded as a defect, the required actions, and the corresponding priority for each failure mode, the table below provides an overview of applicable defects associated with HV OH switches.

Switch Type	Defects	Repair / Replacement	Standard job description		
	1ABSAD	Repair	Adjustments made to re-align ABS to fully close - can be at the assembly/handle		
	1ABSAH	Repair	Repair/ replace arcing horn due to misalignment or due to burning/ wear and tear		
	1ABSBL	Repair	Repairs/ replacement of damaged ABS blade caused by incorrect operation/ fault		
ABS	1ABSOH	Repair	Repairs/ replacement of ABS operating handle. (incl relocating handle higher)		
	1ABSOR	Repair	Replace ABS operating rods		
	1ABSSW	Replace	Replace ABS assembly. Can include operating rods and operating handle.		
	1EARBA	Repair	Replace earth batten on a pole including substations, UGOH poles, ABS poles		
	1DOFCA	Repair	Replace DOF carrier.		
DOF	1DOFSW	Replace	Replace complete DOF		
	1LVLIN	Replace	Replace LV links installed on overhead, including substations		
USL	1USL	Replace	Replace defective under slung link		
LBS 1LBSSW Replace Replace LBS Unit		Replace	Replace LBS Unit		
GENERAL	1LOCK	Repair	Repair locks on equipment that are hard to open or replace missing/damaged locks		
0 = <u>=</u> 10 (E	1FAULT	-	For storms and major events or can be used when another standard job is not suitable		

At present ABS's are creating the majority defects in the HV OH switchgear assert class, however the overall volume has been reducing (improving) over the past five years, indicated an improvement in the condition of the asset base and therefore a reduction in the likelihood of failure. The interventions from the maintenance inspection programs



are also predominantly asset repairs and not asset replacements, again the number of asset replacement initiated based on a conditional asset failure has been reducing over the last five years.





6.3 Risk Based Interventions

Risked based intervention options considered as possible feasible intervention options have been further considered to address the risk presented by HV Overhead Switchgear at the asset level. The customer benefit achieved by the proposed intervention option is compared with the cost of the proposed intervention(s) to determine if the option is financially viable and in the customer's interest. This approach generates a cost to benefit ratio / NPV for every asset and intervention option being considered.

Endeavour Energy Mains Design instruction MDI 0026 provides instructions for the minimum isolations requirements and sets out in detail both the location and the type of isolation points to be installed. For each asset proposed to have an intervention (as specified in the CFI's), the two options are considered:

- Removal/Lockout of the switch: If it is assessed that the functionality of a retired switch is no longer required, then it is locked out and removed from service.
- Replacement of the switch: If it is assessed that the functionality of a retired switch is still required, then it is replaced by either a like-for-like switch, an LBS or an
 automated LBS which is connected to the SCADA network for remote and/or automated operation.

The following volume of forecasts / breakdown between options are based on the results of the CFI's associated with this asset class.





7. Forecasts

7.1 Cost

The risked based replacement program has identified assets within this asset class that are currently justified for a risk-based asset intervention over the upcoming regulatory period. Asset that reach their NPV maximum point are illustrated in the images below. A number of other assets will have reached the point of being NPV positive (e.g. risk are higher than intervention costs), however these will be considered as part of the portfolio optimisation process. The proposed investment profile is relatively flat from FY23, however it is difficult to efficiently introduce these additional replacements into the FY23 and FY24 periods (without impact existing strategies). A proportion of assets identified for intervention over these two periods have been shifted to FY25 as this is the first practical opportunity they will be completed. This has resulted in a peak in investment costs in FY25 as indicated in the expenditure profiles, however additional constraints (e.g. labour, outage availability etc) will likely see this peak flattened over the regulatory period.



Over the next 5 years, inspection and maintenance spend is expected to remain stable.

● Replacement - Conditional Failure ● Replacement - Functional Failure ● Replacement - Risk Based ● Maintenance - Inspection ● Maintenance - Repair





•

7.2 Risk

Network risk associated with HV OH switches has been calculated as per the current value framework. The total risk in this asset class is made up from Reliability (60%), Safety (20%), Bushfire (5%), and Financial (which for this asset class is purely Reactive Replacement costs / functional asset failures (15%).

The baseline risk (no intervention) associated with this asset class is projected to approximately double to \$9 million if no action is taken. The outcome risk based on the proposed intervention profile is however projected to remain steady at \$5.2 million over the following ten-year period.

It can also be seen that the total risk will become much more uniform across the network with the majority of the investment focused in higher density residential / CBD areas, as the risk is predominantly driven by network reliability.





8. Asset Management Systems

This section identifies the strategies, practices and guidelines supporting the management of this asset class. A detailed description of Endeavour Energy's asset management system and its constituent parts is available in the Asset Management System Manual and the Asset Management System Guidelines.

Stakeholder Expectations Business Owner CUSTOMERS SHAREHOLDERS REGULATORS **Business** Corporate Strategy & Management Business Plan Narrative Asset Management Network Business Strategy Polic Management System Manual Enterprise & Enabling Strategies **RAB Asset Strategies** & Procedures **Network Assets** Sustainability Data Procurement Growth Servicing Strategy Future Grid Strategy Asset System Strategies & Resilience Strategy Non-network Assets People & Technology Fleet Strategy Culture ICT Strategy Property Strategy Planning Owner Asset/Area Plans **Unconstrained Plans and Programs** Performance Monitoring & Revi 10 Year Capex and Opex Forecast Asset Mgt Business 2 Plan Models & **Compliance Documents** Forecasts & Reporting **Rolling Delivery Plan** (e.g. FSA, DAPR, RIN) Budget Workforce Plan 1____ **Rolling Divisional Delivery Plans** Works Delivery Schedule and Execution Financial Planning **Project Records** Rev 1.1 3/06/22 Legend System manuals and guidelines Asset record Documents Case For Investments Optimisation - Capex, Deliverability Tool used for analytics / reporting 2 3 Plan Itemised listing Tools

The relationship between this document and the other artefacts within Endeavour Energy's asset management system is illustrated below:



8.1 **Standards, Guidelines & Policies**

Endeavour Energy's asset management practises are governed and guided by numerous legislative requirements, guidelines, and industry best practises throughout Australia and Internationally. Endeavour Energy's manuals, procedures and workplace policies are all underpinned by these key documents as documented in 'GQY 1190 Policy and Procedure Framework' and demonstrated in the adjacent figure. Legislation, regulations, and high-level Australian Standards applicable to HV network operations are detailed in the Endeavour Energy Asset Management System.

Endeavour Energy has developed the following documentation to specifically guide the life-cycle management of HV overhead switchgear:

- **Company Policies** 9.1.6 Approved Materials List 9.1.7 Commissioning network Electrical Assets 9.1.9 Network Technical Compliance Network Planning 9.2.1 9.2.2 Network Protection 9.2.5 Network Asset Design
- Network Asset Construction 9.7.1
- 9.8.3 Network Operations
- Network Asset Maintenance 9.9.1
- 9.9.2 Essential Spares

Approved Materials Lists & Specifications

ETS 0067	11kV & 22kV Enclosed LB
ETS 0071	Distribution Fuses
ETS 0074	12kV & 24kV Reclosers
ETS 0076	24kV Outdoor ABS

12kV & 24kV Expulsion DOFs ETS 0082

Design Instructions

MDI 0031	Overhead Line Design
SDI 215	12kV/24kV Enclosed SF6 LBS
SDI 222	Schneider 12/24kV LBS
SDI 223	ABB 12/24kV LBS

Construction	& Commissioning Standards) (Maintenance	& Operations Standards
MCI 0005	Overhead Construction Standards Manual		MMI 0001	Pole and Line Inspection and Treatment Procedures
SDI 120	Testing and Commissioning for Distribution Systems		MMI 0002	Distribution Overhead Defect Handbook
			MMI 0012	Overhead Transmission Line Routine Inspection
			MMI 0013	Vegetation Clearance Management
			MMI 0032	Thermovision of Distribution & Transmission Lines
			MMI 0034	Pre-summer Bushfire Inspections
			SMI 101	Minimum Requirements for Maintenance of Distribution Equipment
			SMI 204	Disconnectors, Links, and Air Break Switches
		$/ \langle$	SMI 207	HV Reclosers, Sectionalisers, and Load Break Switches



35

8.2 Asset Management Tools

Endeavour Energy use numerous integrated data-base and geographical information system related tools to aid in the management of HV overhead switchgear assets.

Key tools used for the management of HV overhead switchgear include:

Tools	Current Purpose	Future Purpose		
Ellipse Database	Used for historical (2010-2021) asset nameplate details, routine maintenance scheduling, defect workorder recording and management	Superseded by SAP		
SAP	Used for recent (2021-Current) asset nameplate details, routine maintenance scheduling, defect workorder recording and management	 To be used as the primary data source for: Asset characteristics Financials Safety – safety incidents are to be categorised by asset class, asset type, and severity Bushfire – bushfire incidents are to be categorised by asset class, asset type, and severity Environmental – environmental incidents such as SF6 gas leaks are to be captured and categorised by asset class, asset type, and severity 		
ADMS	Not currently used	 To be used as the primary data source for: Reliability – reliability incidents are to be categorised by asset class, asset type, and include SAIDI and SAIFI contributions. Resilience – Benefits from network automation to be quantified Utilisation – switching events are to be categorised by asset class and asset type. 		
Switchlt	Used to determined switch utilisation in terms of switching frequency	Superseded by ADMS		
OMS	Used for historic (2012-2021) asset related reliability incidents	Superseded by ADMS		
FireStart Used for historic (2005-2021) asset related firestart incidents		Superseded by SAP		
MySafe Used for historic (2012-2021) asset related safety incidents categorised by severity		Superseded by SAP		



- •
- •
- •
- •
- Appendix A Cost of Consequence
- Safety



Description	Source/Assumptions
ikelihood that a failure will elate to a safety incident	Endeavour Energy's defect data via Ellipse workorders
ikelihood that a safety incident vill result in an injury	Endeavour Energy's historical Safety Incidents via MySafe database
ikelihood that a safety incident ill result in a fatality	Endeavour Energy's historical Safety Incidents via MySafe database had 0 fatalities in the last 10 years. Assumed 1 fatality every 60 years.
he annual switching frequency or each switch	Endeavour Energy's Switchlt database. Assumed 1 operation every 20 years for switches which were not operated in the last 10 years
cost of a single injury	Disproportionate factor used alongside CoC – Fatality and GNV979 – Quantitative Determination of Reasonably Practicable Risk Control Measures when Assessing Health and Safety Risks
cost of a single fatality	Office of Best Practice Regulation



- •
- •
- •

Reliability

•	In-service Failure Reliability CoC	Parameter	ABS	USL	DOF	LBS	Description/Justification	Source/Assumptions
	Functional	Load factor	0.7	0.7	0.7	0.7	Factor applied to maximum feeder loadings to represent the magnitude of load during a network outage.	Endeavour Energy's Outage Management System
	Failure Data	Outage duration - (Failure on switching)	2	2	2	2	Time taken to restore load. Hour 1-100% load loss Hour 2-100% load loss	Endeavour Energy's Outage Management System
	Powerfactory Average of CMI / No. of CMI / No. of Customers Interrupted HV Load (MW) X Load Factor of 0.7 X Outage time (hrs) X LGA Average VCR (\$/MWh) X Annual Switching Activity Switching Failure Reliability CoC	Outage duration - (Failure in-service)	5	5	5	5	Time taken to restore load. Hour 1-100% load loss Hour 2-100% load loss Hour 3-100% load loss Hour 4-75% load loss Hour 5-50% load loss	Assumed additional 3 hours of travel and fault locating
	Powerfactory	LoC – Switching	Varies by asset	Varies by asset	Varies by asset	Varies by asset	The annual switching frequency for each LBS	Endeavour Energy's Switchlt database. Assumed 1 operation every 20 years for switches which were not operated in the last 10 years
	$\frac{1}{(MW)} \times \frac{1}{1000} \times \frac{1}{1000} \times \frac{1}{(hrs)} \times \frac{1}{1000} \times \frac{1}{(hrs)} \times \frac{1}$	LoC – In-Service	0.62	0.27	0.07	0.38	A multiplier to calculate the annual failures which fail in service (not during switching) Backwards calculated using the annual no. of in-service failures.	Endeavour Energy's Outage Management System
		VCR (\$/MWh)	Varies by asset	Varies by asset	Varies by asset	Varies by asset	The value customers place on having reliable electricity supplies under different conditions. Calculated as an average VCR across each LGA	PowerFactory load data
		Load (MVA)	Varies by asset	Varies by asset	Varies by asset	Varies by asset	The HV load distributed across each feeder at each pole.	PowerFactory load data

•

•

Bushfire



Parameter	ABS	USL	DOF	LBS	Description/Justification	
LoC – Fire Start	Varies by asset	Varies by asset	Varies by asset	N/A	Likelihood that a failure will create a fire	Ende Ende
LoC – Vegetation	Varies by asset	Varies by asset	Varies by asset	N/A	Risk reduction factor based on the asset's spatial location and its proximity to vegetation fuel sources	RFS
CoC – Bushfire	Varies by asset	Varies by asset	Varies by asset	N/A	Cost of a bushfire including costs associated with fatalities, houses lost, residential contents lost, vineyards lost, plantations lost, crops lost, powerlines lost.	, Ignitio



Bushfire Ignition CoC

Source/Assumptions

eavour Energy's defect data via Ellipse workorders

eavour Energy's historical fire database

bushfire prone land maps

on simulation via Phoenix software

Appendix B – Weibull Parameters

Conditional Weibull Parameters

Air Break Switch

Porcelain General

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0.00	0.00
Shape	1.92	2.02	3.60	2.50
Scale	98.46	91.96	57.60	68.00
Predicted average failure age	87	81	52	60
Predicted no. of failures p.a.	22	23	40	35

Input Data Statistics	Value
Mean failure age	22
Population size	3879
Avg number of historical annual failures	40
Age Earliest Failure	0
Age Oldest Asset	62



×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection



Porcelain Problematic

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0	0
Shape	2.36	3.28	3.6	4
Scale	60.49	48.97	36	50
Predicted average failure age	54	44	33	45
Predicted no. of failures p.a.	10	12	30	8





× Failures ● LSR ● MLE (3P) ● Solver (1P) ● Manual Selection



Polymer General

Age Oldest Asset

Mean failure age

Population size

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0	0
Shape	0.78	1.00	2.6	2
Scale	1292.94	396.05	60	74
Predicted average failure age	1486	396	53	66
Predicted no. of failures p.a.	6	9	9	12

Input Data Statistics	Value
Mean failure age	6
Population size	3496
Avg number of historical annual failures	9
Age Earliest Failure	0
Age Oldest Asset	15





× Failures ● LSR ● MLE (3P) ● Solver (1P) ● Manual Selection







20

0 -

0

60

40



Age

- •

Load Break Switch

Automated

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0.00	0.00
Shape	1.92	2.02	3.60	2.50
Scale	98.46	91.96	57.60	68.00
Predicted average failure age	87	81	52	60
Predicted no. of failures p.a.	22	23	40	35

Input Data Statistics	Value
Mean failure age	22
Population size	3879
Avg number of historical annual failures	40
Age Earliest Failure	0
Age Oldest Asset	62

×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection

20

40

Age

60

bility of Failure 90 80

0.4

0.2

0.0

0

Cum

× Failures ●LSR ●MLE (3P) ● Solver (1P) ●Manual Selection



Manual

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0	0
Shape	2.36	3.28	3.6	4
Scale	60.49	48.97	36	50
Predicted average failure age	54	44	33	45
Predicted no. of failures p.a.	10	12	30	8

Input Data Statistics	Value
Mean failure age	30
Population size	1030
Avg number of historical annual failures	30
Age Earliest Failure	0
Age Oldest Asset	58











•

Under Slung Link

Porcelain

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0.00	0.00
Shape	1.92	2.02	3.60	2.50
Scale	98.46	91.96	57.60	68.00
Predicted average failure age	87	81	52	60
Predicted no. of failures p.a.	22	23	40	35

Input Data Statistics	Value
Mean failure age	22
Population size	3879
Avg number of historical annual failures	40
Age Earliest Failure	0
Age Oldest Asset	62

×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection



Age

×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection



Polymer

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0	0
Shape	2.36	3.28	3.6	4
Scale	60.49	48.97	36	50
Predicted average failure age	54	44	33	45
Predicted no. of failures p.a.	10	12	30	8

Input Data Statistics	Value
Mean failure age	30
Population size	1030
Avg number of historical annual failures	30
Age Earliest Failure	0
Age Oldest Asset	58















•

Drop Out Fuse

Porcelain

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0.00	0.00
Shape	1.92	2.02	3.60	2.50
Scale	98.46	91.96	57.60	68.00
Predicted average failure age	87	81	52	60
Predicted no. of failures p.a.	22	23	40	35

Input Data Statistics	Value
Mean failure age	22
Population size	3879
Avg number of historical annual failures	40
Age Earliest Failure	0
Age Oldest Asset	62

×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection

<u> </u> 0.8

ability of Failu 90

0.4

0.2

0.0

0

Cum



60



×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection

Polymer

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0	0
Shape	2.36	3.28	3.6	4
Scale	60.49	48.97	36	50
Predicted average failure age	54	44	33	45
Predicted no. of failures p.a.	10	12	30	8

Input Data Statistics	Value
Mean failure age	30
Population size	1030
Avg number of historical annual failures	30
Age Earliest Failure	0
Age Oldest Asset	58



20

40

Age











Functional Weibull Parameters

Air Break Switch

Porcelain General

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	2.23	0.00	0.00
Shape	2.41	2.27	3.60	3.60
Scale	122.96	118.30	76.43	76.00
Predicted average failure age	109	107	69	68
Predicted no. of failures p.a.	9	10	14	15

Input Data Statistics	Value
Mean failure age	25
Population size	3879
Avg number of historical annual failures	14
Age Earliest Failure	5
Age Oldest Asset	62

×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection



×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection



Porcelain Problematic

Parameters	LSR	MLE	Solver	Selected	
Shift	0.00	2.23	0.00	0.00	
Shape	2.41	2.27	3.60	3.60	
Scale	122.96	118.30	76.43	76.00	
Predicted average failure age	109	107	69	68	
Predicted no. of failures p.a.	9	10	14	15	
laward Data Otatladaa					
Input Data Si	Input Data Statistics Value			value	
Mean failure age				25	
Mean failure age Population size				25 3879	
Mean failure age Population size Avg number of historical annua	al failures			25 3879 14	
Mean failure age Population size Avg number of historical annua Age Earliest Failure	al failures			25 3879 14 5	



×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection



Polymer General

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	2.23	0.00	0.00
Shape	2.41	2.27	3.60	3.60
Scale	122.96	118.30	76.43	76.00
Predicted average failure age	109	107	69	68
Predicted no. of failures p.a.	9	10	14	15

Input Data Statistics	Value
Mean failure age	25
Population size	3879
Avg number of historical annual failures	14
Age Earliest Failure	5
Age Oldest Asset	62



× Failures ● LSR ● MLE (3P) ● Solver (1P) ● Manual Selection





Events Ourrent Population Ocensored





•

•

Load Break Switch

Automated

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0.00	0.00
Shape	1.92	2.02	3.60	2.50
Scale	98.46	91.96	57.60	68.00
Predicted average failure age	87	81	52	60
Predicted no. of failures p.a.	22	23	40	35

Input Data Statistics	Value
Mean failure age	22
Population size	3879
Avg number of historical annual failures	40
Age Earliest Failure	0
Age Oldest Asset	62

×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection



×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection



Manual

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0	0
Shape	2.36	3.28	3.6	4
Scale	60.49	48.97	36	50
Predicted average failure age	54	44	33	45
Predicted no. of failures p.a.	10	12	30	8

Value
30
1030
30
0
58



40

Age

60

20

0













•

Under Slung Link

Porcelain

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0.00	0.00
Shape	1.92	2.02	3.60	2.50
Scale	98.46	91.96	57.60	68.00
Predicted average failure age	87	81	52	60
Predicted no. of failures p.a.	22	23	40	35

Input Data Statistics	Value
Mean failure age	22
Population size	3879
Avg number of historical annual failures	40
Age Earliest Failure	0
Age Oldest Asset	62

×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection



×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection



Polymer

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0	0
Shape	2.36	3.28	3.6	4
Scale	60.49	48.97	36	50
Predicted average failure age	54	44	33	45
Predicted no. of failures p.a.	10	12	30	8

Input Data Statistics	Value
Mean failure age	30
Population size	1030
Avg number of historical annual failures	30
Age Earliest Failure	0
Age Oldest Asset	58



Age

×Failures ●LSR ●MLE (3P) ●Solver (1P) ●Manual Selection













•

•

Drop Out Fuse

Porcelain

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0.00	0.00
Shape	1.92	2.02	3.60	2.50
Scale	98.46	91.96	57.60	68.00
Predicted average failure age	87	81	52	60
Predicted no. of failures p.a.	22	23	40	35

Input Data Statistics	Value
Mean failure age	22
Population size	3879
Avg number of historical annual failures	40
Age Earliest Failure	0
Age Oldest Asset	62



20

<u> </u> 0.8

ability of Failu 90

0.2

Cun

0.4

0.0

0





Polymer

Parameters	LSR	MLE	Solver	Selected
Shift	0.00	0.00	0	0
Shape	2.36	3.28	3.6	4
Scale	60.49	48.97	36	50
Predicted average failure age	54	44	33	45
Predicted no. of failures p.a.	10	12	30	8

Input Data Statistics	Value
Mean failure age	30
Population size	1030
Avg number of historical annual failures	30
Age Earliest Failure	0
Age Oldest Asset	58



40

Age

60

× Failures ● LSR ● MLE (3P) ● Solver (1P) ● Manual Selection









Produced by Asset Planning and Performance branch

- W Endeavourenergy.com.au
- E <u>news@endeavourenergy.com.au</u>
- T 131 081



ABN 11 247 365 823

