

Electrical Safety and Technical Regulation

Validation Report for the CitiPower 2016-2017 Fire Start Report



Document information

Energy Safe Victoria is constantly working to improve our documents and appreciate your feedback. Please send any feedback or enquiries to:



Level 5, Building 2
4 Riverside Quay
Southbank VIC 3006



Open 8:30am – 4:30pm, Monday to Friday



03 9203 9770



info@energysafe.vic.gov.au

Important notice from Energy Safe Victoria regarding this document

In all cases, anyone proposing to rely on or use the information contained in this document should independently verify and check the accuracy, completeness, reliability and suitability of that information for their own purposes. Accordingly, neither Energy Safe Victoria nor the State of Victoria make any representations or warranty as to the accuracy, completeness, reliability or suitability for a particular purpose of the information in this document. Persons reading or utilising this document acknowledge that Energy Safe Victoria and the State of Victoria and their officers, employees, agents and consultants shall have no liability (including liability to any person by reason of negligence or negligent mis-statement) for any information or matter (express or implied) arising out of, contained in or derived from, or for any omissions from, the information contained in this document.

Prepared	Peter Greilach Senior Data and Process Analyst Data and Analytics	
Reviewed	Yuriy Onyshchuk Team Leader, Data and Analytics	
Approved	Ian Burgwin General Manager – Electrical Safety and Technical Regulation	

Document control

Revision	Date	Prepared by	Comments
0	8 Dec 2017	Peter Greilach	As approved by Ian Burgwin
1	15 Feb 2018	Peter Greilach	As approved by Ian Burgwin

Distribution list

Distributed to	David Chan: Director, Australian Energy Regulator
Issue date	15 February 2018

Executive summary

The Victorian Governor in Council made the Order in Council for the F-Factor Scheme Order 2016 under section 16C of the *National Electricity (Victoria) Act 2005*. This was gazetted on 22 December 2016.

CitiPower was required to provide its first full-year fire start report to the Australian Energy Regulator (AER) by 30 September 2017. This report, covering the period 1 July 2016 to 30 June 2017, was the first CitiPower fire start report to undergo validation by Energy Safe Victoria (ESV) as part of the AER review and acceptance process.

Being the first year for a new reporting regime, there were several minor issues identified that need to be addressed by separate processes to improve the reporting and validation process in subsequent years. None of these issues was material in any significant way or compromised the integrity of the reporting and validation process.

The validation process has been undertaken in a staged manner as follows:

- ▶ A **preliminary review** to ensure the information provided was complete and in a satisfactory form
- ▶ A **completeness assessment** to determine whether all fires previously reported to ESV had been included in the fire start report and to ensure all incidents in the fire start report had been previously reported as fires to ESV
- ▶ A **comparative analysis of IRU-specific factors** to identify any *material* differences between the information reported by CitiPower in its fire start report and previously to ESV in relation to those aspects of the fire start report pertinent to the calculation of the total Ignition Risk Units (IRU) amount
- ▶ A **comparative analysis of non-IRU factors** to identify any differences between the information reported by CitiPower in its fire start report and previously to ESV in relation to those aspects of the fire start report not pertinent to the IRU calculation.

Except for the analysis of non-IRU factors, ESV consulted with CitiPower regarding any discrepancies identified to clarify the reasons for the discrepancies and to provide an opportunity to amend the fire start report. Feedback on the non-IRU factors was provided in the formal response to the initial report findings (see below).

Further detail on the methodology used for the validation analysis is provided herein.

On completion of the validation analysis, ESV issued the “Validation Report for the CitiPower 2016-2017 Fire Start Report” (Rev. 0) to the AER on 8 December 2017. The AER provided a copy of this report to CitiPower on 11 December 2017 and invited CitiPower to respond with any comments by 12 January 2018. CitiPower/Powercor wrote to the AER on 22 December 2017, providing a written response to the findings of the Rev. 0 validation reports for both networks.

ESV has reviewed the response provided by CitiPower and updated the original report accordingly. ESV has made no changes to the content of the original Rev. 0 validation report; it has simply added an addendum to the end of the report. This addendum summarises the key points of the CitiPower response, confirms the details of the final fire start report, provides ESV’s comments on the response and updates the conclusions from the Rev. 0 validation report.

Following the validation process, ESV can confirm that the total IRU amount of 0.52 provided in the final CitiPower 2016-2017 fire start report is correct.

Contents

Executive summary	4
Introduction	6
Background	6
Request from AER	6
Process	7
Scope	7
Methodology applied	7
Caveats	9
Accuracy of information provided	10
Preliminary review	10
Completeness assessment	10
Comparative analysis — IRU-specific factors	11
Comparative analysis — non-IRU factors	12
Verification of IRU amount	13
Conclusion (Initial Findings)	14
Addendum : Response to DNSP comments	15
IRU-specific factors	15
Non-IRU factors	15
Revised fire start report	15
Conclusion (revised)	15

Introduction

Background

The Victorian Governor in Council made the Order in Council for the F-Factor Scheme Order 2016 under section 16C of the *National Electricity (Victoria) Act 2005*. This was gazetted on 22 December 2016.

The f-factor scheme is managed by the Australian Energy Regulator (AER). Section 7 of the Order in Council identifies that the AER may request Energy Safe Victoria (ESV) to validate the fire start reports submitted to the AER by the Distribution Network Service Providers. Each fire start report will have an individual validation report.

The Order in Council stipulates that each Distribution Network Service Provider (DNSP) will provide a fire start report to the AER by 30 September each year. The Order in Council also stipulates that, if requested by the AER, ESV will provide a validation report to the AER by 30 November each year.

The Order in Council also identifies that the AER may refer any submissions regarding the validation reports to ESV in order to provide a revised validation that responds to the submissions by 15 February in the following year.

Request from AER

The AER wrote to Paul Fearon, Director of Energy Safety, on 3 October 2017 to formally request that ESV validate the 2016-2017 fire reports provided by the DNSPs (AER ref. 62035). The AER also provided the following documents for the validation assessment:

- | | |
|-----------------------------------------------------|-------------------|
| ▶ CitiPower 2017 F-factor RIN Statutory declaration | PDF document |
| ▶ CitiPower F-factor Audit Opinion 2017 | PDF document |
| ▶ CitiPower F-Factor Scheme Report 2016-17 | Excel spreadsheet |

These documents consider the CitiPower distribution system separately from other systems managed by the service provider.

The AER advised ESV that, where necessary for the purposes of validation, ESV should seek additional information directly from the DNSPs. This is in line with clause 7(4) of the Order in Council. Where additional information was sought, ESV ensured that the AER was copied into any correspondence.

Process

While the scope of the fire start report and the validation process are detailed in the Order in Council (as outlined below), the approach to be undertaken in assessing the accuracy of information provided is not specified. This section describes the process that ESV applied to the validation assessment; the results are provided later in this report.

Scope

In reviewing the information provided in a DNSP's fire start report, clause 7(3) of the Order in Council stipulates that ESV's validation report:

- (b) must include an assessment of the accuracy of the information provided in the fire start report pursuant to clauses 6(3)(d)-(f) and (h);
- (c) must verify the estimate of the ignition risk unit (IRU) amount for the financial year provided under clause 6(3)(g).

These specific items are detailed in clause 6(3) of the Order in Council, which states that a DNSP's fire start report must, among other things:

- (d) if the Distribution Network Service Provider is the service provider in relation to more than one distribution system, distinguish between distribution systems;
- (e) list all fire starts for a financial year, stating in each case and where known:
 - (i) what kind of fire start it was;
 - (ii) the date, time and latitude and longitude for each fire;
 - (iii) the unique identification number of the pole and polyphase electric line nearest to the fire start;
 - (iv) the voltage of the electric line in which the ignition occurred;
 - (v) the estimated value of the fire start expressed in IRUs, calculated in accordance with this Order;
- (f) state whether the fire was reported to a relevant entity;
- (g) calculate the total IRU amount for the financial year on the basis of the information contained in the fire start report, in accordance with this Order;
- (h) include such other information as the AER may from time to time specify;

Clause 6(3) of the Order in Council also requires that the DNSP's fire start report:

- (i) include an independent audit of the fire start report undertaken by an external auditor;
 - (i) stating, in the auditor's opinion, whether the information contained in the fire start report is accurate and reliable; and
 - (ii) which is acceptable to the AER.

Methodology applied

For its validation assessment, ESV broke these items into the two categories:

▶ IRU-specific factors

These comprise those factors within the fire start report that are directly relevant to the calculation of the IRUs for the incident. Specifically these are the date, time and latitude and longitude for the fire and the DNSP's estimate of the IRUs for the fire [items (e)(ii) and (e)(v) in the Order in Council].

▶ Non-IRU factors

These comprise all other information reported in the fire start report [items (e)(i), (e)(iii) and (e)(iv)].

A more detailed analysis was undertaken of the IRU-specific factors than of the non-IRU factors.

ESV validated the DNSP fire start reports as follows:

▶ *Preliminary review*

The purpose of the preliminary review was to determine that the information provided to ESV was complete and in a satisfactory form for ESV to undertake its validation analysis.

ESV started by reviewing the documentation provided by the AER to ensure that all relevant information was provided and readable.

The DNSP's fire start spreadsheet was then subject to a preliminary, high-level review to ascertain whether there were any obvious issues with the information contained therein. If the preliminary review identified any issues, ESV would contact the DNSP so that the DNSP could provide an updated spreadsheet.

▶ *Completeness assessment*

The purpose of the completeness assessment was to determine whether:

- all fires in the DNSP's fire start report are listed as fires in OSIRIS¹
- all network-related fires listed in OSIRIS are included in the DNSP's fire start report.

Where there were differences identified, ESV contacted the DNSP to confirm the reasons for the difference.

The DNSP then provided a rationale for the differences and, where there was a change to the information in the fire start spreadsheet, the DNSP provided an updated spreadsheet reflecting any changes and, in some instances, additional supporting information.

We reviewed the rationale and information subsequently provided by the DNSP to confirm we were satisfied with the reasons for the inclusion or exclusion of specific incidents.

▶ *Comparative analysis — IRU-specific factors*

The purpose of the comparative analysis of IRU-specific factors was to identify any *material* differences between the information reported by the DNSP in its fire start report and through OSIRIS. In determining materiality, ESV considered whether:

- any differences in the location were sufficient to result in a lower location multiplier being applied to the fire start
- any differences in the location were sufficient to result in an incorrect CFA region being used for determining the applicable Fire Danger Rating for the fire start
- any differences in the date and time were sufficient to result in an incorrect Fire Danger Rating being applied to the fire start.

Where potentially material differences were identified, ESV contacted the DNSP to confirm the reasons for the differences.

The DNSP then provided a rationale for the differences and, where there was a change to the information in the fire start spreadsheet, the DNSP provided an updated spreadsheet reflecting any changes and, in some instances, additional supporting information.

We reviewed the rationale and information subsequently provided by the DNSP to confirm we were satisfied with the rationale and information provided.

¹ OSIRIS is ESV's incident reporting portal for the major electricity companies to report details of any serious electrical incidents to ESV. These incidents cover a range of events involving network assets, including fires.

▶ *Comparative analysis — non-IRU factors*

The purpose of the comparative analysis of non-IRU factors was to identify any differences between the information reported by the DNSP in its fire start report and through OSIRIS.

Where differences were identified, ESV has identified these in this report. No further consultation with the DNSP was undertaken.

Following the validation process, ESV then used the final data to calculate an IRU amount for each fire start. We then compared these against the IRU amounts provided by the DNSP, and a total IRU amount was calculated.

Caveats

The following caveats apply to the validation process and the contents and findings of this report:

▶ *Accuracy of the fire start data*

The validation process involves the comparison of two data sets — the DNSP's fire start report and incident data reported by the DNSP via ESV's OSIRIS. Where there are discrepancies between the data reported in these two data sets, ESV has not sought to ascertain which data set provides the true and accurate record of each fire start for the purposes of this report; however, we will pursue this in subsequent discussions with the DNSP.

As such, ESV can only attest that the data provided in the fire start report is appropriate for the purposes of calculating the total IRU amount. The information provided in the DNSP's fire start report should not be used for other purposes without further analysis of the data to verify it is fit for such purposes.

▶ *Validation against third-party sources*

ESV has not sought to validate or verify the data in the DNSP's fire start report in its entirety against third-party sources such as the Country Fire Authority (CFA) and Melbourne Metropolitan Fire Brigade (MFB).

This is not deemed to be a significant limitation on the validation process as any fires involving network assets should be reported by the CFA/MFB to the DNSP and these are, in turn, reportable to ESV.

Individual records may have been subject to confirmation with the CFA and/or MFB on a case-by-case basis. If this has occurred, it is noted within the report.

▶ *Independent verification of fire starts*

ESV does not have the resources available to routinely undertake independent assessments of the DNSP's electricity network in order to ascertain whether the DNSP identifies all incidents, including fires. As such, the fire starts may be under-reported; however, we are confident that the number of such incidents is small and that no significant fires could have gone unreported.

Similarly ESV has not undertaken an independent audit of the DNSP's records to ensure their accuracy. In this regard, we have relied on this being undertaken as part of the independent audit commissioned by the DNSP, the details of which were submitted as part of the fire start report.

Accuracy of information provided

ESV undertook an assessment of the accuracy of the information provided in the CitiPower fire start report in accordance with clause 7(3)(b) of the Order in Council. The following sections outline the findings of the assessment.

Further details regarding the specific incidents reported in the fire start report are available upon request.

Preliminary review

Upon receipt of CitiPower's documentation, we undertook a preliminary review to ensure that all the required documents had been provided to ESV and that the fire reporting spreadsheet had no obvious issues with regard to incomplete or incorrect data.

No high-level issues were identified with the documentation provided by CitiPower.

Completeness assessment

We compared the records provided in the CitiPower fire start spreadsheet with those available from ESV's OSIRIS incident reporting portal. This comparison was undertaken to assess the completeness of the fire start report, with specific attention paid to identifying any records missing from either data set or classified differently between the data sets.

The analysis identified two incidents where there were discrepancies between the CitiPower fire start spreadsheet and ESV's OSIRIS records. Details are provided in Table 1.

Both incidents were reviewed by ESV and deemed to not require follow-up discussions with CitiPower. Neither incident required CitiPower to amend its fire start report.

ESV determined that all fire starts had been reported to ESV as the relevant entity.

Table 1 Discrepancies between fire start report and OSIRIS

OSIRIS report no.	Included in report	Listed as fire in OSIRIS	Comment
20160830PWA_01	✓	✗	This was incorrectly listed in OSIRIS as a Powercor incident. Incorrectly listed in OSIRIS as melting only when the incident description notes that the melting was due to fire. OSIRIS report re-opened for CitiPower to update. No impacts on f-factor validation process.
20161110PWA_01	✗	✓	Incident listed in OSIRIS as a fire, but the description indicates that this was most probably a melted component. No requirement to include in fire start report.

Comparative analysis — IRU-specific factors

We compared the location (latitude and longitude) and timing (date and time) of each record in the fire start report with the record of the same incident in OSIRIS.

As we recognised that errors may be introduced into the location data due to rounding errors and other system-induced errors, we rounded all latitudes and longitudes to five decimal places to reduce the impact of such errors on the analysis.

The subsequent comparison of the records found extensive discrepancies in the location data — 83% of incident locations. Only one of the records differed in incident times between the data sets. Further statistics on these discrepancies are provided in Table 2.

ESV will be following up with CitiPower regarding these discrepancies as a separate matter after completion of the f-factor reporting process.

While there was a high level of difference between the data sets, ESV focused its analysis on those records where the differences could materially affect the IRU calculated for the fire start.

ESV applied the following tests to determine if the differences between the data sets could be material:

- ▶ **Test 1** : Is the difference in coordinates sufficient that a change in location may result in a higher location multiplier being applied?

This was assessed by calculating the distance between each location in the fire start report and the nearest boundary to a region where a larger location multiplier² would apply (the buffer distance). If the difference in coordinates multiplied by 1.1 was greater than the buffer distance, the record was flagged for further discussion with the DNSP.³

Thus, the materiality in Test 1 is not solely a function of the size of the difference in coordinates, but is more directly influenced by where the incident occurs (together with the size of the difference). Those events closer to boundaries are more likely to be flagged for further assessment; those events with large differences, but far from a boundary, are less likely to be flagged.⁴

- ▶ **Test 2** : Does the Fire Danger Rating applicable at the location and time for a record differ when based on the information specified in the fire start report and in OSIRIS?

ESV determined the applicable CFA region for each record by using the EM-COP website to check the CFA region at the OSIRIS coordinates.⁵ We then ascertained the Fire Danger Rating based on that CFA region and the date and time data from OSIRIS. These were then compared against the Fire Danger Ratings specified in the DNSP's fire start spreadsheet and differences identified for further investigation.

Thus, the materiality in Test 2 could either be due to a difference in the location or time data.

Using these two tests, we identified that none of the differences between the data sets would materially affect the IRU for the fire start. No further consultation with CitiPower was therefore required.

² These regions are specified in clause 11(b) of the Order in Council.

³ Given that distance between points on the globe is dependent on the latitude and longitude of the points, we calculate the approximate difference in meters using latitude and longitude conversion factors based on a central location. We then included a further 10 per cent margin to allow for approximations in the calculation.

ESV believes that the use of an approximation is acceptable for the general purpose of identifying records for further analysis.

⁴ As noted earlier, ESV will follow up with CitiPower as a separate process.

⁵ Emergency Management Common Operating Picture (<https://cop.em.vic.gov.au>).

Table 2 Discrepancies in location and timing data

Statistic	Location data	Timing data
Number of records	12	12
Number of discrepancies	10 (83%)	1 (8%)
Minimum discrepancy	10.8 m	7 min
Maximum discrepancy	104.9 m	7 min
Average discrepancy	42.4 m	7 min
Median discrepancy	27.8 m	7 min

Comparative analysis — non-IRU factors

ESV undertook a comparison of the data in the CitiPower fire start report and OSIRIS related to:

- ▶ the kind of fire start
- ▶ the pole and polyphase electric line identifications numbers
- ▶ the voltage of the electric line.

Details from OSIRIS on the asset involved and the incident description were used to determine whether the kind of fire start had been correctly identified. This involved a subjective assessment of the information.

A direct comparison was made of the details of the pole and line identification numbers and line voltage in the fire start report and OSIRIS. This did not require any subjective assessment.

ESV found no mismatches in the ESV fire start category, fire start type, pole identification number and line voltages.

There was one discrepancy in the polyphase line identification number for incident 20161125PWA_02, where the fire start report lists the line as NC014 and OSIRIS lists the line as NC013. This discrepancy has no material impact on the total IRU calculation.

No consultation was held with CitiPower regarding this discrepancy.

Verification of IRU amount

Following the validation of individual records, ESV compiled any changes to the fire start records and assigned the corresponding location and danger multipliers. In assigning multipliers, ESV corrected the danger multiplier formula in the AER template spreadsheet to ignore whether the CFA had declared the fire danger period for the municipality. The individual and total IRU amounts were then calculated.

We then compared our location and danger multipliers with those of CitiPower to determine whether CitiPower had correctly assigned the multipliers for each fire start. As noted previously, there were no material discrepancies in the CitiPower fire start data. ESV found that CitiPower had also assigned the multipliers correctly.

ESV can therefore confirm that the total IRU amount of 0.52 provided in the CitiPower 2016-2017 fire start report⁶ is correct.

⁶ As per CitiPower F-Factor Scheme Report 2016-17.xlsm

Conclusion (initial findings)

As noted earlier, the Order In Council stipulates that this validation report:

- (b) must include an assessment of the accuracy of the information provided in the fire start report pursuant to clauses 6(3)(d)-(f) and (h), specifically:
- (c) must verify the estimate of the ignition risk unit (IRU) amount for the financial year provided under clause 6(3)(g).

Table 3 identifies where these items have been assessed within this report and summarises the key findings of the validation assessment.

Table 3 Initial summary of findings

Statistic	Relevant report section	Key findings
Clause 6(3)(d)	Request from AER	The fire start report addressed the CitiPower distribution system separately from other systems managed by the service provider.
Clause 6(3)(e)(i)	Comparative analysis — non-IRU factors	There were no discrepancies between the assessment of the ESV fire start category and fire type made by CitiPower and that made by ESV.
Clause 6(3)(e)(ii)	Comparative analysis — IRU-specific factors	While there were a significant number of differences between the fire start report and OSIRIS data sets, none of these discrepancies was material to calculation of the total IRU amount.
Clause 6(3)(e)(iii)	Comparative analysis — non-IRU factors	There were no discrepancies between the fire start report and OSIRIS in relation to pole identification number. There was one discrepancy between the fire start report and OSIRIS in relation to a polyphase electric line identification number. This was not material to the calculation of the total IRU amount.
Clause 6(3)(e)(iv)	Comparative analysis — non-IRU factors	There were no discrepancies between the fire start report and OSIRIS in relation to voltage of the line involved in the fire.
Clause 6(3)(e)(v)	Verification of IRU amount	The total IRU amount of 0.52 provided in the CitiPower 2016-2017 fire start report is correct.
Clause 6(3)(f)	Completeness assessment	CitiPower had reported all fires to ESV as the relevant entity.

Addendum : Response to DNSP comments

ESV issued the “Validation Report for the CitiPower 2016-2017 Fire Start Report” (Rev. 0) to the AER on 8 December 2017. The AER provided a copy of this report to CitiPower on 11 December 2017 and invited CitiPower to respond with any comments by 12 January 2018.

CitiPower/Powercor wrote to the AER on 22 December 2017, providing a written response to the findings of the Rev. 0 validation reports for both networks. These comments were forwarded to ESV and, on 19 January 2018, the AER formally requested that ESV review the comments provided and update the validation report in line with the terms of the Order In Council.

The CitiPower/Powercor comments are published separately on the AER website and therefore have not been reproduced herein.

This addendum summarises the key points of the CitiPower response, provides ESV’s comments on the response, confirms the details of the final fire start report and updates the conclusions from the Rev. 0 validation report.

IRU-specific factors

In responding to items that potentially affect the calculation of the total IRU amount for the CitiPower network, CitiPower acknowledged that no discrepancies were found by ESV relating to the IRU amounts and number of fires reported for the CitiPower network.

The total IRU amount of 0.52 reported for the CitiPower network is correct.

In reference to ESV’s findings regarding locational discrepancies between the fire start report and CitiPower’s incident reports in OSIRIS, CitiPower explained that this was due to the different methods used for reporting location data in the fire start report and ESV’s OSIRIS system. ESV looks forward to further discussions with CitiPower/Powercor to improve the accuracy of reporting into ESV’s OSIRIS system.

No comment was offered by CitiPower on the single, minor timing discrepancy identified in the Rev. 0 validation report.

These locational and timing discrepancies can be addressed through a separate process as none of them materially affects the calculation of the total IRU amount.

Non-IRU factors

CitiPower acknowledged the discrepancy in the polyphase line identification number for incident 20161125PWA_02 and issued a revised fire start report that corrected this discrepancy.

Revised fire start report

CitiPower issued a revised (final) fire start report with its response to the Rev. 0 validation report. This was issued as *2017 CP F-Factor RIN (Ver 1.2 Post ESV Validation Report).xism*.

ESV has reviewed the revised fire start report and can confirm that the only change made to the report was the discrepancy in polyphase line identification number noted above.

Conclusion (revised)

ESV has reviewed the conclusions of the Rev. 0 validation report in the light of the comments above. Table 4 provides a revised summary of the initial findings in Table 3.

Table 4 Final summary of findings

Statistic	Relevant report section	Key findings
Clause 6(3)(d)	Request from AER	The fire start report addresses the CitiPower distribution system separately from other systems managed by the service provider.
Clause 6(3)(e)(i)	Comparative analysis — non-IRU factors	There are no discrepancies between the assessment of the ESV fire start category and fire type made by CitiPower and that made by ESV.
Clause 6(3)(e)(ii)	Comparative analysis — IRU-specific factors Addendum	While there are a significant number of differences between the fire start report and OSIRIS data sets, none of these discrepancies is material to calculation of the total IRU amount.
Clause 6(3)(e)(iii)	Comparative analysis — non-IRU factors Addendum	There are no discrepancies between the fire start report and OSIRIS in relation to pole identification numbers or polyphase electric line identification numbers.
Clause 6(3)(e)(iv)	Comparative analysis — non-IRU factors	There are no discrepancies between the fire start report and OSIRIS in relation to voltage of the line involved in the fire.
Clause 6(3)(e)(v)	Verification of IRU amount	The total IRU amount of 0.52 provided in the final CitiPower 2016-2017 fire start report is correct.
Clause 6(3)(f)	Completeness assessment	CitiPower had reported all fires to ESV as the relevant entity.