

Ref.: JD/CP

10 March 2010

Michelle Groves Chief Executive Officer Australian Energy Regulator GPO Box 520 MELBOURNE VIC 3001

AERInquiry@aer.gov.au

Dear Ms Groves

Ergon Energy Distribution Loss Factors for 2010-11

On 19 October 2009, the Australian Energy Regulator (AER) wrote to Ergon Energy Corporation Limited (Ergon Energy) requesting that Ergon Energy calculate Distribution Loss Factors (DLFs) for 2010-11 in accordance with its published methodology and submit them to the AER by 12 March 2010. In accordance with this request and clause 3.6.3(i) of the National Electricity Rules (the Rules), please find attached Ergon Energy's DLFs for 2010-11 at Attachment 1.

Ergon Energy notes that the AER have requested that the DLFs be provided in a format fit for the Australian Energy Market Operator (AEMO). AEMO wrote to Ergon Energy on 15 February 2010, seeking confirmation that the DLFs for 2010-11 would be provided to AEMO in time for publication by 1 April 2010. AEMO also requested that the information be provided in electronic format and that DLF codes be provided for each value. Therefore, in accordance with AEMO's request, Ergon Energy provides an electronic version of the DLFs for 2010-11, including DLF codes, at Attachment 2 to this submission.

In accordance with clause 3.6.3(g) of the Rules and the AER's request of 19 October 2009, the DLFs have been calculated in accordance with the approved methodology which is provided at Attachment 3. The methodology is also published on the Ergon Energy web page and can be found via the following link:

http://www.ergon.com.au/network_info/Distribution_Loss_Factor_Calculation_Methodology.a sp#1

In addition, we have also attached an independent verification by Intelligent Energy Systems (IES) that the DLFs have been calculated in accordance with Ergon Energy's published methodology, as requested in the AER's letter of 19 October 2009.

In accordance with requirements of the Queensland Electricity Act 1994, Ergon Energy has also calculated DLFs for the Mount Isa region. As Ergon Energy's Mount Isa-Cloncurry network is not part of the National Electricity Market, this is not a requirement of the Rules. However, they are included in this submission for completeness and have been referenced in the IES letter.

Should you have any questions or issues relating to this submission, please contact the Manager Regulatory Affairs – Tariff Strategy, Jenny Doyle, on (07) 4092 9813.

97-99 Adelaide Street Maryborough QLD 4650 PO Box 163 Maryborough QLD 4650 Telephone 13 10 46 Facsimile 07 4123 1124 Website www.ergon.com.au Yours sincerely

C.A. Ria .

Carmel Price Group Manager Regulatory Affairs

 Telephone:
 (07) 4121 9545

 Facsimile:
 (07) 4123 1124

 Email:
 carmel.price@ergon.com.au

Table A3						
Network Level	DLFs	applied 20	09/10	DLFs	to apply 20	010/11
	East	West	MI	East	West	м
Sub-Trans. Bus	1.009	1.012	1.001	1.008	1.006	1.000
Sub-Trans. Line	1.021	1.068	1.006	1.018	1.062	1.006
22/11kV Bus	1.022	1.077	1.010	1.019	1.068	1.009
22/11kV Line	1.042	1.119	1.039	1.034	1.109	1.038
LV Bus	1.075	1.162	1.058	1.068	1.147	1.058
LV Line	1.084	1.262	1.083	1.069	1.251	1.180

Network Level		DLF Codes		
	East	West	МІ	
Sub-Trans. Bus	GESB	GWSB	GMSB	
Sub-Trans. Line	GESL	GWSL	GMSL	
22/11kV Bus	GEHB	GWHB	GMHB	
22/11kV Line	GEHL	GWHL	GMHL	
LV Bus	GELB	GWLB	GMLB	
LV Line	GELL	GWLL	GMLL	

Table A4 Ergon Energy - Site Specific Distribution Loss Factors

NMI	DLF Code	DLFs applied 2009/10	DLFs to apply 2010/11
QDDD000005	GBSB	1.000	1.000
QAAALV0001	GBSB	1.000	1.000
QAAAMR0000	GBSB	1.000	1.000
QDDD000019	GS23	1.023	1.025
QDDD000002	GBSB	1.000	1.000
QDDD000004	GS22	1.008	1.008
QAAABW0000	GBSB	1.000	1.000
QAAABW0002	GS02	1.009	1.007
QDDD000026	GS24	1.009	1.008
QDDD000027	GS44	1.003	1.006
QDDD003345	GS77	1.004	1.022
QCCC000004	GS19	1.054	1.056
QCCC001004	GS60	1.043	1.048
QCCC000014	GS73	1.003	1.005
QCCC000002	GS18	1.003	1.003
QWAGW00033	GS66	1.011	1.009
QWAGW00066	GS65	1.011	1.009
QAAABW0001	GS51	1.003	1.003
QDDD000003	GS21	1.003	1.003
QAAALV0000	GBSB	1.000	1.000
QGGG000394	GS40	1.143	1.178
QAAABX0014	GS69	1.007	1.007

NMI	DLF Code	DLFs applied 2009/10	DLFs to apply 2010/11
QEMS000001	GS64	1.011	1.014
QAAALV0002	GBSB	1.000	1.000
QDDD003336	GS50	1.015	1.017
QCCC000003	GBSB	1.000	1.000
QAAALV0004	GBSB	1.000	1.000
QAAABX0012	GS70	1.001	1.001
QAAABX0002	GS06	1.014	1.013
QNGYW00172	GBSB	1.000	1.000
QAAARG0000	GS14	1.004	1.004
QGGG000032	GS33	1.003	1.003
QGNG000103	GS41	1.001	1.001
QGGG000033	GS34	1.000	1.000
QCCC700300	GBSB	1.000	1.000
QAAAMR0001	GS13	1.002	1.003
QAAABW0042	GS63	1.036	1.037
QAAABW0041	GS62	1.015	1.015
QAAALX0000	GS12	1.002	1.021
QGGG000000	GBSB	1.000	1.000
QAAABL0000	GBSB	1.000	1.000
QAAALV0003	GBSB	1.000	1.000
QAAADY0000	GBSB	1.000	1.000
QAAABX0001	GS05	1.008	1.008
QDDD000001	GBSB	1.000	1.000

Table A5 Ergon Energy Distribution Loss Factors – Embedded Generators

NMI	DLF CODE	DLFs applied 2009/10	DLFs to apply 2010/11
QEEE000547	GS26	0.996	0.996
QEEE000026	GS55	0.978	0.979
QCQPW00076	GS49	0.889	0.962
QFFF000010	GS29	0.974	0.979
QFFF00000Z	GS30	0.974	0.979
QCCC001041/3	GS67	0.976	0.973
QDDD003206	GS71	0.996	0.997
(Prior NMI QDDD00	3315)		
QDDD003340	GSBS	1.000	1.000
QCCC001036	GS56	0.983	0.987
QMKYW00147	GBSB	1.000	1.000
QGGG000418	GS74	1.000	1.001
QFFF000000	GS76	0.922	0.921
QEEE000050	GS79	0.971	0.983
3050922955	GS78	0.931	0.994
3050922963	GS78	0.931	0.994

Attachment 2

DLFs in Electronic Format for Provision to AEMO

ERGON ENERGY DISTRIBUTION LOSS FACTOR METHODOLOGY

1.0 Introduction

Section 3.6.3(g) of the National Electricity Rules (NER) requires that the Distribution Network Service Providers (DNSPs) publish the methodology used by them to determine Distribution Loss Factors (DLFs).

DLFs are calculated annually by DNSPs in accordance with the requirements of the NER in order to determine the amount of energy dispatched to supply customers.

Loss factors are applied by retailers in accordance with the NER.

This report describes the method used to establish DLFs for the following nodes in the Ergon Energy network:

- All Individually Calculated Customers (ICCs) and selected Connection Asset Customers (CACs) (customers with greater than 10MW of demand or 40GWh pa consumption); Embedded Generators of greater than 10MW and smaller Generators where required by the Rules.
- All Sub-transmission Bus and Line Customers on an averaged zonal basis.
- All 22/11kV Bus and 22/11kV Line Customers on an averaged zonal basis.
- All LV Bus and LV Line Customers on an averaged zonal basis.

A diagrammatic representation of each of the sections is provided in the Network Configuration Diagram at the end of this report.

2. Definition of Zones

The zones used for calculation of DLFs align with the network pricing zonal boundaries as defined in the Network Price Book.

3. Methodology

3.1 Forecast Quantities and Parameters

The NER now requires DLFs to be calculated using quantities and parameters projected to the year in which the DLFs are intended to apply. Customer and Generator demands, individual and bulk energy sales and energy dispatched quantities used are therefore all forecast quantities for the year of application.

All forecast quantities employed in the DLF calculation process are taken from the detailed demand and energy forecasts which Ergon Energy is required to produce for Planning, Network Pricing and Statutory purposes. The forecasting methodology is described below:

Forecasts produced are intended to reflect the "most likely" or "base" case for "average" weather conditions.

At Connection Point and Bulk Supply Point level, ten year demand and dispatched energy forecasts are prepared based on regression analysis of up to fifteen years of recorded data (typically five-seven years), corrected for switching or other system anomalies. Maximum Demands are extrapolated with adjustments to accommodate confirmed and anticipated developments and other known local factors. An independent Consultant is also retained annually to produce independent forecasts using "bottom-up" methodology incorporating demographic and econometric techniques as well as temperature correction. These forecasts are used to provide a check of and validate the internally produced forecasts. Ergon Energy's forecasts are also reviewed by and agreed with Powerlink for mutual planning purposes. Forecasts are also produced for all Zone substations by a similar process to that for Bulk Supply Points.

Energy sales figures are forecast in a similar manner by customer class and for larger individual customers, based on their individual projections.

The network Model used for load flow analysis is modified to reflect the forecast state of the Network in the applicable year by incorporating the configuration changes and asset upgrades contained in the capital works program leading up to that year.

3.2 DLFs for ICCs and Selected CACs (Site Specific Calculations)

Calculation of DLFs for all ICCs and selected CACs is performed using a Marginal Loss Factor (MLF) approach. This technique is detailed below.

The appropriate part of the sub-transmission network is modelled by including all directly connected 132kV, 66kV, 33kV, 22kV and 11kV customers along with direct connected loads representative of the 22kV and 11kV lines (lumped at the 22kV and 11kV busses). The ICCs and selected CACs are modelled to their metering point. The bulk supply point (Transmission system connection point) is modelled as an infinite bus.

The modelled loads reflect the forecast demand for the year in which the DLFs are to be applied at the time of the co-incident peak of the network being studied, ie the peak of the Bulk Supply/Connection Points.

The individual loads are incremented in turn by five percent and the load increases and net system demand increases recorded. By application of the appropriate Load Factors together with the forecast energy delivered and transformer iron losses, the DLFs are then calculated from the equation:

DLF = 1 + Total Losses/Energy delivered.

3.3 DLFs for Sub-transmission System and Substation 11/22kV busbars

Calculation of DLFs for the sub-transmission system nodes and 11/22kV busbars are performed using a similar MLF approach to that described above.

Using the appropriate DLFs so calculated and forecast annual energy consumption data, the energy losses of the Network Sector are derived. The calculated values are validated using projected metering data where possible. Where appropriate data is available the following process is used:

- Starting with the total network losses (by zone) deduct the losses attributable to the ICCs and selected CACs. This gives the losses to be shared across the remainder of the Customers.
- The network sector loss factor for customers (other than ICCs and selected CACs) connected at the sub-transmission level are determined by calculating the sum of the forecast losses in this network sector and dividing by the sum of the forecast sales in the network sector and all downstream sales (other than ICCs and selected CACs).
- This process is repeated for the 11kV and 22kV busses.

The total losses allocated are reconciled with projections based on data extracted from the metering data collection system where available.

3.4 DLFs for 22/11kV Lines and SWER Lines

DLFs for 22/11kV and SWER Lines are calculated using a MLF approach derived from sample sets of representative feeders.

Sample sets of Distribution feeders representative of feeders throughout Ergon Energy's area of supply are modelled on a zone substation basis, with the 22kV or 11kV busbar being the infinite bus. Using forecast peak loads for the substation, the demand is allocated across all connected loads on all the lines at the substation. No distribution transformers are included in the model as the loads are applied directly to the high voltage line.

Load flow studies are run for each sample substation feeder system and the DLFs are calculated using the MLF approach described previously.

All distribution feeder systems are then classified according to their similarity to the characteristics of the sample sets and allocated the appropriate DLFs calculated as per above. They are then divided into East and West zones and weighted average loss factors calculated for line customers based on the forecast energy supplied from each zone substation.

Zonal average values are then calculated and the network sector losses for 11/22kV line customers are determined by calculating the sum of the losses in this Network Sector and dividing by the sum of the sales in the Network Sector and all downstream sales (other than ICCs and selected CACs).

3.5 LV and SWER Customers

The technique described below is used to determine the losses in distribution transformers and to determine the appropriate allocation of energy (sales and network sector losses) to LV Bus and LV Line customers in each zone.

A list is obtained of the number, size, and voltage rating (11kV/415V or 22kV/415V & SWER) of all distribution transformers in each zone. Typical no load and full load losses in Watts for each different type of transformer have been obtained from test certificates. The maximum demand and projected installed transformer capacity in the zone being examined is used to calculate the peak full load losses of distribution transformers in that zone. The total kWh of losses in distribution transformers for each zone is then calculated by adding the Peak Full Load Losses multiplied by the Load Loss Factor for the zone being examined to the no load losses for that zone.

The break up of the percentage of network sector losses allocated to LV Line and LV Bus customers is estimated by allocating all transformers with 2 or less customers to LV Bus and the remainder to LV Line. The break up of the percentage of LV energy sales used in the East and West zones is obtained by obtaining and projecting LV usage from Customer Information System (CIS) records. Energy on lines in each zone is then summated to determine the total LV energy sales supplied in each zone.

The network sector loss factor for LV bus category is calculated by dividing the projected network sector losses in distribution transformers in the relevant zone by the sum of the projected LV bus sales. This value is then added to the 22/11kV line loss factor to obtain the loss factor for LV bus customers.

The network sector loss factor for LV line category is calculated by dividing the residual losses by the projected LV line energy sales including streetlights. This value is then added to the 22/11kV line loss factor to obtain the loss factor for LV line customers. The network sector loss for LV Line is the residual loss calculated from projected Purchases less projected Sales less all other network sector losses.

4. Reconciliation and Reporting

Calculated DLFs are applied and checked to ensure energy balances are valid throughout the supply network. In addition reconciliation calculation is performed annually for the previous year by applying the published DLFs to actual recorded energy dispatches and sales.

A report detailing the calculations methodology and the detailed results is prepared each year and submitted for approval to the Queensland Competition Authority. Following approval, the DLFs are forwarded to National Electricity Market Management Company Limited (NEMMCO) who publish them on their website by April of each year.

5. Network Configuration Diagram





2 March 2010

Mrs Carmel Price General Manager Regulatory Affairs Ergon Energy Corporation Limited PO Box 15107 City East QLD 4002

Dear Carmel,

REVIEW OF ERGON ENERGY DISTRIBUTION LOSS FACTORS FOR 2010/11

Intelligent Energy Systems Pty Ltd (IES) has undertaken a review (audit) of the Distribution Loss Factors (DLFs) for 2010/11 financial year calculated by Ergon Energy Corporation Limited (Ergon Energy). The IES audit examined the proposed DLFs with regard to their consistency with Ergon Energy's published methodology which is the published methodology operating in Queensland as at 31 December 2009.

Ergon Energy provided IES with the document "Distribution Loss Factors – 2010", dated 25 February 2010, and supporting spreadsheets for review. Its report described its forecast methodology, DLF calculation methodology for independently calculated customers (ICCs), tariff class customers and embedded generators. The report also included proposed DLFs for ICCs and tariff class customers, sources of data, summary data for losses and sales at the various voltage levels for 2010/11, and reconciliation figures for 2008/09.

The supporting spreadsheets were comprehensive and well set out showing the calculation of series and shunt losses, energy flows, workings of the DLF values, and reconciliation of the total forecast energy sales and purchases for 2010/11 with the calculated DLFs. A spreadsheet showing the historical reconciliation for financial year 2008/09 was also provided. Historical reconciliations were included for Ergon Energy's East and West zones both separately and combined. As Ergon Energy consolidates losses into two price zones – (East and West zones) a reconciliation of losses has appropriately been conducted into the two zones.

Ergon Energy's submission was clear and concise, the calculations consistent with the published methodology and, DLF values correctly determined. The

Intelligent Energy Systems Pty Ltd ACN 002 572 090 ABN 51 002 572 090

Head Office – Sydney Level 2 10-12 Clarke Street Crows Nest NSW 2065 Australia PO Box 931 Crows Nest NSW 1585 Telephone 61 2 9436 2555 Facsimile 61 2 9436 1218 Email ies@iesys.com.au Web www.iesys.com.au

MelbourneLevel 845 William StreetMelbourne VIC 3000 AustraliaPO Box 405Collins StreetWestMelbourne VIC 8007Telephone61 3 9614 6200Facsimile 61 3 9614 6255Email ies@iesys.com.auWeb www.iesys.com.au

proposed DLFs for tariff class customers for the East and West zones are shown in Table 1 and their percentage differences (between 2009/10 and 2010/11) in Table 2. Table 3 details the tariff class DLFs for 2010/11 for the Mt Isa region. The percentage differences between the 2009/10 and 2010/11 for Mt Isa are detailed in Table 4. DLFs for ICCs are shown in Table 5 along with the existing DLFs and the percentage changes based on the new calculated 2010/11 values. DLFs for Embedded generators are shown in Table 6, this table also indicates the percentage differences between existing and newly calculated DLFs.

The changes in the DLFs proposed for tariff class customers in the East zone compared to the current DLFs vary from between -1.4 % and 0.0% from the 2009/10 values. The changes in the DLFs proposed for tariff class customers in the West zone compared to the current DLFs vary from between -1.3% and - 0.6% from the 2009/10 values. As the changes in DLFs are decreases they will reduce customer costs across most tariff class categories.

There were three increases in DLF values for Ergon Energy's ICCs which were greater than 1% from last year's DLFs, Ergon provided satisfactory explanations for these increases. The majority of DLFs for ICCs either remained the same or decreased or increased slightly in value. These DLFs changes will in the main not have significant impacts on Ergon Energy's ICCs energy costs for 2010/11. Changes to DLFs for Embedded generators changes will result in decreased losses for Embedded generators.

IES has examined the data provided by Ergon Energy (in the form of spreadsheets) and are of the opinion that they have estimated their projections in accordance with the published methodology and DLFs values correctly determined.

When calculating its distribution loss factors, Ergon Energy has used a forwardlooking approach which utilises forecast sales and purchase figures produced for Planning, Network Pricing and Statutory purposes. Ergon Energy provides an overview of the forecasting procedure in its report whereby 10 year forecasts are produced using a regression analysis of up to 15 years of historical data. Due to the various cross checks in its own organisation and by an independent consultant, IES believes that the forecasts are robust and are applicable to the calculation of DLFs.

Ergon Energy has carried out a reconciliation of losses for financial year 2008/09 in accordance with the National Electricity Rules' requirements. A separate reconciliation was conducted for each of the East and West zones. It found when applying the 2008/09 DLFs to its actual sales figures for 2008/09, reconciled (calculated) energy dispatched in the East zone overstated actual energy dispatched by only 0.1%, and reconciled (calculated) energy dispatched in the

West zone overstated actual energy dispatched by 1.1%. Combining the two zones, calculated energy dispatched overstated actual energy dispatched by 1.1%. It should be noted that when using the forward looking approach, where forecasts of sales and purchase figures are utilised, a result within 5% is acceptable.

Ergon Energy has also calculated DLFs for the Mt Isa region. These DLFs have been calculated in accordance with the same methodology as the DLFs for the East and West zones, similarly these results are valid.

In summary, IES are of the opinion that the DLFs calculated by Ergon Energy for 2010/11 as shown in Tables 1, 3, 5 and 6 are consistent with the published methodology and, DLF values correctly determined.

Yours Sincerely **Bryan Whitlock** Senior Energy Analyst

Tabl	e 1 Ergon Energy proposed tariff class DLFs for 2010/11				
Natural	2009/1	2009/10 DLFs		010/11 DLFs	
Network Level	East Zone	West Zone	East Zone	West Zone	
Sub-Trans Bus	1.009	1.012	1.008	1.006	
Sub-Trans Line	1.021	1.068	1.018	1.062	
22/11 kV Bus	1.022	1.077	1.019	1.068	
22/11 kV Line	1.042	1.119	1.034	1.109	
LV Bus	1.075	1.162	1.068	1.147	
LV Line	1.084	1.262	1.069	1.251	

Table 2	Ergon Energy percent change in proposed DLFs for 2010/11			
Network Level	East Zone	West Zone		
	% Change	% Change		
Sub-Transmission Bus	0.0	-0.6		
Sub-Transmission Line	-0.3	-0.6		
22/11 kV Bus	-0.3	-0.8		
22/11 kV Line	-0.7	-0.9		
LV Bus	-0.6	-1.3		
LV Line	-1.4	-0.8		

Table 3	Ergon Energy proposed tariff class DLFs for Mt Isa for 2010			
Network Level	2009/10 DLF	2010/11 DLF		
	Mt Isa	Mt Isa		
Sub-Transmission Bus	1.001	1.000		
Sub-Transmission Line	1.006	1.006		
22/11 kV Bus	1.010	1.009		
22/11 kV Line	1.039	1.038		
LV Bus	1.058	1.058		
LV Line	1.083	1.180		

Table 4 Ergon Ene	rgy percent change in proposed Mt Is	sa DLFs for 2010/11
Network Level	Mt Isa	
	% Change	
Sub-Transmission Bus	-0.1%	
Sub-Transmission Line	0.0%	
22/11 kV Bus	-0.2%	
22/11 kV Line	0.0%	
LV Bus	-0.1%	
LV Line	9.0%	

Region (customer name deleted)	NMI	Existing DLF 2009/10	Proposed DLF 2010/11	% Change
Northern Region				
-	QCCC000002	1.003	1.003	0.0
	QCCC000003	1.000	1.000	0.0
	QCCC000004	1.054	1.056	0.19
Holdes - Holder Holder Holder Holder - Her All 201 4 ACCA	QCCC000014	1.003	1.005	0.2
	QCCC001004	1.043	1.048	0.48
an a canada	QCCC700300	1.000	1.000	0.0
Capricornia Region				
	QAAABL0000	1.000	1.000	0.0
	QAAABW0000	1.000	1.000	0.0
	QAAABW0001	1.003	1.003	0.0
the Control of the second s	QAAABW0002	1.009	1.007	-0.2
	QAAABW0041	1.015	1.015	0.0
	QAAABW0042	1.036	1.037	0.1
	QAAABX0001	1.008	1.008	0.0
	QAAABX0002	1.014	1.013	-0.1
	QAAABX0012	1.001	1.001	0.0
an and a fair a land and the second of an an an an an an and a second of a second second birs of a second as su	QAAABX0014	1.007	1.007	0.0
	QAAADY0000	1.000	1.000	0.0
	QAAALV0000	1.000	1.000	0.0
1	QAAALV0001	1.000	1.000	0.0
	QAAALV0002	1.000	1.000	0.0
	QNGYW00172	1.000	1.000	0.0
Anti Handrichten officierte Anti-Anti-Anti-	QAAALV0003	1.000	1.000	0.0
	QAAALV0004	1.000	1.000	0.0
	QAAALX0000	1.002	1.021	1.9
	QAAAMR0000	1.000	1.000	0.0
ar sources i no pour processor analyzer and a source e a	QAAAMR0001	1.002	1.003	0.1
	QAAARG0000	1.004	1.004	0.0
	QGNG000103	1.001	1.001	0.0
Mackay Region				
	QDDD000001	1.000	1.000	0.0
	QDDD000002	1.000	1.000	0.0
	QDDD000003	1.003	1.003	0.0
	QDDD000004	1.008	1.008	0.0
n ng manon na analan na aga ana ana ana ana ana ana ana an	QDDD000005	1,000	1.000	0.0
na po na presidencia de la construction en construction en la construction de la construction de la construction	QDDD000019	1.023	1.025	0.2
a an	QDDD000026	1.009	1.008	-0.1
a non-second data and an annual and an a second	QDDD000027	1.003	1.006	0.3
	QDDD003345	1.004	1.022	1.8
	QDDD003336	1.015	1.017	0.2
	QEMS000001	1.011	1.014	0.3

Region (customer name deleted)	NMI	Existing DLF 2009/10	Proposed DLF 2010/11	% Change
Wide Bay Region				
	QGGG000000	1.000	1.000	0.0
	QGGG000032	1.003	1.003	0.1
	QGGG000033	1.000	1.000	0.0
	QGGG000394	1.143	1.178	3.06
South West Region				
	QWAGW00033	1.011	1.009	-0.2
Construct the second s second second se second second sec second second sec	QWAGW00066	1.011	1.009	-0.2

Region (Embedded Generator name deleted)	NMI	DLF 2009/10	DLF 2010/11	% change
Far North Region				
	QEEE000026	0.978	0.979	0.13
	QEEE000547	0.996	0.996	0.03
	QCCC001036	0.983	0.987	0.44
	QEEE000050	0.971	0.983	1.27
Capricornia Region				
	QCCC001041/3	0.976	0.973	-0.26
	QCQPW00076	0.889	0.962	8.23
South West Region				
	QFFF000010	0.974	0.979	0.5
	QFFF00000Z	0.974	0.979	0.5
	QFFF000000	0.922	0.921	-0.09
	3050922955	0.931	0.994	6.82
	3050922963	0.931	0.994	6.82
Mackay Region				
	QDDD003206			
	(prior NMI QDDD003315)	0.996	0.997	0.11
	QDDD003340	1.000	1.000	0.00
	QMKYW00147	1.000	1.000	0.00
Wide Bay Region				
	QGGG000418	1.000	1.001	0.08