

Business Case Overhead LV Services Replacement Program



Executive Summary

This document seeks funding for a program of Service replacements in Ergon Energy with a total quantity of 69,045 and a total value of \$55.2M over the 5-year 2020-25 AER regulatory control period. This initiative is an important component of replacement expenditure to ensure customer safety is maintained and service targets are met.

Under the Queensland Electrical Safety Act and associated regulations, Ergon Energy has an obligation to ensure that its works are electrically safe, are operated in a way that is electrically safe and to ensure the electrical safety of all persons and property likely to be affected by the electrical work. This includes a duty to ensure that it does all that is reasonably practicable (including that which was reasonably able to be done at a particular time) to ensure electrical safety risks are managed to the level so far as is reasonably practicable (SFAIRP). The service replacement program is one important part of delivering an overall safe outcome for the community.

Ergon Energy has an LV services asset population of almost 400,000. Significant quantities of these services are at or near end of life and failure rates are increasing. A replacement program is required to address this critical ageing population and ensure Ergon Energy remains compliant with the Queensland Electrical Safety Act.

Three options were considered but rejected for this business case; installation of off-grid generation, in-situ repair and installation of underground services. All three were deemed unviable due to initial cost estimates being prohibitive relative to other proposed options, without delivering significant additional benefits. Two options have been evaluated in this business case:

Counterfactual – Replacement of defective services based on historical volumes

Option 1 – Replacement of defective services plus an additional program of targeted proactive replacements

Ergon Energy aims to minimise expenditure in order to keep pressure off customer prices but understands that this must be balanced against critical network performance objectives including safety, customer reliability, and security. In this case customer safety is a strong driver, based on the need to replace ageing assets within the population to avoid an increase in failure rates and the associated safety consequences for customers.

To this end, Option 1 is the preferred option. Detailed quantitative risk analysis has shown an escalating trend of expected service failures and customer safety risks based on the counterfactual, assuming a historical replacement approach. Based on the expected numbers of failures, the counterfactual is likely to result in a significant increase in the number of Dangerous Electrical Events (DEEs) and as such would result in Ergon failing to comply with the requirements of the Electrical Safety Act. The quantified economic value of the risks exceeds the costs of the significant replacement program under Option 1, which has a Net Present Value (NPV) of \$20.9M.

The direct cost of the program for each submission made to the AER is summarised in the table below. Note that all figures are expressed in 2018/19 dollars and apply only to costs incurred within the 2020-25 regulatory period for the preferred option.

Regulatory Proposal	Draft Determination Allowance	Revised Regulatory Proposal
\$60.3M	N/A	\$55.2M

Contents

Executive Summary	i
1. Introduction.....	1
1.1 Purpose of document	1
1.2 Scope of document.....	1
1.3 Identified Need	1
1.4 Energy Queensland Strategic Alignment	1
1.5 Applicable service levels.....	2
1.6 Compliance obligations	3
1.7 Limitation of existing assets.....	3
2 Counterfactual Analysis	5
2.1 Purpose of asset	5
2.2 Business-as-usual service costs.....	5
2.3 Key assumptions	5
2.4 Risk assessments.....	6
2.5 Retirement or de-rating decision.....	7
3 Options Analysis	8
3.1 Options considered but rejected	8
3.2 Identified options	8
3.2.1 Network options.....	8
3.2.2 Non-network options.....	9
3.3 Economic analysis of identified options	9
3.3.1 Cost versus benefit assessment of each option.....	9
3.4 Scenario Analysis	9
3.4.1 Sensitivities	9
3.4.2 Value of regret analysis	10
3.5 Qualitative comparison of identified options.....	11
3.5.1 Advantages and disadvantages of each option.....	11
3.5.2 Alignment with network development plan.....	11
3.5.3 Alignment with future technology strategy	11
3.5.4 Risk Assessment Following Implementation of Proposed Option.....	11
4 Recommendation	14
4.1 Preferred option.....	14
4.2 Scope of preferred option	14
Appendix A. References.....	15
Appendix B. Acronyms and Abbreviations.....	16

Appendix C.	Alignment with the National Electricity Rules (NER)	18
Appendix D.	Mapping of Asset Management Objectives to Corporate Plan	20
Appendix E.	Risk Tolerability Table	21
Appendix F.	Quantitative Risk Assessment Details	22
Appendix G.	Reconciliation Table	26

1. Introduction

The purpose of the Low Voltage (LV) services replacement program is to manage the existing and emerging customer and safety risks associated with LV service assets.

1.1 Purpose of document

This document recommends the optimal capital investment necessary for the asset lifecycle management of Ergon Energy's LV service population.

This is a preliminary business case document and has been developed for the purposes of seeking funding for the required investment in coordination with the Ergon Energy Revised Regulatory Proposal to the Australian Energy Regulator (AER) for the 2020-25 regulatory control period. Prior to investment, further detail will be assessed in accordance with the established Energy Queensland (EQL) investment governance processes. The costs presented are in \$2018/19 direct dollars.

1.2 Scope of document

This document presents the economic justification for Ergon Energy's proposed asset lifecycle management approach for LV services. The preferred option is selected based on an economic analysis and quantified risk reduction benefit. This document integrates with the Energy Queensland LV Safety business case that proposes monitoring of LV services to ensure safety outcomes are achieved. This document should also be read in conjunction with the Energy Queensland Asset Management Plan (AMP) Services.

1.3 Identified Need

Ergon Energy has an LV services asset population of almost 400,000. Significant quantities of these services are at or near end of life and failure rates are increasing. A replacement program is required to address this critical ageing population. The need for this work is also based on a detailed quantitative risk assessment that has shown that this investment is required to provide optimal economic outcomes, balancing the value of risks with the cost of managing the risks.

Ergon Energy aims to minimise expenditure in order to keep pressure off customer prices but understands that this must be balanced against critical network performance objectives including safety, customer reliability, and security. In this case customer safety is a strong driver, based on the need to replace ageing assets within the population to avoid an increase in failure rates and the associated safety consequences for customers.

This section of the document describes the need for the proposed investment in relation to EQL's strategy, applicable service levels, compliance obligations and limitations of the existing asset population. This proposal aligns with the CAPEX objectives and criteria from the National Electricity Rules as detailed in Appendix C.

1.4 Energy Queensland Strategic Alignment

Consistent with best practice asset management as per ISO55000, Table 1 below summarises how investment in the LV services asset class contributes to EQL's strategic objectives. The linkages between these Asset Management Objectives and EQL's Corporate Objectives are shown in Appendix D.

Table 1: Asset Function and Strategic Alignment

Objectives	Relationship of Initiative to Objectives
<p>Ensure network safety for staff contractors and the community</p>	<p>Overhead (OH) LV services are an asset which is attached to customer premises. The failure of these assets can result in live conductors on the ground, dangerous voltages on the neutral conductor and/or the customer earthing system, which can impact the safety of any earthed metallic appliance. Given the regular proximity of this asset to people (including children), in and around these premises, plus the consequences of failure of these assets, this initiative targets reductions in the safety risks associated with asset failure So Far as Is Reasonably Practicable (SFAIRP).</p>
<p>Meet customer and stakeholder expectations</p>	<p>Failure of overhead LV service assets will result in interruption to customer supply and the associated cost of unserved energy. This initiative reduces the economic costs associated with loss of supply due to LV service failure.</p>
<p>Manage risk, performance standards and asset investments to deliver balanced commercial outcomes</p>	<p>Investment in LV services considers a total lifecycle cost approach as well as the overall state of the asset population to promote a commercially sustainable direction to manage risk, cost and performance for this asset class.</p>
<p>Develop Asset Management capability & align practices to the global standard (ISO55000)</p>	<p>The initiative is aligned with the EQL Asset Management Plan for LV Services. Refer to the AMP for further details of ISO55000 alignment.</p>
<p>Modernise the network and facilitate access to innovative energy technologies</p>	<p>Services are the “final link” between the shared electricity network and customer’s premises. They are therefore critical as an enabling asset for potential future customer revenue streams such as customer self-generation power export into the distribution network.</p>

1.5 Applicable service levels

Corporate performance outcomes for this asset are rolled up into Asset Safety & Performance group objectives, principally the following Key Result Areas (KRA):

- Customer Index, relating to Customer satisfaction with respect to delivery of expected services
- Optimise investments to deliver affordable & sustainable asset solutions for our customers and communities

Corporate Policies relating to establishing the desired level of service are detailed in Appendix D.

The key applicable service level for this business case relates to safety obligations in the Electrical Safety Act 2002. As a person in control of a business or undertaking (PCBU), Ergon Energy has an obligation to ensure that its works are electrically safe and are operated in a way that is electrically safe.¹ This duty also extends to ensuring the electrical safety of all persons and property likely to be affected by the electrical work.²

¹ Section 29, *Electrical Safety Act 2002*

² Section 30 *Electrical Safety Act 2002*

1.6 Compliance obligations

Table 2 shows the relevant compliance obligations for this proposal.

Table 2: Compliance obligations related to this proposal

Legislation, Regulation, Code or Licence Condition	Obligations	Relevance to this investment
<p>QLD Electrical Safety Act 2002</p> <p>QLD Electrical Safety Regulation 2013</p>	<p>We have a duty of care, ensuring so far as is reasonably practicable, the health and safety of our staff and other parties as follows:</p> <ul style="list-style-type: none"> Pursuant to the Electrical Safety Act 2002, as a person in control of a business or undertaking (PCBU), Ergon Energy has an obligation to ensure that its works are electrically safe and are operated in a way that is electrically safe. This duty also extends to ensuring the electrical safety of all persons and property likely to be affected by the electrical work. 	<p>This proposal is a key component in the management of safety for electricity customers. Customer shocks related to neutral integrity are the most significant proportion of network shock incidents, making up some 60-70% of recorded network-related shock incidents. Over recent years there have been around 157 shocks per annum directly attributable to faulty LV Services.</p>
<p>Distribution Authority for Ergon Energy issued under section 195 of Electricity Act 1994 (Queensland)</p>	<p>Under its Distribution Authority:</p> <ul style="list-style-type: none"> The distribution entity must plan and develop its supply network in accordance with good electricity industry practice, having regard to the value that end users of electricity place on the quality and reliability of electricity services. The distribution entity must use all reasonable endeavours to ensure that it does not exceed in a financial year the Minimum Service Standards (MSS) 	<p>Fundamentally, this proposal aims to ensure LV services are replaced at an adequate rate to effectively manage safety risks and improve safety performance. However, it is also noted that some reliability consequences arise from LV Service failures and these have been factored into the analysis contained in this proposal.</p>

1.7 Limitation of existing assets

Relevant failure modes driving end-of-life for this asset are summarised in Table 5: Overhead Service Life Limiting Factors of the EQL AMP Services document.

Typical condition related failure modes which drive end of life and the subsequent safety risks for this asset are conductor corrosion and insulation aging.

- Ergon Energy has an aging population of LV Services. Approximately **37%** of the population is over **40** years of age.
- Ergon has experienced an average of approximately **1300** overhead service asset failures annually and more than 1700 failures in recent years with an increasing trend.

LV Service failure data in the EQL AMP Services document indicates that historically, approximately 150 LV Service failures resulted in safety consequences annually with this figure rising to approximately 180 in recent years with an **increasing trend**. Figure 1 and Figure 2 outline the frequency of failures and shock events in Ergon Energy networks.

Service Failure Quantity Northern & Southern regions




Figure 1: Service Failure Quantity – Ergon Energy (EQL AMP – Services)

Service related shock performance Northern and Southern regions




Figure 2: Service Failures and Shock Trends – Ergon Energy (EQL AMP – Services)

2 Counterfactual Analysis

2.1 Purpose of asset

LV Services connect electricity supply from the network to customer premises. The service neutral conductor integrity is crucial to ensuring that house appliances do not become “live” resulting in the potential for shocks inside the house. This integrity can be compromised due to various service failures including failure in the network, failure of clamps connecting to the network, failure of the service line itself, failure of the connection to the customer installation and failure within the customer installation. By design, a customer earthing system provides backup in the event of a neutral failure, however this customer earthing system is generally not tested after installation and cannot be relied on when a neutral integrity problem occurs.

2.2 Business-as-usual service costs

The ongoing costs for these assets are relatively minor, with most costs directed at inspection and remediation of defective assets and vegetation clearance works. However, significant costs arise through failures, with shock / tingle incidents requiring emergency response, incident investigation, replacements works, and reporting to the Safety Regulator.

2.3 Key assumptions

The counterfactual case is assumed to be the approximate historical rate of a targeted approach including condition-based replacements of 5309 / year (based on historical rates). The total and per-year quantities and costs for this option are summarised in Table 3 below. Appendix F details the methodology and input assumptions associated with quantification of risk of condition-related failure for Ergon’s LV Service population.

Table 3: Counterfactual - Volumes and Costs

	20/21	21/22	22/23	23/24	24/25	Total Over 2020-25 period
Quantity	5,309	5,309	5,309	5,309	5,309	26,545
Cost (\$k)	4,600	4,600	4,600	4,600	4,600	23,000

Under this option the service failures are forecast to increase steadily over the future from around 2,000 in 2020 to around 2,400 by 2030. This option fails to adequately address the growing failure rate of LV services and irrespective of complementary programs such as LV Safety would not reverse the growing failures and consequent risks.

2.4 Risk assessments

Figure 3 provides the results of a quantitative forecast of emerging risk associated with Ergon's LV Service asset population failure due to condition related failure modes and replacement at historical rates.




Figure 3: Counterfactual quantitative risk assessment

Significant risk costs arise in the counterfactual, due predominantly to safety risks associated with service neutral failures. The cost of a failure includes economic costs relating to safety, fire, reliability and emergency response. The cost of these risks increases substantially over the 10-year period shown, driven mainly by the age profile of the existing population.

A semi-quantitative risk assessment has also been conducted in accordance with the EQL Network Risk Framework and the Risk Tolerability table from the framework is shown in Appendix E. The risk scores are shown for the current risk and this is expected to escalate going forward if the ageing population and increasing failure rates are not addressed.

Table 4: Counterfactual qualitative risk assessment

Risk Scenario	Risk Type	Consequence (C)	Likelihood (L)	Risk Score	Risk Year
Due to degradation / corrosion, a service neutral is broken. A member of the public contacts an energised appliance in their house resulting in a single fatality due to electric shock.	Safety	5 <i>(Single Fatality)</i>	3 <i>(Unlikely)</i>	15 <i>(Moderate)</i>	2020

Risk Scenario	Risk Type	Consequence (C)	Likelihood (L)	Risk Score	Risk Year
Due to degradation / corrosion, service wire loses mechanical strength and breaks. Fuse does not operate due to high impedance fault. Nearby member of the public physically contacting live mains resulting in a single fatality due to electric shock.	Safety	5 <i>(Single Fatality)</i>	3 <i>(Unlikely)</i>	15 (Moderate)	2020
Due to corrosion, service wire losses mechanical strength and breaks. Interruption to customer premises while repairs are made.	Customer	1 <i>(N/A)</i>	6 <i>(Almost certain)</i>	6 (Low)	2020
Due to corrosion, service wire losses mechanical strength and breaks. Fuse does not operate due to high impedance fault. Fire results causing property damage and business impact of >\$100,000 in damages.	Business	2 <i>(business impact of >\$100,000 in damage)</i>	3 <i>(Unlikely)</i>	6 (Low)	2020

Further Details of the risk ratings and descriptions can be found in Energy Queensland's Network Risk Framework.

2.5 Retirement or de-rating decision

LV Services are sized with a capacity that is usually sufficient to prevent overloading, so annealing due to overloading is an unusual failure mode. The life limiting factors described above are predominantly independent of the loading of an LV Service wire asset. Derating would therefore be an ineffective strategy for reducing the risk profile for the asset class.

Additionally, operating these assets at a reduced capacity would involve imposing lower demand limits on customers which would increase customer risk and drive associated cost.

These assets are fundamental to customers' electricity import or export; therefore, retirement is not an option.

Retirement or de-rating are therefore not considered as economical or practical solutions to managing lifecycle risk associated with these assets.

3 Options Analysis

3.1 Options considered but rejected

The following options have been considered and rejected for the reasons described in Table 5 below.

Table 5: Options considered but rejected

Option Considered	Reason for rejection:
Off-grid Generation Solution: Installation of 6kVA of rooftop Solar generation, a residential battery and a backup diesel generator to provide an integrated off-grid supply solution. Initial capital cost: \$25k	Unit rate for an LV Service replacement is ~\$1k. This is 96% lower cost than an off-grid generation storage solution. Unlikely to be a feasible or scalable solution for all customers due to lack of roof-space and existing wiring arrangements. In addition, the maintenance costs for an off-grid supply solution are significantly higher than for an LV Service across the life of the asset.
In-Situ Repair: Repairing Components of LV service wires on failure.	The cost of repairing an LV Service or some of its components (e.g. Terminations) is not expected to be an efficient or effective method of remediating service failures or extending service life. Irrespective of the repair method, the most significant cost is labour to examine the faulted service, effect repairs or replacement, and carry out relevant testing, including polarity testing. Hence, the full replacement is likely to have a relatively similar or lower cost to a repair and provides a much more effective long-term solution, since all components are replaced. Additionally, some failure modes such as insulation degradation are unrepairable.
Replacement with Underground service	The use of an underground service replacement could mitigate risks of overhead service failures in future due to the lower exposure to some causes of failure (e.g. Ultraviolet (UV) degradation of overhead services). The cost to install underground services, mainly driven by civil works and footpath repairs, is prohibitive compared to the cost of overhead service replacement.

3.2 Identified options

3.2.1 Network options

Identified network options are as follows:

Option 1: Planned replacement program (proposed)

This option applies a targeted approach including condition-based replacements of 5309 / year (based on historical rates) plus a proactive replacement program of 8500 / year replacing known problematic service types. It should be noted that the proposed replacement cost in the 2020-25 period reflects lower unit costs of \$800 / service, based on the expected unit rate savings from larger volumes of planned works. The proactive program will allow for greater economies of scale through doing more work in a concentrated area, rather than an approach of responding piece-meal to a greater proportion of condition-based defects as has occurred in the past. The saving in the approach proposed for the future is approximately 8% compared to the historical unit cost. The total and per-year quantities and costs for this option are summarised in Table 6 below.

Table 6: Option 1 - Volumes and Costs

	20/21	21/22	22/23	23/24	24/25	Total Over 2020-25 period
Quantity	13,809	13,809	13,809	13,809	13,809	69,045
Cost (\$k)	11,047	11,047	11,047	11,047	11,047	55,236

Under this proposed approach the modelled service failures reduce steadily over a 10-year period from around 2,000 in 2020 to around 1,900 in 2030. While this is still a significant failure rate, this is complemented by the LV Safety program that further mitigates the safety risk through a neutral failure detection approach. The replacement program needs to be large enough to address the under-lying increasing failures and reverse the increasing trend irrespective of LV monitoring, otherwise the service failure rate will continue to rise into the future. This proposed replacement program is adequate to address the increasing failure trend. Ergon Energy believes that the option should be complemented by an LV Safety program, which is the subject of a separate business case.

3.2.2 Non-network options

Refer to Table 5 in section 3.1 of this report.

3.3 Economic analysis of identified options

3.3.1 Cost versus benefit assessment of each option

The Net Present Value (NPV) of each option has been determined by considering costs and benefits compared to the counterfactual over a 20-year period, discounted at the Regulated Real Pre-Tax Weighted Average Cost of Capital (WACC) rate of 2.62%, using EQL’s standard NPV analysis tool. Table 7 below contains the results of the NPV analysis of the identified options, outlining the Present Value (PV) of Costs and Benefits of each option, and the total NPV of each option. This table confirms that Option 1: Planned replacement program has an NPV benefit of \$21M compared to the counterfactual and is therefore the preferred option from an economic perspective.

Table 7: Summary of Net present value of options (20 year)

Option	NPV (\$M)	PV Costs (\$M)	PV Benefits (\$M)
Option 1: Planned replacement program – condition based plus proposed proactive quantities	\$21M	\$30M	\$51M

3.4 Scenario Analysis

3.4.1 Sensitivities

Identified material sensitivities and their corresponding impact on selection of the preferred option as well as the preferred option NPV have been identified in Table 8 below. The sensitivities tested include the Weibull parameters (failure rates), Cost of Consequence (CoC), and Probability of Severity (PoS). This shows that Option 1 remains the preferred option under 9 out of the 10 sensitivities tested. For the remaining one sensitivity, the counterfactual became the best NPV option. Based on this scenario analysis, Option 1 remains the preferred economic option.

Table 8: Sensitivity analysis.

Sensitivity	Baseline	Applied Parameter	Preferred Option	NPV of Preferred Option 1
Weibull β (Low)	3.5	3	Option 1	\$20M
Weibull β (High)		4	Option 1	\$19M
Weibull η (Low)	89	84	Option 1	\$30M
Weibull η (High)		94	Option 1	\$12M
LV service unit rate (Low)	\$800	\$600	Option 1	\$34M
LV service unit rate (High)		\$1000	Option 1	\$8M
CoC single fatality (Low)	\$49M	\$45M	Option 1	\$19M
CoC single fatality (High)		\$54M	Option 1	\$24M
PoS single fatality (Low)	0.094%	0.01%	Counterfactual	-\$6M
PoS single fatality (High)		0.15%	Option 1	\$39M

3.4.2 Value of regret analysis

In terms of selecting a decision pathway of ‘least regret’, Option 1 presents an economically efficient, balanced approach to investment by targeting replacement works based on asset criticality and assessed condition and reducing risk to the greatest extent without bringing forward unnecessary expenditure.

The key regret identified in this business case is the fatality of a customer through a service neutral failure. The economic value of this risk has been quantified as part of the analysis. Although Option 1 is the preferred approach based on the economic analysis, it is instructive to consider the impact of each option on the key regret scenario. The value of this key risk (cost of fatality) is shown for each option in Table 9.

Table 9: Risk Costs

Option	Fatality Risk Cost 2021 (\$M)	Fatality Risk Cost 2030 (\$M)	Total Fatality 2021-2030 Risk Cost (\$M)
Option 1: Planned replacement program – proposed quantities	9.6	9.3	91
Counterfactual: Planned replacement program – historical quantities	10.0	11.6	109

Option 1 produces the lowest risk cost in relation to fatality risk. It has an \$18M lower fatality risk cost over the 10-year period compared to the counterfactual. This makes Option 1 clearly the least regret option.

3.5 Qualitative comparison of identified options

3.5.1 Advantages and disadvantages of each option

Table 10 below details the advantages and disadvantages of each option considered.

Table 10: Assessment of options

Option	Advantages	Disadvantages
Option 1: Planned replacement program – condition based plus proactive quantities	<ul style="list-style-type: none"> • Provides safety and customer risk reduction benefits • Strong economic value when considering overall costs and benefits • Deliverable within resource constraints • Progressively removes known problematic assets from the population 	<ul style="list-style-type: none"> • Highest capital costs, but strong economic value when considering overall costs and benefits.
Counterfactual: Planned replacement program – condition based, historical volumes	<ul style="list-style-type: none"> • Deliverable within resource profiles 	<ul style="list-style-type: none"> • Risk reduction benefit lower than program cost • Known problematic assets may remain in service • Does not reduce safety risks adequately

3.5.2 Alignment with network development plan

The preferred option aligns with the Asset Management Objectives in the Distribution Annual Planning Report. In particular it manages risks, performance standards and asset investment to deliver balanced commercial outcomes while modernising the network to facilitate access to innovative technologies.

3.5.3 Alignment with future technology strategy

LV Services provide the link between a customer’s premises and the distribution network. The asset is therefore critical for the customer to export or import power from the network and derive the corresponding emerging value streams associated with grid connection, e.g.:

- Ability to participate in demand response incentive schemes
- Ability to export rooftop PV generated power into the grid
- Peer to peer energy trading with nearby energy prosumers
- Ability to participate in virtual power plant (VPP) platform in the future

By improving safety and quality of supply associated with LV Services, this business case supports the initiatives outlined in the Future Grid Roadmap and Intelligent Grid Technology Plan, enabling expanded customer interaction with the distribution network through distributed energy resources.

3.5.4 Risk Assessment Following Implementation of Proposed Option

Table 11 provides a semi-quantitative analysis of the risk reduction benefit for the preferred option.

Table 11: Semi-quantitative risk assessment showing risks mitigated following Implementation

Risk Scenario	Risk Type	Consequence (C)	Likelihood (L)	Risk Score	Risk Year
Due to degradation / corrosion, a service neutral is broken. A member of the public contacts an energised appliance in their house resulting in a single fatality due to electric shock.	Safety	(Original) 5 <i>(Single Fatality)</i>	3 <i>(Unlikely)</i>	15 <i>(Moderate)</i>	2025
		(Mitigated) 5 <i>(As above)</i>	2 <i>(Very unlikely)</i>	10 <i>(Low)</i>	
Due to corrosion, service wire losses mechanical strength and breaks. Fuse does not operate due to high impedance fault. Nearby member of the public physically contacting live mains resulting in single fatality due to electric shock.	Safety	(Original) 5 <i>(Single Fatality)</i>	3 <i>(Unlikely)</i>	15 <i>(Moderate)</i>	2025
		(Mitigated) 5 <i>(As above)</i>	2 <i>(Very unlikely)</i>	10 <i>(Low)</i>	
Due to corrosion, service wire losses mechanical strength and breaks. Loss of supply to customer premises while repairs are made.	Customer	(Original) 1 <i>(N/A)</i>	6 <i>(Almost Certain)</i>	6 <i>(Low)</i>	2025
		(Mitigated) 1 <i>(N/A)</i>	5 <i>(Very likely)</i>	5 <i>(Very Low)</i>	

The following figures provides a quantitative summary of the risk reduction benefit for Option 1. The total in each year represents the counterfactual level of risk as described above.

The green bar is the annual reduction risk following the implementation of the option. The red bar is the remaining total risk that Ergon would be accepting following implementation of the option. This residual risk will be further addressed in the LV Safety business case. Note these graphs assume that the volumes for Option 1 are carried through into the 2025-2030 regulatory period.




Figure 4: Ergon LV Service Lines - Risk Reduction Benefit Option 1

From the above chart the relative merits of Option 1 can be seen. Option 1 provides the optimal economic outcome plus a significantly improved risk reduction outcome compared to the counterfactual.

4 Recommendation

4.1 Preferred option

Based on the analysis contained in this report, the preferred option is Option 1: Planned replacement program – condition based plus proactive quantities.

4.2 Scope of preferred option

The scope of the preferred option is shown in Table 12.

Table 12: Proposed Option 1 - Volumes and Costs (\$18/19 real)

	20/21	21/22	22/23	23/24	24/25	Total Over 2020-25 period
Quantity	13,809	13,809	13,809	13,809	13,809	69,045
Cost (\$k)	11,047	11,047	11,047	11,047	11,047	55,236

The expenditure information in this business case is represented in the same manner as the Reset RIN Repex template. For example, if a project/program contains multiple assets (e.g. OH conductor, poles & pole top structures), the total expenditure is apportioned to respective RIN assets individually as per the Ergon Energy RIN expenditure allocation methodology.

Appendix A. References

Note: Documents which were included in Energy Queensland's original regulatory submission to the AER in January 2019 have their submission reference number shown in square brackets, e.g. Energy Queensland, *Corporate Strategy* [1.001], (31 January 2019).

AEMO, *Value of Customer Reliability Review, Final Report*, (September 2014).

Energy Queensland, *Asset Management Overview, Risk and Optimisation Strategy* [7.025], (31 January 2019).

Energy Queensland, *Asset Management Plan, Services* [7.040], (31 January 2019).

Energy Queensland, *Corporate Strategy* [1.001], (31 January 2019).

Energy Queensland, *Future Grid Roadmap* [7.054], (31 January 2019).

Energy Queensland, *Intelligent Grid Technology Plan* [7.056], (31 January 2019).

Energy Queensland, *Justification Statement – Services* [7.073], (31 January 2019).

Energy Queensland, *Low Voltage Network Monitoring Strategy* [7.080], (31 January 2019).

Energy Queensland, *Network Risk Framework*, (October 2018).

Ergon Energy, *Distribution Annual Planning Report (2018-19 to 2022-23)* [7.049], (21 December 2018).

Appendix B. Acronyms and Abbreviations

The following abbreviations and acronyms appear in this business case.

Abbreviation or acronym	Definition
\$M	Millions of dollars
\$k	Thousands of dollars
\$ nominal	These are nominal dollars of the day
\$ real 2019-20	These are dollar terms as at 30 June 2020
2020-25 regulatory control period	The regulatory control period commencing 1 July 2020 and ending 30 Jun 2025
AEMC	Australian Energy Market Commission
AEMO	Australian Energy Market Operator
AER	Australian Energy Regulator
AMP	Asset Management Plan
Augex	Augmentation Capital Expenditure
BAU	Business as Usual
CAPEX	Capital expenditure
CoC	Cost of Consequence
Current regulatory control period or current period	Regulatory control period 1 July 2015 to 30 June 2020
DAPR	Distribution Annual Planning Report
DC	Direct Current
DNSP	Distribution Network Service Provider
EQL	Energy Queensland Ltd
IT	Information Technology
KRA	Key Result Areas
kVA	Kilovolt Amperes
LV	Low Voltage
MSS	Minimum Service Standard
NEL	National Electricity Law
NEM	National Electricity Market
NEO	National Electricity Objective
NER	National Electricity Rules (or Rules)
Next regulatory control period or forecast period	The regulatory control period commencing 1 July 2020 and ending 30 Jun 2025
NPV	Net Present Value
OH	Overhead

Abbreviation or acronym	Definition
OPEX	Operational Expenditure
PCBU	Person in Control of a Business or Undertaking
PoS	Probability of Severity
Previous regulatory control period or previous period	Regulatory control period 1 July 2010 to 30 June 2015
PV	Present Value
Repex	Replacement Capital Expenditure
RIN	Regulatory Information Notice
RIT-D	Regulatory Investment Test – Distribution
RTS	Return to Service
SAIDI	System Average Interruption Duration Index
SAIFI	System Average Interruption Frequency Index
SAMP	Strategic Asset Management Plan
SCADA	Supervisory Control and Data Acquisition
SFAIRP	So Far as Is Reasonably Practicable
UV	Ultraviolet
VCR	Value of Customer Reliability
VPP	Virtual Power Plant
WACC	Weighted average cost of capital

Appendix C. Alignment with the National Electricity Rules (NER)

The table below details the alignment of this proposal with the NER capital expenditure requirements as set out in Clause 6.5.7 of the NER.

Table 13: Alignment with NER

Capital Expenditure Requirements	Rationale
<p>6.5.7 (a) (2) The forecast capital expenditure is required in order to comply with all applicable regulatory obligations or requirements associated with the provision of standard control services</p>	<p>Pursuant to the Electrical Safety Act 2002, as a person in control of a business or undertaking (PCBU), Ergon Energy has an obligation to ensure that its works are electrically safe and are operated in a way that is electrically safe.³ This duty also extends to ensuring the electrical safety of all persons and property likely to be affected by the electrical work.⁴ This proposal addresses Ergon's key obligation in relation to ensuring that its works are electrically safe SFAIRP.</p>
<p>6.5.7 (a) (3) The forecast capital expenditure is required in order to: (iii) maintain the quality, reliability and security of supply of supply of standard control services (iv) maintain the reliability and security of the distribution system through the supply of standard control services</p>	<p>While the primary purpose of this program is the delivery of safe outcomes for customers, it does also address reliability issues associated with service failures.</p>
<p>6.5.7 (a) (4) The forecast capital expenditure is required in order to maintain the safety of the distribution system through the supply of standard control services.</p>	<p>Pursuant to the Electrical Safety Act 2002, as a person in control of a business or undertaking (PCBU), Ergon Energy has an obligation to ensure that its works are electrically safe and are operated in a way that is electrically safe. This duty also extends to ensuring the electrical safety of all persons and property likely to be affected by the electrical work. This proposal addresses Ergon's key obligation in relation to ensuring that its works are electrically safe SFAIRP.</p>
<p>6.5.7 (c) (1) (i) The forecast capital expenditure reasonably reflects the efficient costs of achieving the capital expenditure objectives</p>	<p>The Unit Cost Methodology and Estimation Approach sets out how the estimation system is used to develop project and program estimates based on specific material, labour and contract resources required to deliver a scope of work. The consistent use of the estimation system is essential in producing an efficient CAPEX forecast by enabling:</p> <ul style="list-style-type: none"> • Option analysis to determine preferred solutions to network constraints • Strategic forecasting of material, labour and contract resources to ensure deliverability • Effective management of project costs throughout the program and project lifecycle, and • Effective performance monitoring to ensure the program of work is being delivered effectively. <p>The unit costs that underpin our forecast have also been independently reviewed to ensure that they are efficient (Attachments 7.004 and 7.005 to the January 2019 regulatory proposal).</p>

³ Section 29, *Electrical Safety Act 2002*

⁴ Section 30 *Electrical Safety Act 2002*

Capital Expenditure Requirements	Rationale
<p>6.5.7 (c) (1) (ii) The forecast capital expenditure reasonably reflects a realistic expectation of the demand forecast and cost inputs required to achieve the capital expenditure objectives</p>	<p>The prudence of this proposal is demonstrated through the options analysis conducted and the quantification of risk and benefits of each option.</p> <p>The prudence of our CAPEX forecast is demonstrated through the application of our common frameworks put in place to effectively manage investment, risk, optimisation and governance of the Network Program of Work. An overview of these frameworks is set out in our Asset Management Overview, Risk and Optimisation Strategy (Attachment 7.026 to the January 2019 regulatory proposal).</p>

Appendix D. Mapping of Asset Management Objectives to Corporate Plan

This proposal has been developed in accordance with our Strategic Asset Management Plan. Our Strategic Asset Management Plan (SAMP) sets out how we apply the principles of Asset Management stated in our Asset Management Policy to achieve our Strategic Objectives.

Table 1: “Asset Function and Strategic Alignment” in Section 1.4 details how this proposal contributes to the Asset Management Objectives.

The Table below provides the linkage of the Asset Management Objectives to the Strategic Objectives as set out in our Corporate Plan (Supporting document 1.001 to our Regulatory Proposal as submitted in January 2019).

Table 14: Alignment of Corporate and Asset Management objectives

Asset Management Objectives	Mapping to Corporate Plan Strategic Objectives
Ensure network safety for staff contractors and the community	<p>EFFICIENCY <i>Operate safely as an efficient and effective organisation</i> Continue to build a strong safety culture across the business and empower and develop our people while delivering safe, reliable and efficient operations.</p>
Meet customer and stakeholder expectations	<p>COMMUNITY AND CUSTOMERS <i>Be Community and customer focused</i> Maintain and deepen our communities’ trust by delivering on our promises, keeping the lights on and delivering an exceptional customer experience every time</p>
Manage risk, performance standards and asset investments to deliver balanced commercial outcomes	<p>GROWTH <i>Strengthen and grow from our core</i> Leverage our portfolio business, strive for continuous improvement and work together to shape energy use and improve the utilisation of our assets.</p>
Develop Asset Management capability & align practices to the global standard (ISO55000)	<p>EFFICIENCY <i>Operate safely as an efficient and effective organisation</i> Continue to build a strong safety culture across the business and empower and develop our people while delivering safe, reliable and efficient operations.</p>
Modernise the network and facilitate access to innovative energy technologies	<p>INNOVATION <i>Create value through innovation</i> Be bold and creative, willing to try new ways of working and deliver new energy services that fulfil the unique needs of our communities and customers.</p>

Appendix E. Risk Tolerability Table

Network Risks - Risk Tolerability Criteria and Action Requirements			
Risk Score	Risk Descriptor	Risk Tolerability Criteria and Action Requirements	
30 – 36	Intolerable (stop exposure immediately)		
24 – 29	Very High Risk	<p>*ALARP Risk in this range managed to As Low As Reasonably Practicable</p>	
18 – 23	High Risk		
11 – 17	Moderate Risk		
6 – 10	Low Risk		
1 to 5	Very Low Risk		
			<p>SFAIRP Risks in this area to be mitigated So Far as is Reasonably Practicable</p>
		<p>Executive Approval (required for continued risk exposure at this level)</p>	<p>May require a full Quantitative Risk Assessment (QRA) Introduce new or changed risk treatments to reduce level of risk Periodic review of the risk and effectiveness of the existing risk treatments</p>
		<p>Divisional Manager Approval (required for continued risk exposure at this level)</p>	<p>Introduce new or changed risk treatments to reduce level of risk Periodic review of the risk and effectiveness of the existing risk treatments</p>
		<p>Group Manager / Process Owner Approval (required for continued risk exposure at this level)</p>	<p>Introduce new or changed risk controls or risk treatments as justified to further reduce risk Periodic review of the risk and effectiveness of the existing risk treatments</p>
		<p>No direct approval required but evidence of ongoing monitoring and management is required</p>	<p><i>Periodic review of the risk and effectiveness of the existing risk treatments</i></p>

Figure 5: A Risk Tolerability Scale for evaluating Semi-Quantitative risk score

Appendix F. Quantitative Risk Assessment Details

Asset Class Data Input			
		Description/Justification	Source
Asset Class	Ergon LV Services	-	-
Asset Median Life (years)	80.2	Calculated from Weibull parameters	-
NPV Period (years)	20	-	-
Historical Unit Rate (\$)	866	Average historical expenditure within the 2015-2020 regulatory period.	Attachment 7.073 of our initial regulatory proposal.
Forecasted Unit Rate (\$)	800	A lower unit rate is used when calculating the cost of the proposed replacements within the 2020-2025 regulatory period. Based on bulk replacements in coastal towns reducing the above historical unit rate.	As agreed with EQL.

Age Profile and Replacements			
		Description/Justification	Source
Total Population	397,633	Total amount of LV services owned by Ergon.	Attachment 7.040 of our initial regulatory proposal.
Replacements - Counterfactual	5,309	Average historical annual replacements within the 2015-2020 regulatory period.	Attachment 7.073 of our initial regulatory proposal.
Replacements - Option 1	13,809	Forecasted annual replacements within the 2020-2025 regulatory period.	Attachment 7.073 of our initial regulatory proposal.
Replacements - Option 2	-	Spare	-



Safety Risk Inputs				
Consequence	Monetisation (\$)	Disproportionality Factor	Description/Justification	Source
Single Fatality	4,900,000	10	Cost of a single fatality scaled by factor of 10.	¹ The sources used to develop the Disproportionality Factors are as follows:
Single Series Injury	490,000	8	Cost of a single serious injury scaled by a factor of 8.	Ausgrid - Revised Proposal - Attachment 5.13.M.4 - Low Voltage Overhead Service Lines program CBA summary - January 2019
Fire	66,000	4	Cost of a fire scaled by a factor of 4.	https://www.pmc.gov.au/sites/default/files/publications/value-of-statistical-life-guidance-note_0_0.pdf
Emergency Response	1,750	1	Cost of an emergency response scaled by a factor of 1 as the DF is not relevant to this consequence.	https://www.hse.gov.uk/risk/theory/alarpcba.htm

¹ Disproportionality factors are applied to the consequence monetisation to offset the gross disproportion (perceived point at which the cost of implementing a safety measure exceeds its expected benefits). The above factors are based on a review of peer organisations, as well as other industries, to identify a single factor within the approximate median of the range of factors identified in the review.

Customer Risk Inputs				
			Description/Justification	Source
Residential	VCR (\$/MWH)	25,420	The value different types of customers place on having reliable electricity supplies under different conditions. Determined from survey results conducted by AEMO.	AEMO Value of Customer Reliability Fact Sheet
	Load (MVA)	0.0035	Load lost per residential LV service failure. Typical ADMD for a residential customer.	Based on EQL planning information.
	Hrs to restore	3	Time taken to get a failed residential LV service operating as usual. Based on typical travel and labour involved with residential customers.	As agreed with EQL.
	Power Factor	0.85	The ratio which determines the real power used by EQL residential customers. Based on the typical uncompensated power factor for an EQL zone substation.	EQL 2018 DAPR – typical values
	Load Factor	0.2	A ratio of average load to peak load within a specific time. Acts as a measure of EQL's utilisation rate. Conservative value based on typical values for EQL residential load profiles.	As agreed with EQL.
	Percentage of Mix	88%	Percentage of EQL customers who are considered as residential loads. Based on the approximate mix of residential versus commercial customers in the EQL network as informed by customer type information.	As agreed with EQL.
Commercial	VCR (\$/MWH)	44,390	The value different types of customers place on having reliable electricity supplies under different conditions. Determined from survey results conducted by AEMO.	AEMO Value of Customer Reliability Fact Sheet
	Load (MVA)	0.0065	Load lost per commercial LV service failure. Typical ADMD for a commercial customer.	Based on EQL planning information.
	Hrs to restore	4	Time taken to get a failed commercial LV service operating as usual. Based on typical travel and labour involved with commercial customers.	As agreed with EQL.
	Power Factor	0.85	The ratio which determines the real power used by EQL commercial customers. Based on the typical uncompensated power factor for an EQL zone substation.	EQL 2018 DAPR – typical values
	Load Factor	0.6	A ratio of average load to peak load within a specific time. Acts as a measure of EQL's utilisation rate. Conservative value based on typical values for EQL commercial load profiles.	As agreed with EQL.
	Percentage of Mix	12%	Percentage of EQL customers who are considered as commercial loads. Based on the approximate mix of residential versus commercial customers in the EQ network as informed by customer type information.	As agreed with EQL.

Incident Conversion Rate (ICR) & Probability of Consequence (PoC)						
ICR		PoC			Description/Justification	Source
Consequence	Incidents Attr. to Cons.	Category	Risk Scale	Probability of Severity		
Single Fatality	180	Safety	5	0.09%	ICR - Based on an average 180 annual shock incidents involved with LV Services. PoC - Calibrated to represent the historically expected 1 fatality every 5 years.	ICR – Attachment 7.040 of our initial regulatory proposal. PoC – Input data provided by EQL.
Major Injury	180	Safety	4	0.23%	ICR - Based on an average 180 annual shock incidents involved with LV services. PoC - Calibrated to represent the historically expected 1 major injury every 4 years.	ICR – Attachment 7.040 of our initial regulatory proposal. PoC – Input data provided by EQL.
Fire	20	Fire	2	20%	ICR – 1% of incidents are attributed to fire. Calibrated based on the expected costs involved with fire risks relative to costs involved with safety in the case of LV Services. PoC - 20% of incidents result in a fire. Based on the severity of the consequence being considered as minor to moderate.	ICR – As agreed with EQL. PoC - Assumed based on EQL and peer organisation industry experience.
Customer Outage	1700	Customer	1	100%	ICR – Assumes that 100% of incidents are attributed to a customer outage. PoC - 100% of incidents result in a customer outage. Based on customers not having a redundant supply.	ICR - Assumed based on EQL and peer organisation industry experience. PoC - Assumed based on EQL and peer organisation industry experience.
Emergency Response	1700	Other	1	100%	ICR - 100% of incidents are attributed to emergency response PoC - 100% of incidents result in an emergency response.	ICR - Assumed based on EQL and peer organisation industry experience. PoC - Assumed based on EQL and peer organisation industry experience.
Total No. of Incidents	1700	-	-	-	Based on known LV Service failures within the 2017/2018 period.	Attachment 7.040 of our initial regulatory proposal.

Statistical Calibration			
Reliability Model Used		Description/Justification	Source
Shape parameter (β)	Weibull	Weibull parameters are calibrated to project the trend in historical failures as shown in the below charts.	Attachment 7.040 of our initial regulatory proposal
Characteristic life (η)	3.5		
Guaranteed Min Life (γ)	89		
	0	Modelled failures are less than the projected historical failures, this is conservative.	



Appendix G. Reconciliation Table

Reconciliation Table	
Conversion from \$18/19 to \$2020	
Business Case Value	
(M\$18/19)	\$55.20
Business Case Value	
(M\$2020)	\$57.61