

STRATEGY

JEM AM ELECTRICITY DISTRIBUTION ASSET CLASS STRATEGY

ELE AM PL 0060

Revision Number: 4.0

Revision Date: 31/01/2020

AUTHORISATION

REVIEWED BY

Name	Job Title	Signature	Date
	Asset Analytics and Programs Manager		27/11/2019

Approved by

Name	Job Title	Signature	Date
	General Manager Asset Management Electricity Distribution		27/11/2019

INTERNAL

© Jemena Limited. All rights reserved. Copyright in the whole or every part of this document belongs to Jemena Limited, and cannot be used, transferred, copied or reproduced in whole or in part in any manner or form or in any media to any person other than with the prior written consent of Jemena.

Printed or downloaded copies of this document are deemed uncontrolled

DOCUMENT HISTORY

Revision	Date	Author	Description of Changes
1.0	20/07/2018		First review incorporating new template.
2.0	30/10/2018		Review asset failure modes, asset information and expenditure.
3.0	21/08/2019		General review, asset data, performance statistics and forecast expenditure update.
4.0	20/12/2019		Updated Executive Summary

OWNING FUNCTIONAL GROUP & DEPARTMENT / TEAM

Asset Management: Asset Management Electricity Distribution : Asset Analytics and Programs

REVIEW DETAILS

Review Period:	Annual
Next Review Due:	November 2020

TABLE OF CONTENTS

Executive Summary	11
1 Introduction.....	12
1.1 Purpose.....	13
1.2 Asset Management System.....	14
1.3 Description of Assets Covered	15
1.4 Governance	16
1.4.1 Approval and communications	16
1.4.2 Responsibilities.....	16
2 Strategic Drivers	17
2.1 Growth.....	17
2.2 Stakeholders.....	18
2.2.1 Customers	18
2.2.2 Shareholders	18
2.2.3 Internal.....	18
2.3 Regulatory and Legislative.....	19
3 Asset Objectives.....	20
4 Sub-Asset Class Strategies.....	21
4.1 Poles Sub-Asset Class.....	21
4.1.1 Introduction	21
4.1.2 Asset Profile	22
4.1.2.1 Life Expectancy.....	22
4.1.2.2 Age Profile.....	27
4.1.2.3 Utilisation	31
4.1.3 Performance.....	33
4.1.3.1 Requirements.....	33
4.1.3.2 Assessment.....	35
4.1.4 Risk.....	41
4.1.4.1 Criticality	41
4.1.4.2 Failure Modes.....	41
4.1.4.3 Current Risks	42
4.1.4.4 Existing Controls	44
4.1.4.5 Future and Emerging Risks	44
4.1.5 Life Cycle Management	44
4.1.5.1 Creation.....	45
4.1.5.2 Asset Operation and Maintenance	45
4.1.5.3 Asset Replacement	50
4.1.5.4 Asset disposal.....	51
4.1.5.5 Spares	51
4.1.6 Information	51
4.2 Pole Top Structures Sub-Asset Class.....	56
4.2.1 Introduction	56
4.2.2 Asset Profile	56
4.2.2.1 Life Expectancy.....	56
4.2.2.2 Age Profile.....	57

4.2.2.3	Utilisation	58
4.2.3	Performance.....	58
4.2.3.1	Requirements.....	58
4.2.3.2	Assessment.....	60
4.2.4	Risk.....	67
4.2.4.1	Criticality	67
4.2.4.2	Failure modes.....	67
4.2.4.3	Current Risks	67
4.2.4.4	Existing Controls	68
4.2.4.5	Future Risks	69
4.2.5	Life Cycle Management	69
4.2.5.1	Creation.....	70
4.2.5.2	Asset Operation and Maintenance	70
4.2.5.3	Asset Replacement	72
4.2.5.4	Asset Disposal.....	73
4.2.5.5	Spares	73
4.2.6	Information	73
4.3	<i>Conductors and Connectors Sub-Asset Class.....</i>	77
4.3.1	Introduction	77
4.3.1.1	Conductors	77
4.3.1.2	Connectors	78
4.3.2	Asset Profile	78
4.3.2.1	Life Expectancy.....	78
4.3.2.2	Age Profile.....	79
4.3.2.3	Utilisation	80
4.3.3	Performance.....	81
4.3.3.1	Requirements.....	81
4.3.3.2	Assessment.....	82
4.3.4	Risk.....	83
4.3.4.1	Criticality	83
4.3.4.2	Failure Modes.....	84
4.3.4.3	Current Risks	85
4.3.4.4	Existing Controls	86
4.3.4.5	Future Risks and Opportunities	86
4.3.5	LifeCycle Management	86
4.3.5.1	Creation.....	87
4.3.5.2	Asset Operation and Maintenance	87
4.3.5.3	Asset Replacement	89
4.3.5.4	Asset Disposal.....	91
4.3.5.5	Spares	91
4.3.6	Information	91
4.4	<i>Underground Distribution Systems Sub-Asset Class.....</i>	95
4.4.1	Introduction	95
4.4.2	Asset Profile	95
4.4.2.1	Life Expectancy.....	95
4.4.2.2	Age Profile.....	96
4.4.2.3	Utilisation	98
4.4.3	Performance.....	100

4.4.3.1	Requirements	100
4.4.3.2	Assessment	100
4.4.4	Risk	101
4.4.4.1	Criticality	101
4.4.4.2	Failure Modes	102
4.4.4.3	Current Risks	102
4.4.4.4	Existing Controls	104
4.4.4.5	Future Risks and Opportunities	105
4.4.5	Life Cycle Management	106
4.4.5.1	Creation	106
4.4.5.2	Asset Operation and Maintenance	106
4.4.5.3	Underground Distribution System Forecast Replacement Volumes	109
4.4.5.4	Asset Disposal	109
4.4.5.5	Spares	109
4.4.6	Information	109
4.5	<i>Pole Type Transformers Sub-Asset Class</i>	113
4.5.1	Introduction	113
4.5.2	Asset Profile	113
4.5.2.1	Life Expectancy	113
4.5.2.2	Age Profile	113
4.5.2.3	Utilisation	114
4.5.3	Performance	115
4.5.3.1	Requirements	115
4.5.3.2	Assessment	115
4.5.4	Risk	120
4.5.4.1	Criticality	120
4.5.4.2	Failure Modes	120
4.5.4.3	Current Risks	121
4.5.4.4	Existing Controls	121
4.5.4.5	Future Risks	122
4.5.5	Life Cycle Management	123
4.5.5.1	Creation	123
4.5.5.2	Asset Operation and Maintenance	124
4.5.5.3	Pole Type Transformer Forecast Replacement Volumes	126
4.5.5.4	Asset Disposal	126
4.5.5.5	Spares	126
4.5.6	Information	127
4.6	<i>Non-Pole Type Distribution Substations Sub-Asset Class</i>	132
4.6.1	Introduction	132
4.6.2	Asset Profile	133
4.6.2.1	Life Expectancy	133
4.6.2.2	Age Profile	133
4.6.2.3	Utilisation	135
4.6.3	Performance	136
4.6.3.1	Requirements	136
4.6.3.2	Assessment	137
4.6.4	Risk	143
4.6.4.1	Criticality	143

4.6.4.2	Failure Modes.....	144
4.6.4.3	Current Risks	144
4.6.4.4	Existing Controls	146
4.6.4.5	Future Risks	147
4.6.5	Life Cycle Management	148
4.6.5.1	Creation.....	148
4.6.5.2	Asset Operation and Maintenance	150
4.6.5.3	Non-Pole Type Transformer Forecast Replacement Volumes.....	154
4.6.5.4	Asset Disposal.....	154
4.6.5.5	Spares	154
4.6.6	Information	155
4.7	<i>Overhead Line Switchgear Sub-Asset Class.....</i>	<i>158</i>
4.7.1	Introduction	158
4.7.2	Asset profile	158
4.7.2.1	Life Expectancy.....	158
4.7.2.2	Age Profile.....	159
4.7.2.3	Utilisation.....	159
4.7.3	Performance.....	159
4.7.3.1	Requirements.....	159
4.7.3.2	Assessment.....	160
4.7.4	Risk.....	164
4.7.4.1	Criticality	164
4.7.4.2	Failure Modes.....	164
4.7.4.3	Current Risks	165
4.7.4.4	Existing Controls	165
4.7.4.5	Future Risks	166
4.7.5	Life Cycle Management	166
4.7.5.1	Creation.....	166
4.7.5.2	Asset Operation and Maintenance	167
4.7.5.3	Asset Replacement	169
4.7.5.4	Asset Disposal.....	170
4.7.5.5	Spares	170
4.7.6	Information	170
4.8	<i>LV Overhead Services Sub-Asset Class</i>	<i>174</i>
4.8.1	Introduction	174
4.8.2	Asset Profile	174
4.8.2.1	Life Expectancy.....	174
4.8.2.2	Age Profile.....	174
4.8.2.3	Utilisation.....	175
4.8.3	Performance.....	175
4.8.3.1	Requirements.....	175
4.8.3.2	Assessment.....	175
4.8.4	Risk.....	176
4.8.4.1	Criticality	176
4.8.4.2	Failure Modes.....	176
4.8.4.3	Current Risks	177
4.8.4.4	Existing Controls	178
4.8.4.5	Future Risks and improvements	178

4.8.5	Life Cycle Management	179
4.8.5.1	Creation.....	179
4.8.5.2	Asset Operation and Maintenance	179
4.8.5.3	Asset Replacement	181
4.8.5.4	Asset Disposal.....	182
4.8.5.5	Spares	182
4.8.6	Information	182
4.9	<i>Public Lighting Sub-Asset Class</i>	185
4.9.1	Introduction	185
4.9.2	Asset profile	185
4.9.2.1	Life Expectancy.....	185
4.9.2.2	Age Profile	186
4.9.2.3	Utilisation	186
4.9.3	Performance.....	187
4.9.3.1	Requirements	187
4.9.3.2	Assessment.....	188
4.9.4	Risk.....	190
4.9.4.1	Criticality	190
4.9.4.2	Failure Modes.....	190
4.9.4.3	Current Risks	191
4.9.4.4	Existing Controls	191
4.9.4.5	Future Risks and Opportunities	191
4.9.5	Life Cycle Management	192
4.9.5.1	Creation.....	192
4.9.5.2	Asset Operation and Maintenance	192
4.9.5.3	Asset Replacement	195
4.9.5.4	Asset Retirement and Disposal.....	198
4.9.5.5	Spares	198
4.9.6	Information	199
4.10	<i>Earthing Sub-Asset Class</i>	202
4.10.1	Introduction	202
4.10.2	Asset Profile	203
4.10.2.1	Life Expectancy	203
4.10.2.2	Age Profile	203
4.10.2.3	Utilisation	204
4.10.3	Performance.....	204
4.10.3.1	Requirements	204
4.10.3.2	Assessment.....	206
4.10.4	Risk.....	206
4.10.4.1	Criticality.....	206
4.10.4.2	Failure Modes	206
4.10.4.3	Current Risks.....	206
4.10.4.4	Existing Controls	207
4.10.4.5	Future Risks	207
4.10.5	Life Cycle Management	207
4.10.5.1	Creation.....	208
4.10.5.2	Asset Operation and Maintenance	208
4.10.5.3	Asset Replacement.....	209

4.10.5.4	Earthing Systems Forecast Replacement Volumes	209
4.10.5.5	Asset Disposal	210
4.10.5.6	Spares.....	210
4.10.6	Information	210
4.11	<i>High Voltage Outdoor Overhead Fuse Sub-Asset Class.....</i>	<i>213</i>
4.11.1	Introduction	213
4.11.2	Asset profile	213
4.11.2.1	Life Expectancy	213
4.11.2.2	Age Profile	213
4.11.2.3	Utilisation	214
4.11.3	Performance.....	216
4.11.3.1	Requirements	216
4.11.3.2	Assessment.....	216
4.11.4	Risk.....	216
4.11.4.1	Criticality.....	216
4.11.4.2	Failure Modes.....	217
4.11.4.3	Current Risks.....	217
4.11.4.4	Existing Control.....	217
4.11.4.5	Future Risks	217
4.11.5	Life Cycle Management	217
4.11.5.1	Creation.....	218
4.11.5.2	Asset Operation and Maintenance	218
4.11.5.3	Disposal	220
4.11.5.4	Spares.....	220
4.11.6	Information	220
4.12	<i>Distribution Surge Arresters Sub-Asset Class.....</i>	<i>224</i>
4.12.1	Introduction	224
4.12.2	Asset Profile	224
4.12.2.1	Life Expectancy	224
4.12.2.2	Age Profile	224
4.12.2.3	Utilisation	225
4.12.3	Performance.....	226
4.12.3.1	Requirements	226
4.12.3.2	Assessment.....	227
4.12.4	Risk.....	228
4.12.4.1	Criticality.....	228
4.12.4.2	Failure Modes.....	228
4.12.4.3	Current Risks.....	229
4.12.4.4	Existing Control.....	229
4.12.4.5	Future Risks	229
4.12.5	Life Cycle Management	230
4.12.5.1	Creation.....	230
4.12.5.2	Asset Operation and Maintenance	230
4.12.5.3	Surge Arrester Forecast Replacement Volumes	233
4.12.5.4	Disposal	234
4.12.5.5	Spares.....	234
4.12.6	Information	234
4.13	<i>Automatic Circuit Reclosers Sub-Asset Class</i>	<i>237</i>

4.13.1	Introduction	237
4.13.2	Asset Profile	237
4.13.2.1	Life Expectancy	237
4.13.2.2	Age Profile	238
4.13.2.3	Utilisation	238
4.13.3	Performance.....	239
4.13.3.1	Requirements	239
4.13.3.2	Assessment.....	239
4.13.4	Risk.....	241
4.13.4.1	Criticality.....	241
4.13.4.2	Failure Modes	241
4.13.4.3	Current Risks.....	242
4.13.4.4	Existing Control	242
4.13.4.5	Future Risks	242
4.13.5	Life Cycle Management	243
4.13.5.1	Creation.....	243
4.13.5.2	Asset Operation and Maintenance	243
4.13.5.3	ACR Forecast Replacement Volumes	244
4.13.5.4	Asset Disposal	244
4.13.5.5	Spares.....	245
4.13.6	Information	245
5	Consolidated Plan	248
5.1	<i>Capital Forecast.....</i>	<i>249</i>
5.1.1	Poles Sub-Asset Class.....	249
5.1.2	Pole Top Structures Sub-Asset Class.....	250
5.1.3	Conductors and Connectors Sub-Asset Class	251
5.1.4	Underground Distribution Systems Sub-Asset Class	253
5.1.5	Pole Type Transformers Sub-Asset Class	254
5.1.6	Non-Pole Type Distribution Substations Sub-Asset Class	255
5.1.7	Overhead Line Switchgear Sub-Asset Class	256
5.1.8	Low Voltage Overhead Services Sub-Asset Class	258
5.1.9	Public Lighting Sub-Asset Class	258
5.1.10	Earthing Systems Sub-Asset Class	259
5.1.11	High Voltage Outdoor Overhead Fuses Sub-Asset Class.....	260
5.1.12	Distribution Surge Arresters Sub-Asset Class.....	261
5.1.13	Automatic Circuit Reclosers Sub-Asset Class	261
5.2	<i>Operating and Maintenance Forecast.....</i>	<i>263</i>
5.2.1	Poles Sub-Asset Class.....	264
5.2.2	Pole Top Structures Sub-Asset Class.....	265
5.2.3	Conductors and Connectors Sub-Asset Class	265
5.2.4	Underground Distribution Systems Sub-Asset Class	267
5.2.5	Pole Type Transformers Sub-Asset Class	268
5.2.6	Non-Pole Type Distribution Substations Sub-Asset Class	268
5.2.7	Overhead Line Switchgear Sub-Asset Class	269
5.2.8	Low Voltage Overhead Services Sub-Asset Class	270
5.2.9	Public Lighting Sub-Asset Class	271

5.2.10	Earthing Systems Sub-Asset Class	271
5.2.11	High Voltage Outdoor Overhead Fuses Sub-Asset Class.....	271
5.2.12	Distribution Surge Arresters Sub-Asset Class.....	272
5.2.13	Automatic Circuit Reclosers Sub-Asset Class	273
6	Glossary	274
6.1	<i>Zone substation abbreviations</i>	<i>274</i>
6.2	<i>Acronyms</i>	<i>275</i>
6.3	<i>Terms and definitions</i>	<i>277</i>
7	Appendices	278
7.1	<i>Appendix A – Asset Criticality Assessment.....</i>	<i>278</i>
7.2	<i>Appendix B - Asset objectives KPI alignment</i>	<i>281</i>

EXECUTIVE SUMMARY


Jemena Electricity Networks (JEN) in Victoria has an Asset Management System (AMS) that contains a set of four Asset Class Strategy (ACS) documents. The ACSs are hierarchically governed by the Asset Business Strategy (ABS) of the AMS.

This ACS document pertains to Electricity Distribution Assets, a term that is used to describe assets downstream of zone substations (ie current carrying components and their associated supporting structures).

The first three sections of this ACS are generic to all the ACS documents. The fourth section is where Electricity Distribution is unpacked and divided into sub-asset classes

- Poles
- Pole top structures (crossarms)
- Conductors and connectors
- Underground distribution systems
- Pole type transformers
- Non-pole type distribution substations
- Overhead line switchgear
- LV overhead services
- Public lighting
- Earthing systems
- HV outdoor overhead fuses
- Distribution surge arrestors
- Automatic circuit reclosers

All of the documented asset management strategies outlined in this document focus on keeping the probability of asset failure at a low level. This means using CBRM to forecast end-of-life asset replacement scenarios before serious failures occur. In line with standard risk assessment methodologies, asset functional failure is assessed based on a combination of probability and consequence. Should an asset failure occur, the consequence is dependent on where the asset is positioned in the network configuration and the number of customers it supplies. In the case of electricity distribution assets, failures will usually result in customer interruption. In addition to customer interruption, safety and regulatory consequences are figural.



There are four ACS documents incorporated into JEN's Asset Management System

CAPEX \$000	2020	2021	2022	2023	2024	2025	2026
Totals	21,533	24,834	25,879	25,917	26,663	26,807	26,581

CapEx and
OpEx
forecasts

OPEX \$000	2020	2021	2022	2023	2024	2025	2026
Totals	12,462	12,277	12,569	12,867	13,173	13,485	13,794


1 INTRODUCTION

This Asset Class Strategy (ACS) covers the Jemena Electricity Networks (JEN) distribution asset class and outlines the methods employed, analysis undertaken and actions to be taken to optimally manage the assets. The document serves as both an internal document to prescribe the management of the distribution asset class but also to support expenditure proposals as part of JEN's electricity distribution price reset (EDPR) submission process.

Within JEN's Investment Framework and Asset Business Strategy (ABS), asset life cycles are considered in terms of creation (acquisition), maintenance or replacement, as applicable, and disposal. Investment recommendations are made by analysing asset condition and age profiling.

There are four Asset Class Strategy (ACS) documents. Each ACS outlines performance measures and objectives which are used to attain key performance targets. This gives visibility to the performance of the asset and, in turn, informs investment decision making.

Figure 1-1 - There are four ACS documents incorporated into JEN's Asset Management System



The distribution assets in this ACS are categorised into the following sub-asset classes located in the following sections of this document:

- 4.1 Poles
- 4.2 Pole top structures (crossarms)
- 4.3 Conductors and connectors
- 4.4 Underground distribution systems
- 4.5 Pole type transformers
- 4.6 Non-pole type distribution substations
- 4.7 Overhead line switchgear
- 4.8 LV overhead services
- 4.9 Public lighting
- 4.10 Earthing systems
- 4.11 HV outdoor overhead fuses
- 4.12 Distribution surge arrestors
- 4.13 Automatic circuit reclosers

1.1 PURPOSE

The purpose of the Electricity Distribution Asset Class Strategy is to document the practical approach that supports the delivery of asset management objectives set out in the JEN's ABS.

This ACS is based on key information about each sub-asset (including risk, performance, life cycle management, capital expenditure and operational expenditure). Based on this information, this ACS contributes to short, medium and long-term planning.


This distribution ACS addresses:

- Distribution asset management practices alignment with the ABS;
- Sub-asset risk causes and consequences;
- Sub-asset performance against objectives, drivers, and service levels;
- Asset condition, along with relative cost considerations, are the primary drivers in making asset maintenance versus asset replacement decisions; and
- Risk weighted decision-making and financial estimates used to inform Operating Expenditure (OPEX) and Capital Expenditure (CAPEX) planning

1.2 ASSET MANAGEMENT SYSTEM

The ACS documents reside in JEN's Asset Management System (AMS) and create a line of sight between the Business Plan and JEN's ABS through to the associated Asset Investment Plan (AIP). Each ACS ensures that the performance, risks and cost of each asset class are analysed and optimum plans developed to align with the Business Plan.

Figure 1-2 – JEN's Asset Management System



1.3 DESCRIPTION OF ASSETS COVERED

Figure 1-3 – JEN's geographical footprint



The distribution assets are comprised of:

- Approximately 111,000 poles which are classified into four main groups (categories) based on the voltage of the lines being supported, they are: sub-transmission poles (ST) operating at 66kV and some 22kV, high voltage poles (HV) operating at 22kV, 11kV and 6.6kV, low voltage poles (LV) operating at 230/400V and public lighting only poles (overhead or underground supplied);
- Approximately 61,000 LV wood crossarms, 8,500 ST steel crossarms, 570 ST wood crossarms, 33,000 HV steel crossarms and 10,000 HV wood crossarms;
- Overhead conductor including: All Aluminium Conductor (AAC); Aluminium Conductor Galvanised Steel Reinforced (ACSR); Copper Conductors; Cadmium Copper Conductors; Galvanised Steel Conductors; Low Voltage Aerial Bundled Conductor (LV ABC); and a small amount of High Voltage Aerial Bundled Conductor (HV ABC);
- Air break and gas insulated load break switches, special purpose limited current breaking switches, remote controlled gas switches, disconnectors (isolators) and LV outdoor switches including fused switch disconnectors;
- 124 three phase 22kV and 11kV Automatic Circuit Reclosers;
- Over 70,000 public lighting lanterns;
- A total of 6,444 sets of HV outdoor overhead fuses, which consists of 3,406 Boric Acid (BA), 308 Expulsion Drop Out (EDO) and 2,739 Powder Filled (PF) fuse sets;
- Approximately 6,600 surge arrester sets (1 set equals 3 surge arresters generally with the exception of the single phase parts of the HV network) at voltage levels of 22kV, 11kV and 6.6kV. Of these, around 90% are of the polymeric insulator housed type, the remainder are porcelain housed types;
- Approximately 2,400 non pole type distribution substations, consisting of five distinct subgroups by design namely ground, indoor, underground, cubicle and kiosk type substations;
- In excess of 1,700 km of high voltage and low voltage underground mains cable including oil filled cable, paper insulated cable and crossed linked polyethylene (XLPE) insulated cable; and

- Approximately 175,000 LV overhead services.

1.4 GOVERNANCE

1.4.1 APPROVAL AND COMMUNICATIONS

Asset class strategy documentation is updated annually by the Asset Engineering Manager for approval by General Manager Asset Management Electricity Distribution

The asset class strategy is reviewed annually to ensure alignment with the Asset Management objectives and to account for any additional asset performance and risk information.

1.4.2 RESPONSIBILITIES

Key stakeholder personnel are

Job Title	Responsibility
GM Asset Management Electricity Distribution	Approval
Asset Analytics & Programs Manager	Document Owner
Senior Asset Performance Engineer	Review and draft ACS
Asset Performance Engineers	Prepare and draft ACS


2 STRATEGIC DRIVERS

The ABS (2019) states the asset management strategic drivers are:

- Market and competitive position, future growth, demand and customer connections;
- Customer and community expectations (service levels);
- Stakeholder expectations;
- Regulation and legislative environment;
- Asset management capabilities (processes, systems, resources, knowledge);
- Technology; and
- Other drivers relevant for the asset such as climate change

Combined, these strategic asset management drivers ensure JEN optimises the condition, performance and associated costs over the life of each asset.

Figure 2-1 – Jemena’s high level strategic goals informs the ABS



2.1 GROWTH

The coming 20 year period for the electricity network holds significant uncertainty. Customer behaviours are changing with the advent of new technologies which have the potential to reduce the need for the network as a source of supply, while at the same time, the demand for supply quality and growth in customer connections continue to rise. These two forces act against one another. JEN's expected position entering the next regulatory reset period is that demand growth, network wide, will continue at a similar rate as the last regulatory reset period. That stated, there are areas within the network where maximum demand growth is forecast well beyond the network average level while other parts of the network are forecast to experience reductions in maximum demand as a result, for

example, of manufacturing closures. Analysis is ongoing and JEN's ABS will evolve as new insights emerge. JEN's ABS contains the ten year forecast which the business is working to. JEN is actively monitoring several dynamics which impact this forecast.

2.2 STAKEHOLDERS

2.2.1 CUSTOMERS

Decision making on behalf of customers involves trade-offs. For example, our customers consistently tell us they value a safe, reliable and responsive supply of electricity. But they also tell us that rising energy prices have become a concern. These priorities are mixed, as higher service levels involve higher costs. It is a 'trilemma'

JEN's ABS states,

'The community expects environmental responsibility; a safe and reliable level of service; a responsive service; public amenity; equitable levels of service available to all consumers; and affordable pricing.'



2.2.2 SHAREHOLDERS

Asset procurement and operation must support the network's ability to produce and sustain profitability for shareholders.

JEN's ABS states,

'Our asset management decisions need to take into account the certainty our shareholders have about recovering their significant up-front investment in the asset.'

2.2.3 INTERNAL

Each ACS relies upon the contributions of several areas of the business. Stakeholders have business and operational insights that contribute to the effectiveness of the asset management. This includes contractors such as our Services and Projects teams. There are also reporting requirements back into the business. Section 1.2 *Asset Management System* maps stakeholder requirements.

2.3 REGULATORY AND LEGISLATIVE

JEN meets legal, licence and regulatory obligations so as to comply with the National Electricity Rules (NER) mandated by the Australian Energy Market Commission (AEMC) together with other rules, codes and guidelines set forth by:

- Australian Energy Regulator (AER);
- Energy Safe Victoria (ESV); and
- Essential Services Commission of Victoria (ESC)

The JEN ABS describes how the business complies with the requirements of each of these stakeholders in order to retain its distribution licence, adhere to the NER and meet safety obligations. There are perennial compliance, analysis and reporting requirements that JEN is required to perform with regard to asset management. For example, JEN provides an annual RIN to the AER for all zone substation and distribution assets so as to account for the state of the network in terms of asset cost, age, reliability and cost of operating the network.

3 ASSET OBJECTIVES

JEN's objectives

...provide the essential link between the Jemena Business Plan's strategic objectives and the JEN asset management plan that describe how the objectives are going to be achieved. The asset objectives transform the required outcomes (product or service) to be provided by JEN, into activities typically described in the JEN asset management plan. This in-turn provides the line of sight for asset management activities

Asset Class Strategy objectives are:

- The practice of a Health, Safety and Environmental (HSE) culture that proactively seeks to control HSE risks;
- Optimise asset availability. Each asset failure is recorded and evaluated. Using standard risk assessment guidelines, an estimate of equipment failure rates are made. Annual probabilistic failure rates can be derived. A documented inspection, condition monitoring, maintenance and replacement strategy is included in this document for all assets to minimise the probability of failure and contains deterioration in service levels;
- Optimise asset life cycle. Defer asset replacement expenditure by use of condition monitoring. Where practical, conduct routine inspections, that can increase in frequency, as the asset approaches its statistical end of life. The aim is to defer capital expenditure whilst controlling the risk of failure and, thus, to maintain service levels; and
- Standardisation and application of established design principles minimises the design and life cycle costs of assets installed.

A table assigning KPI's to the above objectives and aligning them to the ABS is located at Appendix B.

Figure 3-1 - There are five key success measures and objectives



4 SUB-ASSET CLASS STRATEGIES

The Sub Asset Class Strategies provide an asset overview and identify the most appropriate strategies and plans for managing the assets over their lifecycles. Each sub asset class strategy includes information on the asset management practices, including key strategies, options considered and plans that:

- Support the corporate business plan, strategies and objectives; and
- Inform expenditure plans and work programs.

Specifically the Sub Asset Class Strategies address the following:

- Introduction - Function and Asset Description;
- Asset Profile – Life Expectancy, Age Profile, and Utilisation;
- Performance – Requirements and Assessment;
- Risk – Criticality, Failure Modes, Current Risks, Existing Controls and Future Risks;
- Life Cycle Management – Asset Creation, Asset Operation and Maintenance, Asset Replacement, Disposal and Spares; and
- Asset Information.

4.1 POLES SUB-ASSET CLASS

4.1.1 INTRODUCTION

The poles sub-asset class covers all in-service Pole types within JEN and its ancillary equipment (which is limited to stakes, bed-logs and stays). Steel public lighting (P/L) poles will be considered in this section. P/L apparatus, such as brackets, lanterns and lamps, are covered in the Public Lighting sub-asset class strategy.

JEN manages approximately 111,000 poles, grouped as follows:

- Over 105,000 owned by JEN including over 21,000 steel public lighting poles;
- Over 1,500 Private Overhead Electric Line (POEL) poles; and

Over 4,800 owned by other authorities (e.g. Telstra, Tramways, Powercor) but supporting JEN assets. Table 4-1 details the grouping of poles by material type and ownership. Jemena is responsible (regulatory requirement) for the inspection of POEL poles and is responsible for the inspection and maintenance of JEN assets supported on other authorities poles.

Table 4-1: Number of poles owned/managed by JEN

Ownership	Pole Material			
	Wood	Concrete	Steel	Total
JEN	61,081	19,720	24,356	105,157
Other authority	1,598	608	2,636	4,842
Private Overhead Electric Line (POEL)	831	78	612	1,521
Total	63,510	20,406	27,604	111,520

All poles are classified into four main categories based on the voltage of the lines being supported, they are: sub-transmission poles (ST, largely 66kV and some 22kV), high voltage poles (HV, largely 22kV with some 11kV and 6.6kV), low voltage poles (LV, mostly 400V with some rural supplies at

500V) and public lighting only poles (P/L, always supplied by single phase LV either overhead or underground).

If a pole supports more than one voltage then it is referred to as the highest voltage being supported. Steel P/L only poles will be considered in this Poles section. This section will address areas of the steel P/L only poles category which are not covered in the Public Lighting sub-asset class – Section 4.9, including budget evaluations.

There are some ST poles in the JEN area that are not owned by JEN but which support JEN lines e.g. HV, LV or P/L. The Operational Expenditure (OPEX e.g. asset inspection) of JEN assets on these poles is considered in this Strategy. The Capital Expenditure (CAPEX e.g. asset replacement) of JEN assets on these poles is considered in the respective sub-asset class sections, e.g. Pole Top Structures or Conductors and Connectors.

There are some ST poles outside the JEN area owned by JEN which may support the other Distribution Businesses (DB) lines e.g. HV, LV or P/L. The OPEX and CAPEX of these poles is considered in this ACS (excluding supported assets owned by the neighbouring DB).

This chapter includes information on the asset management practices applied to poles and the associated ancillary equipment. The following sections detail the sub-asset classes asset profile, performance, sub-asset class risks, life cycle management and information/data.

4.1.2 ASSET PROFILE

4.1.2.1 *Life Expectancy*

This section details the life expectancy of the pole population for all pole types considered in the ACS. A general overview of the pole characteristics in JEN is covered, followed by details of the factors that affect the life expectancy of poles.

4.1.2.1.1 Jemena Pole Characteristics Information

The following tables in this section are provided to illustrate the characteristics of the types of poles subject to this Asset Class Strategy and under Jemena management. Table 4-2 shows the proportion of poles by material type as a % of the total JEN pole population.

Table 4-2: Population of poles by Material

Material	Poles	% of population of poles
Concrete	20,406	18.30%
Steel	27,604	24.75%
Wood	63,510	56.95%
Total	111,520	100%

Table 4-3 provides details the population of concrete poles by type. Most concrete poles are hollow core type manufactured by spinning a mould containing concrete and a welded steel mesh of reinforcement bar. A small number are solid cast (not spun) tapered I-beams, also known as coffin or Stobie poles (not to be confused with the South Australian Stobie pole, which has the structural steel on the outside of the pole).

Table 4-3: Concrete pole types

Type	No. of poles	% of concrete pole population
Cast	477	2.34%
Spun	19,929	97.66%
Total	20,406	100%

Steel poles require rust protection which is provided by either painting or galvanising. Steel poles are exclusively used for public lighting with the exception of a few known locations on the distribution network where steel poles are used to support ST assets. Generally steel PL poles are frangible which means they crumple or dislodge on vehicle impact. This provides protection to vehicle occupants in the event of a pole impact at the expense of the pole. Cabling of these poles must be via underground connections to ensure the frangible performance of the pole. There is a small population of steel poles that are not of a frangible design and these are sometimes supplied via overhead connections. These are relatively common in older urban areas. Table 4-4 indicates the treatment type applied to the steel pole population as a percentage of the entire population of steel poles.

Table 4-4: Steel pole types

Type	No. of poles	% of steel pole population
Cast	13	0.05%
Galvanised	11,702	42.39%
Painted	15,889	57.56%
Total	27,604	100%

Jemena's wood poles fall into the four (4) main timber durability classes (i.e. Class 1 to Class 4) where Class 1 is the most durable and by definition can withstand direct contact with the ground over long periods without preservative treatment. Class 4 is reserved for Radiata Pine of which only a few poles exist in JEN. Where the belly button is obscured or inaccessible (e.g. removed by vandals, hidden by cable guards, covered by council or Vic Roads signs or simply not installed during manufacture) the asset inspectors are asked to estimate the durability class of the wood. Where the belly button is available the information is recorded for analysis and asset class management purposes. This facilitates the targeting of maintenance and replacement resources, and review of assessment criteria.

Of the wood poles included in Table 4-5 there are over 12,000 poles which have been reinstated to Serviceable condition by Pole Staking. This is a process where a large "nail" or pressed metal stake is driven into the ground beside an Unserviceable or Limited Life pole and the above ground portion is securely attached (bolted) to the pole. The stake is manufactured in various sizes and strengths and usually extends 1.5m below the ground and 1m above.

Table 4-5: Wood pole types

Wood Species	CCA	Creosote impregnated	Creosote pressure treated	Not treated	Count	% of Wood poles
Blackbutt	2,357	48	79	257	2,741	4.32%
Bloodwood	336	27	79	1,397	1,839	2.90%
Brown Stringybark	4	258	17	15	294	0.46%
Class 1	33	17	25	1,047	1,122	1.77%
Class 2	30	17	5	179	231	0.36%
Class 3	1	132	13	14	160	0.25%
Grey Box	108	40	180	1,220	1,548	2.44%
Grey Gum	177	415	431	2,716	3,739	5.89%
Grey Ironbark	1,830	175	1,090	9,195	12,290	19.35%
Ironbark	269	36	110	889	1,304	2.05%
Messmate	37	17,065	4,498	654	22,254	35.04%
Mountain Ash	1	46	31	6	84	0.13%
Mountain Grey Gum	2	878	238	126	1,244	1.96%
Other	91	3	4	21	119	0.19%
Radiata Pine	261	5	85	7	358	0.56%
Red Gum	7			7	14	0.02%
Red Ironbark	49	24	259	1,026	1,358	2.14%
Red Mahogany	98	8	5	56	167	0.26%
Silvertop Ash	2	70	63	3	138	0.22%
Spotted Gum	2,051	42	152	114	2,359	3.71%
Sydney Blue Gum	2	3	1	84	90	0.14%
Tallowwood	268	44	375	4,073	4,760	7.49%
Unknown	861	40	36	447	1,384	2.18%
White Mahogany	73	44	222	2,117	2,456	3.87%
White Stringybark	4	597	340	424	1,365	2.15%
White Topped Box		1		7	8	0.01%
Yellow Stringybark	1	27	4	52	84	0.13%
Total	8,953	20,062	8,342	26,153	63,510	100.0%
% of timber treatment type relative to wood pole population	13.85%	31.73%	13.19%	41.23%		

Table 4-6 lists all the currently staked poles by species and stake type. The two (2) most commonly used stakes are the two smallest stakes available. Messmate wood poles (Class 3 timber) are the most commonly staked species but all Classes are represented.

Table 4-6: Staked poles by wood species

Wood Species	Stake Type								
	HS2	PB21	PB23	RFD600	RFD680	RFD880	RFD881	RFD891	RFD892
Blackbutt				54	57	10	4		
Bloodwood				76	109	43	6	5	7
Brown stringybark				49	46	18			
Class 1		1		141	145	49	7	5	6
Class 2				42	50	13	3	1	1
Class 3	3			9	22	14	2	2	
Grey box	3		2	138	154	33	7	2	8
Grey gum	12	1	2	341	478	127	25	18	10
Grey ironbark	9	1		502	692	184	61	16	23
Iron bark	1			80	108	25	6	8	7
Messmate	78	7	6	1319	2836	1288	218	145	115
Mountain ash				6	14	4		1	1
Mountain greygum	5		1	85	207	92	27	20	12
Other				2	7				
Radiata pine				4	5	1			
Red gum				2		1			1
Red ironbark	1		2	84	85	18	2	2	1
Red mahogany				3	3	2	1		
Silvertop ash				7	19	13	1	1	
Spotted gum				12	8	1			1
Sydney blue gum				14	34	7	1		
Tallowwood	3			220	216	71	19	14	21
Unknown				25	35	4		2	1
White mahogany	1		1	144	141	40	13	4	11
White stringybark	12	1		151	286	76	7	9	1
Yellow stringybark				14	22	5		2	2
Total	128	11	14	3542	5779	2139	410	257	227

Pole condition is classified as either Serviceable, Limited Life or Unserviceable. These pole conditions are defined as follows:

- Serviceable – may remain in service until the next routine inspection;
- Limited Life – must be reinstated (by staking) or reassessed within 12 months; and
- Unserviceable – must be reinstated (by staking) or replaced within 12 weeks.

Refer to the Asset Inspection Manual (AIM) - JEN MA 0500 for a full explanation and specified criteria of the above conditions

4.1.2.1.2 Factors affecting life expectancy

As per the Network Asset Useful Lives Procedure - ELE PR 0012, the life expectancy of a pole varies depending on the pole material. The expected useful life (age over which the pole is depreciated) of JEN's poles are:

- Wooden Poles – 54 years;
- Concrete Poles – 70 years; and
- Steel Poles – 35 years.

The life expectancy of a wooden pole is influenced by a number of factors that include:

- Durability class or species of the timber;
- Soil type and conditions conducive to timber decay;
- Termite areas;
- Vehicle impacts – location in relation to roads;
- Correct application of assessment criteria;
- Wood preservative treatment pre purchase and the on-going wood treatment;
- Water ingress or fungal fruit causing pole top rot; and
- Pole top fires.

The average age of the in service wood pole population is 38.7 years, which means that a large proportion is entering the latter stages of their expected life span. Of the wood pole population 59% are 35 years or older with 12.7% being more than the expected useful life of 54 years.

An analysis of the age of wooden poles when they have been removed has indicated an average age of 39.7 years. Jemena has recorded the details of 17,858 removed poles. This number excludes any "Null" ages and ages less than 10 years (difference between install date and remove date).

Concrete poles are far more durable than wooden poles and the factors that affect their life expectancy are limited to:

- Pole construction type, spun or cast;
- Soil type and conditions conducive to the corrosion of reinforcing bars; and
- Vehicle impacts – location in relation to roads.

The average age of the concrete pole population is 28.9 years. Unlike the wood pole population, a large proportion of concrete poles are well below the designed life span: 90.2% of the concrete pole population is under 40 years of age. The pole age profile is elaborated on in the life cycle management section.

The life expectancy of JEN's population of steel poles and towers is influenced by the following factors:

- Soil type and conditions conducive to the corrosion of metals;
- Preservative treatment of the steel, galvanising and bitumous paints; and
- Vehicle impacts – location in relation to roads;

JEN's in-service steel poles have an average age of 27.5 years. Of the steel pole population 90.0% are classified as P/L poles. Of the P/L steel pole population 5.21% are over the age of 35 years. There are 23 JEN owned subtransmission steel towers with an average age of 54 years. The life expectancy of a steel tower is 70 years. Of the steel tower population two of the 23 ST steel towers are over 60 years of age.

The breakdown frequencies for pole structures are monitored on a monthly basis (by the Asset Performance Review Committee). The data used for the assessment of breakdown frequency is extracted from JEN corporate systems (GIS, SAP, OMS). This data is monitored to identify trends, which may indicate possible strategic deficiencies. Where there are marked changes in breakdown frequency, either increasing or decreasing, then the causes are carefully investigated.

The failure categories which apply to the evaluation of this performance indicator are:

- electrical faults caused by pole failures; and
- in-service pole failures.

In-service pole failures do not include pole failures due to external causes such as vehicles impacts or trucks striking communication cables.

Pole top rot can have a significant impact on the life expectancy of wood poles if appropriate precautions are not taken. The pole top exposes the end grain of the timber and needs to be protected against the weather. The installation of a pole cap to protect the pole top from water ingress and consequential rot is an effective preventative.

Line inspectors are required to raise a maintenance notification for all missing or dislodged pole caps on timber poles. These are rectified in accordance with the assigned priority.

Rigorous maintenance of pole caps ensures the incidence of pole top rot is maintained at levels below one per annum. There are currently no poles with pole top rot on the JEN network.

4.1.2.2 Age Profile

This section provides a summary of the age profile of poles and staked poles.

A number of features of the Pole age profile are:

- Up until 1970 the most commonly used material was wood, almost exclusively;
- The two decades of the '70's and '80's saw an increasing number of poles installed and an increasing preference for concrete and steel poles;
- The widespread use of steel poles is associated with the development of underground residential distribution (URD) technologies;
- Since the privatisation of the State Electricity Commission (SEC) and 11 Municipal Electricity Undertakings (MEU's) the volume of poles installed annually has been steadily reducing. Again, the policy of undergrounding new residential estates has been the main influence on this reduction; and
- In the mid '90's (a year or so after privatisation) it was identified that the initial cost of installing concrete poles was noticeably more than for the equivalent wood pole. Concrete poles are now used rarely and only to satisfy specific design requirements, this decreasing trend can be seen in Figure 4-1 below.



Figure 4-1: Pole age profile by material

Both Figure 4-1 and Figure 4-2 indicate the increased rate at which steel public lighting poles have been installed as a result of the mandating of URD. The use of underground distribution technologies has slowed the rate at which poles are installed generally (with the exception of public lighting poles) so that most new pole installations are currently associated with the maintenance of the existing overhead network.




Figure 4-2: Pole Age Profile by Voltage (Not including Stay Poles)

The Staked Pole age profile is indicated in Figure 4-1 and the age profile of the stakes themselves is indicated in Figure 4-3.




Figure 4-3: Age profile of Stakes (nails)

Some features of these age profiles are:

- Although some poles were staked before privatisation the practise was embraced post privatisation i.e. 4 October 1994; and
- During the 2011-2015 period, high volumes of pole staking occurred (see Figure 4-3).

4.1.2.2.1 Volume of poles approaching end of life

The end of life or alternatively the useful life of a pole is defined by the pole testing criteria that results in a pole being classified as unserviceable.

Analysis of the age of wooden poles at replacement indicates that currently the average age of a wood pole when replaced is 39.7 years. This is significantly less than the expected nominal pole life used by Jemena of 54 years. JEN will continue to use an average life of 54 years in CBRM analysis (refer to ELE PR 0012 Review of Asset Lives Document for details) while the expected nominal asset life is reassessed as increased volumes of data becomes available.

The nominal pole ages used in Jemena's replacement model are likely to understate the volume of poles in the wear-out phase. The proportion of the JEN wood pole population that exceeds their nominal life is shown in Figure 4-4. This is based on the average life of a wood pole being 54 years and the life of a staked wood pole being 80 years.

If no pole replacements occur, over the next 5 years the proportion wooden poles older than their nominal life will increase from 10% of the asset population currently to around 18%. If historical replacement rates continued then the proportion of assets older than their useful life still increases significantly from 10% to almost 17%. The forecast replacement rates will result in an increase in percentage of the population of poles older than their nominal life to 15%.




Figure 4-4: % of Pole Population that Exceeds Useful Life

In order to maintain the performance of this asset class at current levels an increased rate of pole replacement is indicated by the above pole ageing data.

For more information on the forecast volume of poles replacements refer to Section 4.1.5.

Figure 4-5 indicates the condemnation rates for poles from 2001 to 2018. This condemnation rate includes wood, steel and concrete poles of all classifications. The rate at which poles are being condemned is trending up and this is consistent with the increase percentage of poles that have exceeded their expected age.




Figure 4-5: JEN pole condemnation as a percentage of population

Care needs to be taken when interpreting the data on condemnation rates. Year on year rates are affected by the zones being tested and the relative proportion of Class 3 poles in these areas. In

addition, the criteria for pole testing was adjusted in 2012 which resulted in elevated condemnation rates after 2012.

Allowing for the effects of the change in testing criteria and the ageing pole population forecast, condemnation rates are not expected to drop to pre 2012 rates in the foreseeable future and are expected to remain at approximately 1%.

4.1.2.3 *Utilisation*

The section provides high-level information on how poles are utilised (operated). This section includes details of any particular utilisation constraints that are placed on poles:

- For poles maximum asset life equals (=) maximum utilisation. All poles remain in service until their condition is assessed as Unserviceable (US) and they cannot be staked (a number of reasons may exist). The routine condition assessment and treatment (wood poles only) program is designed to assist the attainment of maximum utilisation of the pole asset class;
- Staking Limited Life (LL) and US poles is a life extension treatment and is a cost effective method of extending asset life and is utilised wherever the assessment criteria is met;
- Augmentation or customer projects may occasionally replace poles with remaining life;
- One or two poles annually are identified redundant by the asset inspectors. Their removal is funded from the OPEX budget unless the originating CAPEX project can be identified;
- It is JEN policy to use wood poles wherever possible on the overhead distribution network. Wood poles are used for all voltage classes, i.e. ST, HV, LV, and P/L. Wood poles are not normally used for P/L but may be used to replace an existing wooden P/L pole;
- Steel poles are used for P/L in accordance with Jemena P/L Technical Standard. All steel poles used today are frangible in one of two ways:
 - Impact absorbing (crumple under vehicular impact); or
 - Slip base (the poles detaches from the base at ground level)

It is a Vic Roads requirement that all new P/L poles on main roads be frangible with a preference for slip base poles; and

Concrete poles are predominantly used for aesthetic reasons for example, where a pole replacement is required (e.g. after a vehicle impact) and all the other poles in the street are concrete or, in rare circumstances where pole loads are such that wood pole characteristics e.g. length and/or strength, do not meet the requirements. Concrete poles are used for pole type substations to satisfy pole loading requirements. As reinforced concrete is an engineered product it may be manufactured in lengths and strengths which are not available in wood poles, hence in some rare cases it may be used where there is insufficient space for the installation of a ground stay supported wood pole.

Table 4-7 shows a breakdown of the quantity of poles per material and voltage classification. Wood continues to be the most commonly used material for JEN distribution poles.

Table 4-7: Population of Poles by Material and Classification

Category	Classification	Material			Total
		Concrete	Steel	Wood	
ST	ST	648	21	2,130	2,799
	ST/HV	226	0	844	1,070
	ST/HV/LV	108	0	1,322	1,430
	ST/LV	53	13	1,031	1,097
	ST Total	1,035	34	5,327	6,396
HV	HV	1,046	13	3,638	4,697
	HV/LV	5,906	24	22,503	28,433
	HV Total	6,952	37	26,141	33,130
LV	LV Total	11,094	2,417	30,269	43,780
P/L	PL Total	1,210	24,842	1,196	27,248
Stay	Stay Total	52	8	344	404
Other/unknown	Other	63	266	233	562
Total		20,406	27,604	63,510	111,520

Currently approximately 18% of the poles used for this work are concrete. Steel poles are exclusively used for public lighting (there are a handful of exceptions to this). Embossed nameplates (also known as belly buttons due to the attachment method) are fixed to wood poles. These carry information such as: species, date of manufacture, length, strength, treatment type and purchasing organisation (JEN in our case). Concrete poles have similar information cast into the concrete. Some approved non-standard steel poles carry a nameplate but most steel poles do not.

Jemena maintains a Public Lighting Policy and Technical Standard (Doc No. JEN ST 0500) which specifies steel pole dimensions, material and treatment i.e. hot dip galvanising and additional anticorrosion coating for the in-ground portion of the pole. This standard also lists a number of approved non-standard poles which public lighting customers may choose to install.

Jemena owns all unmetered P/L assets (poles and wires) located in the road reserve and charges an operate / maintain / replace (OM&R) fee to public lighting customers for providing this service. The fee is calculated based on the use of standard equipment (as defined in the Jemena P/L Standard). Customers who choose to install approved Non-Standard equipment (also defined in the Jemena P/L Standard) have an ongoing obligation to supply all non-standard equipment spares. Jemena is responsible for the operation, maintenance and provision of labour for the replacement of approved non-standard P/L equipment.

4.1.3 PERFORMANCE

The performance of the pole sub-asset class is monitored by the use of measures such as in-service failure rates and pole condemnation rates. The performance requirements are defined within the Jemena technical material specifications, the associated and nominated Australian Standards, the Jemena Construction Standards and the Jemena Design Standards.

4.1.3.1 Requirements

There are three principal material specifications that define the requirements for these assets. These are:

- The wood pole specification;
- The concrete pole specification; and
- The steel pole specification.

Each of these specifications reference a number of Australian Standards and the principal of these are listed in Table 4-8 .

Table 4-8 Poles - Relevant Australian Standards

	Title
AS 2878	Timber Classification into Strength Groups
AS 3818.1	Timber-Heavy Structural Products-Visually Graded, Part 1 General
AS 3818.11	Timber-Heavy Structural Products-Visually Graded, Part 11 Utility Poles
AS 5604	Timber – Natural Durability Ratings
AS/NZS 4065	Concrete Utility Service Poles
AS/NZS 4676	Structural Design Requirements for Utility Service Poles
AS 4680	Hot Dipped Galvanised Coatings on Ferrous Articles
AS 1074	Steel Tubes and Tubulars for Ordinary Service
AS/NZ 1163	Cold-formed Structural Steel Hollow Sections

In addition to the performance requirements specified in the Jemena material specifications the in-service performance requirements of the pole sub-asset class are specified and governed by the application of the following Jemena Standards:

- Overhead Line Design Manual – JEN MA 0005;
- Distribution Construction Manual - JEN MA 0006;
- Underground Residential Development Design Standard – JEN MA 0150; and
- Public Lighting Technical Standard – JEN PR 0026

These standards address the installation requirements that ensure the achievement of the designed performance requirements in terms of pole loads and clearances.

At Jemena safety is our number one priority. Poles are located in the public domain so consequently the in-service failure of a pole can have significant safety implications for Jemena employees and the general public. The management of the performance of this group of assets is one of Jemena's major network management activities and is based on a number of condition monitoring programs and targeted maintenance and replacement programs.

The maintenance of the structural and electrical integrity of Jemena's pole population is fundamental to the achievement of Jemena's network performance targets, supply quality targets and the safety of the network as a whole.

In the period leading up to 2017 an increase in the rate of in-service pole failures of Class 3 timber poles was detected. In order to manage this issue the pole inspection criteria for Class 3 timber poles was modified (sound wood measurement for Class 3 poles) to ensure that the mean time to failure of this pole type exceeded the inspection period. The consequence of this change to the inspection criteria was an increase in the condemnation rate for these types of poles and this is expected to continue over one inspection cycle. The change to the inspection criteria does appear to have addressed the in-service failure rate.

In service pole failures are investigated on an individual basis with relevant actions being identified to improve performance.

4.1.3.2 Assessment

The assessment of the performance of the pole population is based on the rate of in-service pole failures. Table 4-9 provides the results of in-service pole failures for the period 2012-2018.

Table 4-9: In service pole failures

Measure	2012	2013	2014	2015	2016	2017	2018
In service pole failures	3	4	7	4	8	2	1

This table indicates that safety performance of the pole sub-asset class has improved over the past few years due to actions being implemented to mitigate the risk of in service pole failures through modification and tuning of the asset inspection criteria. The Energy Networks Association surveyed Australian and New Zealand power utilities to determine pole failure rates. For the period July 2013 to June 2014 the survey found that the pole failure rate was 0.0071%. JEN's pole failure rate (0.0037%) for this period compares favourably with the national average. The data excludes vehicle impact causing pole failure.

The accurate analysis and assessment of the performance of this sub-asset class is dependent upon the following factors:

- A very high level of confidence in the accuracy and completeness of asset data (characteristic and condition);
- The correct application of the asset condition assessment criteria by asset inspectors; and
- The accurate reporting and recording in Jemena's corporate systems (e.g. SAP) of pole failure data.

Throughout this strategy the poles sub-asset class has been categorised by voltage as follows; Subtransmission (ST), High Voltage (HV) and Low Voltage (LV). Each voltage category has been modelled using the CBRM methodology and the output provided in this section. At this time the P/L category is out of scope for CBRM modelling and will be considered for inclusion in subsequent revisions of this strategy or the P/L strategy.

The CBRM modelling provides an output in the form of Health Indices shown in the figures below. These provide a visual demonstration of the condition of the various categories of poles now and a forecast of future condition.

4.1.3.2.1 ST Poles Condition Assessment

The CBRM results in terms of the health index for the current year (Year 0) are shown in Figure 4-6.

This measure of asset health is based upon the current level of expenditure on programs intended to maintain and replace this asset type. These include the asset inspection program, the pole staking program and the end of life pole replacement program. The total estimated cost of risk for all failure scenarios at Year 0 for ST poles is calculated to be \$3.9k per annum with a current condemnation rate of 1.0% per annum.

End of pole life for these purposes is when the pole is classified as unserviceable. It does not include poles that are replaced as a result of third party factors (e.g. vehicle impact).




Figure 4-6: Year 0 (2018) Health Index Profile (ST poles)

By year 7 (2025), if no ST poles are staked or replaced, the health index changes as shown in Figure 4-7. A total of 258 poles will be in poor condition with an associated higher probability of failure (health index of 7 or greater). If no replacement or reinstatement occurs the total estimated cost of the risk for all failure scenarios at Year 7 is calculated to increase to \$4.9k per annum.




Figure 4-7: Year 7 (2025) Health Index Profile (ST poles)

This result (Figure 4-7) indicates that the majority of the population of ST poles are well below their expected life of 54 years for wood poles and 70 years for concrete poles. Contributors to the total risk cost include Network Reliability, Safety, Operating Expenditure (Opex), Capital Expenditure (CAPEX) and the Environment, as indicated in Figure 4-8 below. The main factors contributing to the risk to the network should a ST pole fail are Safety and CAPEX as indicated in Figure 4-8. ST poles identified as being in poor condition at Year 0 will be prioritised for staking or replacement.

In order to maintain the assessed risk associated with the operation of these assets at current (year 0) levels this strategy proposes the replacement or reinstatement of approximately 50 ST poles per

annum over the course of the EDPR period. This is consistent with the current condemnation rate of 1.0% of the population per year.




Figure 4-8: Risk Profile for Year 0 (2018) & Year 7 (2025), ST Poles

4.1.3.2.2 HV Poles Condition Assessment

The CBRM results for HV poles in terms of the health index for the current year (Year 0) are shown in Figure 4-9.

This measure of asset health is based upon the current level of expenditure on programs intended to maintain and replace this asset type. These include the asset inspection program, the pole staking program and the end of life pole replacement program. The total estimated cost of risk for all failure scenarios at Year 0 for HV poles is calculated to be \$256k per annum with a current condemnation rate of 1.0% per annum.

End of pole life for these purposes is when the pole is classified as unserviceable. It does not include poles that are replaced as a result of third party factors (e.g. vehicle impact).




Figure 4-9: Year 0 (2018) Health Index Profile (HV Poles)

By year 7 (2025), if no HV poles are staked or replaced, the health index changes as shown in Figure 4-10. A total of 2,083 poles will be in poor condition with an associated higher probability of failure (health index of 7 or greater). If no replacement or reinstatement occurs the total estimated cost of the risk for all failure scenarios at Year 7 is calculated to increase to \$337k per annum.




Figure 4-10: Year 7 (2025) Health Index Profile (HV Poles)

This result (Figure 4-10) indicates that the majority of the population of HV poles are well below their expected life of 54 years for wood poles and 70 years for concrete poles. Contributors to the total risk cost include Network Reliability, Safety, Operating Expenditure (OPEX), Capital Expenditure (CAPEX) and the Environment. The main factor contributing to the risk to the network should a HV pole fail is Network Reliability as indicated in Figure 4-11. HV poles identified as being in poor condition at Year 0 will be prioritised for staking or replacement.

In order to maintain the assessed risk associated with the operation of these assets at current (year 0) levels this strategy proposes the replacement or reinstatement of approximately 210 HV poles per annum based on condition and the targeted replacement or reinforcement of approximately a further additional 470 poles identified as undersized over the course of the EDPR period (see section 4.1.4.3.1 Undersize Poles). This is consistent with the current condemnation rate of 1.0% of the population per year.




Figure 4-11: Risk Profile for Year 0 (2018) & Year 7 (2025), HV poles

4.1.3.2.3 LV Poles Condition Assessment

The CBRM results in terms of the health index for the current year (Year 0) are shown in Figure 4-12.

This measure of asset health is based upon the current level of expenditure on programs intended to maintain and replace this asset type. These include the asset inspection program, the pole staking program and the end of life pole replacement program. The total estimated cost of risk for all failure scenarios at Year 0 for LV poles is calculated to be \$27k per annum with a current condemnation rate of 1.0% per annum.

End of pole life for these purposes is when the pole is classified as unserviceable. It does not include poles that are replaced as a result of third party factors (e.g. vehicle impact).




Figure 4-12: Year 0 (2018) Health Index Profile (LV poles)

By year 7 (2025), if no LV poles are staked or replaced, the health index changes as shown in Figure 4-13. A total of 3,968 poles will be in poor condition with an associated higher probability of failure (health index of 7 or greater). If no replacement or reinstatement occurs the total estimated cost of the risk for all failure scenarios at Year 7 is calculated to increase to \$38k per annum.




Figure 4-13: Year 7 (2025) Health Index Profile (LV poles)

This result (Figure 4-13) indicates that the majority of the population of LV poles are well below their expected life of 54 years for wood poles and 70 years for concrete poles. Contributors to the total risk cost include Network Reliability, Safety, Operating Expenditure (Opex), Capital Expenditure (CAPEX) and the Environment. The main factor contributing to the risk to the network should a LV pole fail is Safety as indicated in Figure 4-14. LV poles identified as being in poor condition at Year 0 will be prioritised for staking or replacement.

In order to maintain the assessed risk associated with the operation of these assets at current (year 0) levels this strategy proposes the replacement or reinstatement of approximately 450 HV poles per annum based on condition and the targeted replacement or reinforcement of approximately a further additional 470 poles identified as undersized (HV and LV) over the course of the EDPR period (see section 4.1.4.3.1 Undersize Poles) 4.1.4.3.1. This is consistent with the current condemnation rate of 1.0% of the population per year.




Figure 4-14: Risk Profile for Year 0 (2018) and Year 7 (2025), LV poles

4.1.4 RISK

4.1.4.1 Criticality

Asset criticality is a measure of the risk of specified undesired events faced when utilising equipment. An asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A. The asset criticality score is then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This is also used to rank importance of dissimilar sub-asset classes (e.g. transformers and surge diverters) to identify areas where risk should be managed first and control measures implemented.

The poles sub-asset class has an asset criticality score of AC4 (High) due to the consequences for health and safety associated with pole failure or malfunction (for example the fact that concrete poles are conductive and in the event of a fault they can become a step and touch hazard).

The criticality of pole assets located in the Hazardous Bushfire Risk Area (HBRA) requires that they are given special treatment due to the extreme consequence of asset failure in terms of bush fire start. This is applied to a number of sub-asset classes located in the HBRA to mitigate this risk.

Further issues considered as part of asset criticality analysis include:

- Safety regulations and standards mandate minimum clearances to ground, between circuits and to other structures for overhead power lines;
- Typical replacement costs may range from \$9k for an LV pole to \$20k for an ST pole (including pole top replacement). At specific locations the costs may be lower or higher depending on the complexity of the pole top attachments and difficulty in accessing the location (e.g. rail easement);
- The consequence of a pole failure in terms of network reliability varies significantly dependent upon the voltage category. This is because of the number of customers directly effected by the pole failure and the level of network redundancy; and
- When considered from a safety perspective (i.e. in-service pole failure) the voltage category has less impact on the consequences. Every pole failure in the public domain has the potential for serious health and safety consequences for JEN personnel and the general public.

4.1.4.2 Failure Modes

Pole failures can be grouped in three categories:

- Physical failure of a pole, where a pole is no longer able to perform its designed function. In this case it can no longer support its own weight and/or support the overhead infrastructure;
- Functional failure of the pole, where its remaining strength is assessed as being insufficient to safely perform its designed function; and
- Footing failure, where the footing of a pole (i.e. bedlogs or ground condition) does not provide sufficient support to the pole and results in the pole leaning.

In the rare case in which a stake "fails", it is invariably the pole which fails at the attachment points and not the stake itself.

Physical failure can be either assisted or unassisted (such as breakage). Assisted failure occurs due to external influences such as:

- Vehicle impact;
- Tree impact; and

- Failure of adjacent pole.

Unassisted failure can be caused by:

- Wood rot – at the ground line, pole top and crossarm mounting points;
- Termites;
- Pole fire caused by insulator tracking;
- Foundation deterioration (leaning poles);
- Corrosion (steel poles & towers); and
- Reinforcement corrosion/concrete cancer (concrete poles)

Footing failure can occur due to:

- Soil conditions; and
- Incorrect installation or design.

All pole failures carry a risk of third party claims for property damage and/or personal injury. All fire starts incur an F-factor penalty which can range from \$300 to \$345k.

4.1.4.3 Current Risks

Risks associated with the management of electricity distribution poles are documented in JCARS and reviewed annually. The current risks associated with poles are:

- *Conductive pole becoming live:* Conductive poles (steel or concrete) in all voltage categories can become 'live' due to mechanical and electrical failure or faulty equipment. The result is hazards associated with step and touch potentials on or around the pole which are a health and safety risk for JEN staff and the general public;
- *Assisted pole failure:* As discussed above assisted pole failure can occur as a result of third party vehicle or tree contact with Jemena's poles or overhead lines supported on Jemena poles. The consequence of this type of failure can include injury to JEN staff or the general public, fatality, damage to JEN assets or public property and loss of supply; and
- *Unassisted pole failure (i.e. in-service pole failure):* This type of physical failure of a pole during the asset lifecycle can result in injury to JEN staff or the general public, fatality, damage to JEN assets and public property and loss of supply.

Poles treated with Copper Chrome Arsenate (CCA) and creosote have the potential to cause environmental harm and harm to people working with these chemicals.

Other risks that need to be considered are listed in the following sections.

4.1.4.3.1 Undersize Poles

In 2008 a severe wind storm hit Melbourne and especially the northern suburbs with wind gusts recorded at over 120 km/h. Jemena Electricity Networks sustained 6 pole failures in the storm; 2 were substation poles, 1 was a concrete LV pole brought down by a large tree falling on it and 3 poles were intermediate wood LV poles. These 3 LV poles are in a category termed "undersized" poles. An undersized pole is one where its natural girth (no external decay) is less than the minimum tabulated girth for a Serviceable pole. Until now undersized poles have been allowed to remain in service provided there was sufficient sound wood and no external decay. Undersized poles are typically 5kN LV poles and probably installed by previous authorities on the basis of cost. These poles are no

longer standard and it is estimated they have a life span that is between 10 and 20 years less than a standard 8kN or 12kN pole. It has been decided that all in service undersized poles will be either staked or replaced. This does not include public lighting only wood poles.

As of the end of 2018, there are a total of approximately 4,700 undersized poles in service on the network. Of these undersized poles, approximately 2,500 poles are yet to be either staked or replaced (Table 4-10). Due to the volumes of undersized poles identified this program will continue into the 2021-2026 regulatory period.

Table 4-10: Number of undersized poles that are not staked on the network

Pole strength (kN)	No. of undersized poles not staked
1.5	1
3	23
5	2519
5.5	2

4.1.4.3.2 HV Raiser brackets

Another subset of poles that have been examined in the recent past are the LV poles fitted with HV raiser brackets. These are poles that were designed as LV poles and sometime after installation a HV line was added. It is probable that the HV raisers were installed, rather than replacing “new” LV poles with HV poles on the basis of cost. It is arguable the design was acceptable in the past when wood HV arms were standard. The standardisation of the steel HV crossarms has made the use of HV raisers problematic. The issue is, a wood HV crossarm provides additional insulation between the HV and LV circuits, but with a steel arm a situation is created where the raiser bracket could be energised at HV only centimetres from bare LV conductors if a HV insulator is bridged by some airborne debris or a HV tie breaks and the conductor rests on the crossarm. The potential danger is greatest for unsuspecting line workers. To mitigate this risk LV poles with HV raisers are being replaced with standard HV poles when the wood HV crossarm reaches the end of its economic life. It is anticipated some of these poles are also undersized and will be targeted in accordance with the previous paragraph.

4.1.4.3.3 Process Risks

The corporate systems available for recording pole conditions and characteristics are well structured and cater for the information requirements of many business groups. Jemena continuously monitors the databases and systems, and seeks to make improvements and rectify issues when they become apparent. To identify areas of improvement, some examples of monitored areas are:

- In any inspection cycle, zone completion needs to be managed to ensure all poles are inspected and appropriate records kept; and
- In some situations inspections and characteristics are recorded on paper forms or Line Inspection Reports (LIR). This paper trail needs to be managed and cross referenced carefully to prevent multiple inspections of the same pole or the pole to be missed from being inspected.

4.1.4.4 *Existing Controls*

To mitigate the likelihood and consequence of these risks assets are regularly inspected and assessed in order to maintain a high degree of confidence in the structural integrity and safety of the pole population.

Jemena's standards, procedures and management plans are key controls in reducing the likelihood of these events occurring. JEN's internal technical standards and design and construction manuals are intended to ensure all assets on the JEN network are fit for purpose and comply to the relevant design standards. Incident investigations are conducted to determine the root cause of an asset failure. In particular this applies to all in-service unassisted pole failures. The findings of these investigations are reviewed and actions put in place to prevent incidents from re-occurring.

Field staff attend regular training to ensure they are competent and aware of hazards that may be associated with these risks. For example, for the risk of a conductive pole becoming live. Field staff attend regular specific training, such as the VESI training module "Live Low Voltage" which covers the hazards and precautions associated with working on conductive poles.

4.1.4.5 *Future and Emerging Risks*

The risks associated with the sub-asset class are not expected to change significantly in the near future. However, the proportion of poles reaching the wear-out zone and observed increasing condemnation rates, clearly indicate increased replacement volumes in the future. An analysis of pole condition during its wear out phase is discussed in detail in the Performance Section (4.1.3).

An emerging risk for this sub-asset class is an increasing condemnation rate of steel poles (public lighting) due to faster than expected corrosion rates. Revised pole footing wall thickness requirements are being considered for inclusion in the next review of the P/L steel pole specification. Jemena is pro-actively investigating this issue and is seeking to mitigate future risk by considering amendments to the specification.

Jemena's technology strategy involves investigating new technologies to maintain network reliability and reduce costs. Future improvements could be made in the data capture area relating to real-time systems and advanced capability for automatic data validation rules to mitigate some of the issues described in later sections.

4.1.5 LIFE CYCLE MANAGEMENT

The options available for asset lifecycle management reflect a trade-off between capital and operating expenditure. The preferred asset lifecycle management option involves condition based risk management. With the exception of project based pole replacement, all poles are operated based on their assessed condition. The Asset Inspection Manual (AIM) specifies condition criteria for all pole materials. Management of poles occasionally changes based on the investigation of failed poles. Examples of such changes include the management of undersized poles, or reinforcing existing criteria as was the case for sound wood measurement for Class 3 poles.

It is always more cost effective for an overhead network to remain overhead, therefore undergrounding will not be considered as a poles sub-asset class lifecycle management option. Undergrounding may be considered for other policy or project reasons.

Run to failure is generally not considered as a lifecycle management strategy especially on assets which are not fail safe. This type of lifecycle management strategy is typically employed on low cost/high volume and consumable assets (such as public lighting lamps), in which the consequence of failure is low; and spare asset and staff resources, including network response to resultant outages or replacement activity can be promptly addressed at relatively low cost.

4.1.5.1 *Creation*

New poles in this asset class are effectively created via new projects associated with the connection of new network load or the augmentation of network capacity and by the replacement of existing poles.

The principals that are applied to the creation of new pole assets include:

- In the LBRA a pole will only be replaced if it is unsuitable for staking. In the HBRA however, a pole is always replaced when it is classified as having a limited life or as unserviceable;
- Poles that have a girth of less than 720mm at 1m above ground are unsuitable for staking (nails are not manufactured to fit such narrow poles). These poles will be scheduled for replacement when identified;
- When a HV wood crossarm mounted on a raiser bracket reaches the end of its economic life the LV pole that it is mounted on will be replaced with the current standard HV pole;
- All poles are supplied in accordance with Jemena's material specifications and installed in accordance with JEN Design and Construction Standards. These include:
 - Overhead Line Design Manual – JEN MA 0005;
 - Distribution Construction Manual – JEN MA 0006;
 - Underground Residential Distribution Developers Standard – JEN MA 0150; and
 - Public Lighting Technical Standard – JEN PR 0026
- All Class 2 and 3 wood poles purchased today are Copper Chrome Arsenate (CCA) treated. Class 1 timbers when purchased are not treated. Historically creosote impregnation was the treatment used and a significant population of this type of pole are currently in service. Creosote is a known carcinogen and consequently its use ceased in the '80's. CCA has fewer personal and environmental risks associated with its use.
- All public lighting poles shall be steel;
- All substation poles shall be concrete; and
- The standard distribution pole shall be timber.

4.1.5.2 *Asset Operation and Maintenance*

There are three (3) life cycle management strategies applied to the operation and maintenance of the poles sub-asset class:

- Condition Monitoring – Asset Inspection and Testing;
- Preventative Maintenance - Treatment; and
- Reactive and Corrective Maintenance.

Time based replacement and replacement through projects are not considered as life cycle options and this applies for all sub-asset classes presented. Time based replacements are considered to be costly and unreliable. Instead, replacement based on asset condition is the most efficient use of resources as it focuses on assets that require attention. For example, if a time based approach was used for pole replacement, poles would be replaced at a pre-determined age which would lead to increased rates of in-service failures or poles being replaced with a significant amount of residual life. Hence this life cycle management option is not appropriate.

Replacement of poles through projects is not considered because, this activity replaces poles for customer initiated projects and third party impacts; mostly vehicle impacts or an occasional failed tree impact. Although this activity does influence pole statistics it is not a lifecycle management option.

4.1.5.2.1 Condition Monitoring - Asset Inspection and Testing

The poles sub-asset class is inspected routinely as described below. The asset condition assessment criteria includes measurement of internal rot and pole girth. The average sound wood criteria for serviceable, limited life and unserviceable classifications is set out in Chapter 4 of the AIM. Various inspection criteria including inspection cycles are regulated via the Electricity Safety (Bushfire Mitigation) Regulations, e.g. regulation 7(1)(i) for inspection intervals. Full details of asset inspection operations, including wood pole preservative application, are contained in the AIM.

Inspections shall identify, verify and record all poles regardless of type. The corporate systems (e.g. GIS and SAP) are the repository of all asset information and the defined business processes will be adhered to for field data capture. The data to be verified and captured is detailed in the AIM.

4.1.5.2.1.1 Inspection Cycle

The maximum inspection cycles have been mandated by ESV through the Electricity Safety (Bushfire Mitigation) Regulations. These regulations require that in the HBRA the maximum period between subsequent inspections cycle is no more than 37 months and no more than 61 months in the LBRA. This applies for all electricity distribution sub-asset classes.

JEN's pole inspection cycles have been based on RCM studies. External consultants facilitated an RCM study during April 1998 specifically looking at JEN's inspection practices. This study confirmed existing techniques and indicated scope for extension of some asset inspection cycles. At the time it was estimated that 10% of JEN poles were in the HBRA which proved difficult to economically justify an inspection cycle change. It is now known that there are about 4,770 wood poles within the HBRA or approximately 4% (just over 9% when including concrete and steel poles) of the whole JEN pole population. The low volume of poles in the rural areas made it difficult to justify increasing the cycle from 3 years to 4 years, hence it has remained unchanged. ESV, in response to Black Saturday, has mandated a 3-year inspection cycle for all poles in the HBRA.

In 2004 a JEN business case study identified poles, once classified as Limited Life (LL), often stay in this category for quite a long time, on average 7.8 years. This resulted in the business case being approved to stake all existing LL poles (approx. 1300 at the time) and further stake LL poles when identified by routine inspection. Limited Life poles that are unable or unsuitable to be staked remain as LL and are re-tested annually.

The inspection of steel public lighting (P/L) poles is a special subset of pole inspection and is therefore addressed in a separate strategy. The inspection of these assets is covered in the Public Lighting Asset Class Strategy.

Routine inspection intervals including initial inspections, for poles made from various materials are detailed in the AIM. In the order of 25,000 to 35,000 poles are inspected each year. Below is a summary of pole inspection cycles based on their location:

- For Low Bushfire Risk Areas (LBRA) Network Poles
 - 5 year cycle, with no pole exceeding 61 months
 - Annual reinspection for limited life poles that cannot be staked
- Hazardous Bushfire Risk Areas (HBRA) Network Poles
 - 3 year cycle, with no pole exceeding 37 months

Inspection cycles for poles based on classification are as follows:

- **Sub-transmission Poles:** Poles on sub-transmission feeders (66kV and 22kV), with or without subsidiary distribution feeders, are inspected in accordance with their own SAP maintenance plan.
- **Distribution Poles:** Distribution poles including HV/LV mains, public lighting, other distributor's, POELs, other owners (e.g. Telstra, Vic Track, Tramways, etc.) and service poles are divided into areas called inspection zones. The zone boundaries are designed to follow distribution boundaries, designated HBRA boundaries and where possible geographic features like major roads or rivers/creeks. Each inspection zone contains approximately 2,000 poles, and a few zones contain more than 4,000 poles. Maintenance plans in SAP define the inspection cycle for each inspection zone and sub-transmission feeder.
- **Steel Lattice Towers:** JEN owns 23 towers. These towers are inspected on a 5-year cycle in accordance with their own SAP maintenance plan.
- **Public Lighting Poles:** All wood, steel and concrete public lighting poles which are serviced overhead are inspected at the same time as the distribution poles in each inspection zone.
- **Limited Life Poles:** Limited Life (LL) poles that cannot be staked in the LBRA are routinely re-tested each year until they are reclassified as Unserviceable. Limited life poles located in the HBRA are scheduled for replacement.

In the LBRA, when a pole is assessed as LL for the first time it is staked if assessed suitable. LL poles in the LBRA that are unsuitable for staking are added to the current list of LL poles inspected annually in accordance with their own SAP maintenance plan. Some reasons a LL pole may not be suitable for staking include, insufficient amount of sound wood at a metre above ground level, unsuitable attachment points, and obstruction because of underground assets.

4.1.5.2.1.2 *Inspection methods*

A well developed and long standing AIM is used to specify the criteria for the condition assessment of wood, concrete and steel poles. This is a time based activity and a high level summary is provided here for each pole material.

This option allows for an effective condition based management system to be employed. This minimises the number of in-service failures and, replacement of healthy poles when compared with a time based lifecycle management system.

For wood poles inspection may involve (the actual tests performed are determined by the pole age and/or condition):

- Digging around the base to check for external decay and evidence of termites;
- Bore into the pole at ground line to assess remaining sound wood (i.e. not decayed/rotted);
- Bore into the pole at ground line to add pole-saver rods. This is a chalk like compound of Boron and Fluorine used as a fungicide and decay inhibitor;
- Measure the pole girth at the point of maximum decay. This measurement contributes in determining condition. The girth at 1m is measured and in conjunction with the nameplate strength the pole may be targeted by the undersized poles program;
- Sound the pole. The pole is struck with a hammer for the asset inspector to listen for hollow sounds which may indicate the presence of internal voids created by decay or termites;
- Limited Life poles are bored at 1m to determine if sufficient sound wood exists to attach a stake;

- Visual inspection all around the pole from ground to top. Defects (e.g. from unreported vehicle impacts), decay and termite activity is sometimes observed. Pole top rot is almost non-existent due to the requirement of pole caps; Inspection and treatment are coincident activities to capitalise on a single visit; and
- All staked wooden poles only require limited excavation around the pole base to check for rust and termite attack. Testing and treatment are carried out at 1m above ground level.

For Concrete poles inspection involves visual inspection all around the pole from ground to top. Defects (e.g. from unreported vehicle impacts) may cause the steel reinforcement to be exposed resulting in concrete degradation.

For Steel poles inspection involves digging around the base to check for extent of external corrosion and visual inspection all around the pole from ground to top. Defects (e.g. from unreported vehicle impacts) may cause frangible poles to become unstable or protective coatings to be damaged exacerbating above ground corrosion. Vandalised access covers are also identified from time to time

4.1.5.2.1.3 *Private Overhead Electric Line (POEL) Poles*

In an effort to satisfy the requirements contained in the Electricity Safety (Bushfire Mitigation) Regulations 2013, Jemena inspects POELs in the HBRA on a 3 year cycle and LBRA on a 5 year cycle in accordance with Regulation 9.

The inspection holes and treatment holes in these poles are treated with wood preservative (Polesaver rods). Leaning poles shall be identified as per definition of leaning poles in the AIM.

Regulation 10 prescribes the standard of inspection to be applied to a POEL and there is no LL criteria applied to private poles; once these limits are reached the pole is deemed Unserviceable. No inspection holes are drilled in CCA treated pine poles to ensure the CCA treatment remains effective. For a detailed list of inspection criteria applied to POELs refer to Chapter 9 in the AIM.

4.1.5.2.2 Preventative Maintenance - Treatment

Preventative maintenance of the poles sub-asset class is focussed on the prevention or slowing of the ageing and deterioration of timber structures. This section describes the preservative treatments used on distribution timber poles to treat and prevent timber rot.

Poles are on average about 12 metres long but the most important part of each wood pole (from a timber condition perspective) is the 300mm below and 100mm above ground level. Careful treatment of the pole with internal wood preservative at and below the ground line is carried out to extend the life of wood poles. Refer to Chapter 5 of the Asset Inspection Manual (AIM) for full detail on the chemical treatment and its application.

All wooden poles are treated with Polesaver rods in conjunction with each inspection cycle. Treatment commences as detailed in Chapter 4, Table 4.2 of the AIM then continues at each inspection cycle in accordance to Chapter 4 of the AIM. Polesaver rods are placed in treatment holes and provide a 3-5 year protection period against all forms of wood rot, and deter termites from attacking the treated wood. These treatments have had a significant impact on the rate at which timber poles age and deteriorate.

The same treatments are applied to staked (reinstated) poles to slow the above ground deterioration of the pole.

4.1.5.2.3 Reactive and Corrective Maintenance

Corrective Maintenance is monitored in monthly maintenance and activity reports produced by the Asset Planning and Performance team. The Bushfire Mitigation Index is also produced monthly to monitor maintenance activities in JEN Hazardous Bushfire Risk Areas (HBRA). These indices are a

progressive measure of the achievement of business targets for critical activities in the Bushfire Mitigation, Asset Inspections and Preventive Maintenance programs.

Reactive and corrective maintenance is undertaken when faults occur or after inspection has identified a defect (or both). Reactive and corrective maintenance activities include the following:

- Treatment for Termite Infestation - Termite infestation of wood poles occasionally occurs and is readily identified by the inspection process. Termite treatment is carried out in accordance with the requirements of the AIM;
- Correcting Leaning Poles - Leaning poles are poles that:
 - Lean more than 5 degrees from the perpendicular centre-line of the pole and the pole leans over the kerb line in the direction of a vehicular carriageway; or
 - Lean more than 10 degrees from the perpendicular centre-line of the pole elsewhere.

Any pole found to be leaning as per the definition above will be rectified as required by the Electricity Safety (Network Assets) Regulations 1999 and documented in the AIM (table 12 of chapter 4).

- Missing Pole Caps - The pole top being a right angle cut against the natural grain of the timber leaves the pole top exposed which may lead to severe pole top rot unless there are precautions taken to protect it from the elements such as fitting a pole cap. Any missing or dislodged pole caps will be identified by inspection and rectified as required;
- Pole Top Rot - Pole Top Rot (PTR) is a significant issue for all wood poles. Pole caps have proven to be effective in the prevention of PTR and are maintained in line with the inspection program. If an assessment deems the pole top is likely to fail before the next scheduled inspection the pole will be replaced within the notification priority time frame;
- Refurbishment (Pole Staking) - Unserviceable poles must be actioned within 12 weeks of identification. When a wood pole is assessed as LL or US the first option is to assess its suitability for staking. The pole will either be staked (if suitable) or replaced giving consideration to, mechanical loading, wood condition at staking height and above, pole top rot or termite infestation. The suitability for staking criteria is detailed in the AIM but generally includes available sound wood at 1m, sufficient space on the pole, clear of underground assets at the pole base, type of pole structure (e.g. not some undersize poles nor LV poles with nonstandard HV raiser brackets) and access to the pole with the staking machinery/tools (e.g. difficult terrain). It is estimated that pole life is extended at least 20 years after being staked. The RFD staking system is currently approved for use on JEN poles; and
- Undersized poles (as mentioned in section 4.1.4.3.1) will be addressed as they are identified.

4.1.5.2.3.1 *Fault response strategy*

Corrective maintenance prioritisation and time-frames include the following:

- Treatment for Termite Infestation – within 4 weeks of assessment;
- Correcting Leaning Poles – depending on the severity of the lean, between 12 weeks and 12 months of assessment;
- Missing Pole Caps – within 6 months of assessment; and
- Refurbishment (Pole Staking) – within 12 weeks of assessment

The fault response strategy for this asset class involves replacement of the damaged pole. When a wood, concrete or steel pole fails (for any reason) it cannot be repaired (e.g. by staking) making replacement necessary in every case.

All poles assessed as Serviceable and identified with failed footings, i.e. leaning more than 5 to 10 degrees may be straightened by under-digging and/or installing a bed log (wood and concrete poles only).

As the stake is not attached to the pole butt (footing) staked poles identified with excessive leans must be replaced.

4.1.5.2.3.2 Predictive maintenance / on condition maintenance

The need for Pole and Pole Top maintenance is determined by the asset inspection process and any work carried out beyond inspection and treatment (by the asset inspector) should, except in the case of minor maintenance or third party accident damage, be carried out as a direct result of raised Notifications or inspection reports. Minor maintenance as defined in the AIM (e.g. installation/repair of guy warning tubes, earth cover strips, cable guards, etc.) will be performed by the Asset Inspector and details recorded in a Notification. Notifications will also be created for maintenance after faults (e.g. pole top fires, lightning strike, etc.). As part of the pole routine asset inspection program the AIM requires the asset inspector to perform minor maintenance work when identified. Chapter 17 in the AIM provides detailed information on the application of this requirement.

Jemena has implemented the Reliability Centred Maintenance strategy for the management of all network assets. On the distribution network wood and steel poles are unique in that the physical measurements are taken to assess the condition, all other distribution assets are assessed by visual examination. As a form of condition based monitoring, visual assessments (of distribution assets other than poles) have matured to a point where reliable condition is obtained.

4.1.5.3 Asset Replacement

All pole types are either replaced or reinforced, following pole inspection and testing, once their condition has been classified as Unserviceable (US). Only wooden poles can be reinforced via the installation of pole stakes and then only those wooden poles that satisfy the staking criteria.

Undersized poles are also replaced if they are not suitable for reinforcement via the staking option. When LV poles with HV raiser brackets are assessed as US they are replaced with HV poles. These poles are also required to be replaced when the HV wood crossarm is identified as unserviceable (due to the unacceptable separation between HV and LV if a steel HV crossarm were to be installed).

4.1.5.3.1 Pole Replacement and Reinforcement - Forecast Volumes

As detailed in this strategy, a number of pole replacement or reinforcement projects have been identified to ensure the maintenance of network performance, and also address our compliance requirements. These are included in the forecast volumes in Table 4-11 .

Table 4-11: Poles Replacement and Reinforcement – Forecast Volumes

Service Code	Poles	Replacement Volumes – Poles					
		CY20	CY21	CY22	CY23	CY24	CY25
RPH	Pole Repl. (Incl. Pole Top) - HV	51	45	45	45	45	45
RPH	Pole Repl. (Incl. Pole Top) - HV - HBRA	-	5	5	5	5	5
RPL	Undersize Pole Replacement	32	65	65	65	65	65
RPL	Pole Repl. (Incl. Pole Top) - LV	80	76	76	76	76	76
RPS	Pole Repl. (Incl. Pole Top) - ST	7	5	5	5	5	5
RPS	Pole Repl. (Incl. Pole Top) - ST - HBRA	-	4	4	4	4	4
RRH	Pole Reinforcement - HV	159	151	151	157	164	157

Service Code	Poles	Replacement Volumes – Poles					
		CY20	CY21	CY22	CY23	CY24	CY25
RRL	Undersize Pole Reinforcement	-	366	443	443	443	366
RRL	Pole Reinforcement - LV	392	373	373	375	376	375
RRS	Pole Reinforcement - ST	40	38	38	38	38	38

4.1.5.4 Asset disposal

Untreated poles are generally diverted to landfill or recycled as firewood.

CCA and creosote treated poles contain chemicals and have a different disposal process to untreated poles. Treated poles should not be used for any other purposes that create health risks to employees or the general public, for example – treated wood should not be reused as firewood. A trial has been undertaken involving the removal of the contaminated layer from the treated pole and repurposing the wood for furniture.

It is preferable treated poles are reused within the community. In the case where a treated pole cannot be safely reused it must be appropriately disposed to landfill in accordance with EPA requirements. For more information on CCA management and handling refer to the work instruction JEM HSE PR 0016 WI 01 Copper Chrome Arsenic (CCA) management and Handling.

4.1.5.5 Spares

Spares requirements for critical assets are assessed by following the Critical Spares Assessment Procedure (JEM AM PR 0015). Spares for the range of pole types and sizes are maintained at Tullamarine depot and stock holdings are managed by the Services & Projects team.

Common pole sizes are turned over regularly and stocks are maintained to service this need which also covers the need for unplanned and emergency replacements. Due to the long lead times associated with the sourcing of poles a stock of poles of less common lengths like 15m and 17m is maintained.

Although very few poles fail “in-service” a stock is kept for poles damaged by vehicle impact (approximately 200 poles per annum are replaced due to vehicular impact). Pole replacements due to vehicle impacts are treated as recoverable works and as such are not included in forecast replacement numbers associated with the end of life replacements and reinstatements.

Furthermore when assets are retired from service consideration is given to retaining components or the entire asset (after refurbishment) as spares to service existing aging assets.

4.1.6 INFORMATION

JEN uses a number of systems to ensure that network assets are operated in a safe manner consistent with their ratings and operating environment. Principal among these is the System Control and Data Acquisition System (SCADA) operated by the Control and Dispatch Centre of Network Operations, Electricity. This system is used to manage the Subtransmission and High Voltage networks. The Low Voltage network and associated assets are managed using data sources and systems which are collectively referred to as Business Intelligence (BI). The principle data used is the smart meter (AMI) energy consumption data and data on connectivity contained in the Graphical Information System (GIS). This allows the compilation of loading information on the various elements of the LV network from substations down to LV services. It also provides data on supply quality parameters.

Information required to support asset strategies, performance and risks is recorded in SAP, Geographic Information System (GIS) and the Enterprise Content Management System (ECMS). Additional fault related data is available in the Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

GIS is used to capture all the characteristic information about a pole and its location. This includes information like length, strength, owner, other attached or supported assets, geographic location, age, inspection zone, fire danger area, declared vegetation zone and so on. All JEN owned poles are identified with an "A" number and all private poles where Jemena is responsible for inspection are marked with a "P" number. The pole is classified automatically in GIS by the voltage of the lines attached. The functional location of the highest voltage line supported is automatically assigned to the pole.

The AIM specifies which assets to assess and the relevant condition criteria for an accurate assessment of the pole's condition to be made. SAP defines how this information is to be recorded.

SAP is used to capture; e.g. pole condition assessment records, defect Notifications, PM Orders, labour and material costs, maintenance plans etc. The list is extensive but can generally be categorised as condition information or lifecycle management information. SAP is also used to record specifications for each pole type which has been agreed with the vendor, whose details are also recorded in SAP.

Pole inspection and characteristic information is recorded in the field by the asset inspector on a field computer. The records captured each week by each inspector are transferred to Jemena. GIS Data Capture staff validate the data and upload it to GIS and SAP.

Photographs of the assets and poles, taken by the asset inspectors, are also transferred to Jemena weekly where GIS Data Capture staff link each photo to the relevant equipment in GIS. Photos of defects are linked to Notifications.

Jemena's AMS provides a hierarchical approach to understanding the information requirement to achieve Jemena's business objectives at the Asset Class. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and Asset Class Strategy (ACS) all provide the context for and determine the information required to deliver an Asset Class's business objectives.

From these business objectives, it is possible to identify at a high-level the content of the business information systems' required to support these objectives (Table 4-12).

Table 4-12: Poles sub-asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Information Sources	Externally Sourced Data
Operational Excellence <ul style="list-style-type: none"> • Manage assets throughout their lifecycle in safe and environmentally responsible manner • Maintain assets in accordance with RCM principals • Maintain asset information/knowledge to enable efficient and effective decision making • Embed continuous improvement throughout asset lifecycle Customer <ul style="list-style-type: none"> • Maintain our current service levels • Incorporate customer feedback in our decision making process 	GIS/JEN Viewer <ul style="list-style-type: none"> • Geospatial representation of the JEN Network • Asset attributes SAP <ul style="list-style-type: none"> • Work schedule & status • Planned and corrective (faults) maintenance records • Asset inspection measurements • Financial information ECMS	<ul style="list-style-type: none"> • Current cadastre (including land ownership) for JEN's geographical extent. • DELWP - HBRA and LBRA area boundaries • CFA for fires, warnings and restrictions, incidents • Emergency Management Common Operating Picture (EM-COP) • Aerial Imagery for JEN's geographical extent (NearMap) • Google 'Street View' • Melway

Business Objectives	Jemena Information Sources	Externally Sourced Data
Growth <ul style="list-style-type: none"> Acquire/install/maintain assets to meet future demand requirements People <ul style="list-style-type: none"> Maintain safe work environment Engage team leaders in assessment of new assets Training 	<ul style="list-style-type: none"> Asset Inspection Manual, inspection methods & criteria Policies, procedures and guidelines General asset audits/surveys not stored in SAP Incident investigations Drawbridge <ul style="list-style-type: none"> Standards Operations diagrams Line design manual Construction manual SCADA/RTS <ul style="list-style-type: none"> Outage Management System (OMS) & SCADA (DMS) Planned and Unplanned outages JEN Analytics <ul style="list-style-type: none"> Power quality data Energy consumption 	<ul style="list-style-type: none"> SAI global (Australian and International Standards) ESV / ESC / AER for regulatory obligations

Table 4-13 identifies the current and future information requirements to support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-13 Poles sub-asset Class Critical Business Decisions Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
Pole acquisition and application	<ul style="list-style-type: none"> Purchase specification (ECMS) Distribution Design Manual (ECMS) Distribution Construction Manual (ECMS) Period contracts (ECMS) Logistics system (SAP) 		<ul style="list-style-type: none"> High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.
Life cycle management: <ul style="list-style-type: none"> Asset identification Condition monitoring Condition assessment Replacement / retirement strategy Disposal 	<ul style="list-style-type: none"> Each asset identified by geospatial representation in GIS and equipment ID in SAP Asset Inspection Manual (ECMS) Maintenance plan (SAP) JEN Analytics (e.g. deteriorated neutral) Measurement record (SAP / ECMS) PM Notifications/Orders (SAP) 	<ul style="list-style-type: none"> Enhanced inspection data quantities such as: <ul style="list-style-type: none"> Drill hole score Type of Rot Photo database of failed assets Girth ratio (below ground / above ground) Near real time updating of asset record Photos database of all failed assets 	<ul style="list-style-type: none"> High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
	<ul style="list-style-type: none"> • Strategy detailed in this document • GIS asset attributes: <ul style="list-style-type: none"> - Asset status (e.g. existing/historical) - Status (in service, isolated, out of commission) - Operating voltage - Pole number (A-number) - Pole Type (distribution, public lighting etc.) - Material - Classification - Length - Strength - Disc Year - Date Installed - Timber Treatment - Owner • Fault / failure records: <ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 	<ul style="list-style-type: none"> • Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	

Table 4-14 details the information initiatives required to provide for the future information requirements identified in Table 4-13. Included within this table is the risk to the Asset Class from not completing the initiative.

Table 4-14 Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information capture	Ability to capture all relevant asset attributes from the field through mobility solution.	High	Complete, Current, Accurate attribution
Improve/review MAT Code definitions	Ability to align to AER service classification structure.	High	Precise definition
Improved Asset Attributes	Review current asset attribution fields to ensure attributes being collected are asset specific.	Medium	Appropriate and Accurate attribution
Increased Timeliness	Decrease latency between fault/maintenance delivery and fault/maintenance record capture.	High	Complete, Current, Accurate attribution

Improved fault information capture	Ability to capture all relevant asset failure information from the field through mobility solution and photos.	High	Complete, Current, Accurate fault information
---	--	------	---

The relevant metrics used to measure data quality for all sub-asset classes are defined below:

- **Currency:** Concerned with attribution values that are up to date with respect to their actual value in the real world. For example, if a pole is replaced in the field, the databases (GIS and SAP) need to reflect this change within a timely manner. During each pole inspection the asset inspector is instructed to confirm the pole data is up to date. To be able to quantify currency, an additional field will need to be added for field inspectors to confirm they have “checked data”.
- **Completeness:** This is a measure on the totality of the pole characteristic data set. To measure the completeness of data a sample of approximately 100,000 poles was used. From this sample the percentage of completeness represents the number of unknown values relative to the sample size. Table 4-15 indicates the accuracy of pole data characteristics for a sample of pole characteristics.
- **Consistency:** Is a measure of the consistent delivery of a business requirement. For example, all private poles have a “P” number and all JEN poles have an “A” number.
- **Accuracy:** This would typically require a field audit to confirm data the database and the field are the same. To ensure the accuracy of current and future data, validation audits should be conducted to confirm the accuracy and currency of the information in the field and database.

Table 4-15 indicates the completeness and consistency of particular pole data characteristics. To calculate completeness a sample of 100,000 poles was used. The completeness metric is a measure of the number of unknown values for that pole characteristic relative to the total population of poles. The results in Table 4-15 show the completeness of information for poles is near 100%.

Table 4-15: Data quality metrics for Poles

<i>Pole Metric</i>	<i>Completeness</i>
Pole number (A-number)	98.61%
Material	100%
Species	98.99%
Length	99.89%
Strength	99.47%
Date installed	Approx. 99% Majority of install dates for poles pre 1960 were based on estimated installation date. Unable to differentiate this in SAP business objects.

4.2 POLE TOP STRUCTURES SUB-ASSET CLASS

4.2.1 INTRODUCTION

The pole top structures sub-asset class includes crossarms, insulators, insulator ties, braces, bird covers and bolts. The main focus of this sub-asset class is crossarms.

Crossarms are categorised by two main types; Low Voltage (LV) wooden types and High Voltage (HV) or sub-transmission (ST) normally steel.

- The HV and ST crossarms are interchangeable i.e. the same arm type (e.g. SL24) can be used to support HV or ST conductors but the actual choice of a crossarm type is dependent upon the conductor loads and required conductor separation. All new HV and ST crossarms installed since the mid '90's have been made from galvanised steel. HV and ST wood crossarms are susceptible to Pole Top Fires (PTF) however un-bonded steel crossarms on a wood pole have been known to result in PTF's. All ST and HV crossarms in the HBRA are steel. In the LBRA, HV and ST crossarms are progressively being replaced with steel crossarms through the pole top fire mitigation program and proactive replacement.
- LV crossarms that support open wire mains are always made from wood. This is an important safety feature for open wire circuits from a "Live" works practices perspective.
- Suspension brackets for LV ABC are recorded as steel LV crossarms in the asset data systems and there are about 24,000 of these on JEN.
- There are approximately 61,000 LV wood crossarms, 9,800 HV wood crossarms, and 33,000 HV steel crossarms as indicated in Table 4-16.

4.2.2 ASSET PROFILE

4.2.2.1 Life Expectancy

Pole Top Structures display a wear-out characteristic of the type indicated in Figure 4-15. The onset of wear out occurs at the end of the useful life, and failure follows a normal distribution after the useful life. This overall failure behaviour is depicted in Figure 4-15.




Figure 4-15: Graph of assumed pole top structure life

The useful (average) life expectancy (Y) of a wood crossarm is 45 years. The useful (average) life expectancy for steel crossarm is 70 years. X is the expected life with a low probability of failure. The difference between average life expectancy (Y) and expected life (X) is the remaining life span in which the crossarm has, on average, an increased probability of failure (Table 4-16).

As per, ELE PR 0012 Network Asset Useful Lives Procedure it is estimated that most poles older than 45 years will have had the crossarms changed at least once. It is generally accepted that all ST and HV crossarms installed after 1980 are steel. The table below suggests the majority of HV and ST crossarms are now steel.

Table 4-16: Crossarm Life expectancy and Quantities

Crossarm Type	Pre 1980	1980 to present	Total	Useful Life 'Y'	Span Y-X
Wood ST crossarms	437	137	574	45	10
Wood HV crossarms	4,549	5,334	9,883	45	10
Wood LV crossarms	24,793	36,023	60,816	45	10
Total Wood	29,779	41,494	71,273		
Steel ST crossarms	136	8,349	8,485	70	10
Steel HV crossarms	213	32,843	33,056	70	10
Total Steel	349	41,192	41,541		
Total Crossarms	30,128	82,686	112,814		

4.2.2.2 Age Profile

Due to the unavailability of recorded data relating to crossarm and insulator age significant effort was made to estimate this profile. The effort was placed in accurately determining the age of adjacent assets such as poles and conductor.

To establish an age profile (Figure 4-16) with a high level of confidence some assumptions made include:

- Steel crossarms are likely younger than the supporting pole and unlikely to have been installed prior to the mid '70's;
- While it is unlikely that HV wood crossarms installed prior to 1969 have not been replaced, and in the absence of alternate positive references, the age is assumed to closely relate to the pole age;
- The use of wood HV and ST crossarms completely ceased post privatisation (Oct 1994); and
- The use of LV ABC has significantly accelerated since privatisation. Due to the reduced tree clearance space requirements LV ABC is encouraged by the regulator and preferred by councils and customers.




Figure 4-16: Pole Top Structures Age Profile

The Pole Top Structure age profile covers a broad time-span. It is assumed that the bulk of older pole assets dating back to the 1920's have had their Pole Top Structures replaced at least once in the last forty years. The majority of the assets were constructed by the State Electricity Commission and five Municipal Electricity Undertakings with asset types ranging from wooden crossarms fitted with porcelain or glass insulators through to steel crossarms fitted with polymeric insulators.

The total volume of LV ABC support brackets and LV wood crossarms demonstrate the consistently high volume of work required on the LV reticulation circuits. As shown in Figure 4-16, any crossarms installed prior to 1974 are older than the expected average life of 45 years. There are more than 24,000 crossarms (both steel and wood) over the age of 45 years.

The population of LV ABC brackets are relatively young in age, with a large proportion of LV ABC brackets (LV steel crossarms) being installed post 1990. Due to their relatively young age, deterioration or failures within the next 20 years is not expected.

4.2.2.3 Utilisation

Pole top structures are comprised of passive devices such as crossarms, insulators, insulator ties, braces, bird covers and bolts which mainly perform the task of providing structural support and insulation for the overhead distribution network.

Pole top structures are inspected on a periodic basis to ensure that they are structurally sound and provide sufficient levels of insulation.

4.2.3 PERFORMANCE

4.2.3.1 Requirements

The principal function of a pole top structure and its associated components is the structural support and insulation of the conducting components of the overhead distribution network. To this end they are designed and configured to ensure the required phase to phase separation, ground clearances and clearances to adjacent structures are achieved and maintained under all operating conditions and

for the design life of the asset. This includes the maintenance of the required insulation withstand strength and impulse strength in all weather conditions.

Pole top structures are also designed and constructed so as to address known factors that can impact on network performance and reliability. These include:

- Structural design that accounts for conductor loads and maximum stringing tensions;
- Wind loads and conductor vibration issues;
- Conductor clashing due to the passage of fault current and the effect of high winds and tree movement;
- The mitigation and elimination of pole top fires; and
- The mitigation of bird and animal strikes on pole top structures.

The requirements for pole top assemblies are set out in the following Jemena standards:

- Overhead Line Design Manual – JEN MA 0005; and
- Distribution Construction Manual – JEN MA 0006;

In addition there are three principal material specifications that define the requirements for these assets. These are the:

- wood crossarm specification;
- steel crossarm specification; and
- insulator specification.

Each of these specifications reference a number of Australian Standards and the principal of these are listed in Table 4-17: .

Table 4-17: Pole Top Assemblies - Relevant Australian Standards

Standard	Title
AS 2878	Timber Classification into Strength Groups
AS 1148	Timber - Nomenclature - Australian, New Zealand and imported species
AS 3818.1	Timber-Heavy structural products-Visually graded, Part 1: General requirements
AS 3818.4	Timber-Heavy structural products-Visually graded, Part 4: Cross-arms for overhead lines
AS/NZS 2947.1	Insulators - Porcelain and Glass for Overhead Power lines - Voltages greater than 1000 Test Methods – Individual units
AS/NZS 2947.4	Insulators - Porcelain and Glass for Overhead Power lines – Voltages greater than 1000 Test Methods – Insulator Strings and Insulator Sets
AS 3608	Insulators - Porcelain and Glass, Pin and Shackle Type - Voltages not exceeding 1000

Standard	Title
AS 4398.1	Insulators, Ceramic or Glass - Station post for indoor and outdoor use. Voltages greater than 1000 V AC – Characteristics
AS 3609	Insulators - Porcelain Stay Type - Voltages greater than 1000 V AC
AS/NZS 4680	Hot Dipped Galvanised (Zinc) Coatings on Ferrous Articles
AS 1074	Steel Tubes and Tubulars for Ordinary Service
AS/NZ 1163	Cold-formed Structural Steel Hollow Sections

4.2.3.2 Assessment

The assessment of the performance of this sub-asset class is based on the following criteria and measures:

- Crossarm failure rates or breakdown frequency;
- The monitoring of the timely completion of corrective maintenance tasks (notifications) via the asset maintenance monthly reports;
- The monitoring of the Bushfire Mitigation Index; and
- CBRM generated health indexes.

4.2.3.2.1 The Breakdown Frequency

The breakdown frequencies for pole top structures are monitored on a monthly basis. The data for the measurement of breakdown frequency is derived from data recorded as fault notifications and extracted from SAP. This data is monitored for increased failure trends which may indicate possible strategic deficiencies.

A pole top structure breakdown is defined as the in-service failure of the crossarm, conductor supporting brackets or insulator system resulting in the failure of the structure to support or provide insulation of the electrical conductors. Pole top structure failure modes are discussed in detail in Section 4.2.4.2.

As shown in Figure 4-17 and Table 4-18, the number of pole top structure breakdowns occurring on an annual basis is variable with an average of around 24 per annum. A minor peak occurred in 2011 due to adverse weather patterns. This data only considers in service crossarm failures and includes crossarm failures caused by pole top fires.

Table 4-18: Pole Top Structure Breakdown

Crossarm Voltage	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018
LV	7	5	0	23	8	10	7	24	25	25
HV	2	6	46	18	5	9	3	1	5	3
ST	0	0	13	0	1	0	0	0	0	0
Total per annum	9	11	59	41	14	19	10	25	30	28

The age profile of the wood crossarm population indicates that there is a large and increasing population of LV wood crossarms that are operating beyond their expected asset life. This is further highlighted by the volume of LV crossarms in-service failures indicated in Table 4-18.

The volume of in-service crossarm failures of ST and HV crossarms is on a downward trend assisted by the pole top fire mitigation program. This program targets at risk timber ST and HV crossarms and replaces them with new steel crossarms. This trend is expected to continue into the future as the population of these crossarms diminishes with time.

Maintenance plans and projects are reviewed regularly to ensure JEN assets perform satisfactorily, against regulatory obligations and customer expectations. A focus remains on the rectification of maintenance notifications in a timely manner so as to reduce this breakdown frequency.




Figure 4-17: Crossarm failures per annum (in-service and third party impact)

4.2.3.2.2 Corrective Maintenance Measures

The timely and satisfactory completion of identified maintenance tasks and activities are monitored via;

- The Bushfire Mitigation Index.

These are measures of the achievement of performance targets for critical activities in the Bushfire Mitigation and Inspection/Maintenance programs.

The performance of this analysis is underpinned by the following factors:

- There is a very high level of confidence in the accuracy and completeness of data (characteristic and condition) is assumed;
- The asset inspectors apply the asset assessment criteria correctly every time; and
- Pole top failures are always reported accurately in Jemena's corporate systems (e.g. SAP)

The Pole Top sub-asset class has been categorised according to its operating voltages, namely ST, HV and LV.

4.2.3.2.3 CBRM Condition Assessment

Outputs from the CBRM model are used to provide an assessment of crossarm condition. CBRM outputs in the form of Health Indices (shown in sections below) provide a visual demonstration of the condition of the population of pole top structures now and into the future.

4.2.3.2.3.1 ST and HV Crossarms Condition Assessment

Figure 4-18 shows the current Year 0 (2018) health index for the population of ST and HV crossarms.




Figure 4-18: Year 0 (2018) Health Index Profile, ST and HV Crossarms

At Year 7 (2025), the health index is predicted to change as shown in Figure 4-19. A total of 4,433 crossarms will be in poor condition with an associated higher probability of failure (health index of 7 or greater).




Figure 4-19: Year 7 Health Index Profile, ST and HV Crossarms

These results indicate that the majority of the population of ST and HV crossarms are well below their expected life of 45 years for wooden crossarms and 70 years for steel crossarms.

4.2.3.2.3.2 ST and HV Insulators Condition Assessment

Figure 4-20 shows the current Year 0 (2018) health index for the population of ST and HV insulators.




Figure 4-20 Year 0 (2018) Health Index Profile, ST and HV Insulators

At Year 7 (2025), the health index is predicted to change as shown in Figure 4-21. A total of 19,035 insulators will be in poor condition with an associated higher probability of failure (health index of 7 or greater).




Figure 4-21: Year 7 (2025) Health Index Profile, ST and HV Insulators

These results indicate that a significant proportion (almost one quarter) of the population of ST and HV insulators are approaching end of expected life of 45 years.

The risk for both ST and HV crossarms and insulators is combined within the CBRM model to form an assembly. The risk to the network should an assembly fail is highly influenced by risk to network reliability as indicated in Figure 4-22.




Figure 4-22: Risk Profile for Year 0 (2018) and Year 7 (2025), ST and HV crossarms and insulators

The CBRM model forecasts a total of 633 ST and HV crossarms and associated insulators need to be replaced per annum over 7 years to reduce at risk ST and HV crossarm and insulator assembly failures. Assemblies identified as being in poor condition at Year 0 will take priority for consideration of replacement.

In order to maintain the assessed risk associated with the operation of these assets at current (year 0) levels this strategy proposes the replacement of approximately 450 crossarms and insulators per annum over the course of the EDPR period. In addition to this the replacement of a further 460 crossarms per annum are planned as part of the pole fire mitigation program.

4.2.3.2.3.3 LV Crossarms Condition Assessment

Figure 4-23 shows the current Year 0 (2018) health index profile for the population of LV crossarms.




Figure 4-23: Year 0 (2018) Health Index Profile, LV Crossarms

At Year 7 (2025), the health index changes as shown in Figure 4-24. A total of 19,722 crossarms will be in poor condition with an associated higher probability of failure (health index of 7 or greater).




Figure 4-24: Year 7 (2025) Health Index Profile, LV Crossarms

These results indicate that a significant proportion (greater than one quarter) of the population of LV crossarms are approaching their expected asset life of 45 years for wooden crossarms.

4.2.3.2.4 LV Insulators Condition Assessment

Figure 4-25 shows the current Year 0 (2018) health index for the population of LV insulators.




Figure 4-25: Year 0 (2018) Health Index Profile, LV Insulators

At Year 7, the health index changes as shown in Figure 4-26: Year 7 Health Index Profile. A total of 23,225 insulators will be in poor condition with an associated higher probability of failure (health index of 7 or greater).




Figure 4-26: Year 7 Health Index Profile, LV Insulators

These results indicate that significant proportion of the population of LV insulators are approaching their expected life of 45 years.




Figure 4-27: Risk Profile for Year 0 (2018) & Year 7 (2025), LV crossarms and insulators

The risk for both LV crossarms and insulators is combined within the CBRM model to form an assembly. The risk to the network should an assembly fail is highly influenced by the risk to safety as indicated in Figure 4-27.

The CBRM model forecasts a total of 2,817 LV crossarms and associated insulators need to be replaced per annum over 7 years to reduce the risk of LV crossarm and insulator failure. This is a significant increase in replacement rates over the historic levels due to the age profile of these assets.

The CBRM model forecasts are driven by the age profile of the LV crossarm population. Actual asset replacements however are driven by the results of asset inspections. In order to maintain the assessed risk associated with the operation of these assets at current (year 0) levels this strategy proposes the replacement of approximately 600 crossarms and insulators per annum over the course of the EDPR period driven by the results of condition monitoring assessments. In addition to this the removal of all

LV crossarms in the HBRA is planned over the course of the EDPR period as part of the Bushfire Mitigation strategy.

4.2.4 RISK

The major risks associated with pole top structures relate to public safety associated with pole top fires.

4.2.4.1 Criticality

Asset criticality is a measure of the risk of specified undesired events faced when utilising equipment. An asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A. The asset criticality score is then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This is also used to rank importance of dissimilar sub-asset classes (e.g. transformers and surge diverters) to identify areas where risk should be managed first and control measures implemented.

The pole top structures sub-asset class has an assessed asset criticality score of AC1 (Low) due to the consequence of pole top failure in terms of operational and health and safety impacts. These are considered minor impacts on customers.

4.2.4.2 Failure modes

The main failure modes for these assets include:

- **Wooden crossarm age related failure** – occurrence of timber rot (e.g. due to fungal fruit body) or termites reducing the quantity of sound wood until eventually the cross arm breaks, failing to support the insulators and conductors or other cross arm mounted assets;
- **Crossarm fire** – generally caused by excessive electrical tracking across the insulator surface and causing heating to ignition point of structural timber elements. Often this can be attributed to a point contact between the insulator fixing and the cross arm surface due to loose fixing;
- **Insulator failure** – either physical failure due to material defect or applied stress or electrical failure to insulate due to pollution or deterioration of the surface or puncture through the material;
- Breakage of the **mounting hardware** or steel crossarm due to severe corrosion of steel components;
- Breakage of crossarms, insulators and hardware due external influences such as vegetation impact, vehicle impact and extreme wind; and
- Insulator failure due external influences such as vegetation contact, lightning, birds and other animals

Pole top structures have relatively low failure rates (refer to section 4.2.3.1) with minor safety and supply reliability consequences with the exception being large scale pole/crossarm fire events.

4.2.4.3 Current Risks

Risks associated with the management of pole top structures are documented in JCARS and reviewed annually. The main risks for pole top structures are:

- **Pole top fires:** Involve the ignition of pole top assets (including crossarm) generally caused by a combination of environmental related deterioration, loose pole top hardware, un-bonded metallic components and increased leakage currents associated with pollutants and unfavourable weather conditions. The conditions conducive to the ignition of pole top fires typically involve the accumulation of pollutants on the insulator surfaces, often following long dry spells followed by small amounts of moisture from light rain or fog. This allows larger leakage currents to flow resulting in pole top fires;
- **Unassisted in-service age related crossarm failure:** The risk of a crossarm failure during asset operation caused by rot (e.g. due to fungal fruit body), rust (on steel crossarms), termites and incorrect design. Historically, broken crossarms occur largely as a result of deterioration due to rot which occasionally goes undetected from the ground during routine asset inspection;
- **Assisted in-service crossarm failure:** The risk of third-party vehicles or trees impacting on JEN crossarms resulting in asset failure; and
- **Pin Insulators:** Particular line pin insulators have been identified as prone to failure by cracking of the upper or lower porcelain components. Insulator glazing (predominantly brown and grey porcelain type) is also deteriorating. This is generally accepted as an age related deterioration. It results in a build-up of contaminants contributing to larger current leakage which may develop into pole top fires

The main risks outlined above all have similar consequences in terms of supply availability and health and safety. Potential consequence of these events include:

- Loss of supply;
- Minimal impact to the health and safety to staff, contractors or member(s) of the public;
- High Voltage Injection (HVI) due to pole top structure being unable to support the HV conductors which may result in claims for property damage; and
- Risk of a fire start which may result in financial impact to JEN under the regulatory F-factor scheme, or the possibility of a bushfire start.

4.2.4.4 Existing Controls

The principal control applied to the management of the risks associated with the operation of this sub-asset class is the asset inspection program. The likelihood of any of the failure events described above of occurring is almost certain. JEN has a history of pole top fire and assisted and unassisted in-service crossarm failures occurring on an annual basis. To mitigate the likelihood of these risks assets are regularly inspected and assessed so as to maintain a high degree of confidence in the integrity and safety of this sub-asset class. The JEN Asset Inspection Manual (AIM) sets out the criteria and requirements for the inspection, maintenance and replacement of this sub-asset class. This is the principal condition monitoring activity applied to these assets and drives the replacement of these assets base on their condition.

Jemena's design and construction standards, procedures and management plans are also all key controls in reducing the likelihood of these events from occurring. JEN's internal technical standards and design and construction manuals ensure all assets on the JEN network are fit for purpose and have been constructed so as to address and mitigate known risk factors.

Incident investigations are conducted to determine the cause of an asset failure and put in place the appropriate action to prevent this incident from occurring again.

JEN has an established pole top fire mitigation measures to reduce related pole fires. The Pole Top Fire Mitigation (PTFM) program replaces wooden crossarms with steel crossarms for poles and/or feeders that have been assessed as being more susceptible to a fire start. The PTFM program has been effective, as evidenced by the downward trend in pole and crossarm fires. Weather conditions

have a large influence on the number of pole top fires and hence the trend of pole top fires can fluctuate.

Jemena ensure all staff and contractors have up to date training records to ensure they are competent and aware of potential hazards in the field and are able to attend to these risks safely.

The JEN Bushfire Mitigation (BFM) plan is a key control for the mitigation of the risk of fire starts in the HBRA. The JEN BFM plan details the policies and procedures that are to be followed and the preventative and corrective maintenance programs required in order to achieve compliance with the Electricity Safety Act 1998, the Electricity Safety (Bushfire Mitigation) Regulations 2013 and the Electricity Safety (Electric Line Clearance) Regulations 2015. One of the aspects of this plan is the monitoring of BFM program of works to ensure all BFM activities are completed prior to the start of the fire season. Executing this program of works will ensure the potential for a fire start on JEN is minimal.

In conjunction with the JEN BFM plan, the PTFM project has mitigated the risk of pole top fires in HBRA areas. The likelihood of a pole top fire within the HBRA is low, thus Jemena is unlikely to incur a large F-factor penalty.

4.2.4.5 Future Risks

Emerging risks for this asset class include:

- The large population of wood crossarms and insulators that are forecast to be replaced due to age related condition (CBRM assessments); and
- The management of the volume of maintenance notifications associated with this sub asset class.

Jemena's technology strategy involves investigating new technologies to improve network safety and reduce costs. Future improvements being explored for this asset class involve the following:

- The elimination of pole top fires by the accelerated replacement of at risk pole top structures with current steel crossarm designs. This is occurring under the PTFM program, and there has been a downward trend in pole top fires;
- The continued monitoring of the performance of bird and animal protection systems. Investigate the possibility of a retirement program for poorly performing bird and animal covers based on the increase in reliability benefits;
- Consideration of the retrofitting of bird and animal protection on at risk structures in the HBRA. Structures including pole mounted substations, cable head poles, scout surge arresters, some switches or spur fuses. Consideration should also be given to concrete poles with steel crossarms or more complex pole top structures;
- Consideration of the use of steel LV crossarms. There are 2 competing perspectives; continue to maintain open wire LV mains (crossarms required) or, when LV assets become unserviceable replace with LV Aerial Bundled Conductor (ABC). In practice, due to cost factors, it is likely both technologies need to be maintained. This option has a drawback in that the Line Worker Handbook may need a complete rewrite and all line workers will need to be re-trained; and

4.2.5 LIFE CYCLE MANAGEMENT

Since the introduction of the GIS in 1995, SAP in 1998 and Field Data Capture (FDC) units also in 1998, line inspectors have assessed the condition of poles at the ground line and also noted any obvious signs of deterioration of pole top hardware. For many years, emphasis has been placed on investigating asset failures and sharing findings with asset inspectors and accordingly their skill level has increased. Asset Inspectors now monitor the condition of every asset attached to the pole. For the purpose of this sub-asset class, this includes crossarms, insulators, insulator ties, braces, bird covers and bolts.

The options available for asset lifecycle management reflect a trade-off between capital and operating expenditure. The aim is to achieve predictable and sustainable OPEX and CAPEX programs that manage the network risk and deliver improved safety outcomes that are associated with the replacement of unserviceable assets and the deployment of new technologies. The preferred asset lifecycle management option involves condition based replacement of pole top hardware.

The strategy includes time based asset inspections followed by condition based maintenance and replacement, as well as in-service failure based corrective maintenance.

4.2.5.1 *Creation*

New pole top assets are installed on the network as the need is identified by the Customer and System Planning team to meet growth on the network or as required by customer requests.

Three scenarios trigger the need to acquire and install new cross arms and insulator assemblies:

- Installation of new equipment;
- Replacement due to failure; and
- As part of routine maintenance or as a result of overhead line inspection programs.

All new pole tops structures are installed in accordance with the current Jemena design, construction and material standards. The principal standards used for the creation of these assets are;

- Overhead Line Design Manual – JEN MA 0005; and
- Distribution Construction Manual – JEN MA 0006;

4.2.5.2 *Asset Operation and Maintenance*

There are three (3) life cycle management strategies applied to the operation and maintenance of the pole top sub-asset class:

- Condition Monitoring – Asset Inspection;
- Preventative Maintenance - (replacement due to condition); and
- Reactive and Corrective Maintenance

4.2.5.2.1 *Condition Monitoring - Asset Inspection*

Poles and pole tops are inspected as part of the asset inspection program on a five-yearly cycle in the LBRA and a three-year cycle in the HBRA.

Pole and pole top asset inspection is a condition monitoring procedure used to monitor the condition of pole tops and prioritise maintenance and replacement activities intended to maintain network performance at desired levels. The scope of this inspection plan includes wood poles (prevention of climbing animals), transformer bushings, crossarms, crossarm braces, bolts, insulators, conductor, bird and animal covers, fuse brackets, cable terminations and surge arrestors. Identified visible damage and deterioration are attended to on a priority basis. This system of inspection helps to maintain the reliability of HV and ST feeders.

The cycle for pole top inspection is the same as the pole asset inspection cycle and both assets are inspected at the same time. A visual inspection of the pole top is conducted during every inspection to identify detached or damaged pole top equipment (such as splits, cracks and bends in the crossarm), fungal fruiting bodies, rot or missing pole caps. LV ABC brackets are also visually inspected during pole top structure inspections and have a condition based replacement strategy. During the visual

inspection of LV ABC brackets the brackets are assessed and checked to confirm if the galvanising has deteriorated on the bracket.

The asset inspection programs determine the preventive maintenance and planned replacement of pole top structures that could potentially fail causing line outages. For more information on the pole top structure asset inspection program refer to Section 8 – Line Hardware of the AIM.

The asset inspection strategy adopts different inspection programs and cycles dependent on whether pole lines are located in the HBRA or LBRA which are detailed below.

4.2.5.2.1.1 Inspection in the LBRA

In the LBRA pole top structures are inspected as part of the asset inspection program on a five-year cycle. In cases where the inspections identify a pole top structure that looks deteriorated but it is difficult to accurately determine the extent of deterioration, an aerial inspection may be arranged. In these instances an inspection from close-up and from above enables an accurate assessment of the asset condition. This type of assessment is organised at the discretion of the asset inspector.

4.2.5.2.1.2 Inspection in the HBRA

Similarly in the HBRA asset inspection is carried out on the same basis but on a three-year cycle. In addition a visual inspection is currently performed for all lines in the HBRA annually prior to summer. This annual inspection is intended to identify any obvious hardware defects which may result in a fire ignition or cause a supply outage. In addition to this, extensive auditing of lines in the HBRA occurs prior to and during the declared fire danger period.

4.2.5.2.1.3 Private Overhead Electric Line (POEL) Inspection

All POEL are inspected on a three-year cycle; in the HBRA the cycle coincides with the inspection of distribution assets and in the LBRA the cycles are autonomous and mutually exclusive.

For the detailed inspection criteria refer to the JEN Asset Inspection Manual.

4.2.5.2.2 Preventative Maintenance

Pole top structures are considered to be maintenance free. Although methods to treat/refurbish crossarms exist, they are all considered either uneconomical or ineffective. Pole top structures have an expected engineering life of 45 years for wood crossarms and, 70 years for steel crossarms, provided they are installed correctly. No preventative maintenance is undertaken, however the PTFM program requires line workers to inspect crossarms, in the targeted areas, up close from an EWP. Every HV and ST crossarm is assessed for replacement under the PTFM program. All crossarms checked and assessed as not requiring replacement will have all nuts and bolts checked for tightness and tightened as required.

The environmental and atmospheric conditions prevailing across the JEN area do not justify insulator washing programs. In addition these has been found to be ineffective in the prevention of pole top fire. Consequently this activity is not performed on the JEN.

Refurbishment of pole top structures is not an efficient lifecycle management option for crossarms for two main reasons:

- There is no known technology available which can extend the life of already decayed timber; and
- The labour cost associated with an arm replacement far outweighs the material cost. Therefore it is significantly more cost effective to allow a wood crossarm to reach the end of its economic life and then have it replaced with the current standard steel crossarm.

4.2.5.2.3 Reactive and Corrective Maintenance

Any pole top component found to be defective or significantly deteriorated during the asset inspection cycle shall be assigned a priority in accordance with the descriptions in the AIM. Defects are also identified following audits and occasionally work remains to be completed post temporary fault repairs.

Faults and defects that pose a risk to public health and safety will be corrected immediately; using live-line techniques wherever possible.

Pole or pole top fires in particular have a significant impact on the JEN network in terms of network performance and public safety. Pole fire events can be large scale events that occur in a short period of time and may stretch resources. The population of wooden HV crossarms is slowly diminishing due to the practice of replacing wooden crossarms with steel crossarms through the asset replacement process and the PTFM project. The age of the remaining wooden crossarm population is increasing. It is anticipated that the scale and frequency of future pole fire events will continue to decrease as the remaining HV wood crossarms are slowly retired.

4.2.5.3 Asset Replacement

4.2.5.3.1 Replacement of crossarms

Crossarm replacement is the only practical (cost effective) option available for the management of crossarms which have reached the end of their economic life. The criteria employed to determine the end of economic life (asset condition) is optimal from the perspective of ensuring the crossarms are not replaced too early (excessive residual life) or too late (increased failure rate). There are established programs for replacing:

- Deteriorated HV wood crossarms with steel crossarms on distribution and sub-transmission feeders based on crossarm condition;
- Deteriorated LV wood crossarms based on asset condition; and
- HV and ST crossarms as part of the pole top fire mitigation program. Inspections of identified high risk areas, nominate replacement of all crossarms with brown pin, brown post or brown disc insulators. Replacement of crossarms with other types of insulators mounted on them will be prioritised based upon evidence of charring, arcing or unacceptable deterioration of condition (e.g. cracking, deglazing, corrosion and crossarm damage).

The asset inspection programs drives the crossarm replacement requirements, refer to section 8 – Line Hardware of the AIM for details of the criteria for asset replacement.

4.2.5.3.2 Replacement of insulators

4.2.5.3.2.1 Replacement of 66kV Brown & Grey Fog Pin Insulators

Insulator replacements occur as part of the crossarm replacement works. There is no current program for the targeting of these particular insulator types aside from the crossarm replacement program. If any 66kV brown or grey fog pin insulators are identified as defective during inspections or other work, they shall be scheduled for replacement with current standard insulators and a steel crossarm. Also during conductor replacement or augmentation projects any 66kV brown or grey fog pin insulators shall be opportunistically replaced with current standard insulators and crossarms as part of the project.

4.2.5.3.2.2 Replacement of Superseded 5 Shed 22kV Post Insulators

There has been a history of faults caused by bird flash-over across the superseded 22kV 5 shed 565mm creepage post insulators, which were mounted vertically or horizontally on steel crossarms or wooden crossarms on concrete poles. These are suitable for use on wooden poles only.

When these insulators are identified during inspection, and are mounted on a concrete pole, they will be replaced with the “stretched” 9 shed version of the same creepage distance, but 485mm physical clearance.

4.2.5.3.3 Pole Top Replacement - Forecast Volumes

As detailed in this strategy, a number of projects have been identified to ensure that we maintain network performance, and also address our compliance requirements.

Table 4-19: Pole Top Forecast Replacement Volumes

Service Code	Pole Top Structures	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RXG	ST Insulators Replacement	10	10	10	10	10	10
RXI	HV Insulators Replacement	51	49	49	49	49	49
RXH	HV Crossarm Replacement	380	362	362	364	365	364
RXH	Pole Top Fire Mitigation	586	459	459	459	459	459
RXL	LV Crossarm Replacement	526	606	606	606	606	606
RXS	ST Crossarm Replacement	20	19	19	20	21	20
PDS	Bird/Animal Proofing	13	18	18	18	18	18

4.2.5.4 Asset Disposal

Pole top structures are not normally repaired as a failure usually results from condition or external factors which have damaged the asset beyond repair and usually require the asset to be replaced.

Pole top structures such as crossarms, insulators, braces etc. do not contain hazardous materials and should be disposed of in accordance with JEM PO 1600 (Scrap Materials Policy).

4.2.5.5 Spares

As part of criticality assessment consideration is given to appropriate levels of spare equipment. Spares requirements for critical assets are assessed by following Critical Spares Assessment Procedure (JEM AM PR 0015). It has been determined that adequate spares are maintained at Tullamarine depot and stock holdings are managed by Services and Projects

4.2.6 INFORMATION

Jemena's AMS provides a hierarchical approach to understanding the information required to achieve Jemena's business objectives at the Asset Class level. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and the Asset Class Strategy (ACS) all provide the context for and determine the information required to manage and operate an Asset Class.

From these business objectives, it is possible to identify at a high-level the content of the business information systems required to support these objectives (Table 4-20).

Table 4-20 Pole Top Sub-Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Information Sources	Externally Sourced Data
Operational Excellence <ul style="list-style-type: none"> • Manage assets throughout their lifecycle in safe and environmentally responsible manner • Maintain assets in accordance with RCM principals • Maintain asset information/knowledge to enable efficient and effective decision making • Embed continuous improvement throughout asset lifecycle Customer <ul style="list-style-type: none"> • Maintain our current service levels • Incorporate customer feedback in our decision making process Growth <ul style="list-style-type: none"> • Acquire/install/maintain assets to meet future demand requirements People <ul style="list-style-type: none"> • Maintain safe work environment • Engage team leaders in assessment of new assets • Training 	GIS/JEN Viewer <ul style="list-style-type: none"> • Geospatial representation of the JEN Network • Asset attributes SAP <ul style="list-style-type: none"> • Work schedule & status • Planned and corrective (faults) maintenance records • Asset inspection measurements • Financial information ECMS <ul style="list-style-type: none"> • Asset Inspection Manual, inspection methods & criteria • Policies, procedures and guidelines • General asset audits/surveys not stored in SAP • Incident investigations Drawbridge <ul style="list-style-type: none"> • Standards • Operations diagrams • Line design manual • Construction manual SCADA/RTS <ul style="list-style-type: none"> • Outage Management System (OMS) & SCADA (DMS) • Planned and Unplanned outages JEN Analytics <ul style="list-style-type: none"> • Power quality data • Energy consumption 	<ul style="list-style-type: none"> • Current cadastre (including land ownership) for JEN's geographical extent. • DELWP - HBRA and LBRA area boundaries • CFA for fires, warnings and restrictions, incidents • Emergency Management Common Operating Picture (EM-COP) • Aerial Imagery for JEN's geographical extent (NearMap) • Google 'Street View' • Melway • SAI global (Australian and International Standards) • ESV / ESC / AER for regulatory obligations

Table 4-21 identifies the current and future information requirements to support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-21: Pole Top Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
Pole top acquisition and application	<ul style="list-style-type: none"> • Purchase specification (ECMS) • Distribution Design Manual (ECMS) 		<ul style="list-style-type: none"> • High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
	<ul style="list-style-type: none"> • Distribution Construction Manual (ECMS) • Period contracts (ECMS) • Logistics system (SAP) 		
<ul style="list-style-type: none"> • Life cycle management: • Asset identification • Condition monitoring • Condition assessment • Replacement / retirement strategy • Disposal 	<ul style="list-style-type: none"> • Each asset identified by geospatial representation in GIS and equipment ID in SAP • Asset Inspection Manual (ECMS) • Maintenance plan (SAP) • JEN Analytics (e.g. deteriorated neutral) • Measurement record (SAP / ECMS) • PM Notifications/Orders (SAP) • Strategy detailed in this document • GIS asset attributes: <ul style="list-style-type: none"> - Asset status (e.g. existing/historical) - Status (in service, isolated, out of commission) - Operating voltage - Pole number (A-number) - Asset Status (e.g. existing) - Rated Voltage (for insulators) - Type - Material - Length - Depth - Width - Date Installed - Date Removed • Fault / failure records: <ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 	<ul style="list-style-type: none"> • No of Insulators • No of Armour Rods • No of Sheds • Near real time updating of asset record • Photos database of all failed assets • Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> • High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Table 4-22 provides the information initiatives required to provide the future information requirements identified in Table 4-21. Included within this table is the risk to the Asset Class from not completing the initiative.

Information required to support asset strategies, performance and risks is recorded in SAP, Geographic Information System (GIS) and ECMS. Additional fault related data is available in the

Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

SAP is used to capture assessment records, defect Notifications, PM Orders, Labour and Material costs, maintenance plans etc. The list is extensive but can generally be categorised as condition information or lifecycle management information.

Table 4-22: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information capture	Ability to capture all relevant asset attributes from the field through mobility solution.	High	Complete, Current, Accurate attribution
Improve/review MAT Code definitions	Ability to align to AER service classification structure.	High	Precise definition
Improved Asset Attributes	Review current asset attribution fields to ensure attributes being collected are asset specific.	Medium	Appropriate and Accurate attribution
Increased Timeliness	Decrease latency between fault/maintenance delivery and fault/maintenance record capture.	High	Complete, Current, Accurate attribution
Improved fault information capture	Ability to capture all relevant asset failure information from the field through mobility solution and photos.	High	Complete, Current, Accurate fault information

4.3 CONDUCTORS AND CONNECTORS SUB-ASSET CLASS

4.3.1 INTRODUCTION

Jemena owns and operates approximately 5000 km of overhead conductor at various operating voltages. This represents approximately 70% of the distribution network by network length. In conjunction with this there are many thousands of connectors deployed across the network.

4.3.1.1 Conductors

The overhead conductor types in use across the JEN include:

- All Aluminium Conductor (AAC);
- Aluminium Conductor Galvanised Steel Reinforced (ACSR);
- Copper Conductors;
- Cadmium Copper Conductors;
- Galvanised Steel Conductors;
- Low Voltage Aerial Bundled Conductor (LV ABC); and
- High Voltage Aerial Bundled Conductor (HV ABC)

These conductors are deployed on the Subtransmission Network, the High Voltage Distribution Network and the Low Voltage Distribution Network. AAC type conductor is the current standard for all overhead HV and ST urban applications. LV ABC is the current standard for all overhead LV applications and is used in both urban and rural areas.

Aluminium and copper overhead conductors have been used in urban areas for residential, commercial and industrial distribution. They have also been used for the construction of subtransmission lines all over the network. The design and construction of subtransmission lines generally involves the use of large capacity conductors and the use of longer spans. Consequently the mechanical loads and associated conductor stringing tensions are high and approach the structural limits for the supporting structures.

Steel conductor is used mainly in rural areas where long spans are necessary to cover larger distances with small electrical load densities. Steel conductor used in the rural areas is also strung at very high stringing tensions and therefore armour rods and vibration dampers must be installed to combat conductor damage due to wind induced conductor vibration. This means that again the supporting structures operate at loads approaching the design limits. Fault levels are also an issue wherever steel conductor is used and care needs to be taken to protect the steel conductor from fault levels that could result in damage to the conductor or conductor burn down due to the passage of fault current.

Historically a large range of conductor types and sizes have been used to construct the network. Consequently a large range of sleeves, wrap-ons, connectors and spare conductor needs to be kept to facilitate the maintenance and repair of these assets.

Table below indicates the length of overhead conductors by voltage category on JEN.

Table 4-23: Conductor Length by Voltage

Conductor	LV	6.6kV	11kV	22kV Single Phase	22kV Multi Phase	66kV
Length (m)	2,457,372	55,539	210,575	243,867	1,198,130	327,800

4.3.1.2 Connectors

Connectors are categorised as either full tension or non-tention types. There are hundreds of non-tension and full tension connectors on every feeder out of every zone substation. In addition there are many thousands on the associated low voltage networks.

The standard full tension connector for use with AAC conductor is the compression sleeve. The standard non-tension connector for use with AAC conductor is the fired wedge type (Ampact) connector. Historically many types of non-tension connectors have been used on the network including compression sleeves, parallel groove (PG) clamps, D clamps, U-Bolt connectors, split bolts and fired wedge (Ampact) connectors. These connectors are on every strain, tee off, cable head, anchor pole, etc.

Full tension connectors are not used with LV ABC, rather the cable is terminated at a pole and connected to the next span using non-tension insulation piercing connectors.

4.3.2 ASSET PROFILE

4.3.2.1 Life Expectancy

The life expectancy and information on the range of installation dates for the various conductor types used on JEN are indicated in Table 4-24. The oldest copper conductors in service date from the 1920's. The current standard Aluminium Alloy Conductor (AAC) was first introduced in 1975 and is the most widely used bare conductor in the urban areas.

Table 4-24: Conductor and Connector Life Expectancy and Installation Date

Conductor Type	Installation Years	Useful life 'Y' (Nominal Years)	Span Y-X (Nominal Years)
Copper	1920 – 1960	60	20
Cadmium Copper	1960 – 1975	60	20
Steel (Sc Gz)	1960 – 1975	50	20
ACSR	1960 – 1975	50	20
AAC	1975 – present	60	20
LV ABC	1990 – present	50	20
HV ABC	1994 – 2011	35	10




Figure 4-28: Graph of Conductor and Connector Wearout Characteristic

Conductor and connectors displays a wear-out characteristic of the type indicated in the Figure 4-28 above, with the onset of wear out at the end of the useful life. Asset failure follows a normal distribution at the end of the useful life period.

Despite the wearout characteristic above the life expectancy of connectors is a far more complex issue as it is very dependent on the following factors:

- Workmanship;
- Correct selection of size;
- Conductor type and size;
- Electrolytic corrosion associated with dissimilar metals;
- Conductor preparation; and
- The magnitude and frequency of load cycles.

In addition the lack of data on connector types and their location on the network makes detailed analysis of their performance problematic.

4.3.2.2 Age Profile

The age profile for overhead conductor on the JEN is categorised by voltage in Figure 4-29 below. The graph indicates a step change in the rate of installation of overhead conductor that occurred around the time of the privatization of the electricity industry. This coincided with a legislated change in construction methods requiring all new residential development to occur using underground services. This change is also reflected in the age profile data for underground cable which indicates a corresponding increase in the rate of installation of underground cable from 1990 onwards.

The rate of installation of overhead conductor in all voltage categories has remained approximately constant over the last two decades with the exception of HV single-phase overhead conductor. The installation rate of this conductor has increased in recent years due to the steel conductor assessment and replacement programs. These programs have resulted in the replacement of significant lengths of corroded steel conductor. In addition the removal of the Single Wire Earth Return (SWER) systems in the HBRA, to mitigate the fire start risk associated with these systems, has resulted in the growth in the installed length of HV single phase overhead conductor.




Figure 4-29 Conductor and Connector Age Profile

There is a small quantity (approximately 1.3km) of non-metallic screen HV ABC overhead conductor installed in the LBRA area of JEN. There is none of this cable type installed in the HBRA. This cable design has been found to suffer premature failure in service associated with the installation method. JEN has about 500m in service that is in excess of 20 years old.

4.3.2.3 Utilisation

4.3.2.3.1 Distribution Feeder Ratings

The capacity of a feeder is usually limited by the current carrying capacity of the overhead or underground sections on the main backbone. The limiting section of a backbone is likely to be close to the zone substation.

Generally feeders are loaded up to 70-85% utilisation as this is the point most augmentations become economic. This allows part of the load from a faulted feeder to be transferred to each adjacent feeder at peak.

In some areas this may not provide 100% backup due to insufficient ties and so emergency ratings may need to be utilised. It is a matter of probabilistic analysis as to the amount of risk this represents. Once the utilisation moves above 67% there will be in general a less than 100% backup capability.

4.3.2.3.2 Overhead Line Rating

The current construction standard for new overhead lines is for a maximum operating temperature of 65°C. Many older lines were built to 50°C (120°F) maximum.

Current ratings are based on a summer ambient temperature of 35°C and a winter ambient of 10°C and a wind speed of 0.6 m/s. As there are many days where the summer ambient is above 35°C, this rating basis is currently under review.

Feeders are also limited by the differential rating which is generally based on the worst case of the minimum clearance obtained when a loaded feeder is above a subsidiary circuit at minimum temperature.

It is possible to operate AAC conductors at up to 80°C without long term annealing occurring providing that there is adequate ground and circuit to circuit clearance. Generally only new feeders are designed for the higher (80°C) maximum operating temperatures and in special situations.

Existing feeders can also be up-rated from 65°C to as high as 80°C. Up-rating can only be carried following a detailed survey of the conductor clearances. If the sections to be uprated are in urban areas where the span lengths are invariably short it has been found that very little construction work is required to achieve the up-rating. Up rating has implications for the performance of all the associated connectors.

There are no emergency ratings for overhead lines, however dynamic wind ratings may be available for certain weather conditions.

4.3.3 PERFORMANCE

4.3.3.1 Requirements

The requirements for overhead conductors and connectors are set out in JEN's technical specification "66kV, 22kV, 11kV and LV Overhead Conductors and Underground Cables" which references a number of relevant Australian Standards (see Table 4-25). In order to ensure that overhead lines achieve their designed operational ratings and ensure network reliability is maintained overhead lines are installed in accordance with the requirements of the following Jemena standards:

- Overhead Line Design Manual – JEN MA 0005;
- Distribution Construction Manual – JEN MA 0006; and
- Jemena Planning Manual – JEN MA 0010

JEN's internal standards ensure compliance with a number of regulations that cover the installation of overhead conductor systems. These standards include design parameters which address areas including clearances, conductor stringing, conductor clashing, and the recording of asset data including asset location and type.

All overhead conductors are assigned ratings (including cyclic ratings) that are based on the type of conductor, ground clearances and circuit to circuit clearances. In addition fault ratings for conductors are specified to ensure cables are matched to the networks fault levels.

The monitoring and optimisation of the performance of the overhead distribution systems occurs via the use of the following systems and programs:

- Feeder loads are monitored and managed via SCADA;
- The LV network loads are monitored via the business objects application using AMI data;
- Faults and failures are monitored via the Outage management system (OMS);
- Defects and failures are monitored via the Plant Maintenance notification systems (SAP);
- The in service operating temperatures of conductors and connectors are monitored via infra-red thermal surveys with the intention of finding and preventing defects from becoming faults; and
- Monthly asset performance review meetings review performance and faults.

Table 4-25 Conductor and Connectors - Relevant Australian Standards

Standard	Title
AS 1222	Steel Conductors and Stays - Bare Overhead Part 1 Galvanized (SC/GZ) Part 2 Aluminium Clad (SC/AC)

Standard	Title
AS 1531	Conductors - Bare Overhead - Aluminium & Aluminum alloy
AS 1746	Conductors - Bare overhead - Hard drawn copper.
AS 3607	Conductors - Bare Overhead, Aluminium and Aluminium Alloy – Steel Reinforced

4.3.3.1.1 Current Jemena Standards for Overhead conductors

The following standard overhead conductors are used for 11kV and 22kV distribution feeders:

- 19/3.25 AAC ¹(Standard); and
- 19/3.75 AAC (High capacity)

19/3.25 AAC is the preferred choice for all new overhead construction.

In the former Municipal Electricity Undertaking (MEU) area of Footscray 19/3.75 AAC was used to match the capacity of the original 0.2 square inch Copper conductor feeders.

19/3.75 AAC is used in heavy industrial areas, where high capacity interconnections are required or in stations where additional feeder exits are not available.

6/1/3 ACSR is used at rural locations where load densities and lower fault levels exist, for example spurs that are not likely to become a tie line or part of the backbone feeder or have a substantial load increase in the foreseeable future. Voltage drop and network losses need to be considered where this conductor is used.

The standard overhead LV mains conductor is 150mm² LV ABC.

4.3.3.2 Assessment

Specific conductor and connector performance measures (and condition monitoring) include the following:

- Reporting tree related faults;
- Fire starts; and
- Maintenance notifications resulting from the infra-red thermal surveys.

Each of these targets is reported on a monthly basis in the JEN Customer & Asset KPI's at an aggregate level, to which performance of conductor and connectors contribute Figure 4-30 shows the downward trend of conductor failures.

¹ 19/3.25 AAC is the naming convention used to describe conductor size and type. That is 19 strands of 3.25mm diameter aluminium alloy conductor. Approximately a 150mm² cross sectional area.




Figure 4-30 Conductor and Connector Failures by fault cause category

4.3.4 RISK

4.3.4.1 Criticality

Asset criticality is a measure of the risk of specified undesired events faced when utilising equipment. Asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A. The asset criticality score was then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This is used to rank importance of dissimilar sub-asset classes (e.g. transformers compared with buildings and grounds) to identify areas where risk should be managed first and control measures implemented.

Conductor and connectors sub-asset class has an asset criticality score of AC4 (High) due to the health and safety consequences (for example, accidental connection with switch wire).

Due to the availability of ground fuel in the HBRA, if a fire were to ignite, Jemena's historical record shows, it is often an acre or more in size which catches fire. Recognising this Jemena has implemented several programs in the HBRA to minimise the likelihood of connector or conductor failure. The programs include:

- Steel Conductor Assessment Program (SCAP) which prioritises the replacement of steel conductor based on the assessed condition. This program is in addition to the routine asset inspection program;
- Installation of vibration dampers and armour rods where required. This program is complete for all conductor type/materials in the HBRA; (The equivalent program in the LBRA is scheduled to be completed by end of 2020 in line with regulatory requirements);

- Replacement of unreliable non-tension connectors (e.g. parallel groove clamps, wire wound D-loops);
- Installation of LV spreaders where required;
- Removal of open wire LV mains in the HBRA;
- Routine asset inspection – 3-year cycle;
- Dedicated Hazard Tree management program; and
- Auto Reclose suppression for feeders in the HBRA on Total Fire Ban (TFB) days

Most of these programs have been initiated by Jemena to maintain network performance at desired levels and address known defects. A number result from recommendations made in the Final Report handed down by the Victorian Bushfires Royal Commission into the fires of Black Saturday, 7 Feb 2009.

Recommendation 66 of that report directed the State to appoint an independent monitor to assess the State's progress with implementing the Commission's recommendations. For a detailed statement of progress refer to the "Annual Report July 2014" prepared by the Bushfires Royal Commission Implementation Monitor.

4.3.4.2 *Failure Modes*

Failure modes for conductor and connectors include:

- Corrosion of conductor material resulting in reduced cross sectional area, reduced tensile strength, conductor annealing and ultimately fusion and physical breakage, this is particularly an issue for steel conductor, ACSR and small cross-section AAC;
- Conductor breakage due to work hardening embrittlement caused by wind induced aeolian vibration This leads to fatigue failure of the conductor;
- Conductor overload resulting in elevated operating temperatures which leads to conductor annealing, loss of tensile strength, increased conductor sag and reduced conductor clearances;
- Corrosion of connector/conductor interface causing high resistance joint, and fusion particularly when conducting fault currents;
- Loss of clamping tension due to load cycling of connector resulting in breakage or fusion of joint;
- Conductor breakage due to external influence such as vehicle impact to poles or trees falling onto lines;
- For non metallic screened HV ABC, insulation deterioration and progression to flashover between live conductor and earthed screen, causing molten particles to fall with very high risk of fire starts; and
- Theft of copper conductor.

The consequence of these types of failures of conductors and connectors can include equipment damage, supply outages and damage to customer's equipment from HV injections. However, the criticality assigned to this asset group results principally from the risks associated with three major failure consequences, namely:

- Supply interruption;
- Fire start including bushfire start; and
- Electric shock or electrocution associated with live conductors on the ground.

Of the above consequences, supply interruption is the most likely to occur. Electric shock or electrocution is a rare consequence and fire starts most commonly occur in the LBRA and are generally restricted to a small portion of a nature strip.

Fire starts can also have a financial impact for JEN under the regulatory F-Factor scheme. Figure 4-30 above indicates a downward trend in conductor/connector failures on JEN, for both those caused by third parties and those related to asset failure. This can be attributed to the various proactive replacement and maintenance programs that JEN has implemented in the last few years to address various known conductor and connector issues. More detail on these strategies is included in section 4.3.5, Life Cycle Management.

4.3.4.3 *Current Risks*

The major risks associated with conductor and connectors are related to the consequences of failure mentioned above. These risks are documented and responsibilities are assigned and tracked in JCARS (Jemena Compliance and Risk Systems) as outlined in the Jemena Compliance Management System Manual (JEM RCM MA 0001).

In the Victorian Electricity Supply Industry, a number of incidents have occurred while work crews have been performing “Live Line” glove and barrier work on 7/2.5 and 7/3.0 AAC conductor. In these cases the conductors involved had experienced excessive conductor damage at the point of contact with the insulator. This damage was not obvious to the lineworkers until the conductors were untied and lifted from the insulator. The cause of the conductor damage in these cases was aeolian vibration caused by the effect of steady winds on long spans of tightly strung conductor. This has led to live line work ceasing on these conductor types.

Similarly there are sections of 7/.064 copper conductor on the Jemena network that cannot be worked on live due to the risk of conductor breakage. Consequently this has an impact on planned SAIDI.

The range of full tension type connectors used on the JEN include compression sleeves, helical splices, McIntyre sleeves and automatic line splices (Fargo sleeves). The use of Fargo sleeves on JEN has been banned due to a number of in-service failures associated with poor electrical connection at low stringing tensions and copper McIntyre sleeves are being phased out in favour of compression sleeves. The location and number of full tension connectors installed is not known and is very difficult to estimate. Although a program was undertaken to identify and remove Fargo sleeves from service proactively in the early 2000's they continue to be identified from time to time by the asset inspection program.

The passage of fault current on HV feeders can result in secondary damage at connectors, in particular non-tension connectors such as PG clamps, Dee loops and U-bolt connectors. This occurs typically at bridges on strian structures, tee-offs or at switches and isolators. This type of secondary damage reduces system availability and the ability of the HV network to successfully restore supply in the event of transient faults. The reasons for this are:

- Damaged connectors can fail under load current at some time after the original fault;
- Single phasing of customer loads can result from failed connectors;
- Feeder patrol after a fault takes longer than necessary due to the need to inspect for obvious secondary damage. The requirement to patrol for secondary damage also reduces the potential effectiveness of automation and remote control systems; and
- Restoration of supply after a fault takes longer due to the need to repair secondary damage.

Patrol of feeders after faults can only identify visibly failed connectors, but not potential connector failures that could fail on re-energising or at a later time resulting in another outage.

4.3.4.4 Existing Controls

Table 4-26 below summarises some of the key controls currently applied to maintain an acceptable risk rating for the conductor and connectors sub-asset class. These risk controls result in a 'Moderate' risk rating for the sub-asset class. That is down from the untreated risks level which was assessed as a 'High' risk. The details of the current risk assessment is recorded in the relevant risk register in JCARS.

Table 4-26: Existing Controls – Conductors and Connectors

Control Name
Design and Construction Manuals (provides a cohesive and consistent approach for the distribution network)
Thermal inspection program (1-3 year cycle) provides proactive alerts ahead of asset failure – Key control
Asset inspection manual (defines process and procedure for asset inspection) - Key control
Electric line clearance management plan (enables effective management of vegetation in vicinity of conductors) - Key Control
Steel Conductor Assessment Program (SCAP) which targets replacement in the HBRA – key control in the HBRA
HV spreader installation and removal policy (redesign structures to prevent clashing)

4.3.4.5 Future Risks and Opportunities

Conductor and connector risks are not expected to change in the near future. However, future improvements have been suggested to manage the current level of risk. Analysis of feeder faults involving secondary damage indicates that non-tension connector failure is a major cause. This has a significant impact on both SAIDI and SAIFI reliability indices.

The following are some options and strategies that Jemena is considering to minimise future risks:

- Expanding the non-tension connector replacement program to feeder spurs not just the feeder backbone;
- Expanding the SCAP program in the HBRA to include conductor materials other than just steel conductors (e.g. copper, aluminium). Lines built with these other materials are of similar age to the steel conductor;
- Exploring other non-tension connector technologies (other than Ampact) to improve work practices; and
- Introducing modern HV ABC technology. Other DNSP's have experienced significant failures on non-metallic screened HV ABC conductor systems including fire ignitions. JEN has a small quantity of this cable type (1.3 km) located in the LBRA. The consequences of failure of these assets is deemed low given all of the HV ABC population is located in the LBRA area. Therefore, proactive replacement of these is not recommended at this stage.

4.3.5 LIFECYCLE MANAGEMENT

The options available for asset lifecycle management reflect a trade-off between capital and operating expenditure. The aim is to achieve predictable and sustainable OPEX and CAPEX programs that manage the network risk and deliver improved safety outcomes that are associated with the replacement of unserviceable assets and the deployment of new technologies. The preferred asset lifecycle management option involves condition based replacement of conductor and connectors hardware.

This strategy is based on asset inspections and condition assessment followed by condition based maintenance and replacement, as well as in-service failure based corrective maintenance.

The effective management of these assets will reduce the number of faults caused by connectors burning out, and reduce incidence of secondary damage.

4.3.5.1 *Creation*

The need to acquire and connect new conductor and connectors is driven by:

- Installation of new overhead lines (may or may not include upgrade of existing lines) to facilitate the connection of new load and accommodate organic load growth;
- Replacement due to asset failure; and
- Condition based proactive replacement.

The various types of conductor and connectors are typically purchased using period contracts in accordance with the requirements of the Distribution Construction Manual (JEN MA 0006) and the applicable material specifications.

4.3.5.2 *Asset Operation and Maintenance*

There are three (3) life cycle management strategies applied to the operation and maintenance of the conductor and connector sub-asset class:

- Asset Inspection and Condition Monitoring;
- Preventative Maintenance; and
- Reactive and Corrective Maintenance.

4.3.5.2.1 *Asset Inspection and Condition Monitoring*

Inspection of conductor and connectors is conducted as part of the overhead line inspection program, in accordance with the requirements of the Asset Inspection Manual (JEN MA 0500). The Asset Inspection Manual details the processes and procedures for JEN asset inspection and is the basis for routine inspections, observations and assessments. These criteria are applied by asset inspectors in order to maintain the integrity of the conductor and connectors sub-asset class.

Maintenance notifications are raised for the rectification of defects or replacement of assets as identified by the asset inspectors.

Thermal surveys have been altered and are now conducted on variable cycle which consists of an annual, two-year and three-year cycle. HV feeders are allocated to each group on the basis of risk ranking. High risk feeders, which are surveyed annually, are all business (e.g. industrial, commercial, hospital), highly loaded feeders (> 80%) or feeders with greater than 2,500 customers. Feeders with an average fault history of greater than 3 faults per annum will be surveyed on a 2-year cycle. All other low risk feeders are to be surveyed on a 3-year cycle. If a feeder is deemed a "rogue" feeder then an additional survey may be ordered. All subtransmission lines are to be thermal surveyed on a 2 year cycle.

This enables, any faults detected by asset inspections and thermal surveys to be recorded and packaged into logical groups for maintenance rectification in the same electrical area. A complete list of all the feeders and the cycles can be found in SAP Maintenance Plans.

Steel conductor in the HBRA is visually assessed on a routine 5 year cycle to determine the extent of any conductor corrosion. High quality aerial photographic techniques are utilised to provide accuracy, consistency and confidence in the assessment. This technique has been implemented successfully for

steel conductor; a program is currently being developed to test this technique on other conductor materials (i.e. other than steel) in the HBRA.

During this Steel Conductor Assessment Program (SCAP) the conductor is assigned a condition category from 1 to 10; where 10 is new conductor and 1 is severely rusted conductor. Steel conductor assessed with condition categories between 1 and 5 inclusive will be planned for replacement (projects are initiated) during the five-year period before the next inspection. Locations with Conductor Categories of 6 (CC6) may also be considered for replacement by the project initiator.

4.3.5.2.2 Preventative Maintenance

The following are the key preventive strategies and options applied to the JEN network to manage the conductor and connector sub-asset class:

- The minimisation of end-of-life failures (typically due to corrosion) by specifying observable condition criteria, currently available for steel. Criteria are currently being developed for copper and aluminium conductor;
- The minimisation of the number of trees contacting overhead conductor. The single biggest cohort responsible for conductor breakage is trees. Jemena has implemented vegetation management programs to minimise the occurrence of these faults and is now supplementing the HBRA programs with a continuing hazard tree management program;
- To maximise asset life and performance Jemena have standardised on the use of All Aluminium Conductor (AAC) and Ampact connectors. In addition to cost savings through economies of scale these standards are proving beneficial in other ways. These include: minimised the variety and number of tools required; minimised the variety of spares held in stock; simplified work method statements and thereby improved safety of line workers; there have been no recorded cases of corroded aluminium conductor on JEN;
- It is more cost effective to use steel conductor in the HBRA due to the length of spans which can be achieved. In the absence of empirical data it is assumed vibration dampers will extend the life of conductor by reducing micro abrasion caused by aeolian vibration. It must be noted that the installation of vibration dampers and armour rods in accordance with the standard is a regulatory obligation;
- All HV and subtransmission non-tension connections shall be made with Ampact fired wedge connectors only (according to the JEN standard there are some exceptions for steel and copper conductor). On the LV network Ampact fired wedge connectors shall also be used. Ampact connectors shall be used as follows:
 - if two copper conductors larger than 19/2.00 or equivalent require connection use a copper Ampact;
 - use brass split bolts for all other for copper to copper conductor connections; and
 - if two aluminium conductors require connection, use an aluminium Ampact.
- When a copper conductor needs to be joined to an aluminium conductor use a bi-metal Ampact and ensure the aluminium conductor is above the copper conductor to prevent corrosion;
- When maintenance or refurbishment works on HV line switches is undertaken connections shall be changed to Ampact stalk lugs;
- Copper to aluminium D loops with Live Line Clamps (LLC) are to be replaced with Ampact stainless steel LLC bails. Copper to aluminium D loops with split bolt connections are to be removed and replaced with Ampact stainless steel LLC bails;
- Aluminium alloy LLC's are to be replaced with brass LLC;
- Aluminium split bolt clamps are not to be used and shall be removed;

- Dampers and armour rods are to be installed at spans in accordance with the Line Construction Manual and at sites that have shown signs of Aeolian vibration damage. All steel conductor spans on intermediate poles in the HBRA will have armour rods and vibration dampers installed;
- All Fargo automatic line splices shall be removed and replaced with current standard full tension sleeves;
- All conductors shall be properly prepared i.e. brushed and cleaned before making connections;
- Aluminium conductors are to be located above copper conductors to avoid corrosion;
- On bridges remove non tension sleeves and replace with a continuous bridging conductor connected with Ampacts at each end. Non tension sleeves in air break switch tails can remain in service if each end of tail has already been Ampacted and there is no defect on the non-tension sleeve;
- Bridges shall contain no more than two connections and shall be replaced with a conductor of equivalent rating or greater than the line conductor;
- New LV isolators shall be fitted with stalk lugs and old isolators changed to current standard;
- LV spreaders shall be fitted to LV conductors within HBRA on all spans;
- If double Ampacting is required, Ampact wedges must be installed 200 mm apart and both wedges must be fired in the same direction to prevent caging the conductor;
- Whenever a connector is being replaced on a pole, all HV connectors on each phase on that pole are to be replaced;
- There is no requirement to retain bolted non-tension connectors. Once such a connector is taken off the line it is not to be used again;
- All open wire LV spans in the HBRA will be fitted with spreaders (maximum 75m spacing between spreaders or spreader and crossarm as specified in the Asset Inspection Manual);
- All HV steel conductor on intermediate crossarms in the HBRA will be retrofitted with armour rods and vibration dampers; and
- All other conductor construction types (e.g. AAC, ACSR, Cu etc.) on intermediate crossarms in the HBRA will be retrofitted with armour rods and vibration dampers in accordance with the requirement of JEN standards.

4.3.5.2.3 Reactive and Corrective Maintenance

All reactive and corrective maintenance tasks result in the raising of a maintenance notification in SAP. Faults and defects are reported and rectified in accordance with directions given by the Control and Dispatch Centre or the priority assigned by the asset inspector.

4.3.5.3 Asset Replacement

The majority of all bare overhead conductors on the JEN are in good condition. The replacement strategies detailed below are specifically focused on stabilising and maintaining asset performance through replacement of conductor and connectors with identified poor performance issues.

The following replacement strategies are being applied to the conductor and connector sub-asset class on the JEN:

- The bulk replacement of connectors, such as PG clamps, U-bolts and Cu to Al Tee clamps, (Dee loops) on the HV system with Ampact fired wedge connectors shall be undertaken where fault mapping and cost benefit analysis shows this to be economically viable. This program proactively replaces non-tension connectors in the backbone of HV feeders and at the start of feeders based on fault history and I^2t or fault level considerations;
- The replacement of corroded copper and steel, and aluminium steel re-enforced conductors will be based on condition inspections and conductor failure history;
- The future replacement non-metallic screened HV ABC is likely to be required based on evidence from other DB's and at least one failure within JEN. The failure rate and condition of this type of cable is being monitored, with failures anticipated to start occurring from 25 years of age. Replacements are to be assessed on case-by case basis, with options being, underground cable section, return to standard bare overhead where possible or installation of new fully screened and earthed HV ABC;
- The proactive retirement of public lighting switch wire. This is a program that involves public lighting switch wires which have been largely redundant since the mid 1980's as lighting control was transferred to photo electric switching on each lantern. On the JEN the switch wires were not removed when old style luminaires were replaced with PE cell controlled luminaires and in many areas have remained in place for over 30 years as an unmaintained asset. A program to remove switch wire was undertaken by JEN in the previous regulatory period, and JEN is on track to deliver against those targets. The objective of this program is to remove the remaining public lighting switch wire to reduce operating risks and hazards and eliminate the risk associated with the ongoing degradation of unmaintained assets;
- There is 39kms of LV open wire mains in the HBRA of the JEN network. The removal of LV Mains in the HBRA is a cost effective way of reducing customer's exposure to bushfire risk. The program has commenced with the removal of 1.5km of LV mains in Sunbury, Bulla, Gisborne, Gisborne South and Meadow Heights areas. The LV open wire mains in the HBRA are being replaced using one or more of the following options:
 - Installation of a small (10kVA) pole mounted transformer and associated customer services;
 - Replacement of the bare LV mains with LV ABC (fringe areas of HBRA/LBRA only or where there are a minimal number of bays required rather than install a small kVA transformer), utilising existing poles; and
 - Undergrounding of the LV open wire mains and services on a case by case basis.
- It should be noted that all Single Wire Earth Return (SWER) systems in the HBRA of JEN were removed and replaced with three phase and single phase distribution feeders lines by 2013.

4.3.5.3.1 Conductor and Connector - Forecast Replacement Volumes

As detailed in this strategy, a number of projects have been identified to ensure the maintenance of network performance, and also address our compliance requirements.

Table 4-27: Conductor and Connector Forecast Replacement Volumes

Service Code	Conductors and Connectors	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
PDA	Ampect Connectors	95	95	95	95	94	95
PDB	Ampect Switch Lugs and Connection	59	60	60	64	68	64
PDH	HV Line Clash Mitigation	15	12	12	12	12	12
PDL	LV Line Clash Mitigation	15	12	12	12	12	12
ROH	HV Open Wire Conductor Repl. (km)	3	3	3	3	3	3
ROH	Steel Conductor Repl. (km)	-	-	-	3	4	-
ROL	LV Open Wire Conductor Repl. (km)	3	3	3	3	3	3
ROL	Electric Line Clearance Solutions	1	1	2	2	2	2
ROL	LV Mains Removal in HBRA (km)	-	8	8	8	8	8
ROH	Vibration Dampers and Armour Rods	271	-	-	-	-	-

4.3.5.4 Asset Disposal

Conductor and connectors do not contain hazardous materials and should be disposed of in accordance with JEM PO 1600 – Scrap Materials Policy.

4.3.5.5 Spares

As part of the criticality assessment, consideration is given to the appropriate levels of spare equipment required to manage the risk of unplanned failures and to minimise unplanned supply interruptions which affects Jemena's SAIDI and SAIFI reliability indices. The requirements for critical assets spares are assessed by following the Critical Spares Assessment Procedure (JEM AM PR 0015). It was determined that adequate spares are maintained at Tullamarine depot and stock holdings are managed by Services and Projects.

4.3.6 INFORMATION

Jemena's AMS provides a hierarchical approach to understanding the information required to achieve Jemena's business objectives at the Asset Class level. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and the Asset Class Strategy (ACS) all provide the context for and determine the information required to manage and operate an Asset Class.

The Electricity Distribution Asset Class Strategy facilitates the safe, efficient and reliable delivery of electricity to JEN's customers.

From these business objectives, it is possible to identify at a high-level the content of the business information systems' required to support these objectives (Table 4-28).

Table 4-28: Conductors and Connectors Sub-Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Information Sources	Externally Sourced Data
Operational Excellence <ul style="list-style-type: none"> • Manage assets throughout their lifecycle in safe and environmentally responsible manner • Maintain assets in accordance with RCM principals • Maintain asset information/knowledge to enable efficient and effective decision making • Embed continuous improvement throughout asset lifecycle Customer <ul style="list-style-type: none"> • Maintain our current service levels • Incorporate customer feedback in our decision making process Growth <ul style="list-style-type: none"> • Acquire/install/maintain assets to meet future demand requirements People <ul style="list-style-type: none"> • Maintain safe work environment • Engage team leaders in assessment of new assets • Training 	GIS/JEN Viewer <ul style="list-style-type: none"> • Geospatial representation of the JEN Network • Asset attributes SAP <ul style="list-style-type: none"> • Work schedule & status • Planned and corrective (faults) maintenance records • Asset inspection measurements • Financial information ECMS <ul style="list-style-type: none"> • Asset Inspection Manual, inspection methods & criteria • Policies, procedures and guidelines • General asset audits/surveys not stored in SAP • Incident investigations Drawbridge <ul style="list-style-type: none"> • Standards • Operations diagrams • Line design manual • Construction manual SCADA/RTS <ul style="list-style-type: none"> • Outage Management System (OMS) & SCADA (DMS) • Planned and Unplanned outages JEN Analytics <ul style="list-style-type: none"> • Power quality data • Energy consumption 	<ul style="list-style-type: none"> • Current cadastre (including land ownership) for JEN's geographical extent. • DELWP - HBRA and LBRA area boundaries • CFA for fires, warnings and restrictions, incidents • Emergency Management Common Operating Picture (EM-COP) • Aerial Imagery for JEN's geographical extent (NearMap) • Google 'Street View' • Melway • SAI global (Australian and International Standards) • ESV / ESC / AER for regulatory obligations

Table 4-29 identifies the current and future information requirements to support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-29: Conductor and Connectors Sub-Asset Class Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
Conductors and Connectors application	<ul style="list-style-type: none"> • Purchase specification (ECMS) • Distribution Design Manual (ECMS) • Distribution Construction Manual (ECMS) 		<ul style="list-style-type: none"> • High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
	<ul style="list-style-type: none"> • Period contracts (ECMS) • Logistics system (SAP) 		
Life cycle management: <ul style="list-style-type: none"> • Asset identification • Condition monitoring • Condition assessment • Replacement / retirement strategy • Disposal 	<ul style="list-style-type: none"> • Each asset identified by geospatial representation in GIS and equipment ID in SAP • Asset Inspection Manual (ECMS) • Maintenance plan (SAP) • JEN Analytics (e.g. deteriorated neutral) • Measurement record (SAP / ECMS) • PM Notifications/Orders (SAP) • Strategy detailed in this document • GIS asset attributes: <ul style="list-style-type: none"> - Asset status (e.g. existing/historical) - Status (in service, isolated, out of commission) - Circuit Name - Circuit Voltage (i.e. ST, HV, LV) - Material - Conductor size/stranding - Neutral Conductor Material - Route Length - Date Installed - Owner - Feeder - Inspection Zone • Fault / failure records: <ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 	<ul style="list-style-type: none"> • Automated assessment of thermal survey results • Near real time updating of asset record • Photos database of all failed assets • Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> • High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Table 4-30 provides the information initiatives required to provide the future information requirements identified in Table 4-29. Included within this table is the risk to the Asset Class from not completing the initiative.

Information required to support asset strategies, performance and risks is recorded in SAP, Geographic Information System (GIS) and ECMS. Additional fault related data is available in the Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

Table 4-30: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information capture	Ability to capture all relevant asset attributes from the field through mobility solution.	High	Complete, Current, Accurate attribution
Improve/review MAT Code definitions	Ability to align to AER service classification structure.	High	Precise definition
Improved Asset Attributes	Review current asset attribution fields to ensure attributes being collected are asset specific.	Medium	Appropriate and Accurate attribution
Increased Timeliness	Decrease latency between fault/maintenance delivery and fault/maintenance record capture.	High	Complete, Current, Accurate attribution
Improved fault information capture	Ability to capture all relevant asset failure information from the field through mobility solution and photos.	High	Complete, Current, Accurate fault information

4.4 UNDERGROUND DISTRIBUTION SYSTEMS SUB-ASSET CLASS

4.4.1 INTRODUCTION

The JEN underground distribution systems includes Sub-transmission (ST) cables, High Voltage (HV) distribution cables and Low Voltage (LV) cables and their ancillary equipment such as LV pillars and pits. The sub-transmission underground systems consist of 66kV and 22kV cables entering and exiting zone substations. The HV underground systems consist of 22kV, 11kV and 6.6kV cables. The LV cable network supplies electricity to customers via pole and non-pole type substations. As of December 2018, there are in excess of 3,700km of underground cables in service on the network with some cables installed as early as the late 1930's still in service. Underground cables are often considered a more aesthetically pleasing means of power distribution, and can operate with much greater reliability as there are fewer sources of environmental impact. However, the construction and maintenance of underground distribution systems is far more expensive compare to that of overhead networks. In addition, when faults occur on underground networks it takes much longer to locate and repair compared to an overhead network.

4.4.2 ASSET PROFILE

This section includes information about the type, specifications, life expectancy and age profile of the underground distribution systems in service across the Jemena Electricity Network (JEN).

4.4.2.1 Life Expectancy

As prescribed in *ELE PR 0012 – Network Asset Useful Lives Procedure*, the applicable useful life for the major elements of underground distribution systems is as follows:

Underground Cables and their Terminations:

- | | |
|--|----------|
| • ST Oil Filled Cable | 70 years |
| • ST, HV and LV Paper Impregnated Cable | 70 years |
| • ST and HV Cross linked polyethylene (XLPE) | 40 years |
| • LV XLPE | 55 years |

Pillars and Pits:

- | | |
|--------------|----------|
| • LV Pillars | 30 years |
| • LV Pits | 40 years |

The Network Asset Useful Lives Procedure considers asset lives based on good industry practice and specific Jemena Electricity Network experience and represents the lives of assets at which end-of-life replacement will be considered. For good industry practice, JEN has referenced a number of reviews of asset useful lives from consulting agencies and discussions with other Distribution Businesses (DB).

4.4.2.1.1 Factors Affecting Life Expectancy

Factors that have a detrimental effect on the life of underground cable distribution systems include:

- Water ingress in cables;
- Partial discharge within cable insulation systems;
- Overload;

- Third party intervention (dig up of assets); and
- Workmanship.

4.4.2.2 Age Profile

The population of underground distribution systems can be characterised as follows (figures extracted as at December 2018):

Underground Cables and their Terminations:

- | | |
|-------------------------------------|------------|
| • Sub-transmission Oil Filled Cable | 3.44km |
| • Sub-transmission XLPE | 10.60km |
| • Sub-transmission Paper | 3.46km |
| • High Voltage XLPE | 635.95km |
| • High Voltage Paper | 153.45km |
| • Low Voltage Mains Cable | 1,269.34km |
| • Low Voltage Service Cable | 1,659.52km |

Pillars and Pits:

- | | |
|-----------------------|---------------|
| • Low Voltage Pillars | 1,957 assets |
| • Low Voltage Pits | 71,547 assets |




Figure 4-31: ST Cable Age Profile

N.B. assets indicated as installed in the 2016 -2020 interval are those installed between 2016 and 2018.




Figure 4-32: HV Cables Age Profile

N.B. assets indicated as installed in the 2016-2020 interval are those installed between 2016 and 2018.




Figure 4-33: LV Cables Age Profile

N.B. assets indicated as installed in the 2016 -2020 interval are those installed between 2016 and 2018.




Figure 4-34: Underground Service Cables Age Profile

N.B. assets indicated as installed in the 2016 -2020 interval are those installed between 2016 and 2018.

The increase in the rate of installation of HV, LV and service cables is due primarily to the many and extensive new residential estates installed within the JEN area of supply. All new estates are developed using Underground Residential Distribution (URD) systems.

4.4.2.3 Utilisation

The main function of the underground distribution system as a sub-asset class is to distribute electricity to customers in a more aesthetically pleasing and far more reliable manner as compared to overhead distribution networks. The underground distribution system now comprises approximately 30% of JEN's total network length.

The current range of cables in service and their application is listed below in Table 4-31.

Table 4-31 Current In Service Cable Application Guide

Usage	Type	Description
66kV U/G cable	38/66 kV, 1 Core 1000 mm ² Copper Conductor, Corrugated Aluminium sheath, High Density Poly-ethylene outer sheathed	ST line cable for use as exit cables from zone substations or underground sections of ST lines.
HV U/G cable	12.7/22kV, 1 Core 35mm ² Aluminium, Conductor, PVC outer sheath	This cable has only one PVC outer sheath and is most suitable for use indoor or kiosk distribution substations to connect between the transformer and the switch fuse unit. The cable can also be used for transformer droppers on pole substations.
	12.7/22kV, 1 Core 35mm ² Copper, Conductor, PVC outer sheath	This cable is used in 22kV indoor distribution substations to connect between the transformer and circuit breaker (CB) unit.
	12.7/22kV, 3 Core 35mm ² Aluminium, Conductor, High Density Poly-ethylene sheathed.	This cable is used as a distribution feeder cable in radial situations. The cable cannot withstand the possible fault current when

Usage	Type	Description
		protected primarily by the zone substation CB and normally must be fuse protected.
	12.7/22kV, 1 Core 185mm ² Aluminium Conductor, PVC outer sheath	This cable is used in 22kV zone substations as a jumper cable on capacitor banks and is also used to connect the station service transformer to the CB. A further application for this cable is to connect between the transformer and the circuit breaker in 11kV indoor substations.
	12.7/22kV, 3 Core 185mm ² Aluminium Conductor, High Density Poly-ethylene sheathed	This cable is the standard distribution feeder cable. The cable is used to link substations or to link overhead lines.
	12.7/22kV, 3 Core 240mm ² Aluminium Conductor, High Density Poly-ethylene sheathed	This cable is used for 22kV zone substation feeder exits which may run to either a cable head pole (CHP) or directly to a distribution substation or a customer's HV switchgear.
	12.7/22kV, 1 Core 630mm ² Copper Conductor, High Density Poly-ethylene sheathed	This cable is used for heavily loaded zone substation feeder exits which run to either a CHP or directly to a customer's HV switchgear. It is also used for the connection of zone substation power transformers to the 22/11kV switchboard.
LV U/G mains cable	185 mm ² cross-sectional area, 90 degree Sector Conductor, 4 Core	<p>There are two main applications for these cables, there are:</p> <ul style="list-style-type: none"> As service cables, supplied from either overhead or underground mains, for customer supplies above 170 Amps diversified maximum demand (D.M.D). These cables may also be used as an alternative to the 50mm² cable for supplies in the range of 150 to 170 Amps. As a mains cable. The standard mains cable for medium density URD is the 185mm² cable, however in some circumstances the 240mm² may be used where long circuits are involved, particularly where there is unusually long distances prior to any service tapping.
	240 mm ² cross-sectional area, 90 degree Sector Conductor, 4 Core	
LV U/G service cable	2 Cores of 16mm ² (7/1.70mm) Annealed Copper. Colour Coding Black & Red. Flat construction.	<p>These cables are for use as service cables for customer supplies up to 100 Amps D.M.D. For URD areas the 4 core cable is the standard service cable. When servicing from overhead distribution 4 core cable is used as standard. These cables are also used in the public lighting schemes.</p> <p>The main application for this cable is a service cable, supplied from overhead distribution in the range of 150 to 170 Amps D.M.D.</p>
	4 Cores of 16mm ² (7/1.70mm) Annealed Copper. Colour Coding Red, White, Blue and Black.	
	4 Cores of 50 mm ² (19/1.78mm) Annealed Copper. Colour Coding Red, White, Blue and Black.	

4.4.3 PERFORMANCE

4.4.3.1 Requirements

The requirements for cables and their accessories are set out in JEN's technical specification "66kV, 22kV, 11kV and LV Overhead Conductors and Underground Cables" which references a number of relevant Australian Standards (see Table 4-32 below). In order to ensure that cable systems achieve their designed operational ratings and ensure network reliability is maintained cable systems are installed in accordance with the requirements of the "Distribution Construction Manual Section 4".

JEN's internal construction standards ensure compliance with a number of regulations that cover the installation of underground cable systems. These standards include design parameters which address areas including clearances, equipment types, ratings and the recording of asset data including asset location (Dial Before You Dig data).

All underground assets are assigned ratings (including cyclic ratings) that are based on the type of cables, the method of installation and the load profile. In addition fault ratings for both the conductors and screens of cables are specified to ensure cables are matched to the networks fault levels. Refer to Distribution Standard Manual Section 4.5 for various cable rating details.

The monitoring and optimisation of the performance of the underground cable distribution systems occurs via the use of the following systems and programs:

- Feeder loads are monitored and managed via SCADA;
- The LV cable network loads are monitored via the business objects application using AMI data;
- Faults and failures are monitored via the Outage Management System (OMS);
- Cable termination defects and maintenance issues are identified through Asset Inspection and Enclosed Substation Inspection Programs;
- Defects and failures are monitored via the Plant Maintenance notification systems (SAP)
- Monthly asset performance review meetings review performance and faults.

Table 4-32 Cables and Accessories - Relevant Australian Standards

Standard	Title
AS 1125	Conductors in Insulated Electric Cables
AS 1429.1	Electric Cables – Polymeric insulated Part 1 3.6kV – 36kV
AS 1429.2	Electric Cables – Polymeric insulated Part 2 36kV – 145kV
AS 2629	Separable Insulated Connectors for Power Distribution System Above 1kV
AS 4026	Electric Cables – For Underground Residential Distribution Systems
AS 5000.1	Electric Cables – Polymeric Insulated Part 1 up to 1.2kV

4.4.3.2 Assessment

The principal method of assessment of the performance of the underground distribution system is based on the monitoring of asset failures and maintenance notifications. The on-line or in-service monitoring of the condition and performance of underground cables is limited to the inspection of the visible parts of these systems. That is mainly the cable terminations and many of these are also not visible. There is some ability to monitor cable condition on-line but this is limited and comprehensive

diagnostic condition assessment generally involves taking cables out of service and often the physical disconnection of the cable. For this reason these types of tests are generally only performed at the time of commissioning or following a cable fault or incident. They are not suited to the routine assessment of cable condition.

The failure history associated with individual sections of cable is a key indicator of condition. The failure data indicates that on average over the past 9 years there were 25 HV and 58 LV faults per year.




Figure 4-35 Underground Cable Failure Data

4.4.4 RISK

4.4.4.1 Criticality

Asset criticality is a measure of the risk of specified undesired events faced when utilising equipment. Asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A. The asset criticality score is then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This is also used to rank importance of dissimilar sub-asset classes (e.g. transformers and surge diverters) to identify areas where risk should be managed first and control measures implemented.

The underground distribution system sub-asset class has an asset criticality score of AC3 (Significant) due to the consequence of underground cable failure and JEN's limited ability to respond to a some types of faults (e.g. leaks in the oil insulating system in the case of ST cables) due to the availability of skilled technicians.

Several sections of JEN's ST oil filled cables have been identified as at risk due to the limited availability of skilled maintenance crews, either external or internal. This impacts JEN's ability to respond to a fault or leak in the oil insulating system. In addition, pressurised cables take a long time to repair and leaks can be detrimental to the environment.

Good underground network design ensures that customer outages are typically minimised through HV switching and the isolation of damaged cable sections. JEN has access to appropriately skilled

technicians so that the maintenance and repair of modern cable systems can be undertaken without delay, hence modern HV cable systems can be considered medium criticality.

LV cable faults cause limited customer outages and like the modern HV cable systems there are maintenance crews readily available to repair the faults in a timely manner hence LV cables are considered low criticality.

4.4.4.2 *Failure Modes*

The failure modes for this sub-asset class include:

4.4.4.2.1 ST/HV cables

Insulation failures are the most common type of cable failure. These can be caused by partial discharge associated with voids in insulating material and the ingress of moisture. "Water treeing" in XLPE cables leads to insulation breakdown and puncture.

In oil impregnated paper insulated cables, the aging of the paper is due to the presence of oxygen, moisture and heat. This results in drying of the oil impregnation. Corrosion of the lead sheath which provides the moisture barrier in these cables is commonly associated with electrolysis associated with DC traction systems. This leads to failure of the lead sheath and consequently moisture ingress and insulation failure. Physical damage also results in cable failure either immediately or after moisture enters the damaged cable.

Cable failures most commonly occur at joints and terminations as they are areas where the control of the electrical stresses can be problematic.

Exceeding the cyclic and emergency ratings of cables or poor thermally conductive bedding materials can cause severe overheating of cable insulation systems. This can result in insulation system failures (for example the infamous Auckland 110 kV multiple cable failures).

Pitch filled metal enclosed cable terminations have a history of catastrophic rupture causing projection of pieces of metal, porcelain and pitch. These are age related failures associated with the failure of the sealing systems on these cable boxes (CABUS types).

4.4.4.2.2 LV cables and Terminations

Similar modes of failures for ST/HV cable apply for LV cables.

There are a range of LV cable terminations on the JEN where the inner colour coded plastic insulation has not been protected from the effects of UV light. This insulation is not UV light stabilised resulting in the insulation cracking and falling off resulting in bare conductors at the termination point. This is a severe safety risk and potential for flashovers exist due to the absence of the cable insulation.

4.4.4.3 *Current Risks*

4.4.4.3.1 HV XLPE Cable

HV XLPE cable installation began in the mid 1970's. Worldwide research has shown that many of the cable faults experienced on cables after 10 - 15 years in service are attributed to insulation degradation through water treeing. The presence of water trees in cable insulation is known to decrease the residual life of the cable.

Water may enter the cable during initial installation or as a result of subsequent sheath damage. Furthermore, the manufacturing process of XLPE cable changed from steam curing to dry curing around 1985. Steam curing introduced water to the XLPE insulation at the point of manufacture which promotes the growth of water trees when the cable is electrically stressed. This has had a significant impact on the life expectancy of these cable types.

4.4.4.3.2 Paper Insulated (MI type) HV Cable

This cable type was predominantly installed on the 11kV and 22kV networks prior to the 1970's, however was still used up to the 1990s. The cable utilises mass impregnated (MI) paper as the insulating medium. Many of the older cables were originally operated at 6.6kV and converted to 11kV. The early cable designs used oil impregnated paper but these suffered oil migration leading to the drying out of the papers. Advances in cable design resulted in the development of MI type cables that were non-draining. Many of these sections of cable are short (typically 200 m) and are used as feeder exit cables.

There appear to be two main causes of MI type cable failure namely:

- Failure of paper insulation due to oil migration over the life of the cable, leaving paper dry and brittle. Failure is particularly evident in existing cable joints or when new joints are installed. Due to the condition of the insulation in these cables, the risk of failure is significantly increased when cables are physically disturbed or handled.
- Failure due to moisture ingress resulting from lead sheath fatigue and corrosion. This problem is particularly evident in the inner suburban areas that are prone to electrolytic corrosion due to the proximity of tram and rail systems.

Some sections of this type of cable have been identified as having excessive failure rates. For instance, cable on the FT9 feeder has experienced failures attributed to moisture ingress as a result of lead sheath fatigue and electrolytic corrosion.

4.4.4.3.3 HV CABUS Type Outdoor Cable Terminations

These terminations were installed on the 6.6kV, 11kV and 22kV networks. They are a pitch filled terminations housed in a cast iron cable box and many have failed catastrophically which can result in personnel injury and damage to public property. They are particularly hazardous when failure occurs as the cast iron can shatter and is often expelled over a wide area. The root cause of failure of these boxes is the ingress of moisture in the pitch filled cable boxes resulting in the deterioration of the ageing paper insulation. Over the years paper can become brittle and absorb moisture which reduces its dielectric strength giving way to partial discharges. Degradation of paper also occurs from heating of the copper conductor, especially during times of peak demand. These partial discharges break down and weaken the paper insulation. Once the insulation breaks down the phases flash over and generate a 3-phase fault.

4.4.4.3.4 HV and LV Pitch Filled Fabricated Metal Outdoor Cable Terminations

These terminations are of similar vintage to the CABUS type HV terminations. These terminations are also pitch filled but housed in a fabricated metal box. Failure of this type of termination is not as hazardous as the metal box does not shatter but can split expelling pitch and other debris. Failure is often associated with the effects of corrosion and moisture ingress. The consequences of failure are far less severe compared with CABUS terminations in terms of risk of injury to the general public however the potential for injury is still present. With LV terminations the impact on reliability of supply is minimal. There have been a small number of recent incidents of explosive failure of this type of HV termination.

4.4.4.3.5 LV Outdoor Terminations with Exposed Conductor Insulation

There have been a number of reports of LV XLPE cable terminations deteriorating in service as the result of the effects of UV radiation. These terminations have been incorrectly terminated such that the LV cable cores have the inner phase coloured insulation remaining exposed. As this insulation is non-UV resistant, it can deteriorate and expose bare LV conductors. The construction standard requires that when terminating these cables outdoors, each of the cores has to be covered with a UV

resistant heat shrink sleeve. This is a potential safety risk (especially on concrete poles) and also a potential source of LV fault due to short circuits between LV phases of the cable.

4.4.4.3.6 LV Pillars and Cabinets

There are various types of LV pillars which exist within the underground distribution system including paralleling pillars, paralleling service pillars and service pillars. These pillars are generally installed in Underground Residential Distribution (URD) estates with the latter two confined to older installations where individual lots are serviced from the pillar instead of a pit. In addition, there are LV cabinets used to provide multiple LV feeders in industrial and commercial areas. These require ongoing inspection to ensure they remain secure and if damaged are repaired.

4.4.4.3.7 Cable Sheath Voltage Limiters (SVL's)

In order to manage the voltages induced on the screens of single core 66kV cables, special cable earthing designs are required as part of the cable design and installation. The condition of the SVL's needs to be monitored.

4.4.4.3.8 66kV Oil Filled Cables

There are a small number (3.44km) of 66kV oil filled cables installed at JEN zone substations that form part of the ST network. The oil in the cable forms part of the insulation system and is maintained under pressure. In the event that the lead sheath on these cables is damaged then oil can leak out of the cable resulting in a pressure drop and associated alarm. Pressure alarms need to be monitored via SCADA and manually checked regularly.

4.4.4.3.9 22kV XLPE Cable Joints

JEN has experienced elevated failure rates of 22kV XLPE circuits which were installed in the 1990's. These are relatively new cables and the cause of the underground cable faults has been attributed to joint failure. Failures have occurred on feeders supplied from AW, ST and COO. All of the recent joint failures occurred on cables that were installed between the years 1993 and 1999. The cable failures also all occurred at below rated current and before their expected engineering end of life.

It has been concluded that poor workmanship, issues with the size of the conductor crimp, and the associated conductor contributed to the failures. JEN is aware that the specification of 22kV cable at that time was changed to be based on conductivity where as previously they directly specify conductor cross-sectional area. Consequently the actual conductor in the cable could have a reduced cross-sectional area but still satisfy the cable performance requirements by varying the conductor alloy composition. The result is that the standard crimp sizes were too big for the supplied conductor cross-sectional area. This has resulted in joints that can overheat and fail when loaded. This was in particular applicable to the 185mm² HV cable as the joint manufacturer had the joints take certain ranges and the 185mm² conductors were at the low end of the size meaning there was too much space left over after the crimp.

4.4.4.3.10 Third Party Intervention

Another source of failure for cables is accidental third party intervention (i.e. third party damaged JEN underground assets).

4.4.4.4 Existing Controls

4.4.4.4.1 HV XLPE Cable

The JEN cable specification was changed in 2008 and consequently all new HV cable is supplied with water tree retardant XLPE insulation. The performance of this modified XLPE insulation has been documented overseas and found to impede the formation of water treeing in the insulation.

4.4.4.4.2 Paper Insulated (MI type) HV Cable

Proactive replacement has been undertaken to address MI type HV cable failure issues based on failure rates.

4.4.4.4.3 HV CABUS Type Outdoor Cable Terminations

A proactive replacement program is now underway to replace all remaining CABUS cable terminations and all remaining HV fabricated metal cable box terminations.

The project has reached a stage where all 22kV installations have been replaced due to their criticality. There are 122 remaining installations at either 11kV or 6.6kV. As there are plans to replace the existing 6.6kV areas around Preston and East Preston Zone Substations in the near future, the HV CABUS terminations (22 off) in Preston and East Preston will be removed in due time as a part of that project.

This leaves the program with only the 11kV HV CABUS terminations to replace. A total of 100 11kV terminations have been identified for replacement. A new business case will be proposed each year from 2020-2026 to replace the old terminations with modern terminations. It is suggested that the program continue to 2035 until all terminations of this type are removed from the network. As these terminations can fail catastrophically, it is prudent that Jemena address the issue before there is any subsequent damage from their failure.

4.4.4.4.4 HV and LV Pitch Filled Fabricated Metal Outdoor Cable Terminations

As with the above HV CABUS type terminations, the HV fabricated metal box terminations are also proactively being replaced under the same program.

4.4.4.4.5 LV Outdoor Terminations with Exposed Conductor Insulation

The Asset Inspection Manual has been modified to draw inspector's attention to these defects. These terminations are to be rectified as they are found.

4.4.4.4.6 LV Pillars and Cabinets

Replacement programs have been completed which targeted some types that were made of materials containing asbestos.

4.4.4.4.7 Cable Sheath Voltage Limiters (SVL's)

SVL's are installed to protect the cable sheath from damage that may occur due to high screen voltages being induced in the screens by fault currents passing through the cables. The SVL's also prevent the flow of induced earth currents which can de-rate the cable if not correctly managed.

4.4.4.4.8 66kV Oil Filled Cables

Fault locating tools have recently been purchased and have aided in the location of sheath faults. Subsequently a number of these faults have been repaired.

Asset replacement projects are being implemented in both a reactive and proactive manner to manage this issue.

4.4.4.4.9 Third Party Intervention

Accidental dig ups occur from time to time and are mitigated via "Dial Before You Dig" campaigns and warning signs that declare there are underground assets in the area.

4.4.4.5 Future Risks and Opportunities

The availability of the technical skill sets required to promptly repair / joint oil filled cables in the event of a sheath or cable fault is a risk that JEN faces. A plan needs to be developed to determine the

required technology and resources necessary to repair a cable fault in an oil filled cable. There are a small number of 66kV cables that have been identified with sheath faults on the JEN. Accurate fault location is required in order to affect repairs economically.

There are numerous cable monitoring tools available to assist with the condition monitoring of underground cables. The efficiency and practicality of these systems is currently being assessed. A screening program that can be simply applied without undue disruption of the network and give an indication of deteriorating cable condition is needed.

A cable management strategy is to be developed to optimise the proactive and reactive use of testing equipment purchased during 2012. The cable management strategy should document the requirements to undertake a testing regime (both online and offline testing), as well as a record management system to capture and proactively assess cable condition.

Future analysis of data captured by this strategy will provide information on developing trends in cable condition. This should enable identification of developing conditions and prioritise the ongoing monitoring of cable condition and the proactive maintenance or replacement activities.

4.4.5 LIFE CYCLE MANAGEMENT

The options available for asset lifecycle management reflect a trade-off between capital and operating expenditure. The aim is to achieve predictable and sustainable OPEX and CAPEX programs that manage the network risk and deliver improved safety outcomes that are associated with the replacement of unserviceable assets and the deployment of new technologies. The preferred asset lifecycle management option involves condition based replacement.

The strategy covers time based inspections followed by condition based maintenance and replacement, as well as in-service failure based reactive maintenance.

4.4.5.1 *Creation*

Underground cable distribution systems are installed and extended as required for new customer projects and where needed to augment the capacity of the distribution network. This is the preferred method for the distribution of electrical energy due to the superior reliability of underground network assets and the environmental and aesthetic advantages. Underground distribution systems are mandated for all new residential development. There is still a significant additional cost associated with underground systems over the cost of overhead assets however the differential has decreased over the years.

Underground cables have in recent years been purchased under contract via two manufacturers, namely Prysmian Cables and Olex Cables. These contracts have been in place for the last 8 years.

LV pillars manufactured by Tappat Engineering are currently under contract and supplied by Australian Powerline Industries and pits are sourced through BVCI Pty Ltd.

4.4.5.2 *Asset Operation and Maintenance*

There are four (4) life cycle management strategies applied to the operation and maintenance of the underground distribution systems sub-asset class:

- Asset Inspection;
- Preventative Maintenance;
- Reactive and Corrective Maintenance; and
- Run to Failure.

This group of assets are operated and monitored via the SCADA system and via the Business Objects functionality applied to the AMI data. This is used to monitor the operational state and loads applied to the various elements of the ST, HV and LV underground assets.

4.4.5.2.1 Asset Inspection

4.4.5.2.1.1 66kV XLPE Cables

A sheath integrity test is performed on 66kV XLPE cables of significant length every two (2) years. This test confirms the integrity of both the metallic sheath and outer PVC and HDPE sheaths.

The Sheath Voltage Limiters (SVL) are also inspected and tested every two years.

It is recommended that this program be timed to coincide with the oil filled cable inspections as described below.

4.4.5.2.1.2 66kV Oil Filled Cables

A sheath integrity test and SVL test shall be performed every two years as per 66kV XLPE cables.

Every two years the oil pressure shall be inspected to confirm it is within limits and the oil pressure alarm system check shall be performed to ensure the integrity of the system.

The last tests of these cables were completed in September 2017. Most of the cables passed the above tests with a handful of them requiring some attention to locate and repair sheath faults.

4.4.5.2.1.3 HV XLPE Cables

There is limited efficient cable condition monitoring/inspection for these types of cables. This type of asset is replaced based on failure history and the results of diagnostic tests following asset failure. Currently they are managed on a run to failure basis.

4.4.5.2.1.4 Paper Insulated (MI) Type HV Cable

As for XPLE cables there is limited cable condition monitoring currently performed. Similarly this type of asset is replaced based on failure history and the results of diagnostic tests following asset failure. They are managed on a run to failure basis.

4.4.5.2.1.5 HV and LV Outdoor Cable Terminations (Metal Enclosed)

The condition of these terminations is monitored via the Asset Inspection and Substation Inspection programs. The inspection is looking for signs of deterioration such as rust or leaking insulating pitch. Any terminations identified as in poor condition and likely to fail shall be reported and programmed for replacement. Currently there is a program to phase out HV Metal Box Outdoor cable terminations.

4.4.5.2.1.6 LV Outdoor Cable Terminations with Exposed Conductor Insulation

The inspection of these assets is specifically looking for cases where the inner conductor (usually coloured to match the phase) insulation is exposed to UV light (sunlight) which causes deterioration. The construction standard requires that each core is covered by a UV resistant heat shrink sleeve to protect the insulation from UV damage. Although there is low risk associated with reliability of supply, the safety risk is unacceptable. On this basis a pro-active approach has been taken to identify and inspect these terminations with a planned repair program. The majority of these have been rectified, however if any of these are discovered a notification shall be raised against the terminations and scheduled for repair.

4.4.5.2.1.7 LV Pillars and Cabinets

Pillars and cabinets are to be inspected on a 3-year cycle in the Hazardous Bushfire Risk Areas (HBRA) and a 5-year cycle in the Low Bushfire Risk Areas (LBRA) coinciding with various asset

inspections or scheduled maintenance of the distribution substation that supplies the pillar or cabinet. The following list details the main areas of inspection:

- Damaged or cracked pillar cover or damaged and corroded cabinet enclosure;
- Damaged, broken or missing stainless steel cord or other device used for locking pillar;
- Damaged cabinet lock; and
- Confirm that surrounding landscape does not prohibit normal operational access to pillar or cabinet

For further details on pillar inspection and management refer to JEN MA 0500 - Asset Inspection Manual.

The development of a comprehensive condition monitoring strategy for cables will help identify the health of the cables and inform a proactive approach to the maintenance and replacement of this sub-asset class.

4.4.5.2.2 Preventative Maintenance

4.4.5.2.2.1.1 *Proactive Retirement*

Proactive retirement of underground cables is a less common activity and will generally take place as a result of network augmentation due to redevelopment of a network area or expansion of surrounding supply network.

4.4.5.2.2.1.2 *Proactive Replacement*

This strategy aims to achieve high reliability whilst balancing safety and performance considerations in establishing an inspection and planned replacement program. Planned replacement programs are specifically focused on stabilising asset performance through retirement of underground cables with identified poor performance issues as a result of asset inspection.

4.4.5.2.3 Reactive and Corrective Maintenance

Reactive and corrective maintenance is carried out when faults occur or after asset inspection programs identify any required maintenance, resulting in the repair of:

- Cable and their termination accessories; and
- Pillars and Pits.

4.4.5.2.4 Run to Failure

This is an appropriate lifecycle management strategy when the consequences of failure do not include any risk of injury or harm and where the failure rate is low. This asset sub group is reliable and the failure rates are low compared to the overhead parts of the network. In general cable systems are not accessible and therefore their failure does not occur in the public domain and thus the failure of the buried parts of these asset has in general no HS&E consequences. There are however significant consequences in terms of network reliability when a failure occurs.

A review of maintenance notifications reveals that over the past 5 years approximately 177 HV cables and 277 LV cables have been repaired or jointed as a result of an in-service failure due to the following causes:

- Accidental human intervention by JEN/contractor;
- Accidental human intervention by others;

- Component failure;
- Electrical failure / deterioration;
- Mechanical failure / deterioration; and
- Underground dug up by others.

Three of these six failure causes relate to interference with underground assets. When assessing the intrinsic performance of this sub-asset class these failure causes should be discounted.

4.4.5.3 *Underground Distribution System Forecast Replacement Volumes*

As detailed in this strategy, a number of projects have been identified to ensure that we maintain network performance, and also address our compliance requirements.

Table 4-33 lists the forecast replacement volumes for underground distribution system elements from 2020 to 2026.

Table 4-33 Replacement Volumes – Underground Distribution Systems

Service Code	Underground Distribution Systems	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RUA	HV U/G Cable Replacement (m)	952	1,228	1,228	1,233	1,239	1,233
RUA	Replace Metal Trifurcating Boxes	6	6	6	6	6	6
RUC	LV U/G Cable Replacement (m)	385	363	363	365	365	365
RUF	Pillar to Pillar	5	5	5	5	5	5
RUH	HV U/G Termination Replacement	15	14	14	14	14	14
RUL	LV U/G Termination Replacement	47	45	45	44	44	44
RUS	ST U/G Cable Replacement - BTS-FF Oil Filled Cables (m)	505	-	-	-	-	-

4.4.5.4 *Asset Disposal*

Underground cables typically do not contain hazardous materials and should be disposed of in accordance with JEM PO 1600 - Jemena Scrap Materials policy.

4.4.5.5 *Spares*

Spare underground cables and their associated components and accessories are stored at JEN's various depots for fault and emergency use. Currently there is no spare equipment kept for 66kV oil filled cables. If a substantial fault occurs on these cables, a specialist contractor will need to be contacted to repair the cable as there is no expertise within the business to repair this type of cable.

4.4.6 INFORMATION

Jemena's AMS provides a hierarchical approach to understanding the information required to achieve Jemena's business objectives at the Asset Class level. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and the Asset Class Strategy (ACS) all

provide the context for and determine the information required to manage and operate an Asset Class.

The Electricity Distribution Asset Class Strategy facilitates the safe, efficient and reliable delivery of electricity to JEN's customers.

From these business objectives, it is possible to identify at a high-level the content of the business information systems required to support these objectives (Table 4-34).

Table 4-34: Underground Distribution Sub-Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Information Sources	Externally Sourced Data
<p>Operational Excellence</p> <ul style="list-style-type: none"> • Manage assets throughout their lifecycle in safe and environmentally responsible manner • Maintain assets in accordance with RCM principals • Maintain asset information/knowledge to enable efficient and effective decision making • Embed continuous improvement throughout asset lifecycle <p>Customer</p> <ul style="list-style-type: none"> • Maintain our current service levels • Incorporate customer feedback in our decision making process <p>Growth</p> <ul style="list-style-type: none"> • Acquire/install/maintain assets to meet future demand requirements <p>People</p> <ul style="list-style-type: none"> • Maintain safe work environment • Engage team leaders in assessment of new assets • Training 	<p>GIS/JEN Viewer</p> <ul style="list-style-type: none"> • Geospatial representation of the JEN Network • Asset attributes <p>SAP</p> <ul style="list-style-type: none"> • Work schedule & status • Planned and corrective (faults) maintenance records • Asset inspection measurements • Financial information <p>ECMS</p> <ul style="list-style-type: none"> • Asset Inspection Manual, inspection methods & criteria • Policies, procedures and guidelines • General asset audits/surveys not stored in SAP • Incident investigations <p>Drawbridge</p> <ul style="list-style-type: none"> • Standards • Operations diagrams • Line design manual • Construction manual <p>SCADA/RTS</p> <ul style="list-style-type: none"> • Outage Management System (OMS) & SCADA (DMS) • Planned and Unplanned outages <p>JEN Analytics</p> <ul style="list-style-type: none"> • Power quality data • Energy consumption 	<ul style="list-style-type: none"> • Current cadastre (including land ownership) for JEN's geographical extent. • DELWP - HBRA and LBRA area boundaries • CFA for fires, warnings and restrictions, incidents • Emergency Management Common Operating Picture (EM-COP) • Aerial Imagery for JEN's geographical extent (NearMap) • Google 'Street View' • Melway • SAI global (Australian and International Standards) • ESV / ESC / AER for regulatory obligations

Table 4-35 identifies the current and future information requirements that support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-35: Underground Distribution Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
Underground distribution acquisition and application	<ul style="list-style-type: none"> • Purchase specification (ECMS) • Distribution Design Manual (ECMS) • Distribution Construction Manual (ECMS) • Period contracts (ECMS) • Logistics system (SAP) 		<ul style="list-style-type: none"> • High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.
Life cycle management: <ul style="list-style-type: none"> • Asset identification • Condition monitoring • Condition assessment • Replacement / retirement strategy • Disposal 	<ul style="list-style-type: none"> • Each asset identified by geospatial representation in GIS and equipment ID in SAP • Asset Inspection Manual (ECMS) • Maintenance plan (SAP) • JEN Analytics (e.g. deteriorated neutral) • Measurement record (SAP / ECMS) • PM Notifications/Orders (SAP) • Strategy detailed in this document • GIS asset attributes: <ul style="list-style-type: none"> - Asset status (e.g. existing/historical) - Status (in service, isolated, out of commission) - Operating voltage - Construction type - Conductor material - No of cores - Cross-section area - Date Laid - Date Removed - Computed Length - Feeder - Owner • Fault / failure records: <ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 	<ul style="list-style-type: none"> • Design voltage • Cable position • Near real time updating of asset record • Photos database of all failed assets • Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> • High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Table 4-36 details the information initiatives required to provide for the future information requirements identified in Table 4-35. Included within this table is the risk to the Asset Class from not completing the initiative.

Information required to support asset strategies, performance and risks is recorded in SAP, Geographic Information System (**GIS**) and ECMS. Additional fault related data is available in the Outage Management System (**OMS**). Data from SAP can be extracted and analysed using SAP Business Objects.

Table 4-36: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information capture	Ability to capture all relevant asset attributes from the field through mobility solution.	High	Complete, Current, Accurate attribution
Improve/review MAT Code definitions	Ability to align to AER service classification structure.	High	Precise definition
Improved Asset Attributes	Review current asset attribution fields to ensure attributes being collected are asset specific.	Medium	Appropriate and Accurate attribution
Increased Timeliness	Decrease latency between fault/maintenance delivery and fault/maintenance record capture.	High	Complete, Current, Accurate attribution
Improved fault information capture	Ability to capture all relevant asset failure information from the field through mobility solution and photos.	High	Complete, Current, Accurate fault information

4.5 POLE TYPE TRANSFORMERS SUB-ASSET CLASS

4.5.1 INTRODUCTION

Pole type transformers and their associated circuits are the principal asset at the overhead networks interface with domestic, commercial and industrial customers. These facilitate the customers energy supply and export requirements.

Jemena Values include Health and Safety, Teamwork, Excellence, Accountability and Customer Focus. These values underpin how we operate and manage this asset class to provide a high quality, reliable and safe supply to our customers.

To ensure this asset class successfully delivers these values requires distinct performance measures, condition based monitoring, inspection programs, risk analysis and customer interaction, all of which are described in this sub-asset class document.

The key factor determining the pole type transformers performance is its capacity to interface with the various types of equipment customers connect to the network. An appropriately rated transformer along with an electrically strong network will deliver a quality electricity supply that meets customer demands reliably and safely.

The transformers principle purpose is to convert High Voltage (HV) of 22kV, 11kV or 6.6kV to a nominal supply voltage of 400/230V. These voltages are then delivered to our customers through the low voltage distribution network.

Transformer selection is determined by the type and size of load it will supply. The load capacity of the transformer is expressed by its kVA rating, JEN pole type transformers vary in size from 10kVA up to 500kVA.

JEN operates 4,105 pole type transformers, the number of customers supplied by these individual transformers ranges between 1 and 416 customers (2018 Figures).

4.5.2 ASSET PROFILE

4.5.2.1 *Life Expectancy*

As prescribed in ELE PR 0012 – Network Asset Useful Lives Procedure, the applicable useful life for pole type transformers is as follows:

- Pole type transformer 50 years;

The above procedure considers asset lives based on good industry practice and specific Jemena Electricity Network experience and represents the lives of assets at which end-of-life replacement will be considered. JEN has undertaken a number of reviews of asset useful lives with consulting agencies and held discussions with other Distribution Businesses to ensure assigned asset lives are realistic.

4.5.2.2 *Age Profile*

There is a total of 4,105 single and two pole transformers in service within JEN. The age distribution of pole type transformers indicated in Figure 4-36 shows that the majority of transformers are less than 50 years old with only 6% of the transformer population older than 50 years.




Figure 4-36: Pole Type Transformer Age Profile

4.5.2.3 Utilisation

A pole type transformers operating capacity is determined by its cyclic rating. Cyclic ratings are dependent on load types or load profiles, consequently the loading of a pole type substations is assessed against its cyclic rating rather than its nameplate rating. Refer to Table 4-37 for details.

Table 4-37: Pole Type Transformer Cyclic Ratings

Nameplate (kVA)	Load Type	Summer Rating (kVA)	Winter Rating (kVA)
≤100	Residential	119	141
≤100	Comm/Industrial	110	124
200	Residential	238	282
200	Comm/Industrial	220	248
315	Residential	374	443
315	Comm/Industrial	338	391
500	Residential	593	704
500	Comm/Industrial	537	621

The rating table above is a guide only. For further details, refer to the Jemena Transformer Rating (Zone Substation and Distribution) plant guidance document. Consultation with the Customer and System Planning team and the Asset Engineering team shall be sought regarding rating matters.

The utilisation of distribution substations are reviewed periodically as part of the Distribution Substation Augmentation Program. For details, refer to the Distribution Substation Augmentation, Network Development Strategy (Doc No. ELE PL 0017) and the Network Performance Plan 2021-2025 (Doc No. ELE-999-PA-IN-002). Proactive replacement of pole type distribution substations is normally driven by load growth and occurs as a result of a substation upgrade following a customer's request for increased supply. The transformers which are taken out of service are then assessed and refurbished if suitable.

4.5.3 PERFORMANCE

4.5.3.1 Requirements

The Electricity Safety (Management) Regulations 2009 prescribes that JEN will comply with its internal technical standards. JEN internal standards reflect the Electricity Safety (Network Assets) Regulations 1999 to which the JEN assets have been designed, constructed and maintained. JEN has conducted a Formal Safety Assessment as part of its Electricity Safety Management Scheme (ESMS) submission to Energy Safe Victoria (ESV) which incorporated a risk assessment of the adequacy of JEN's current internal technical standards.

Pole type transformers are the major component of a pole type substation, JEN follows strict construction standards when building substations. These are prescribed in the "Distribution Construction Manual, Volume 2, Section 3.0 Substation and Plant construction". These standards include design parameters such as clearances, animal proofing, equipment types, ratings and minimum mounting height.

All distribution transformers and their component parts are designed, manufactured and tested in accordance with the Australian Standards set out in Table 4-38 and as prescribed in "Jemena Electricity Networks (Vic) Ltd 22kV, 11kV & 6.6-11kV, 16 kVA To 2000 kVA Distribution Transformers, Technical Specification".

These standards include design parameters such as voltage withstand, no load losses, thermal cyclic loading characteristics, and voltage tolerances.

Table 4-38: Relevant Australian Standards

Standard	Title
AS 1767	Insulating liquids - Specification for unused mineral insulating oils for transformers and switchgear
AS 2374	Power transformers - Minimum Energy Performance Standard (MEPS) requirements for distribution transformers
AS 60076	Power transformers – General
AS 2629	Separable Insulated Connectors for Power Distribution System Above 1kV
ENA DOC 007- 2006	Specification for Pole Mounting Distribution Transformers

The transformers primary purpose is to provide a nominal LV voltage to customers and therefore must deliver an electricity supply that maintains compliance with the Victorian Electricity Distribution Code (VEDC); Quality of Supply (QOS) and Reliability of Supply (ROS) requirements. The electrical performance is measured against VEDC, Section 4 Quality of Supply, and Section 5 Reliability of Supply.

Network related and customer initiated QOS and ROS issues are dynamic in nature, they inherently develop as a result of the localised and cumulative increasing demand and diversity that customers load and generation places on the LV networks. As customers electrical equipment is modernised; its impact and reliance on the networks compliance with the regulated QOS and ROS requirements increases. Reduced supply quality can have perceived and/or real impacts on the operation and lifecycle of connected electrical equipment. Transformers play a vital role in maintaining a stable and reliable supply. Jemena must therefore ensure it responds to these increasing needs and continues to remain compliant by matching the networks capacity to its customers load demands.

4.5.3.2 Assessment

The operational performance of the pole top transformer population is assessed through failure rates, supply quality and load profiling.

Transformer failures generally result in customer supply outages and can lead to public and operational risks, including oil spills and fire starts. Outages are captured by JEN's Outage Management System (OMS) where event details and disruption times are recorded. Failure modes and rates are monitored through SAP notifications to identify equipment reliability issues.

Annual pole type transformer failure rates compiled between 2010 and 2018 showed an average of approximately 14 transformers that required replacement per annum. Figure 4-37 indicates the annual failure/replacement rates.

There have been numerous failures as a result of transformer overloads, faulty connections and external factors such as lightning but there have not been any failures directly attributed to the malfunction of a pole type transformer.




Figure 4-37: Annual Pole Type Transformer Failures

Quality of supply issues directly caused by transformers generally occur as a result of overload, an overload occurs when there is an excess of customer load or reverse energy flow due to embedded generation relative to the transformers rating.

Overloads are being proactively assessed through customer energy usage obtained from customer energy meters. Load profiles of the pole type transformers were analysed for the 2017-2018 period. 303 pole type transformers were identified with loads exceeding 150% of the transformers nameplate rating which exceeds the cyclic ratings indicated in Table 4-39.

Table 4-39: Maximum demands greater than 150% of rating

Transformer Rating (kVA)	Maximum Demands > 150 % of Rating
10	111
16	6
25	19
50	6
100	17
200	59
250	9
300	52
315	8
400	1
500	15

QOS non compliances are being identified reactively through customer initiated enquires and since 2018 proactively through the AMI (Advanced Metering Infrastructure) meter 5-minute voltage monitoring data.

Power quality customer enquiries are investigated by Jemena's Network Technology & Measurement team to determine if the issues are customer initiated or network related. The number and type of verified issues are tabled below.

Table 4-40: Verified QOS Issues

Performance Indicator	2010	2011	2012	2013	2014	2015	2016	2017	2018
Low supply voltage	39	27	16	30	29	23	29	20	30
Voltage dips	15	12	13	9	10	6	18	15	20
Voltage swell	0	0	2	1	1	0	2	0	5
Voltage spike (impulsive transient)	2	0	2	1	1	1	1	0	2
Waveform distortion	0	0	0	0	0	0	0	0	1
Solar Related *	-	-	-	-	-	19	28	73	89
Other	127	73	66	125	102	61	48	47	27

*Solar Related performance indicators began in 2015.

Proactive transformer quality and reliability performance assessments are developing with the introduction of 5-minute AMI meter data. Transformer voltage profiles will be traced over extended time periods and adjustments instigated to resolve noncompliance's. Abnormalities in voltage levels will be used to identify developing faults at both the substation and LV distribution network level.

Transformers proactively or reactively identified having supply quality issues or excessive overload are being addressed as part of the Distribution Substation Augmentation program, where substations and their associated LV components would be upgraded or reconfigured to resolve the supply issues.

There are approximately 259 JEN substations that have been identified with transformers mounted at heights that do not comply with the minimum specified in JENS ESMS. They are being addressed based on a priority assigned following a risk assessment of each site. The rectification work is scheduled to continue until 2021. Figure 4-38 shows the required clearance.




Figure 4-38: Pole Type Transformer Mounting Requirements

4.5.3.2.1 Condition Assessment – Pole Mount Transformers

Condition assessment of pole type transformers is conducted through inspections and audit programs such as the standard asset inspection program and thermal surveys, during which plant maintenance notifications are raised for the rectification of defects or replacement of assets as identified.

The overall condition of the pole type transformer family has been assessed using the Condition Based Risk Management (CBRM) methodology. Figure 4-39 shows the current Year 0 (2018) health index for the population of pole type transformers.

Total risk for all failure scenarios at Year 0 is calculated to be \$498k with a current failure rate of 18 per annum. These failures can range from a minor failure where maintenance work is required such as an oil leak, to a major failure that includes replacement of the unit.




Figure 4-39: Year 0 (2018) Health Index

If replacement is deferred until Year 7 (2025) the health index changes as indicated in Figure 4-40.

Total risk for all failure scenarios at Year 7 is calculated to be \$622k with a predicted failure rate of 21.4 per annum.




Figure 4-40: Year 7 (2025) Health Index Profile

These results indicate that the majority of distribution pole type transformers are well below their expected life of 50 years and are in good condition. Furthermore, the cost of risk to the network should they fail is highly influenced by the cost of replacement (CAPEX) as indicated in Figure 4-42.




Figure 4-41: Risk Profile for Year 0 (2018) and Year 7 (2025), Pole Mounted Transformers

The CBRM model forecasts a failure rate of between 18 and 23 transformers over the 7 year period. This is consistent with the recent failure rates for these types of assets. In order to maintain the assessed risk associated with the operation of these assets at current (year 0) levels this strategy proposes the replacement of approximately 22 transformers per annum over the course of the EDPR period. These are exclusive of the transformers identified for height rectification. Pole type transformers identified as being in poor condition at Year 7 will be prioritised for replacement.

4.5.4 RISK

4.5.4.1 *Criticality*

Asset criticality is a measure of the risk of specified undesired events faced when utilising equipment. Asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A. The asset criticality score is then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This is also used to rank the importance of dissimilar sub-asset classes (e.g. transformer platforms) to identify areas where risk should be managed first and control measures implemented.

The Pole type transformer asset class has an asset criticality score of AC2 (Moderate) due to the consequence of a pole type transformer failure having the potential to cause third party damage and injury to JEN personnel and members of the public.

Pole type distribution substations contribute to JEN's overall service level performance through reliability and quality of customer supply. There are 4,105 pole type substations, the number of customers supplied by these transformers is in a range between 1 and 416 per transformer; therefore a loss of supply from a pole type substation has a minor impact. Network configuration is also designed such that in the majority of cases the impact of customer outages can be minimised through HV switching and LV parallels so that supply to customers can be restored promptly.

4.5.4.2 *Failure Modes*

Failure modes for this sub class include:

- Thermal failure - due to overload, out-of-balance load, and deteriorated or high resistance connections;
- Insulation failure - due to loss of insulation medium (oil leak), heat and age related winding insulation deterioration, lightning strikes, high voltage injections, switching events, or water penetration;
- Winding failure – winding distortion due to a through-fault;
- Deterioration or corrosion – age and environmental related deterioration of seals, paint, insulation, connections; and
- Failure due to external factors – such as vehicle strikes, animals, vandalism and weather.

The consequences of the above failures varies from:

- Operation of protective devices including blown fuses and circuit breaker trips;
- Excessive heat, hot spots and annealing;
- Molten material and possible fire;
- Internal or external flashover between HV to LV, HV to earth, LV to earth and inter-turn;
- Oil spill and possible environmental impacts; and
- Distortion of tank, winding, lead supports.

4.5.4.3 *Current Risks*

The risks associated with the pole type transformer failures are described in Section 4.5.4.2. For details of the risk assessment, refer to Jemena's Compliance and Risk System (JCARS).

Apart from transformer failures, poor performance has credible regulatory compliance risks.

Pole type transformer performance is directly related to customer energy usage, the ability to deliver a compliant level of supply quality and reliability is compromised when a customer's supply or export energy demand exceeds the transformer rating.

The uptake of solar generation by customers is rapidly increasing the level of energy being exported into the distribution network. As it grows in capacity it is creating conditions which have never been experienced or planned for when designing the network. The main impact is on the level of voltage being supplied to customers. To export energy, embedded generation (EG) systems require the voltage output of the EG to be higher than the network voltage at the customer's Point of Supply (POS), this facilitates the export of energy back into the distribution network. A cumulative voltage rise is further generated as more EG systems are connected to the low voltage network. Where voltage loss occurs as a result of load there is now a voltage rise due to the reverse current flows generated into the network. The supply voltage experienced by the customer can rise above the VEDC requirements at the customer's Point of Common Coupling (POCC). At a localised level the excessive voltage causes inverters to shut down and/or adversely affect QOS limits at both the customer's premise and neighbouring properties. At the network level the cumulative export capacity can potentially exceed the rating of the transformer and its associated components leading to possible asset failure.

Energy export does not always occur in sync with energy usage, at a domestic level peak usage times are of an evening whereas the majority of energy being exported by solar systems occurs during the day when the sun is shining. This means that distribution substations require the capacity to supply the maximum energy demands of customers loads of an evening without the influence of embedded generation, and maintain an acceptable level of voltage during the day when embedded generation is at a maximum. Satisfying these varying network characteristics is not always possible with the existing static network elements.

In addition, there is an increase in the amount of non-linear, "dirty" load and generation from customers' equipment that affects the ability of distribution substations to deliver a clean distortion free supply. Non-linear loads, such as DC to AC power converters, switch-mode power supplies, dimmable switches, DC chargers (Electric Cars) and arc furnaces produce harmonics which inherently distort supply voltages creating a dirty supply. The cumulative impact of these dirty loads increases the base levels of harmonic distortion which increase the impact of individual localised harmonic distortion. Experience indicates that localised harmonic distortions can exceed the 5% supply voltage VEDC distortion limit.

4.5.4.4 *Existing Controls*

New transformer designs undergo an initial type test by the manufacturers to ensure they comply with the requirements of the product specifications.

Transformers installed in the field are constructed to the standard design requirements and the final construction is audited to safeguard compliance. The design and construction standards incorporate the following controls to mitigate against failure events.

- Substation and Plant construction standards (Distribution Construction Manual, Volume 2, Section 3.0) – reduce the likelihood of poor construction practices, and the use of non-standard construction methods;

- Clearances, Design & Construction Principles (Distribution Construction Manual, Volume 1, Section 2.6) - prevent point of contact between network elements;
- Surge arrester procedure (JEN PR 0011) – sets out the requirements for overvoltage protection of high cost equipment to protect against events such as lightning strikes;
- Animal and Bird Protection Procedure (JEN PR 0065) – Sets out the requirements for the installation of added covers to prevent animal contact between live and earthed components.

Other operational controls include:

- Standard asset inspection program – 3 to 4 yearly visual inspections to ensure asset integrity;
- Thermographic Surveys – on a 1 to 3 year cycle pole type transformers along the backbone of the feeder are surveyed to identify hot spots caused by overload and high impedance connections;
- Maintenance process - Plant maintenance notifications are raised and prioritised for the rectification of defects or replacement of assets when identified;
- Pole type transformer load monitoring – cumulative customer energy load profiling relative to transformer nameplate rating; and
- Quality of Supply monitoring – 5 minute spot voltages, voltage variations and outages are monitored via AMI (Smart) meters.

As part of criticality assessment; consideration is given to appropriate levels of spare equipment. Spares requirements for critical assets are assessed by following Critical Spares Assessment Procedure (JEM AM PR 0015). It was determined that adequate spares are maintained at Tullamarine depot and stock holdings are managed by Services and Projects.

4.5.4.5 Future Risks

Changes in load profiles due to both usage and generation are occurring and the outcomes of these changes are currently being assessed and modelled. The initial indicators are that there will be an overall increase in the demand for energy and that the increase will need to be diversified to avoid excessive increases in maximum demands. The most significant impact will come from Electric Vehicle (EV) charging.

As Victoria is moving towards a lower carbon footprint there will be a push towards EV away from the traditional fossil fuelled vehicles. The energy demands for EV's will have to be met by the current electricity infrastructure in conjunction with non-network generation. Their demands will add to the daily load profiles and if they follow a similar pattern will increase usage in peak demand periods. Usage will therefore need to be managed to limit their impact on network maximum demands. This can be achieved by incentivising off peak usage, Infrastructure Victoria made the following statement relating to this topic.

“Do Now - Review state-based regulatory settings to allow electricity providers to set demand-variable rates and demand management strategies. For example, consider amending metering and pricing arrangements to allow for separate ‘vehicle only’ electricity tariffs to be offered to zero emissions vehicle owners to shift the electricity demand from these vehicles away from peak times.” *

Infrastructure Victoria concluded that not adopting an off peak incentive scheme will have significant implications on Victoria's energy network.

“Although the overall energy consumption of vehicles remains constant regardless of the load profile in each scenario, their contribution to maximum demand can change dramatically. This could have significant implications for Victoria's energy network. For example, a non-incentivised load profile

would reflect users plugging their cars in at night as soon as they get home, leading to demand peaking in the early evening to an even greater extent than in the base case.”*

(*Source: Infrastructure Victoria, Advice on Automated and Zero Emissions Vehicles Infrastructure, October 2018)

Both scenarios, off peak and peak usage, will have an impact on the cyclic rating of transformers. Off peak usage will result in load being diversified across a 24 hour period thus reducing the transformer cooling time and as a result, require a reduction in the cyclic ratings to manage the transformers performance. An increase in peak usage will require more capacity to be added to the network increasing the network cyclic rating. Further studies are required to identify the impact that the new energy profiles will have on the cyclic rating of transformers.

With the roll-out of smart meters (AMI) and the consequential introduction of full interval metering data, the accuracy of the distribution substation utilisation analysis will be further improved through increased data availability and accuracy. It is anticipated that there will be an increase in the number of transformer QOS and loading problems identified. JEN must therefore ensure that it is positioned to respond to these increasing demands and continues to remain compliant by adapting and reacting to the new demands with an equally dynamic response and an ability to efficiently match the networks supply capacity with our customers load demands. This will require working in collaboration with customers to develop and implement non network solution in conjunction with traditional network solutions.

Voltage Optimised Transformer (VOT) are currently being trialled to address QOS steady state voltage non compliances that have developed as a result of the increased penetration of grid connected photovoltaic (PV) installations. In order to export energy the output voltage generated by a PV system has to be higher than the grid voltage at the Point of Supply (POS). Consequently, when a number of PV systems are clustered close together excessive voltage rise can result, in some circumstances leading to exceedance of the VEDC, QOS, Steady State Voltage Variation limits”. A VOT is used to automatically adjust the network voltage so that it remains within limits, this is achieved by adjusting the output voltage via the inbuilt on load tap changer. There are routine maintenance costs associated with VOT due to the mechanical and electrical wear on the on load tap changer. These maintenance costs are not currently including in this asset class and will need to be added if the VOT's are accepted as standard equipment.

4.5.5 LIFE CYCLE MANAGEMENT

The options available for asset lifecycle management reflect a trade-off between capital and operating expenditure. The aim is to achieve predictable and sustainable OPEX and CAPEX programs that manage the network risk and deliver improved safety outcomes that are associated with the replacement of unserviceable assets and the deployment of new technologies. The preferred asset lifecycle management option involves condition based replacement.

The strategy covers time based inspections followed by condition based maintenance and replacement, as well as in-service failure based reactive maintenance.

4.5.5.1 *Creation*

New pole top transformers (pole type substations) are deployed on the JEN in response to the following primary drivers:

- New network load via the Customer Initiated Construction process;
- The Distribution Substation Augmentation Program in response to organic load growth in established parts of the distribution network; and

- The Distribution Substation Augmentation Program in response to supply quality non compliances.

The need for new distribution substations is identified by the Customer and System Planning team to meet customer load requests via the CIC processes or by the Asset Analytics and Programs team after reviewing and confirming substation loading data and the results of supply quality investigations. This then drives the Distribution Substation Augmentation Program.

JEN has standardised the range and capacity of pole type transformers for use on the network as indicated in Table 4-41. Other sizes and capacities have been used historically but as these reach end of life or are upgraded they are replaced with a standard size pole type transformer.

Table 4-41: Standard Pole Type Transformers

Primary Voltage	Capacity (kVA)							
	Single Phase			Three Phase				
22kV	16	25	50	25	63	100	315	500
11kV	16	-	-	-	-	-	315	500
6.6/11kV	-	-	-	-	-	-	315	500

The population of pole type transformers installed on the JEN and characterised by their kVA rating is indicated in Figure 4-42.




Figure 4-42: Pole Type Transformer Population by Rating

4.5.5.2 Asset Operation and Maintenance

There are three (3) considered life cycle management options for pole type transformers:

- Asset Inspection and Condition Monitoring;
- Preventative Maintenance; and
- Reactive and Corrective Maintenance.

4.5.5.2.1 Asset Inspection and Condition Monitoring

The inspection of transformers is carried out as part of the standard asset inspection program. All assets in the HBRA are inspected every 3 years, and in the LBRA every 5 years. A thermal survey of transformers and connections is also performed to assist in the detection of potential failures before they occur and are aligned with the regular overhead line thermal survey cycle which occurs every 1, 2, or 3 years depending on asset criticality.

Inspection activities include checks for general cleanliness, oil level, signs of oil leaks, corrosion of tank/cooler/conservator, tank distortion, broken porcelain, tracking on bushings and surge arresters if fitted on transformers, bushing leads and animal shields are secured, droppers are free from vegetation interference, and clearances between live conductors are maintained.

For details of the activities involved in the inspection program, refer to the JEN MA 0500 (2018) - Asset Inspection Manual.

4.5.5.2.2 Preventative Maintenance

4.5.5.2.2.1 *Proactive Replacement*

Proactive replacement is driven by the monitoring of pole type transformer loads and the results of supply quality investigations. The Distribution Substation Augmentation Program drives the replacement as well as the creation of pole type transformers. For details of the program and the criteria used to assess and prioritise replacements refer to the Distribution Substation Augmentation, Network Development Strategy ELE PL 0017. Proactive replacement of pole type distribution substations will typically occur as a result of load growth or customer requests for increased supply. The replacement normally also involves an upgrade in capacity if possible. Given that the capacity of the largest pole type transformer is limited to 500kVA. The pole type transformers that are taken out of service as part of the replacement process are then assessed and refurbished where possible.

On the JEN small single phase 10kVA pole type transformers are a family of transformers that have been identified as being most at risk of overload. Customer loads and export energy demands can easily exceed their limited capacity. The 10kVA's are the smallest transformer currently in service and are commonly installed in the Hazardous Bushfire Risk Area (HBRA) where they can supply up to 4 customers in isolation from alternative sources of LV supply. The transformers themselves are configured with two LV windings each rated at 5kVA, the LV windings can be connected in parallel or series. When in parallel the two LV windings form a single phase 240/250 Volts supply and are rated at 42/40A. When in series they form two single phase 240/250 Volts supplies rated at 21/20A each or 240-480/250-500 Volts supplies rated at 21/20A. Care needs to be taken when connecting load to these transformers as they can be easily overloaded particularly if large PV installations are involved

Loading data has revealed that over 33% of the 387 smaller capacity 10kVA transformers installed in the HBRA are supplying loads greater than 120% of their nameplate rating and 16% are supplying in excess of 150% of their nameplate rating. These 10kVA transformers no longer have sufficient capacity to service the current customer loads connected to them, placing them at risk of failure due to overload.

These 10kVA transformers are an older style of transformer with 75% of the units currently in service over 30 years old. The historical failure rates of these 10kVA transformers are not reflective of their overload status or age profile. Even though historically these 10kVA transformers have not had high failure rates the risk and associated potential consequence of any future failures in the HBRA is significant.

4.5.5.2.2.2 *Condition Based Replacement*

The condition of pole top transformers is monitored via the pole and line inspection program and the thermal survey program. In addition the operating environment as defined by transformer loads is

monitored via the Business Objects system which uses connectivity data from GIS and AMI energy data to measure and report on the load profiles for the various elements of the distribution system.

The results of this condition monitoring activity is used to drive the condition based replacement of pole type transformers when they are found to be in poor condition. Poor condition is defined by a range of conditions including the effects of corrosion and oil leaks.

4.5.5.2.3 Reactive And Corrective Maintenance

Reactive and corrective maintenance is carried out when faults occur or after asset inspection programs identify any urgent maintenance, for example, in service electrical faults or excessive oil leaks.

4.5.5.3 Pole Type Transformer Forecast Replacement Volumes

A program has been developed to target for replacement pole top transformers that are overloaded at levels greater than 150% of their nameplate rating. In particular those located within the HBRA will be prioritised. This work is planned to occur in the 2020-2025 period. The forecast CAPEX associated with this program of works is detailed in the Distribution Substation Augmentation (Service Code DSJ) section of the Network Performance Plan 2021-2025 (Doc No. ELE-999-PA-IN-002) and is not included in the CAPEX forecasts included in this strategy.

In addition to the replacements proposed for the overloaded family of pole type transformers a number of projects have been identified that are required to ensure that network performance is maintained at current levels and our compliance requirements are addressed.

Table 4-42 lists the forecast replacement volumes for pole type transformers from 2020 to 2026 required to maintain the performance of the asset class.

Table 4-42 Forecast Replacement Volumes - Pole Type Transformers

Service Code	Pole Type Transformers	Forecast Replacement Volumes					
		FY20	FY21	FY22	FY23	FY24	FY25
RHA	Transformer Pole Mounted	22	22	21	22	23	22
RHA	Transformer Platform Rectification	-	10	10	10	10	10

4.5.5.4 Asset Disposal

All pole type transformers that are taken out of service for any reason are returned to the store for assessment. Transformers that are considered unsuitable for refurbishment for any reason are scrapped. The transformer is taken out of service, returned to the depot and stored in a banded area. The transformer oil is tested for PCB content and disposed of appropriately under a contract arrangement.

Disposal of all materials shall be in accordance with JEM PO 1600 – Scrap Material Policy.

4.5.5.5 Spares

The replacement of pole type transformers is largely driven by the need to upgrade transformers to meet increasing capacity requirements. This significantly impacts on the number of transformers that would otherwise be replaced because they had reached the end of life.

When transformers are removed from service for reasons other than defect repair, such as load growth, load decrease, noise, redundancy or maintenance, they are assessed using the criteria set out in the Distribution Transformer Refurbishment Policy – ELE PO 0600. Transformers that satisfy

the criteria shall be refurbished and returned to stock for future use. Those that do not meet the criteria shall be scrapped.

The replaced transformer will be assessed according to the below criteria to determine if the transformer should be refurbished and returned to service or be scrapped:

- PCB Contamination;
- Voltage ratio and tapping range*;
- Conditions including, internal faults, brown porcelain bushings, rust, impacts, distortion, confirmed noise complaints;
- Age and capacity;
- Configuration, size and weight; and
- Cost of refurbishment.

Refurbishment shall only be carried out if the refurbishment cost is less than the residual transformer value as described in the Distribution Transformer Refurbishment Policy – ELE PO 0600.

*The typical tapping range for old transformers is between 100% and 90% for 415/240V transformers and 102.5 to 92.5% for 433/250V transformers, these ranges fall outside of the retention range of 105-95% as depicted in the ELE PO 0600 – Distribution Transformer Refurbishment Policy. In general, transformer tapping ranges are not clearly defined in existing records. An emphasis will be placed on identifying and documenting the tapping range and set tap position while conducting upcoming Inspection Programs.

Emergency pole type transformer stock is determined by the Asset Analytics and Programs team based on the quantity of the items in service on the network and its historical usage. Emergency stock levels are shown in Table 4-43.

Table 4-43: Pole Type Transformers Emergency Stock Levels

Voltage	Phases	Capacity	Minimum Stock	Maximum Stock
22kV	1	16kVA	3	4
22kV	1	50kVA	2	5
22kV	3	25kVA	1	1
22kV	3	63kVA	1	2
22kV	3	100kVA	1	1
22kV	3	315kVA	4	7
22kV	3	500kVA	4	7
11kV	3	500kVA	1	1
11/6.6kV	3	315kVA	2	2
11/6.6kV	3	500kVA	1	1

Emergency stock is also supplemented by Network Project stock when required.

4.5.6 INFORMATION

Jemena's AMS provides a hierarchical approach to understanding the information requirement to achieve Jemena's business objectives at the Asset Class. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and Asset Class Strategy (ACS) all provide the context for and determine the information required to deliver an Asset Class's business.

The Electricity Distribution Asset Class manages the Jemena Electricity Network (JEN) to safely, efficiently and reliably deliver electricity to its customers.

From these business objectives, it is possible to identify at a high-level the content of the business information systems' required to support these objectives, Table 4-44. Table 4-45 identifies the current and future information requirements to support the Asset Class's critical decisions and their value to the Asset Class. Table 4-46, provides the information initiatives required to provide the future information requirements identified in Table 4-45. Included within this table is the risk to the Asset Class from not completing the initiative.

Information required to support asset strategies, performance and risks is recorded in SAP, Geographic Information System (GIS) and ECMS. Additional fault related data is available in the Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

Table 4-44: Pole Transformer Sub-Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Sources	Information	Externally Sourced Data
Operational Excellence <ul style="list-style-type: none">• Manage assets throughout their lifecycle in safe and environmentally responsible manner• Maintain assets in accordance with RCM principals• Maintain asset information/knowledge to enable efficient and effective decision making• Embed continuous improvement throughout asset lifecycle Customer <ul style="list-style-type: none">• Maintain our current service levels• Incorporate customer feedback in our decision making process Growth <ul style="list-style-type: none">• Acquire/install/maintain assets to meet future demand requirements People <ul style="list-style-type: none">• Maintain safe work environment• Engage team leaders in assessment of new assets• Training	GIS/JEN Viewer <ul style="list-style-type: none">• Geospatial representation of the JEN Network• Asset attributes SAP <ul style="list-style-type: none">• Work schedule & status• Planned and corrective (faults) maintenance records• Asset inspection measurements• Financial information ECMS <ul style="list-style-type: none">• Asset Inspection Manual, inspection methods & criteria• Policies, procedures and guidelines• General asset audits/surveys not stored in SAP• Incident investigations Drawbridge <ul style="list-style-type: none">• Standards• Operations diagrams• Line design manual• Construction manual SCADA/RTS <ul style="list-style-type: none">• Outage Management System (OMS) & SCADA (DMS)• Planned and Unplanned outages JEN Analytics <ul style="list-style-type: none">• Power quality data• Energy consumption	<ul style="list-style-type: none">• Current cadastre (including land ownership) for JEN's geographical extent.• DELWP - HBRA and LBRA area boundaries• CFA for fires, warnings and restrictions, incidents• Emergency Management Common Operating Picture (EM-COP)• Aerial Imagery for JEN's geographical extent (NearMap)• Google 'Street View'• Melway• SAI global (Australian and International Standards)• ESV / ESC / AER for regulatory obligations	

Table 4-45: Pole Transformer Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
Pole transformers acquisition and application	<ul style="list-style-type: none"> • Purchase specification (ECMS) • Distribution Design Manual (ECMS) • Distribution Construction Manual (ECMS) • Period contracts (ECMS) • Logistics system (SAP) 		<ul style="list-style-type: none"> • High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.
Life cycle management: <ul style="list-style-type: none"> • Asset identification • Condition monitoring • Condition assessment • Replacement / retirement strategy • Disposal 	<ul style="list-style-type: none"> • Each asset identified by geospatial representation in GIS and equipment ID in SAP • Asset Inspection Manual (ECMS) • Maintenance plan (SAP) • JEN Analytics (e.g. deteriorated neutral) • Measurement record (SAP / ECMS) • PM Notifications/Orders (SAP) • Strategy detailed in this document • GIS asset attributes: <ul style="list-style-type: none"> - Asset status (e.g. existing/historical) - Status (in service, isolated, out of commission) - Sub Name - Type - Operating level - Feeder - Circuits - Date Installed - Live Line Clamp - CMEN - Inspection Zone • Fault / failure records: <ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 	<ul style="list-style-type: none"> • Utilisation • Load balance on each circuit by phase • Near real time updating of asset record • Photos database of all failed assets • Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> • High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Table 4-46: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information capture	Ability to capture all relevant asset attributes from the field through mobility solution.	High	Complete, Current, Accurate attribution
Improve/review MAT Code definitions	Ability to align to AER service classification structure.	High	Precise definition
Improved Asset Attributes	Review current asset attribution fields to ensure attributes being collected are asset specific.	Medium	Appropriate and Accurate attribution
Increased Timeliness	Decrease latency between fault/maintenance delivery and fault/maintenance record capture.	High	Complete, Current, Accurate attribution
Improved fault information capture	Ability to capture all relevant asset failure information from the field through mobility solution and photos.	High	Complete, Current, Accurate fault information

4.6 NON-POLE TYPE DISTRIBUTION SUBSTATIONS SUB-ASSET CLASS

4.6.1 INTRODUCTION

Non-Pole Type Distribution Substations as a group includes the following types of distribution substations:

- Indoor substations;
- Kiosk or padmount substations;
- Ground type substations;
- Underground substations;
- Cubicle substations;
- HV metering cubicles; and
- Switching cubicles

These substations and their associated circuits and ancillary equipment are the networks interface with domestic, commercial and industrial customers and service these customers energy supply and export requirements.

Jemena Values include Health and Safety, Teamwork, Excellence, Accountability and Customer Focus. These values underpin how we operate and manage this asset class to provide a high quality, reliable and safe supply to our customers.

To ensure this asset class successfully delivers these values requires distinct performance measures, risk analysis, condition based monitoring, inspection programs and customer interaction, all of which are described in this sub-asset class document.

The key factor determining the non-pole type distributions substations performance is its capacity to interface with the various types of equipment customers connect to the network. An appropriately rated transformer along with an electrically strong network will deliver a quality electricity supply that meets customer demands reliably and safely.

These substations are made up of one or more of the following components:

- the structure or enclosure;
- transformer/s;
- HV switchgear;
- LV switchgear;
- protective devices, HV and LV; and
- metering and wiring attached.

Substations that supply LV customers convert High Voltage (HV) at either 22kV, 11kV or 6.6kV to a nominal supply voltage of 400/230V. Supply is provided either directly to customers via dedicated consumers mains cables or via the low voltage distribution network. Substations can be comprised of one or multiple transformers that can be configured in parallel for increased capacity or operated separately for individual customer supplies. Transformers are selected based on the HV network voltage, the type of customer and the size of load it will supply. The capacity of the transformer is expressed by its kVA rating. The capacity of JEN's non-pole type substations varies from 50kVA up to 10,500kVA.

HV metering structures are generally provided to dedicated HV customers who manage their own electrical network beyond the metering structure.

HV switching stations are used to provide operational flexibility and control of the HV underground network.

JEN operates 2,407 non-pole type distribution substations, the number of customers supplied by each of these substations ranges between 1 and 341 customers (2018 Figures). There are 1,853 HV switching devices contained within these substations. They include SF6, oil and air insulated switching devices with differing current making and interrupting capabilities.

4.6.2 ASSET PROFILE

4.6.2.1 *Life Expectancy*

As prescribed in ELE PR 0012 – Network Asset Useful Lives Procedure, the applicable useful life for non-pole type distribution substation assets is as follows:

- kiosk/pad mount substations 40 years;
- ground/indoor substations 50 years; and
- distribution switchgear 40 years

The above procedure considers asset lives based on good industry practice and specific Jemena Electricity Network experience and represents the lives of assets at which end-of-life replacement will be considered. JEN has undertaken a number of reviews of asset useful lives with consulting agencies and held discussions with other Distribution Businesses to ensure assigned asset lives are realistic.

4.6.2.2 *Age Profile*

The population of non-pole type distribution substations as at December 2018 can be characterised as follows:

- 176 ground type substations;
- 468 indoor substations;
- 5 underground substations;
- 5 cubicle type substations; and
- 1,633 kiosk substations.

The population of distribution switchgear as at December 2018 can be characterised as follows:

- 1,656 Ring Main Units; and
- 197 indoor air break switches.

Of the 1,656 Ring Main Units, 443 units are of an oil immersed rotary switch type which is incorporated into the current Wilson Transformer kiosks.

The age profile for non-pole distribution substations is classified into two categories.

- Location, the date when the substation site was first established.
- Transformer age profile.

The substations location date remains constant whereas the transformer date is updated when the transformer is upgraded or replaced.




Figure 4-43: Non-Pole Type Distribution Substations Age Profile




Figure 4-44: Non Pole Type Transformer Manufactured Age Profile

Figure 4-45 includes all substation types installed on the JEN. The chart indicates that the installation of new non-pole type substations has consistently increased and now exceeds the number of pole type substations installed year on year. This is reflective of the growth in the JEN underground distribution network.




Figure 4-45: All Substation Types Installed

4.6.2.3 Utilisation

The operating capacity of a transformer is determined by its cyclic rating and its operating environment. Cyclic ratings are dependent on load types or load profiles, consequently the loading of a transformer is assessed against its cyclic rating rather than its nameplate rating. Refer to Table 4-47 for details. It should be noted that the rating of transformers located in enclosures is significantly impacted by this environment as cooling of the transformer is constrained by the enclosure.

Table 4-47: Cyclic Rating For Non-Pole Distribution Substations

Type	Nameplate (kVA)	Load Type	Summer Rating (kVA)	Winter Rating (kVA)
Indoor	315	Commercial	323	389
Indoor	500	Commercial	513	616
Indoor	750	Commercial	734	881
Indoor	1000	Commercial	979	1175
Indoor	1500	Commercial	1397	1680
Indoor	2000	Commercial	1862	2240
Ground	315	Commercial	337	403
Ground	500	Commercial	535	640
Ground	750	Commercial	767	913
Ground	1000	Commercial	1023	1218
Ground	1500	Commercial	1465	1736
Ground	2000	Commercial	1953	2315

Type	Nameplate (kVA)	Load Type	Summer Rating (kVA)	Winter Rating (kVA)
Kiosk	315	Residential	339	420
Kiosk	500	Residential	539	666
Kiosk	500	Comm/Industrial	501	591
Kiosk	750	Comm/Industrial	719	848
Kiosk	1000	Comm/Industrial	959	1130
Kiosk	1500	Comm/Industrial	1439	1695
Kiosk	2000	Comm/Industrial	1918	2260

The rating table above is a guide only. For further details, refer to Jemena Transformer Rating (Zone Substation and Distribution) plant guidance document. Consultation with the Customer and System Planning and Asset Engineering teams shall be sought regarding rating matters.

The utilisation of distribution substations is reviewed via the Distribution Substation Augmentation Program. For details, refer to the Distribution Substation Augmentation, Network Development Strategy (Doc No. ELE PL 0017) and the Network Performance Plan 2021-2025 (Doc No. ELE-999-PA-IN-002).

4.6.3 PERFORMANCE

4.6.3.1 Requirements

The Electricity Safety (Management) Regulations 2009 require that JEN comply with its internal technical standards. JEN's internal standards reflect the requirements of the Electricity Safety (Network Assets) Regulations 1999. JEN's network assets have been designed, constructed and are maintained in accordance with these regulations. In addition JEN has conducted a Formal Safety Assessment as part of its Electricity Safety Management Scheme (ESMS). This included a risk assessment of the adequacy of JEN's current internal technical standards.

JEN uses internal construction standards when building non-pole substations. These are prescribed in "Distribution Construction Manual, Volume 2, Section 3.0 Substation and Plant construction". These standards include design parameters which address areas including clearances, protection, equipment types, and ratings.

Each substation type shall be designed, manufactured and tested in accordance with the Standards listed in Table 4-48. These standards are called up and referenced in the "Jemena Electricity Networks (Vic) Ltd 22kV, 11kV & 6.6-11kV, 16 kVA To 2000 kVA Distribution Transformer, Technical Specification".

These standards include design parameters such as voltage withstand, no load losses, thermal cyclic loading characteristics, and voltage tolerances.

Table 4-48: Relevant Australian Standards

Standard	Title
AS 1767	Insulating liquids - Specification for unused mineral insulating oils for transformers and switchgear
AS 2374	Power transformers - Minimum Energy Performance Standard (MEPS) requirements for distribution transformers
AS 60076	Power transformers - General
AS 2629	Separable Insulated Connectors for Power Distribution System Above 1kV

Standard	Title
ENA DOC 007- 2006	Specification for Pole Mounting Distribution Transformers

The primary purpose of a substation is to provide a supply of electrical energy at a nominal HV or LV voltage to the connected customers. The substation must deliver an electricity supply that is compliant with the Victorian Electricity Distribution Code (VEDC) with respect to the Quality of Supply (QOS) and Reliability of Supply (ROS) requirements of the code. The electrical performance is measured against the VEDC, Section 4 Quality of Supply, and Section 5 Reliability of Supply.

QOS and ROS issues are dynamic in nature, they develop as a result of the localised and cumulative effects of increasing demand and diversity that customers load and customers generation places on the LV networks. As customers electrical equipment is modernised; its impact and reliance on the networks compliance with the regulated QOS and ROS requirements increases. Reduced supply quality can have perceived and/or real impacts on the operation and lifecycle of connected electrical equipment. Substations play a vital role in maintaining a stable and reliable supply. The challenge for Jemena is to remain compliant with the QOS and ROS parameters by efficiently matching the networks capacity to the varying requirements of its customer loads.

4.6.3.2 Assessment

The operational performance of the non-pole type substation population is assessed via the analysis of failure rates, quality of supply issues and load profiling.

Substation failures generally result in customer supply outages and can lead to public and operational risks, including oil spills and fire starts. Outages are captured via JEN's Outage Management System (OMS) where event details and disruption times are recorded. Failure modes and rates are monitored through SAP maintenance notifications to identify equipment reliability issues.

Annual non-pole type distribution substation failure rates compiled between 2010 and 2018 indicate that on average approximately 3 substations fail catastrophically per annum, see Figure 4-46. In addition to these failures a number of transformers will be replaced based on their condition.




Figure 4-46: Non Pole Type Distribution Substation Failures

Condition monitoring of these substations is conducted as part of the Enclosed Distribution Substation Inspection Program (EDSIP) on a 3 and 5 yearly basis dependent upon their location (HBRA or LBRA). These inspections are carried out in accordance with the requirements of the "Enclosed

Distribution Substation Inspection Manual - JEN MA 0695". Individual substations or particular classes of substation which are identified as having a current or emerging issue may be placed on a more frequent inspection cycle or included in a routine maintenance program designed to ensure the safety and operability of the substation is maintained.

To ensure the safety of network operators and maintenance staff, "Caution Regarding Operation (CRO)" tags are applied to switchgear identified as having operational issues or belonging to an asset class family which has a history of defect or failure. The CRO tag alerts all network staff to the fact that the switch requires particular work instructions or precautions related to its operation. The Network Control and Coordination Centre are able to identify and provide instruction to field staff regarding the specific requirements of a CRO tag applied to a particular network asset.

Since the creation of the Enclosed Distribution Substation Inspection Program in 2012, approximately 2,150 notifications have been raised to rectify defects on non-pole substations. The majority of the notifications were raised against site issues such as overgrown vegetation, subsidence of cable trenches, missing signs, graffiti, and access issues with only a small number of all notifications relating to electrical asset integrity issues such as low oil, low gas and missing or damaged insulation. The Enclosed Substation Inspection Notifications (ESIN) project was developed to address the issues identified by the inspection program.

The inspection program identified 81 substations which may have asbestos related issues. As a result a management plan has been developed that aims to monitor and or remove the asbestos and thus address the associated HSE risk level.

The capture of information on the type and setting of protective devices within these substations will be considered in the scope of future EDSIP's as there is limited information currently stored. Special consideration is to be given to fuse shunt trip type overcurrent protection systems employed in older indoor substations as there is limited information available in regards to this type of protective device.

Quality of supply issues related to these types of substations generally occur as a result of overload, an overload occurs when there is an excess of customer load or reverse energy flow due to embedded generation relative to the substations rating.

Overloads are being proactively assessed through customer energy usage data obtained from customer energy meters. The load profiles of non-pole type transformers were analysed for the 2017-2018 period and 40 transformers were identified with loads exceeding 150% of the transformers nameplate rating. These far exceeds the cyclic rating of these transformers. The number of overloaded non-pole transformers and their sizes are indicated in Table 4-49.

Table 4-49: Maximum demands greater than 150% of rating (non-pole type)

Transformer Rating (kVA)	Maximum Demands > 150 % of Rating
50	2
200	2
300	22
315	2
500	8
1,000	1
1,500	1
2,000	2
Grand Total	40

QOS non compliances are being identified reactively through customer initiated enquires and since 2018 proactively through AMI meter 5-minute voltage monitoring data.

Power quality customer enquiries are investigated by Jemena's Network Technology & Measurement team to determine if the issues are customer initiated or network related. The number and type of verified issues are indicated in Table 4-50.

Table 4-50: Verified Quality Of Supply Issues (non-pole type substations)

Performance Indicator	2010	2011	2012	2013	2014	2015	2016	2017	2018
Low supply voltage	39	27	16	30	29	23	29	20	30
Voltage dips	15	12	13	9	10	6	18	15	20
Voltage swell	0	0	2	1	1	0	2	0	5
Voltage spike (impulsive transient)	2	0	2	1	1	1	1	0	2
Waveform distortion	0	0	0	0	0	0	0	0	1
Solar Related *	-	-	-	-	-	19	28	73	89
Other	127	73	66	125	102	61	48	47	27

*Solar Related performance indicators began in 2015.

Proactive substation quality and reliability performance assessments are being facilitated by the introduction of 5-minute AML meter data. Substation voltage profiles can now be traced over extended time periods and adjustments instigated to resolve noncompliance's. Abnormalities in voltage levels will be used to identify developing faults at both the substation and LV distribution network level.

Substations proactively or reactively identified as having supply quality issues or excessive overload are addressed as part of the Distribution Substation Augmentation program. As a result substations and their associated LV components are upgraded or reconfigured to resolve these supply issues.

4.6.3.2.1 CBRM Assessment - Transformers

The overall condition of the non-pole type distribution transformer family has been assessed using the Condition Based Risk Management (CBRM) methodology. Initial CBRM modelling results for the current (Year 0) health index are shown in Figure 4-47.

Total risk for all failure scenarios at Year 0 is calculated to be \$753k with a current failure rate of 18 per annum. These failures can range from a minor failure (maintenance work required) to a major failure that includes replacement of the unit. It consists of impacts to network performance, safety of the public and staff, operational and capital expenditure to maintain/replace the unit and any associated environmental damage.




Figure 4-47: Non-pole type transformers Year 0 (2018) Health Index Profile

If replacement is deferred until 2025 (Year 7) the health index changes as shown in Figure 4-48.

Total risk for all failure scenarios at Year 7 is calculated to be \$797k with a predicted failure rate of 20 per annum (all failure types).




Figure 4-48: Non-pole type Transformers Year 7 (2025) Health Index Profile

These results indicate that majority of the population of non-pole type distribution transformers are well below their expected life of 50 years. Furthermore, the risk should they fail is highly influenced by the cost of replacement (CAPEX) as indicated in Figure 4-49.




Figure 4-49: Non-pole type Transformers Risk Profile for Year 0 (2018) & Year 7 (2025)

The model forecasts the replacement or repair of approximately 20 transformers per annum over 7 years to maintain the risk at current (Year 0) levels. This is consistent with current failure rates. Assets identified as being in poor condition at Year 7 will take priority when considering replacements.

4.6.3.2.2 CBRM Assessment – Ring Main Units

The overall condition of non-pole type distribution substation Ring Main Units (RMU's) has been assessed using the Condition Based Risk Management (CBRM) methodology. This assessment indicates that there are no systemic concerns in the medium term due primarily to the fact that these assets are aged well under their expected life.

Initial CBRM results indicated that the current (Year 0) health index is as shown in Figure 4-50.

Total risk for all failure scenarios at Year 0 is calculated to be \$312k with a current failure rate of 3 per annum. These failures can range from a minor failure (maintenance work required) to a major failure that includes replacement of the unit. It consists of impacts to network performance, safety of the public and staff, operational and capital expenditure to maintain/replace the unit and any associated environmental damages.

These results indicate that majority population of Ring Main units are well below their expected life of 40 years. Ring Main Unit failures affect the switching flexibility of the network, therefore their risk to the system if they do fail impacts primarily on network performance and the STPIS incentive.




Figure 4-50: Year 0 (2018) Health Index Profile, RMU's

If replacement is deferred until 2025 (Year 7) the health index changes as shown in Figure 4-51.

Total risk for all failure scenarios at Year 7 is calculated to be \$317k with a predicted failure rate of 3 per annum.




Figure 4-51: Year 7 (2025) Health Index Profile, RMU's

These results indicate that the majority of the population of Ring Main Units are well below their expected life of 40 years. Ring Main Unit failures affect the switching flexibility of the network, therefore their risk to the system if they do fail impacts the network reliability incentive as indicated in Figure 4-52.




Figure 4-52: Risk Profile for Year 0 (2018) & Year 7 (2025), RMU's

The model forecasts that one Ring Main Unit per annum will require replacement over the next 7 years to maintain the risk at current (Year 0) levels. Assets identified as being in poor condition at Year 7 will take priority for consideration of replacement. The forecast replacement volumes included in this strategy include the number of replacements associated with planned replacement programs as well as the condition based failures forecast here.

4.6.4 RISK

4.6.4.1 Criticality

Asset criticality is a measure of the risk of specified undesired events faced when utilising equipment. Asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A. The asset criticality score is then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This also ranks importance of dissimilar sub-asset classes (e.g. transformers and buildings and grounds) to identify areas where risk should be managed first and control measures implemented.

Non-pole type distribution substation asset class has an asset criticality score of AC2 (Moderate) due to the consequence of non-pole substation failure having the potential to cause third party damage and injury to JEN personnel and members of the public.

Non-pole type distribution substations contribute to JEN overall service level performance through reliability and quality of customer supply. There are 2,407 non pole type substations, the number of customers supplied by these substations individually is in a range between 1 and 341; therefore a loss of supply from a non-pole type substation has a minor impact on STPIS incentives. Network configuration is also designed such that in the majority of cases customer outages can be minimised through HV switching and LV parallels so that supply to customers can be restored promptly. It should be noted however that this type of substation is generally used to service Jemena's high profile customers such as major shopping centres, large sporting venues, show grounds, hospitals and public transport networks. Although the customer numbers may be low from a STPIS perspective the impact of an outage can have a significant impact on Jemena's public profile.

4.6.4.2 *Failure Modes*

Failure modes for this sub class include:

- Thermal failure - due to overload, out-of-balance load, and deteriorated or high resistance connections;
- Insulation failure - due to loss of insulation medium (SF6 gas or oil leak), heat and age related winding insulation deterioration, lightning strikes, high voltage injections, switching events, or water penetration;
- Winding failure – winding distortion due to a through-fault;
- Deterioration or corrosion – age and environmental related deterioration of seals, paint, insulation, and connections; and
- Failure due to external factors – such as vehicle strikes, animals, vandalism and weather.

The symptoms of the above failures varies from:

- Operation of protective devices including blown fuses and circuit breaker trips;
- Excessive heat, hot spots and annealing;
- Molten material and possible fire;
- Internal or external flashover between HV to LV, HV to earth, LV to earth and inter-turn;
- SF6 leak or Oil spill having possible environmental impacts; and
- Distortion of tank, winding, lead supports.

4.6.4.3 *Current Risks*

The risks associated with the non-pole type distribution substation failures are described in Section 4.6.4.2. For details of the risk assessment, refer to Jemena's Compliance and Risk System (JCARS).

The particulars of current risks that have the potential to impact the performance of this sub-asset class are as follows:

- During 2013, a number of Wilson kiosks manufactured between 2005 and 2009 failed catastrophically. As a safety measure the operation of 123 Wilson Kiosks of similar design was restricted via CRO tags. An investigation by the manufacturer found no root cause for the failures but hypothesised that there could have been internal clearance issues causing partial discharge which eventually led to the failures; and
- Another iteration of Wilson kiosks has suffered two bushing failures. These issues have been taken up with the manufacturer to identify possible remedies.

The following HV switch types have known issues specific to their design, these switches are either being maintained or are targeted for replacement:

- Schneider RM6s RMU's (manufactured between 1983 & 87) use SF6 gas as their insulating medium. A number of these units have been found with low gas levels and as a result have degraded insulation systems. A small number of catastrophic failures have resulted from low gas levels;

- Schneider RM6 units (manufactured between 1983 & 87) also have issues with their spring operating mechanism, over time grease hardens within the mechanism resulting in a misalignment of the semaphore which leads to failure during operation. The manufacturer recommends that these units be maintained to ensure that the grease does not affect the operation. Maintenance work orders have been created so that the identified units can be safely utilised until their replacement;
- Early versions of the Merlin Gerin gas insulated RMU were supplied without any indication of gas pressure. The integrity of these RMU's is dependent on the maintenance of gas pressure within the unit and without a gas pressure gauge operators have no way of ensuring the integrity of the unit prior to performing any operation. A program has been established to retire all RMU's that do not have gas pressure indication (all makes) as they are identified either via the substation inspection program or when reported by operators. An examination of GIS records indicate that there are in the order of 27 of these units still in service. It is planned that they be retired during the 2021-2025 period. The principal driver of this program is safety, it is not expected to materially change overall network reliability performance;
- F & G RMU's were purchased in the 1990's for use in indoor distribution substations at both 22kV and 11kV. When operated at 22kV these units suffered a partial discharge problem in the HV fuse compartment. Modifications were made to the fuse compartments in an attempt to rectify the issue but this has not proved to be a long term solution. Tracking is occurring on the insulating surfaces in the fuse compartment and these RMU's need to be retired. There are three units operating at 22kV. These units are to be replaced in conjunction with the RMU replacement program detailed above;
- Calor Emag 22kV air break switchgear has been known to fail when operated due to the drying out of lubricants, one known failure occurred in the Powercor network. These units are being targeted for replacement;
- Siemens 3AC-20N Minimum Oil Breaker have failed to operate. In one case the field personnel attended the site and found that the DC supply was switched off and the batteries were dead. Upon replacing the batteries and ensuring DC supply was restored to the circuit breakers, it was found that the circuit breaker was still inoperable electrically and mechanically. It was found that the circuit breaker required lubrication for a seized mechanism and the interrupters were found to have no insulating medium;
- A number of different types of air break switches have been identified as having high maintenance costs and a high probability of failure. Indoor arc-chute switchgear has been responsible for a number of faults and one operator injury; and
- Some oil filled circuit breakers have been identified with low levels of insulating oil within the interrupting mechanism. These units require manual operation and consequently have no fault making capability. These breakers also have shunt fuse protection schemes that are obsolete and not supported.

Apart from substation failures and known design issues, poor performance has credible regulatory compliance risks.

Non-pole type substation performance is directly related to customer energy usage, the ability to deliver a compliant level of supply quality and reliability is compromised when a customer's load or export energy demand exceeds the substation rating.

The uptake of solar generation by customers is rapidly increasing the level of energy being exported into the distribution network. As it grows in capacity it is creating conditions which have never been experienced or planned for when the distribution network was designed. The main impact is on the voltage levels seen by the connected customers. To export energy; embedded generation (EG) systems require the voltage output of the EG to be higher than the network voltage at the customer's Point of Supply (POS), this facilitates the export of energy back into the distribution network. There is a cumulative effect on voltage rise as more EG systems are connected to the low voltage network.

Where voltage drop occurs as a result of increasing load there is now a voltage rise due to the reverse current flows into the network from multiple EG systems. The voltage experienced by the customer can rise above the VEDC requirements at the customer's Point of Common Coupling (POCC). At a localised level the excessive voltage causes inverters to shut down and/or adversely affect QOS limits at both the customer's premise and neighbouring properties. At the network level the cumulative export capacity can potentially exceed the rating of the transformer and its associated components leading to possible failure.

EG energy generation does not always occur in sync with energy usage, at the domestic load level peak usage times occur of an evening whereas the majority of energy being exported by solar systems occurs during the day when the sun is shining. This means that distribution substations require the capacity to supply the maximum energy demands of customers loads of an evening without the influence of embedded generation, and maintain an acceptable level of supply voltage during the day when embedded generation is at a maximum level. Satisfying these varying network requirements is not always possible with the existing static network elements.

In addition, there is an increase in the amount of non-linear, "dirty load" and generation from customers' equipment that affects the ability of distribution substations to deliver a clean, distortion free supply. Non-linear loads, such as DC to AC power converters, switch-mode power supplies, dimmable switches, DC chargers (Electric Cars) and arc furnaces produce harmonics which inherently distort supply voltages creating a dirty supply. The cumulative impact of these dirty loads increases the base levels of harmonic distortion which increase the impact of individual localised harmonic distortion. Experience indicates that localised harmonic distortion can exceed the 5% supply voltage VEDC distortion limit.

4.6.4.4 Existing Controls

All plant and equipment utilised in the construction of these distribution substations undergoes an initial type test by the manufacturers to ensure compliance with the requirements of the product specifications and applicable standards.

Substations installed in the field are constructed to Jemena's standard design requirements and the final construction is audited to ensure compliance. The design and construction standards incorporate the following controls to mitigate against failure events and ensure the required performance is achieved:

- Substation and Plant construction standards (Distribution Construction Manual, Volume 2, Section 3.0) – reduce the likelihood of poor construction practices, and the use of non-standard construction methods;
- Clearances, Design & Construction Principles (Distribution Construction Manual, Volume 1, Section 2.6) - prevent point of contact between network elements;
- Surge arrester procedure (JEN PR 0011) – sets out the requirements for the overvoltage protection of high cost equipment to protect against events such as lightning strikes; and
- Animal and Bird Protection Procedure (JEN PR 0065) – sets out the requirements for the installation added covers to prevent animal contact between live and earthed components.

Other operational controls include:

- Enclosed Distribution Substation Inspection Program – 3 to 5 yearly visual inspections to ensure asset integrity;
- Thermographic Surveys – on a 1 to 3 year cycle non-pole type distribution substations along the backbone of the feeder are surveyed to identify hot spots caused by overload and high impedance connections;

- Maintenance process - Plant maintenance notifications are raised and prioritised for the rectification of defects or replacement of assets when identified;
- Non-pole type distribution substation load monitoring – cumulative customer energy load profiling relative to transformer nameplate rating; and
- Quality of Supply monitoring – 5 minute spot voltages, voltage variations and outages are monitored via AMI (Smart) meters.

As part of criticality assessment; consideration is given to appropriate levels of spare equipment. Spares requirements for critical assets are assessed by following the Critical Spares Assessment Procedure (JEM AM PR 0015). Adequate spares are maintained at the Tullamarine depot and stock holdings are managed by Services and Projects.

4.6.4.5 *Future Risks*

Changes in energy profiles due to both changing usage and generation patterns are occurring and the outcomes of these changes are currently being assessed and modelled. The initial indicators are that there will be an overall increase in energy demand and that the increase will need to be diversified to avoid excessive increases in maximum demands. The most significant impact will come from Electric Vehicle (EV) charging.

As Victoria moves towards a lower carbon footprint there will be a push towards EV's away from the traditional fossil fuelled vehicles. The energy demands for EV's will have to be met by the current electricity infrastructure in conjunction with non-network generation. Their demands will add to the daily load profiles and if they follow a similar pattern will increase usage in peak demand periods. Usage will therefore need to be managed to limit their impact on energy maximum demands. This can be achieved by incentivising off peak usage, Infrastructure Victoria made the following statement relating to this topic.

"Do Now - Review state-based regulatory settings to allow electricity providers to set demand-variable rates and demand management strategies. For example, consider amending metering and pricing arrangements to allow for separate 'vehicle only' electricity tariffs to be offered to zero emissions vehicle owners to shift the electricity demand from these vehicles away from peak times." *

Infrastructure Victoria concluded that not adopting an off peak incentive scheme will have significant implications on Victoria's energy network.

"Although the overall energy consumption of vehicles remains constant regardless of the load profile in each scenario, their contribution to maximum demand can change dramatically. This could have significant implications for Victoria's energy network. For example, a non-incentivised load profile would reflect users plugging their cars in at night as soon as they get home, leading to demand peaking in the early evening to an even greater extent than in the base case."*

(*Source: Infrastructure Victoria, Advice on Automated and Zero Emissions Vehicles Infrastructure, October 2018)

Both off peak and peak usage, will have an impact on the cyclic rating of transformers. Off peak usage will result in load being diversified across a 24 hour period thus reducing the transformer cooling time and as a result, require a reduction in the cyclic ratings to manage the transformers performance. An increase in peak usage will require more capacity to be added to the network increasing the network cyclic rating. Further studies are required to identify the impact that the new energy profiles will have on the cyclic rating of transformers.

With the roll-out of smart meters (AMI) and the consequential introduction of full interval metering data, the accuracy of the distribution substation utilisation analysis will be further improved through increased data availability and accuracy. It is anticipated that there will be an increase in the number of substation QOS and loading problems identified. JEN must therefore ensure that it is positioned to

respond to these increasing demands and continues to remain compliant by adapting and reacting to the new demands with an equally dynamic response and an ability to efficiently match the networks supply capacity with our customers load demands. This will require working in collaboration with customers to develop and implement non network solution in conjunction with traditional network solutions.

4.6.5 LIFE CYCLE MANAGEMENT

The options available for asset lifecycle management reflect a trade-off between capital and operating expenditure. The aim is to achieve predictable and sustainable OPEX and CAPEX programs that manage the network risk and deliver improved safety outcomes that are associated with the replacement of unserviceable assets and the deployment of new technologies. The preferred asset lifecycle management option involves condition based replacement.

The strategy covers time based inspections followed by condition based maintenance and replacement, as well as in-service failure based reactive maintenance.

The principal strategy applied to this sub-asset class is condition based. Maintenance, refurbishment and replacement activities are driven by the results of a number of formal inspection programs and the CRO protocols. This is supplemented by a number of proactive replacement programs that are designed to address load related issues and known asset performance issues and risks.

4.6.5.1 Creation

Non-pole type distribution substations are created as a result of the following principal drivers:

- requests for new customer load via the Customer Initiated Construction process;
- organic load growth;
- an existing customer's request for an increase in supply capacity; and
- the identification of a maintenance or performance issue that requires augmentation to address.



The need for new or the upgrading of existing distribution substations is either identified by the Customer and System Planning team to meet customer load requests or by the Asset Analytics and Programs team after reviewing the substation loading and confirming overloads from test reports. The Distribution Substation Augmentation Program is designed to address organic load and supply quality related drivers for substation augmentation. Equipment failure is addressed reactively.

JEN has standardised the capacities of non-pole type transformers and kiosk substations to be purchased for general use on the distribution system and these are indicated in Table 4-51 below.

Table 4-51: Standard Non Pole Type Transformers and Kiosk Substations

Type	Capacity (kVA)											
	11/6.6kV			11kV				22kV				
Kiosk	500	-	315	500	1000	1500	2000	315	500	1000	1500	2000
Indoor	500	1000	-	500	1000	1500	2000		500	1000	1500	2000

The numbers of transformers installed on the distribution network characterised by their kVA rating is indicated in the following figures. Kiosk and padmount types, Figure 4-53, indoor transformers, Figure 4-54 and ground mounted transformers, Figure 4-55.

**Figure 4-53: Kiosk and Padmount Type****Figure 4-54: Indoor Type**




Figure 4-55: Ground Type

4.6.5.2 Asset Operation and Maintenance

There are three (3) considered life cycle management options for non-pole type transformers:

- Asset Inspection and Condition Monitoring;
- Preventative Maintenance (Condition Based Replacement); and
- Reactive and Corrective Maintenance.

4.6.5.2.1 Asset Inspection and Condition Monitoring

All non-pole type distribution substations are inspected in accordance with the criteria set out in the JEN MA 0695 - Enclosed Distribution Substation Inspection Manual on a three year cycle in HBRA and a five year cycle in LBRA. All assets within the substations are recorded, with identification, compilation & scheduling of any defects or problems for rectification.

The inspection of these assets includes as a minimum:

- visual inspection of SF6 gas gauges and photographs of pressure gauges with abnormal levels;
- thermal scanning;
- inspection for the effects of corrosion;
- detection of abnormal audible discharge;
- inspection of cable and cable termination conditions;
- checks of transformer and switchgear oil leaks and oil levels; and
- site security.

In conjunction with the above inspection program all non-pole distribution substations located in non-CMEN areas have their earthing installations tested every ten years in accordance with the Earthing Inspection and Testing Plan. This is consistent with the JEN ESMS (refer to JEN PL 0034 - Earthing System Asset Class Strategy).

For ground-type substations and the associated pole mounted switchgear, switch inspection will be included in the overhead line inspection program.

Defects identified in these inspections are to be scheduled for later repair in logical work packages to minimise the number of times customers are off supply.

Inspection of distribution circuit breakers within indoor and underground substations must be done when opportunities arise and as part of substation inspection and maintenance. Given the physical constraints imposed by switchgear front panels, an inspection will invariably be limited to the following:

- General check for cleanliness;
- Check condition of shunt trip fuses for any signs of creep from the fuse holder and/or deterioration of the fuse wire;
- Check for any obvious wiring insulation failures and/or loose connections;
- Check status and record information such as installation year and type of DC supply systems including batteries and battery charger; and
- Check and record information on the relay (if applicable)

Historically very little information has been retained on file with respect to the switchgear and protection systems employed in JEN non-pole type distribution substations. The initial program has gathered nameplates where possible but has not transferred this information from the photos to the system. Data gathering has a high priority in upcoming inspection programs.

In order to prevent HV indoor distribution switchgear failures due to HV fuse candling all general or back-up type fuses are to be replaced with full range fuses. A list of the correct fuse size for the various transformer sizes can be found in the JEN GU 0500 – JEN Fusing Guideline. If a suitably sized full-range fuse is not available the fused switchgear should be replaced with a modern CB ring main unit.

Families of HV switchgear identified as being problematic or prone to failure will be phased out, replacements will be managed within the capital budget.

A planned replacement program will be introduced for all distribution substation DC supply systems, such as batteries and chargers as these units require ongoing maintenance and have been proved to be unreliable. Upcoming asset inspection programs should be used to collect information on substations with DC supplies.

Any LV switchgear found in a damaged condition, in an inoperable condition or with obvious overheating deterioration, shall be replaced.

Buildings that contain asbestos are a potential health and safety risk. The replacement or major refurbishment of buildings may be governed by legislative changes in the future, requiring the safe removal of all asbestos within specified timeframes.

Suitably sizing substations will not only improve the quality of supply for customers but will generate improvements in supply reliability as the risks of failures will be reduced when the networks capacity is designed to align with customer loading demands. These improvements will include a reduction in the risk of network losses that are elevated when distribution transformers are overloaded, a reduction in the risk of environmental issues associated with oil leaks from overloaded/overheated transformers and a reduction in the risk of fire starts caused by catastrophic failures. The utilisation of distribution

substations is reviewed as per the Distribution Substation Augmentation Program. For details, refer to the Distribution Substation Augmentation, Network Development Strategy ELE PL 0017.

The indoor transformers and kiosk substations which are taken out of service as a result of the augmentation program are then assessed in accordance with the requirements for refurbishment. When substations are removed from service for reasons other than defect repair, such as load growth, load decrease, noise, redundancy or maintenance, they are assessed using the criteria set out in the Distribution Transformer Refurbishment Policy – ELE PO 0600. Substations that satisfy the criteria shall be refurbished and returned to stock for future use. Those that do not meet the criteria shall be scrapped.

The replaced substation will be assessed according to the below criteria to determine if the substation should be refurbished and returned to service or be scrapped:

- PCB Contamination;
- Voltage ratio and tapping range;
- Conditions including, internal faults, brown porcelain bushings, rust, impacts, distortion, confirmed noise complaints;
- Age and capacity;
- Configuration, size and weight; and
- Cost of refurbishment.

Kiosks shall also be check for:

- Ring main switchgear with no gas pressure indicator;
- “Compact” LV switchgear with J type fuses;
- Oil insulated HV switchgear that is not fully fault rated; and
- Substantial corrosion or rust on the enclosure.

For more information, refer to ELE PO 0600 – Distribution Transformer Refurbishment Policy.

Generally Ring Main Units are not refurbished. They are typically tested and reused if they are still performing within specification. Otherwise they are disposed of according to JEM PO 1600 – Scrap Materials.

Refurbishment shall only be carried out if the refurbishment cost is less than the residual substations value as described in the Distribution Transformer Refurbishment Procedural Standard – ELE PO 0600.

The typical tapping range for old transformers is between 100% and 90% for 415/240V transformers and 102.5 to 92.5% for 433/250V transformers, these ranges fall outside of the retention range of 105-95% as depicted in the ELE PO 0600– Distribution Transformer Refurbishment Procedural Standard. In general, transformer tapping ranges are not clearly defined in existing records. An emphasis will be placed on identifying and documenting the tapping range and set tap position while conducting upcoming Inspection programs.

4.6.5.2.2 Preventative Maintenance

4.6.5.2.2.1 *Proactive Replacement*

To address the manufacturing defects identified in Wilson kiosks with enclosed rotary switches, 35 kiosks will need to be removed from service and refurbished by Wilsons Transformer Co. It is planned to refurbish 6 units per year until the population of problem units are rectified.

Problematic air break switches are CRO tagged and labelled as inoperable. Each year, condition information and failure history will be reviewed and priorities established for switchgear replacement in the following year within the planned CRO Switch replacement project.

4.6.5.2.2.2 *Condition Based Replacement*

The condition of non-pole type transformers is monitored via the substation inspection program and the thermal survey program. In addition the operating environment as defined by transformer loads is monitored via the Business Objects system which uses connectivity data from GIS and AMI energy data to measure and report on the load profiles for the various elements of the distribution system.

The results of this condition monitoring activity is used to drive the condition based replacement of non-pole type transformers.

Transformers are designed for operation with an ambient temperature of up to 40°C and a maximum top oil temperature rise of 60°C above ambient at full load. Operating temperatures that exceed these limits can result in the degradation of the transformers insulation systems, initiate oil leaks and cause catastrophic failures. Transformers housed in enclosures such as indoor substations and kiosk substations have their cooling impacted by the enclosure and consequently the cyclic rating of these transformers is constrained. The management of substation loads via accurate substation loading data and load profiles are essential to ensuring that transformers achieve their designed asset life.

The secondary voltage ratings of distribution non-pole type transformers do not align with Australia's nominal supply voltages and the difference creates inconsistencies in the current ratings in ampere between network supply capacities and customer loads. A change in the standard transformer secondary voltage from 415/240V to 433/250V was adopted approximately 30 years ago, following this, the Australian nominal voltage shifted from 415/240V to 400/230V. Discrepancies between transformer rated and customers nominal voltages have widened with these changes. As a result a transformers rated current is 8% lower than customers nominally rated current for an equivalent load expressed in kVA. That is to say that there is a difference between the currents associated with loads expressed in kVA that is dependent upon the voltage reference. A future adoption of a 400/230V secondary voltage would result in the need to increase the current carrying capacity of network elements required to deliver a particular load in kVA.

Transformer are static and not subjected to wear and tear, the only moving component is the on load tap changer which is rarely adjusted and only when the transformer is disconnected from service. Consequently there are no ongoing wear related maintenance requirement for transformers when operating within their capabilities.

The HV switchgear on the other hand has moving components and is used to operate and isolate various network elements. The condition of HV switchgear and its functional health is managed via condition based maintenance. This is informed by a number of inspection programs and the CRO protocol.

4.6.5.2.3 Reactive And Corrective Maintenance

Reactive and corrective maintenance is carried out when faults occur or after asset inspection programs identify any urgent maintenance, for example, in service electrical faults or excessive oil leaks.

4.6.5.3 Non-Pole Type Transformer Forecast Replacement Volumes

As detailed in this strategy, a number of projects have been identified to ensure that we maintain network performance, and also address our compliance requirements.

Table 4-52 lists the forecast replacement volumes for non-pole type distribution substations from 2020 to 2026 required to maintain network performance at current levels. In addition to this the Distribution Substation Augmentation Program drives the replacement of overloaded substations. Details of this program are included in the Network Performance Plan 2021-2025 (Doc No. ELE-999-PA-IN-002).

Table 4-52: Non-Pole Type Distribution Substations Forecast Replacement Volumes

Service Code	Non-Pole Type Distribution Substations	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RHD	Transformer Ground/Indoor	10	10	10	9	9	9
RHE	Indoor/Kiosk Switchgear, RMU Age & Fault Replacement	3	9	6	6	6	3
RHK	Transformer/Substation Failure Kiosk	11	11	11	11	11	11
RHM	Kiosk Refurbishment	16	12	12	12	12	12
RHF	LV Switchgear Replacement	2	1	1	2	2	2

4.6.5.4 Asset Disposal

Failed or damaged substations that are considered unsuitable for refurbishment are scrapped. The substation is taken out of service, returned to the depot and stored in a banded area. The substation oil is tested for PCB content and disposed of appropriately under a contract arrangement.

As a result of the initial EDSIP, a total of 81 non pole type distribution substations containing asbestos were identified, primarily found in cable entry conduits, and arc chute type air break switchgear. Following the Enclosed Substation Inspection Notification (ESIN) project, an external asbestos contractor is to be engaged to determine an appropriate rectification process to remove or mitigate the risks of the historically installed asbestos.

Disposal of all materials shall be in accordance with JEM PO 1600 – Scrap Material Policy.

4.6.5.5 Spares

Emergency non-pole type distribution substation stock is determined by the Asset Analytics and Programs team based on the quantity of the items in service on the network and its historical usage. Emergency stock levels are shown in Table 4-53.

Table 4-53: Non-Pole Type Distribution Substation Emergency Stock Levels

Material	Material Description	Min	Max. level
11000018	TRANSFORMER,11-6.6KV/433-250V,1000KVA,CE	1	1
11002271	KIOSK,22KV/433V, 500KVA,IFT,4FS	1	1
11004358	KIOSK/SUB,22KV,2000KVA,433V,RMU	1	1
11004361	TRANSFORMER,11-6.6KV, 500KVA,3P,433V,CE	2	2
11004377	TRANSFORMER,11KV,1500KVA,3P,433-250V,CE	1	1
11004794	TRANSFORMER,22KV/433-250V 2000KVA 3PH CE	1	1
11004804	TRANSFORMER,22KV/433-250V 500KVA 3PH CE	1	1
11004813	PAD,22KV/433V 100KVA LOOP THROU,1 FS	1	1

Material	Material Description	Min	Max. level
11004817	KIOSK,22KV/433V, 500KVA,RING,4FS	1	1
11004819	TRANSFORMER,22KV/433-250V 1000KVA 3PH CE	1	1
11005057	TRANSFORMER,11KV,1000KVA,3P,433-250V,CE	1	1
11005247	PAD,22KV/433V, 315KVA, RING, 4FS	1	1
11005248	PAD,22KV/433V, 500KVA, RING,4FS	1	1
11005249	PAD,22KV/433V,1000KVA,RING,1FS	1	1
11005251	PAD,22KV/433V, 2000KVA,RING,1FS	1	1
11005252	PAD,11-6.6KV/433V, 500KVA, RING, 4FS	1	1
11005420	PAD,11-6.6kv/433V,1500KVA,RMU	1	1
11012802	TERM, TEE SPLICE, FOR PIN ELBOWS	2	2
11012821	PAD,22KV/250V,50KVA,LOOP THRU,1PH	2	2
11005369	PAD,22KV/433V, 500KVA,RAD,4FS.DNR	1	1

Emergency stock is also supplemented by Network Project stock when required.

4.6.6 INFORMATION

Jemena's AMS provides a hierarchical approach to understanding the information required to achieve Jemena's business objectives at the Asset Class level. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and the Asset Class Strategy (ACS) all provide the context for and determine the information required to manage and operate an Asset Class.

The Electricity Distribution Asset Class Strategy facilitates the safe, efficient and reliable delivery of electricity to JEN's customers.

From these business objectives, it is possible to identify at a high-level the content of the business information systems required to support these objectives (Table 4-54).

Table 4-54: Non-Pole Transformer Sub-Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Sources	Information	Externally Sourced Data
Operational Excellence <ul style="list-style-type: none">• Manage assets throughout their lifecycle in safe and environmentally responsible manner• Maintain assets in accordance with RCM principals• Maintain asset information/knowledge to enable efficient and effective decision making• Embed continuous improvement throughout asset lifecycle Customer <ul style="list-style-type: none">• Maintain our current service levels• Incorporate customer feedback in our decision making process Growth	GIS/JEN Viewer <ul style="list-style-type: none">• Geospatial representation of the JEN Network• Asset attributes SAP <ul style="list-style-type: none">• Work schedule & status• Planned and corrective (faults) maintenance records• Asset inspection measurements• Financial information ECMS <ul style="list-style-type: none">• Asset Inspection Manual, inspection methods & criteria	<ul style="list-style-type: none">• Current cadastre (including land ownership) for JEN's geographical extent.• DELWP - HBRA and LBRA area boundaries• CFA for fires, warnings and restrictions, incidents• Emergency Management Common Operating Picture (EM-COP)• Aerial Imagery for JEN's geographical extent (NearMap)• Google 'Street View'• Melway	

<ul style="list-style-type: none"> Acquire/install/maintain assets to meet future demand requirements People <ul style="list-style-type: none"> Maintain safe work environment Engage team leaders in assessment of new assets Training 	<ul style="list-style-type: none"> Policies, procedures and guidelines General asset audits/surveys not stored in SAP Incident investigations Drawbridge <ul style="list-style-type: none"> Standards Operations diagrams Line design manual Construction manual SCADA/RTS <ul style="list-style-type: none"> Outage Management System (OMS) & SCADA (DMS) Planned and Unplanned outages JEN Analytics <ul style="list-style-type: none"> Power quality data Energy consumption 	<ul style="list-style-type: none"> SAI global (Australian and International Standards) ESV / ESC / AER for regulatory obligations
--	---	---

Table 4-55 identifies the current and future information requirements to support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-55: Non-Pole Transformer Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
Non-pole transformers acquisition and application	<ul style="list-style-type: none"> Purchase specification (ECMS) Distribution Design Manual (ECMS) Distribution Construction Manual (ECMS) Period contracts (ECMS) Logistics system (SAP) 		<ul style="list-style-type: none"> High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.
Life cycle management: <ul style="list-style-type: none"> Asset identification Condition monitoring Condition assessment Replacement / retirement strategy Disposal 	<ul style="list-style-type: none"> Each asset identified by geospatial representation in GIS and equipment ID in SAP Asset Inspection Manual (ECMS) Maintenance plan (SAP) JEN Analytics (e.g. deteriorated neutral) Measurement record (SAP / ECMS) PM Notifications/Orders (SAP) Strategy detailed in this document GIS asset attributes: <ul style="list-style-type: none"> Asset status (e.g. existing/historical) 	<ul style="list-style-type: none"> Utilisation Load balance on each circuit by phase Near real time updating of asset record Photos database of all failed assets Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
	<ul style="list-style-type: none"> - Status (in service, isolated, out of commission) - Sub Name - Type - Operating level - Feeder - Circuits - Date Installed - Live Line Clamp - CMEN - Inspection Zone • Fault / failure records: <ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 		

Table 4-56 provides the information initiatives required to provide the future information requirements identified in Table 4-55. Included within this table is the risk to the Asset Class from not completing the initiative.

Information required to support asset strategies, performance and risks is recorded in SAP, Geographic Information System (GIS) and ECMS. Additional fault related data is available in the Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

Table 4-56: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information capture	Ability to capture all relevant asset attributes from the field through mobility solution.	High	Complete, Current, Accurate attribution
Improve/review MAT Code definitions	Ability to align to AER service classification structure.	High	Precise definition
Improved Asset Attributes	Review current asset attribution fields to ensure attributes being collected are asset specific.	Medium	Appropriate and Accurate attribution
Increased Timeliness	Decrease latency between fault/maintenance delivery and fault/maintenance record capture.	High	Complete, Current, Accurate attribution
Improved fault information capture	Ability to capture all relevant asset failure information from the field through mobility solution and photos.	High	Complete, Current, Accurate fault information

4.7 OVERHEAD LINE SWITCHGEAR SUB-ASSET CLASS

4.7.1 INTRODUCTION

The overhead line switchgear sub-asset class applies to pole mounted:

- air break load break switchgear;
- gas insulated load break switchgear; and
- disconnectors (isolators and live line clamps).

There are a total of 525 HV air break switches, 2,203 HV disconnectors, and 1,067 gas switches installed on the JEN as of December 2018. There are 226 high voltage (HV) feeders in JEN and each feeder supplies an average of 1542 customers. Each feeder has an average of 2 air break switches, 10 sets of isolators and 4 gas switches; therefore a failure to operate can adversely affect the operational efficiency and flexibility of the network.

The gas insulated switches come in two forms, manual and automated. The automated units are the principal device used to facilitate the remote control of the distribution network.

Table 4-57 provides details of the number of HV overhead switchgear by type and operating voltage installed on the JEN.

Table 4-57: HV Overhead Line Switchgear

Overhead Switchgear Type	Operating Volume			Total
	22kV	11kV	6.6kV	
Air Break Switches				
Arc Chute	43		3	46
Ganged Arc Chute	233	4	2	239
Ganged Flicker Blade	173	66		239
Horn Deflector	1			1
HV Disconnectors				
Isolator	1382	309	216	1907
Ganged Isolator	1			1
Live Line Clamp	261	32	2	295
Gas Switch	921	118	28	1067
Total	3015	529	251	3795

4.7.2 ASSET PROFILE

4.7.2.1 Life Expectancy

As prescribed in ELE PR 0012 – Network Asset Useful Lives Procedure, the applicable useful life for overhead switches is 50 years.

The Procedure considers asset useful lives based on good industry practice and specific Jemena Electricity Networks experience and represents the lives of assets at which end-of-life replacement

will be considered. For good industry practice, JEN has referenced a number of reviews from asset useful lives consulting agencies and discussions with other DB's.

4.7.2.2 Age Profile

There are approximately 3,800 pole mounted HV overhead switches as of December 2018. These include air break type switches, disconnectors (isolators and live line clamps) and gas switches. The age profile for HV overhead switchgear is shown in Figure 4-56.

Faulty air break switches and disconnectors have been removed and, where required, replaced with gas insulated switches. Fully enclosed, metal clad, gas insulated load break, fault make, switches have been installed on JEN as standard equipment since 1995. Air break switchgear has not been used as standard since this time due to problems associated with bird and animal strikes and maintenance requirements. A small number of air break switches have been installed since 1995 but it is probable that these are specialised, high capacity, project specific installations.




Figure 4-56: Age Profile of HV Overhead Switches

4.7.2.3 Utilisation

The main function of the overhead line switchgear is network switching. This enables the distribution network to be operated, sectionalised and isolated at numerous points along distribution feeders, minimising disruption of electricity supply to customers on the overhead feeder. The switchgear is used to isolate parts of the network to facilitate maintenance and construction activity and to reconfigure the network and manage network load. Automated gas switches facilitate the remote control of the network and are critical to future plans for self-healing network capabilities.

4.7.3 PERFORMANCE

4.7.3.1 Requirements

The requirements for all new overhead line switchgear are set out in Jemena's technical specification for the purchase of this equipment. This specification sets out the performance standards to be met and the design features of the switchgear. The specification references a number of Australian Standards. Unless otherwise specified, all HV overhead line switchgears shall be designed, manufactured and tested in accordance with the following Australian Standards (refer to Table 4-58).

Table 4-58: Relevant Australian Standards

Standard	Title
AS 1852.441	International Electrotechnical Vocabulary – Switchgear, Control gear and Fuses
AS/NZS 60265.1	High-Voltage Switches – Switches for Rated Voltages above 1kV and less than 52kV
AS 62271.1	High-voltage switchgear and control gear – Common specifications
AS 62271.200	High-voltage switchgear and control gear – A.C. metal-enclosed switchgear and control gear for rated voltages above 1kV and up to including 52kV

The equipment must be able to operate with the required performance parameters when exposed to climatic conditions in the state of Victoria. In particular the switchgear shall have the following features:

- Load breaking capacity equal to its rated current;
- Fault current making capacity to match the network design fault levels;
- Short circuit withstand levels that match the network design fault level: and
- Lighting impulse withstand level of 150KV for the 22kV network.

The HV gas switch will have a "Low Gas" lockout feature which will be activated upon reaching an unsafe operation level of insulant.

All future gas switches shall incorporate a device or indicator to show the gas level. Suitably marked zones shall be provided to indicate whether the unit is satisfactory for service or not. A red zone on an indicator signifies an unsafe operation level when the insulant is consumed to the point of non-serviceability. The indicator must be clearly visible from the ground when mounted on the pole structure and give a clear indication of the serviceability of the switch.

The requirements for the installation of overhead line switchgear are specified in the Jemena Distribution Construction Manual (JEN MA 0006). This includes the requirements for the installation of overvoltage protection on normally open switches.

4.7.3.2 Assessment

The operational performance of overhead switchgear is assessed by the examination of fault reports and the monitoring of maintenance notifications that relate to overhead switchgear. In addition the Caution Re Operation (CRO) tagging system used by the NOC to identify problems associated with the operation of distribution switchgear also provides a clear indication of the condition of this equipment.

4.7.3.2.1 CBRM Assessment – Air Break Switches

Initial CBRM results indicated that the current (Year 0) health index is as shown in Figure 4-57. Total risk for all failure scenarios at Year 0 is calculated to be \$479k with a current failure rate of 8 per annum. These failures can range from a minor failure (maintenance work required) to a major failure that includes replacement of the unit.




Figure 4-57: Year 0 Health Index Profile, Air Break Switches

If replacement is deferred until 2025 (Year 7) the health index changes as shown in Figure 4-58.

Total risk for all failure scenarios at Year 7 is calculated to be \$905k with a predicted failure rate of 14 per annum.




Figure 4-58: Year 7 Health Index Profile, Air Break Switches

These results indicate that the population of air break switches are approaching their expected useful life. Switchgear and isolator failures affect the switching flexibility of the network, therefore the consequence of failure is primarily related to the network reliability and the STPIS incentive as indicated in Figure 4-59.




Figure 4-59: Risk Profile for Year 0 & Year 7, Air Break Switches

The model forecasts a total of 23 air break switch replacements per annum over 7 years to maintain the failure rate at current (Year 0) levels for this asset class. Assets identified as being in poor condition at Year 7 will be prioritised for replacement.

In order to maintain the assessed risk associated with the operation of these assets at current (year 0) levels this strategy proposes the replacement of approximately 24 air break switches per annum with gas switches over the course of the EDPR period. Air break switches are obsolete and are being replaced with gas switches when required.

4.7.3.2.2 CBRM Assessment – HV Isolators

Initial CBRM results indicated that the current (Year 0) health index is as shown in Figure 4-60.

The total cost of risk for all failure scenarios at Year 0 is calculated to be \$560k with a current failure rate of 15 per annum. These failures can range from a minor failure (maintenance work required) to a major failure that includes replacement of the unit. In general replacement is the most common maintenance activity for this asset type.




Figure 4-60: Year 0 Health Index Profile, HV Isolators

If proactive replacement is deferred until 2025 (Year 7) the health index changes as shown in Figure 4-61. The total cost of risk for all failure scenarios at Year 7 is calculated to be \$904k with a predicted failure rate of 25 per annum.




Figure 4-61: Year 7 Health Index Profile, HV Isolators

Switch and isolator failures affect the switching flexibility of the network, therefore the consequence of failure is primarily related to the network reliability and the STPIS incentive as indicated in Figure 4-62.




Figure 4-62: Risk Profile for Year 0 & Year 7, HV Isolators

The model forecasts a total of 74 HV isolator replacements per annum over 7 years to maintain the failure rate at current (Year 0) levels for this asset class. Assets identified as being in poor condition at Year 7 will be prioritised for replacement.

In order to maintain the assessed risk associated with the operation of these assets at current (year 0) levels this strategy proposes the replacement of approximately 45 HV Isolators per annum over the course of the EDPR period.

4.7.3.2.3 Assessment – Gas Insulated Switches

Gas insulated switches have been deployed on the network since approximately 1990 in both the manual and remote controlled form. As such the age of the population is quite young with the oldest units at approximately 50% of their expected life. No units will exceed the expected life by 2025.

These assets have no integrity problems and the only common issues have related to communications with the remote controlled types. There have been some units damaged by direct lightning strike.

In order to maintain the risk associated with the operation of these assets at current (year 0) levels this strategy allows for the replacement of approximately 2 gas switches per annum over the course of the EDPR period as a result of asset failure. The majority of gas switch replacements included in this strategy are to facilitate the retirement of air break switches.

4.7.4 RISK

4.7.4.1 Criticality

Asset criticality is a measure of the risk of specified undesired events faced when utilising equipment. An asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). The results of this assessment are presented in Appendix A. The asset criticality score is then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This is also used to rank the importance of dissimilar sub-asset classes (e.g. transformers and buildings and grounds) to identify areas where risk should be managed first and control measures implemented.

The overhead HV switchgear sub-asset class has an asset criticality score of AC1 (Low) due to the consequence rating being minor.

Overhead line switchgear impacts on the JEN overall network reliability and Service Target Performance Incentive Scheme (STPIS) via the minimisation of customer numbers off supply during an unplanned outage.

4.7.4.2 Failure Modes

Failure modes for this sub class include:

- Fail to operate – either open or close, often due to seized, or misaligned mechanism, faulty latching mechanism or contact system. For air break switches this includes defective handles or down rods. For remote controllable gas switches this includes the failure of the communication or control system;
- Fail to carry load – due to deteriorated or high resistance internal components; could lead to thermal overheating and explosive failure;
- Overheating - due to high resistance external connections/components; could lead to thermal overheating and damage;
- Insulation breakdown - internally, due to contamination or lack of SF6 or externally due to insulator or bushing failures;
- Hardware mechanical failure – Includes operating mechanisms, handles and earthing connections;
- Failure due to external factors – includes animal contact and extreme weather condition; and
- Failure due to operational errors or third party – includes operator not closing and latching the switch properly and vandalism.

4.7.4.3 *Current Risks*

This section provides information about specific overhead line switchgear issues, as well as general issues. For details of the risk assessment, refer to the relevant section in Jemena's Compliance and Risk System (JCARS).

The following list of current and emerging network risks includes those which are for information purposes only, as well as items which require further development of inspection, maintenance or replacement programs:

- Recurring issues for overhead switches typically relate to a particular manufacturer or model, potentially installed during a consecutive series of years. An example of this is the family of ABB HV isolators which have failed due to cracks forming on the porcelain supporting insulator;
- For air break switches, given the age of this group of assets and the ongoing maintenance requirements, only minor corrective maintenance shall be undertaken as a result of the inspection program. Where significant component replacement, adjustment or repair is required, the air break switch shall be replaced with a gas switch;
- Recurring issues on 22kV air break switches include, adjustments needed as a result of incorrect installation, the early use of green timber segments in operating rods, operating handle diameters, the earthing of operating handles, brown insulators and identification plates;
- A visual inspection of gas switches is required to be carried out every 10 years. As these switches are inspected as a part of the line inspection program every 3 or 5 years and this can be undertaken from ground level, no allowance is made for additional gas switch inspection;
- In late 2003, the first of a series of ABB HV isolator failures was observed with the mode of failure being cracks forming on the porcelain insulator. These cracks resulted from corrosion of the supporting pin where it is cemented into the insulator. The cracks cause the insulator to fail mechanically resulting in breakage often when the isolator was being operated. An initial survey identified and subsequently replaced 18 ABB isolators with the new standard type isolators. A project was then setup to replace these isolators which has replaced all ABB isolators manufactured between 1996-1998. Current programs have replaced 207 ABB isolators since 2011, with 59 replaced between 2015 to 2017. Between 2021 and 2025, the remaining 34 ABB isolators will be scheduled for replacement in order to completely remove this population from the Jemena Electricity Network;
- From approximately 2002 to 2009 the make of isolator used was a non-latched NGK model. In 2009 a number of outages were attributed to non-latched isolators 'falling' open. Upon investigation it was suspected that bolts that had not been sufficiently tightened during manufacturing were allowing the isolators to be closed incorrectly (too much lateral movement in the arm). The manufacturer, NGK, changed their isolator design to one with a latching mechanism when closing and is now standard design. Monitoring of faults attributed to isolators will continue to identify whether pro-active measures are warranted; and
- Manual handling issues are always present in the operation of overhead switches, in particular switches that are operated by an operating rod and handle from ground level. Older switches can become stiff and difficult to operate. Safe operating procedures and correct manual handling practices are mandatory for operating any switch and adherence to these practices mitigates potential health and safety risks. The increased use of manual gas switches also improves the conditions for field staff required to operate a switch.

4.7.4.4 *Existing Controls*

The controls that are applied to this group of assets in order to maintain their performance and manage risk include the following:

- Inspection - All overhead line switchgear is inspected in conjunction with the asset line inspection program which involves a visual inspection of insulator condition, mounting hardware, operating arm and connections. For HV gas insulated switchgear, visual inspection also includes switch OPEN/CLOSE status indicators and tank condition;
- Functional checks – all manually operated overhead line switchgear is inspected by field operators before it is operated. Any defects or malfunctions are reported and maintenance notifications created. Defective plant will be CRO (caution regarding operation) tagged;
- Routine maintenance - For remote controllable gas switches, the control and radio communications equipment is maintained at 8 yearly intervals while battery change is at 4 yearly intervals; and
- Proactive replacement – JEN has identified certain HV switches that require proactive replacement as highlighted in Section 4.7.4.3 Current Risk (Issues).
 - Vertically or horizontally mounted Taplin two insulators type switches (all 1977) with 25mm drive shafts which twist and result in the three phases of the switches not operating together shall be identified and replaced with a gas switch;
 - Due to increasing problems with insulators breaking, any vertically or horizontally mounted Taplin D209 switches shall be identified and scheduled for replacement;
 - During the 2016-2020 EDPR period, a program was established to replace a backlog of CRO tagged switches. CRO tagged air break switches are now dealt with on a BAU basis. When they are identified they are scheduled for replacement or maintenance.

4.7.4.5 Future Risks

Single phase switching of any network segment with a significant length of three phase underground cable disrupts the normally balanced and self-cancelling capacitance in the cable resulting in capacitive current flow to earth. With the increasing utilisation of underground cables in JEN, the potential for single phase switching to create capacitive current flow of sufficient capacity to trip the sensitive earth fault protection on a feeder is substantial. This in turn will result in unplanned interruption to customer supply. The proposal to cease the installation of HV isolators in favour of manual gas switches aligns with the progressive movement away from single-phase switching in JEN.

4.7.5 LIFE CYCLE MANAGEMENT

The options available for asset lifecycle management reflect a trade-off between capital and operating expenditure. The aim is to achieve predictable and sustainable OPEX and CAPEX programs that manage the network risk and deliver improved safety outcomes that are associated with the replacement of unserviceable assets and the deployment of new technologies. The preferred asset lifecycle management option involves condition based replacement.

The strategy covers time based inspections followed by condition based maintenance and replacement, as well as in-service failure based reactive maintenance.

4.7.5.1 Creation

The various assets within the overhead line switchgear group are typically purchased under period contracts and installed in accordance with the standards described in the distribution construction manual and specification requirements.

They are deployed to sectionalise the distribution network in accordance with the principals set out in the Jemena Planning Manual – JEN MA 0010 and to facilitate the remote control of the network. Consequently they are installed in conjunction with projects that involve load growth and also as a result of projects aimed at the improvement or maintenance of network reliability performance.

Proposals for future improvements in this document will be incorporated in the contents of future plant specifications. Refer to Section 4.7.3.1 (Performance-Requirements) for overhead line switchgear design and construction standards.

4.7.5.2 *Asset Operation and Maintenance*

There are four (4) life cycle management strategies applied to the operation and maintenance of overhead line switchgear:

- Asset Inspection and Condition Monitoring;
- Preventative Maintenance ;
- Reactive and Corrective Maintenance; and
- Run to Failure.

4.7.5.2.1 *Asset Inspection and Condition Monitoring*

All overhead line switchgear is inspected in conjunction with the asset line inspection program which involves a visual inspection of insulator condition, mounting hardware, operating arm and connections.

For HV gas insulated switchgear, visual inspection also includes switch OPEN/CLOSE status indicators and tank condition. Furthermore, for remote controllable gas switches, the control box and radio communications equipment is checked at 4 yearly intervals as part of the battery change maintenance.

Pole mounted switches for non-pole type substations (ground type substations) are included in the asset line inspection program. Non-pole type switchgear is included in the non-pole type substation policy and substation inspection program.

In addition to the 3-5 yearly visual inspection, most switches & disconnectors are included in the 1-2-3 yearly thermal survey of overhead lines. It is expected that some hot connections and contacts will be detected, which shall be programmed for repair.

These programs help identify and resolve issues with the overhead switch population to prevent in service failures.

Individual switches or a particular family of switches which are identified as having a current or emerging issue may be placed on a more frequent inspection cycle or allocated within a routine maintenance program to ensure the continuous safety and operability of the switch is maintained.

For remote controllable gas switches, if a low gas alarm appears, they will lock out and an alarm will be sent to SCADA. There also have condition monitoring of the AC and DC supply of the Control box and alert Control Room via SCADA in times of failure with the AC Supply Fail alarm or Battery Fail alarm.

Other overhead line switchgear assets do not employ on-line condition monitoring.

4.7.5.2.2 *Preventive Maintenance*

The necessity for maintenance activities on overhead line switchgear shall be determined by the results of the scheduled inspections based on the priority of the defects. If switchgear passes all aspects of the inspection no maintenance is necessary. Any required maintenance shall be carried out in accordance with the "Strategic Maintenance Manual, Volume 2, Section 1 - Overhead Line Switchgear".

Remote controllable gas switches shall be maintained every eight years to functionally check the integrity of the control box and the switch mechanism. The battery for the operation of the control box and remote communications are to be replaced every four years.

Preventive maintenance is not considered cost effective for disconnectors and therefore only corrective maintenance is to be performed.

4.7.5.2.3 Reactive And Corrective Maintenance

Reactive and corrective maintenance is conducted when asset inspections deem it necessary. The below maintenance descriptions are for HV air break switches and isolators.

Note: All arc-chute switches recovered from concrete poles and as a result of the removal of unnecessary switches from the network shall not be reused or refurbished.

4.7.5.2.3.1 Minor Maintenance

Items classified as 'Minor Maintenance' can be performed without removing the switch from the pole, or making significant adjustments to the switch whilst remaining mounted to the pole.

In possum and bird prone areas, an economic assessment shall be conducted to assess the benefit of a manual gas switch to minimise frequency of animal contacts. If a positive economic assessment is achieved, a manual gas switch shall be installed.

4.7.5.2.3.2 Major Maintenance

Items classified as 'Major Maintenance' generally require the switch to be removed from the pole in order to complete the maintenance. Typical work required will include: replace insulators, main contacts & moving blades and fitting of expulsion interrupters.

If it is identified that major maintenance is required on a switch, the switch shall either be retired or replaced with a manual gas switch (refer to JEN GU 0010 - JEN Planned & Opportunistic Maintenance & Workmanship Guideline for more information).

For gas switches, no maintenance is performed on the switch itself and if there are mechanical issues, the switch is replaced. For remote controllable gas switches, communications to Supervisory Control and Data Acquisition (SCADA) system are monitored and equipment are maintained as required.

Historic inspections and notification analysis reveal the large majority of notifications related to incorrect installation, or the use of inappropriate component in the operating rods. As an example, ganged flicker blade air break switch toggle arm's movement are affected when the wooden operating arm has dried and shrunk which magnifies the leverage ratios and prevent the flicker blades from properly resting on the pins.

In addition, issues have been identified with operating handles, earthing, brown insulators and identification plates.

The issues requiring attention from past inspections, and subsequently scheduled for rectification, include:

Table 4-59: Raised Notification Issues

Issue	Action
Arc-chute switches on concrete poles present a flashover safety hazard.	Replace with gas switch
Vertically or horizontally mounted Taplin two insulator switches with 25 mm drive shaft (all 1977) which twist and result in the three phases of the switches not operating together	Replace with gas switch

Issue	Action
Vertical mounted Taplin type D209 switches with brown pin insulators which sometimes break at the grouting point between porcelain sections	Replace with gas switch
Stanger PR2 installed prior to 1982, which have been identified to have a manufacturing weakness in the contacts area	Replace with gas switch
Connections visually damaged or overheating	Require replacement with Ampact stalk lugs
Signs of insulator tracking (burning)	Replace with gas switch
Open point switches with obvious signs of flash-overs	Replace with gas switch
Isolators with loose mounting bolts due to wood shrinkage or burnt cross-arms due to insulator tracking	Replace crossarm and non-preferred isolators

4.7.5.2.4 Run to Failure

Run to failure is a replacement strategy which can be applied when the consequence of failure in terms of safety and reliability are minor and where the network response to the resultant outages or replacement activities can be promptly addressed at relatively low cost.

Over the past 10 years approximately 76 sets of HV isolators have been removed due to failure described by the following damage causes:

- Failed mechanical integrity (mechanical failure/deterioration);
- Failed required mechanical support;
- Failed to carry load (electrical overload);
- Failed to close;
- Failed to maintain physical clearances; and
- Failed to open.

Due to the low percentage of known asset installation dates for overhead line switchgear there is insufficient data available to accurately determine historic average asset life at time of replacement for overhead line switchgear.

4.7.5.3 Asset Replacement

4.7.5.3.1 Proactive Replacement

Proactive replacement of overhead line switchgear will generally take place as a result of failure of a type or model of switches which may present significant risk to network reliability or safety.

A family of ABB isolators manufactured between 1994 and 2000 that were installed within JEN have been observed to fail from cracks forming on the porcelain support insulator. This poses a risk to personnel when the isolator is being operated.

4.7.5.3.2 Proactive Retirement

Proactive retirement of overhead switchgear is not common and will generally take place as a result of network augmentation due to redevelopment of a network area or expansion of surrounding supply network. If the air break switches or HV disconnectors within the project area require major

refurbishment or a non-preferred type, they are considered for either replacement with a gas switch or retired and the switching point bridged through. Refer to JEN GU 0010 - JEN Planned & Opportunistic Maintenance & Workmanship Guideline for more information.

4.7.5.3.3 Condition Based Replacement

Due to its role within the network, condition assessment of overhead line switchgear is conducted as part of the day to day switching operations by the network operators, during which time notifications are raised for the rectification of defects or replacement of assets as identified. There is a proactive program to replace these ABB isolators within JEN.

Visual and physical inspection of overhead air break switches and isolators are the only means of condition monitoring, as they are not connected to any communications network, bent operating arms, burnt blades, cracked insulators, etc. would be identified for rectification.

Gas switches are designed to lock the mechanism to prevent operation when the pressure of the SF6 gas insulation is not sufficient. Low gas and battery fail alarms are flagged in SCADA if it is a remote controllable unit.

4.7.5.3.4 Overhead Line Switchgear - Forecast Replacement Volumes

As identified in this strategy, a number of projects have been created to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 4-60 lists the forecast replacement volumes for overhead line switchgear from 2020 to 2026.

Table 4-60: Forecast Replacement Volumes - Overhead Line Switchgear

Service Code	Overhead Line Switchgear	Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RHG	Gas Switch Replacement	22	26	26	26	26	26
RHG	Replace CRO'd Switches - Stage 9	7	-	-	-	-	-
RHH	HV Isolators	47	44	43	44	48	46
RHL	LV Isolators	39	38	36	36	39	38

4.7.5.4 Asset Disposal

Disposal of all replaced or retired gas switchgear shall be in accordance with JAM PR 0060 WI 16 – SF6 Gas – Identification, Storage, Handling and Disposal.

All other assets shall be disposed of in accordance to JEM PO 1600 – Scrap Material Policy.

4.7.5.5 Spares

As part of the criticality assessment consideration is given to appropriate levels of spare equipment. Spares requirements for critical assets are assessed by following the Critical Spares Assessment Procedure (JEM AM PR 0015). It was determined that adequate spares are maintained at Tullamarine depot and stock holdings are managed by the Services and Projects team.

4.7.6 INFORMATION

The Information required to support asset strategies, performance and risks is recorded in SAP, the Geographic Information System (GIS) and ECMS. Additional fault related data is available in the Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

Jemena's AMS provides a hierarchical approach to understanding the information required to achieve Jemena's business objectives at the Asset Class level. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and the Asset Class Strategy (ACS) all provide the context for and determine the information required to manage and operate an Asset Class.

The Electricity Distribution Asset Class Strategy facilitates the safe, efficient and reliable delivery of electricity to JEN's customers.

From these business objectives, it is possible to identify at a high-level the content of the business information systems required to support these objectives (Table 4-61).

Table 4-61: Overhead Line Switchgear Sub-Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Information Sources	Externally Sourced Data
<p>Operational Excellence</p> <ul style="list-style-type: none"> • Manage assets throughout their lifecycle in safe and environmentally responsible manner • Maintain assets in accordance with RCM principals • Maintain asset information/knowledge to enable efficient and effective decision making • Embed continuous improvement throughout asset lifecycle <p>Customer</p> <ul style="list-style-type: none"> • Maintain our current service levels • Incorporate customer feedback in our decision making process <p>Growth</p> <ul style="list-style-type: none"> • Acquire/install/maintain assets to meet future demand requirements <p>People</p> <ul style="list-style-type: none"> • Maintain safe work environment • Engage team leaders in assessment of new assets • Training 	<p>GIS/JEN Viewer</p> <ul style="list-style-type: none"> • Geospatial representation of the JEN Network • Asset attributes <p>SAP</p> <ul style="list-style-type: none"> • Work schedule & status • Planned and corrective (faults) maintenance records • Asset inspection measurements • Financial information <p>ECMS</p> <ul style="list-style-type: none"> • Asset Inspection Manual, inspection methods & criteria • Policies, procedures and guidelines • General asset audits/surveys not stored in SAP • Incident investigations <p>Drawbridge</p> <ul style="list-style-type: none"> • Standards • Operations diagrams • Line design manual • Construction manual <p>SCADA/RTS</p> <ul style="list-style-type: none"> • Outage Management System (OMS) & SCADA (DMS) • Planned and Unplanned outages <p>JEN Analytics</p> <ul style="list-style-type: none"> • Power quality data • Energy consumption 	<ul style="list-style-type: none"> • Current cadastre (including land ownership) for JEN's geographical extent. • DELWP - HBRA and LBRA area boundaries • CFA for fires, warnings and restrictions, incidents • Emergency Management Common Operating Picture (EM-COP) • Aerial Imagery for JEN's geographical extent (NearMap) • Google 'Street View' • Melway • SAI global (Australian and International Standards) • ESV / ESC / AER for regulatory obligations

Table 4-62 identifies the current and future information requirements needed to support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-62: Overhead Line Switchgear Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
Overhead line switchgear acquisition and application	<ul style="list-style-type: none"> • Purchase specification (ECMS) • Distribution Design Manual (ECMS) • Distribution Construction Manual (ECMS) • Period contracts (ECMS) • Logistics system (SAP) 		<ul style="list-style-type: none"> • High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.
Life cycle management: <ul style="list-style-type: none"> • Asset identification • Condition monitoring • Condition assessment • Replacement / retirement strategy • Disposal 	<ul style="list-style-type: none"> • Each asset identified by geospatial representation in GIS and equipment ID in SAP • Asset Inspection Manual (ECMS) • Maintenance plan (SAP) • JEN Analytics (e.g. deteriorated neutral) • Measurement record (SAP / ECMS) • PM Notifications/Orders (SAP) • Strategy detailed in this document • GIS asset attributes: <ul style="list-style-type: none"> - Asset status (e.g. existing/historical) - Status (in service, isolated, out of commission) - Sub Name - Type - Operating level - Feeder - Circuits - Date Installed - Live Line Clamp - CMEN - Inspection Zone • Fault / failure records: <ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 	<ul style="list-style-type: none"> • Switch rating • Manufacturer • Near real time updating of asset record • Photos database of all failed assets • Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> • High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Table 4-63 provides the information initiatives required to provide the future information requirements identified in Table 4-62. Included within this table is the risk to the Asset Class from not completing the initiative.

Table 4-63: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information capture	Ability to capture all relevant asset attributes from the field through mobility solution.	High	Complete, Current, Accurate attribution
Improve/review MAT Code definitions	Ability to align to AER service classification structure.	High	Precise definition
Improved Asset Attributes	Review current asset attribution fields to ensure attributes being collected are asset specific.	Medium	Appropriate and Accurate attribution
Increased Timeliness	Decrease latency between fault/maintenance delivery and fault/maintenance record capture.	High	Complete, Current, Accurate attribution
Improved fault information capture	Ability to capture all relevant asset failure information from the field through mobility solution and photos.	High	Complete, Current, Accurate fault information

4.8 LV OVERHEAD SERVICES SUB-ASSET CLASS

4.8.1 INTRODUCTION

An LV overhead service is defined as the terminating span that connects the distribution low voltage overhead mains (JEN asset) to the point of supply (customer's asset), including the associated hardware such as termination clamps, brackets and connectors. Whilst low voltage overhead services are singularly one of the least expensive items on the distribution system; as an asset class the volume and value is significant.

As of December 2018 there are in excess of 170,000 overhead services owned and operated by JEN and 98% of these are of three main types:

- Neutral Screened;
- Grey twisted PVC; and
- LV ABC.

Large scale batch replacements of service cables result in minimal gains in SAIDI, etc. as most low voltage overhead service faults result in single customer short duration outage.

4.8.2 ASSET PROFILE

4.8.2.1 *Life Expectancy*

As prescribed in ELE PR 0012 – Network Asset Useful Lives Procedure, the applicable useful life for overhead service line is 40 years.

The review of asset useful lives considers asset lives based on good industry practice and specific Jemena Electricity Networks (JEN) experience and represents the lives of assets at which end-of-life replacement will be considered.

4.8.2.2 *Age Profile*

The LV overhead service age profile encompasses a broad time-span, with some of the LV services dating back to the 1930's. LV overhead services installed on JEN, i.e. sourced from 2018 Regulatory Information Notice (RIN), are listed in the Table 4-64 .

Table 4-64 LV Overhead Service Population by Type (December 2018)

Service Type	First Used	Last Used	Population	Percentage of Overhead Population
Bare/Open Wire	1930's	1990's	1,599	0.94%
Red Lead	1940's	1960's	61	0.04%
Neutral Screened	1960's	1974	62,887	36.82%
Twisted Wire	1976	1989	21,128	12.37%
ABC	1989	Present	85,098	49.83%
Total			170,773	100.00%

Figure 4-63 below indicates the age profile of the LV Overhead Service population.




Figure 4-63: LV Overhead Services - Age Profile

4.8.2.3 Utilisation

Overhead services are provided to service single phase, two phase and three phase customer installations. Current overhead service lines range in capacity from 80 ampere single phase to 250 ampere three phase. They are limited to one span length (approximately 20m maximum) and normally terminate on the customers premises but they can terminate on a Private Overhead Electric Line (POEL).

Traditionally they provided energy to a customer's installation but today they also facilitate the reverse flow of energy from a customers embedded generation system to the grid.

4.8.3 PERFORMANCE

4.8.3.1 Requirements

The Electricity Safety (Management) Regulations 2009 require that JEN comply with its internal technical standards. JEN's internal standards reflect the requirements of the Electricity Safety (Network Assets) Regulations 1999. JEN's network assets have been designed, constructed and are maintained in accordance with these regulations. In addition JEN has conducted a Formal Safety Assessment as part of its Electricity Safety Management Scheme (ESMS). This included a risk assessment of the adequacy of JEN's current internal technical standards.

JEN uses internal construction standards when building LV services. These are prescribed in the "Distribution Construction Manual". These standards include design parameters which address areas including clearances and equipment types.

4.8.3.2 Assessment

The performance measures for LV overhead services are based on shocks, fire starts, height non-conformance and NST failures.

Figure 4-64 below shows the number of reported electrical shocks related to JEN assets in that calendar year. The blue graph shows the number of reported shocks since 2000. In recent years, there have been an increasing number of reported electrical shocks. These are typically minor shocks such as tingles from taps.




Figure 4-64 Electrical Shocks due to Network Assets

4.8.4 RISK

4.8.4.1 Criticality

Asset criticality is a measure of the risk of specified undesired events faced when utilising equipment. An asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A. The asset criticality score was then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This is used to rank importance of dissimilar sub-asset classes (e.g. transformers and buildings and grounds) to identify areas where risk should be managed first and control measures implemented.

The overhead service line sub-asset class has an asset criticality score of AC4 (High) due health and safety risk to staff and the general public caused by electrical shocks associated with broken or high impedance neutrals.

4.8.4.2 Failure Modes

Failure modes for the sub class include:

- Electrical failure of cable insulation material and joints/terminations;
- Corrosion of neutral screen causing high resistance or open circuited neutrals and lack of earth bonding;
- Mechanical failure of cable and or anchoring fixtures due to deterioration, and physical impacts; and

- Cable damage associated with abrasion of the insulation by vegetation.

Figure 4-65 below indicates LV Overhead Service failures by cause category since 2010.




Figure 4-65 LV Overhead Service Failures by Cause Category

The dominant mechanism which may lead to an electrical shock is failure of the service neutral, customer installation neutral or neutral connections, to the extent that the neutral impedance is unacceptably high. When the neutral impedance becomes high, the parallel return path for neutral currents provided by the customers' installation earth connection becomes important. If this earth impedance is also high, then as current flows in the installation, a voltage rise will occur and it is possible for the potential of the metalwork bonded to the earth system to also rise relative to the general mass of the earth.

When there is a potential rise on bonded metalwork there is the risk of electrical shock to persons who contact the metalwork and conducting earthed material simultaneously. Typically this occurs in showers where wet conditions and contact with both live taps and the waste pipe allows a small current to flow.

Although the failure rate is very low in relation to the number of existing services, the trend is increasing. Services are failing at a greater rate than they are being replaced and as such this trend will only begin to decrease once the situation is reversed.

4.8.4.3 Current Risks

For details of the risk assessment, refer to relevant section in Jemena's Compliance and Risk System (JCARS).

The major risk associated with LV overhead services and terminations is electrical shocks that result from damaged services. Current risks include:

- Investigations into reports of minor electrical shocks continue to identify failure of neutral screened services as a contributor to the incident. Of the incidents allegedly caused by network service assets, about 66% are attributable to a failure in a neutral screened service. Aluminium neutral screened cable is particularly problematic. It is not possible to distinguish between aluminium and copper neutral screened cables externally. The remainder of incidents are made up of other non-preferred services.
- The risk of electric shock associated with the inadvertent contact of the active service conductor with the supporting structures at the customer end. There have been a small number of incidents that have caused raiser brackets and building spouting to be made live due to damage to the insulation on the active conductor and contact with these structures.
- Due to the fire hazard associated with Private Overhead Electric Lines (POEL) in the HBRA, the Victorian Service and Installation Rules (VSIR) requires that where "a POEL has to be substantially re-constructed in a hazardous bushfire risk area the line is to be placed underground". Hence all POEL's in the HBRA will eventually be placed underground. As a further encouragement, customers within the HBRA and LBRA are offered the free installation of a pit at their boundary to facilitate the undergrounding of their POEL.
- A Safety Gram from Energex highlighted that some Low Voltage XLPE service cables installed during 2005 and 2006 (LV ABC) have experienced insulation failure on the top surface of the cable through UV degradation. The insulation failures have originated from batches of 25mm² Aerial XLPE service cable imported from an overseas factory. XLPE service cable from the same manufacturer was received during the same timeframe and installed on JEN. No similar premature failure of XLPE has been observed, monitoring of this continues.

4.8.4.4 Existing Controls

The existing controls that are intended to mitigate the risks associated with the operation of overhead service lines includes the following:

- All LV overhead services are visually inspected for mechanical integrity as part of the standard asset inspection program, every 3 years in the HBRA and every 5 years in the LBRA. Refer to the Asset Inspection Manual - JEN MA 0500. This is to ensure that the service line remains clear of surrounding supporting structures, that strain clamps are correctly attached and supported and the integrity of the insulation on the service cable is maintained;
- The neutral Integrity Testing program requires the testing of all service neutral impedances to detect failed or failing service neutrals. This program was completed in 2009 and is required to be repeated on a ten year cycle; and
- The roll out of the AMI program meant that neutral integrity was tested with the meter replacements that occurred. This has delayed the need to repeat the NST program; and

4.8.4.5 Future Risks and improvements

Improvements to the management of LV overhead services:

- Customer supply impedance measurement technology can be used to detect service joint degradation. This technology is planned to be introduced in the next EDPR period and is detailed in the Strategic Planning Paper "AMI Benefits Realisation – Supply Monitoring." The technology is deployed as an AMI meter software upgrade. The function constantly measures the supply loop resistance (active + neutral) and if the resistance rises above a nominal 1ohm an alarm is given. It is expected that once receiving the alarm sufficient time will be available to schedule repair before a joint failure occurs. This will reduce customer shock hazard and reduced time off supply. For details, refer to AMI Benefits Realisation Supply Monitoring Strategic Planning Paper.

4.8.5 LIFE CYCLE MANAGEMENT

The options available for asset lifecycle management reflect a trade-off between capital and operating expenditure. The aim is to achieve predictable and sustainable OPEX and CAPEX programs that manage the network risk and deliver improved safety outcomes that are associated with the replacement of unserviceable assets and the deployment of new technologies. The preferred asset lifecycle management option involves condition based replacement.

The strategy covers time based inspections followed by condition based maintenance and replacement, as well as in-service failure based reactive maintenance.

4.8.5.1 *Creation*

LV overhead services are created and installed in response to requests for new connections from network customers.

As of March 2014, all LV ABC service cables are purchased from Olex Cables, from either the Tottenham or South Korea factories.

4.8.5.2 *Asset Operation and Maintenance*

There are three (3) life cycle management strategies applied to the operation and maintenance of LV overhead services:

- Asset Inspection and condition monitoring;
- Preventative Maintenance; and
- Reactive and Corrective Maintenance.

4.8.5.2.1 *Asset Inspection*

All LV overhead services are visually inspected for mechanical integrity as part of the standard asset inspection program, every 3 years in the HBRA and every 5 years in the LBRA. Refer to JEN MA 0500 – Asset Inspection Manual for details. Visual inspections of overhead services are also conducted as part of vegetation management, height measurements and opportunistically during maintenance. The routine inspection and testing of services is mandated by the Electricity Safety (Bushfire Mitigation) Regulations 2013. Defective services identified during inspection and testing are replaced.

Asset Inspection activities include:

- Check service integrity from the pole end to the premise end (e.g. tree damage, UV degradation, broken/wrong fittings, conductor clearance to supporting brackets, etc);
- Low voltage overhead services shall be visually inspected from ground level during any fault investigation;
- Service Clearance Inspections as specified in the JEN Electricity Safety Management Scheme (ESMS) for low services; and
- Testing of the service with a Neutral & Supply Tester at the supply metering equipment.

4.8.5.2.1.1 *Neutral Supply Test (NST) Program*

The Electricity Safety (Management) Regulations 2009 prescribes that JEN will comply with its internal technical standards. JEN internal standards reflect the Electricity Safety (Network Assets) Regulations 1999 to which the JEN assets have been designed, constructed and maintained. JEN has conducted a Formal Safety Assessment as part of its Electricity Safety Management Scheme

(ESMS) submission to Energy Safe Victoria (ESV) which incorporated a risk assessment of the adequacy of JEN's current internal technical standards, in particular the NST program which requires that all overhead services have a neutral to earth resistance of less than 1Ω and that this must be verified at least once every 10 years. The ESV has reviewed and approved JEN's ESMS which includes the NST program.

The initial NST program was completed at the end of 2009. The program has been suspended for the duration of the advanced interval metering (AMI) roll out because the obligation for the 10 year period (2010 to 2019) will be met by the AMI program with respect to resistance testing of all service neutrals. The installation of AMI was concluded at the end of 2014 and as such all neutrals have been tested in a 5 year period instead of the requisite 10 years.

4.8.5.2.1.2 Metering Data Analytics

Since the beginning of 2017 Jemena has been implementing a "supply monitoring" project which involves the collection of time synchronised data (voltage, current and power factor) from every AMI meter at 5-minute intervals. In 2017 the software system for the acquisition of 5-minute data was commissioned and is in service. A hardware platform for running advanced data analytics has been installed and a number of data analytic algorithms are being developed as follows:

- Supply neutral integrity monitoring – provides round-the-clock monitoring of the integrity of the service line. High impedance connections on the service line/cable can indicate the presence of a health & safety hazard for individual customers or could indicate upstream problems with the potential to impact the wider area;
- Customer phase connection identification – is used to identify the phase connection of low voltage customers based on voltage correlation studies. Correct phase identification allows Jemena to develop an accurate LV network model which can be used to balance loads between phases, improve asset utilisation and improve quality of supply to its customers; and
- Proactive quality of supply monitoring – the time series voltage data collected can be used to assist with voltage complaint investigations and general improvements to supply quality.

In 2019 the data analytic algorithms are planned to be verified by site measurements followed by operational implementation.

Neutral Supply Test (NST) will continue on a 10 year cycle (from 2019) for customers who do not have AMI metering.

4.8.5.2.2 Proactive Maintenance

LV overhead services are replaced according to JEN PO 0501 – Overhead Service Replacement Procedural Standard.

Replacement of an LV overhead service will occur in the following circumstances:

- Proactive replacement in poor performing suburbs based on the number of shocks and service rectifications;
- Failure of or damage to a service line or service termination;
- When a maintenance notification has been created following inspection and testing as prescribed by the Electricity Safety (Installations) Regulations 2009;
- In conjunction with asset replacement or project work involving pole or pole top assembly replacement or conductor replacement, see JEN GU 0010 – JEN Planned and Opportunistic Maintenance and Workmanship Guidelines; and

- Where re-sagging of the service line does not achieve minimum regulated heights as prescribed by the Electricity Safety (Installations) Regulations 2009. See JEN PR 0027 – Overhead Service Height Procedural Standard.

Non-preferred low voltage overhead service cable types include:

- Red lead;
- Open wire for residential supply;
- Aluminium neutral screen;
- Rubber (neoprene) insulated copper neutral screen;
- Flat type (non-twisted) PVC insulated services with 10mm² aluminium conductor; and
- Grey twisted, PVC insulated 25mm² and 35mm² aluminium service cable

Note: Three-phase open wire commercial or industrial services are acceptable services and assessed for replacement based on condition.

4.8.5.2.3 Reactive and Corrective Maintenance

All defective LV overhead services shall be replaced. It is not acceptable for LV overhead service conductor (of any construction type) to have a straight joint connected mid-span.

4.8.5.3 Asset Replacement

Overhead services are replaced based on condition. Service lines are not repaired or maintained. All service defects result in the replacement of the service line.

Proactive replacement programs for LV overhead services lines involve the identification and replacement of all non-preferred services in a targeted area based on asset performance. All new LV overhead services lines are constructed using Aerial Bundle Cable (ABC), typically either 25mm² and 35mm².

4.8.5.3.1 LV Overhead Service Lines - Forecast Replacement Volumes

As indicated in this strategy, a number of projects have been identified to ensure that we maintain network performance, and also address our compliance requirements.

Table 4-65 lists the forecast replacement volumes for LV overhead services from 2020 to 2026.

Table 4-65: LV Overhead Service Line - Forecast Replacement Volumes

Service Code	LV Overhead Services	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RMF	Service Fault Replacement	651	604	604	606	607	606
RMJ	Replace Service and Alter Terminations	86	82	82	82	83	82
RML	Install Disconnect Device	53	49	49	50	50	50
RMP	Replace Services - Planned	324	322	322	324	326	324
RMP	Service Rectification Program (Non-Preferred Service)	3,651	4,310	4,310	4,310	4,310	4,310
RMU	OH to UG Serv Replaced with UG	18	17	17	17	17	17

4.8.5.4 Asset Disposal

LV overhead services are typically not repaired but instead are replaced as required.

LV overhead services should be disposed of in accordance with JEM PO 1600 – Scrap Materials Policy.

4.8.5.5 Spares

As part of criticality assessment consideration is given to appropriate levels of spare equipment. Spares requirements for critical assets are assessed by following Critical Spares Assessment Procedure (JEM AM PR 0015). Adequate spares are maintained at Tullamarine depot and stock holdings are managed by the Service and Projects team.

LV overhead services parts and components are stocked in the stores and replenished as required.

4.8.6 INFORMATION

Jemena's AMS provides a hierarchical approach to understanding the information required to achieve Jemena's business objectives at the Asset Class level. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and the Asset Class Strategy (ACS) all provide the context for and determine the information required to manage and operate an Asset Class.

The Information required to support asset strategies, performance and risks is recorded in SAP, the Geographic Information System (GIS) and ECMS. Additional fault related data is available in the Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

The Electricity Distribution Asset Class Strategy facilitates the safe, efficient and reliable delivery of electricity to JEN's customers.

From these business objectives, it is possible to identify at a high-level the content of the business information systems' required to support these objectives (Table 4-66).

Table 4-66: LV Overhead Services Sub-Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Sources	Information	Externally Sourced Data
Operational Excellence <ul style="list-style-type: none">• Manage assets throughout their lifecycle in safe and environmentally responsible manner• Maintain assets in accordance with RCM principals• Maintain asset information/knowledge to enable efficient and effective decision making• Embed continuous improvement throughout asset lifecycle Customer <ul style="list-style-type: none">• Maintain our current service levels• Incorporate customer feedback in our decision making process Growth <ul style="list-style-type: none">• Acquire/install/maintain assets to meet future demand requirements People	GIS/JEN Viewer <ul style="list-style-type: none">• Geospatial representation of the JEN Network• Asset attributes SAP <ul style="list-style-type: none">• Work schedule & status• Planned and corrective (faults) maintenance records• Asset inspection measurements• Financial information ECMS <ul style="list-style-type: none">• Asset Inspection Manual, inspection methods & criteria• Policies, procedures and guidelines	<ul style="list-style-type: none">• Current cadastre (including land ownership) for JEN's geographical extent.• DELWP - HBRA and LBRA area boundaries• CFA for fires, warnings and restrictions, incidents• Emergency Management Common Operating Picture (EM-COP)• Aerial Imagery for JEN's geographical extent (NearMap)• Google 'Street View'• Melway• SAI global (Australian and International Standards)• ESV / ESC / AER for regulatory obligations	

Business Objectives	Jemena Sources	Information	Externally Sourced Data
<ul style="list-style-type: none"> • Maintain safe work environment • Engage team leaders in assessment of new assets • Training 	<ul style="list-style-type: none"> • General asset audits/surveys not stored in SAP • Incident investigations <p>Drawbridge</p> <ul style="list-style-type: none"> • Standards • Operations diagrams • Line design manual • Construction manual <p>SCADA/RTS</p> <ul style="list-style-type: none"> • Outage Management System (OMS) & SCADA (DMS) • Planned and Unplanned outages <p>JEN Analytics</p> <ul style="list-style-type: none"> • Power quality data • Energy consumption 		

Table 4-67 identifies the current and future information requirements to support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-67: LV Overhead Services Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
LV overhead service acquisition and application	<ul style="list-style-type: none"> • Purchase specification (ECMS) • Distribution Design Manual (ECMS) • Distribution Construction Manual (ECMS) • Period contracts (ECMS) • Logistics system (SAP) 		<ul style="list-style-type: none"> • High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.
Life cycle management: <ul style="list-style-type: none"> • Asset identification • Condition monitoring • Condition assessment • Replacement / retirement strategy • Disposal 	<ul style="list-style-type: none"> • Each asset identified by geospatial representation in GIS and equipment ID in SAP • Asset Inspection Manual (ECMS) • Maintenance plan (SAP) • JEN Analytics (e.g. deteriorated neutral) • Measurement record (SAP / ECMS) • PM Notifications/Orders (SAP) • Strategy detailed in this document • GIS asset attributes: <ul style="list-style-type: none"> - Asset status (e.g. existing/historical) 	<ul style="list-style-type: none"> • Breakaway device and date installed • Phase Colour • Near real time updating of asset record • Photos database of all failed assets • Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> • High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
	<ul style="list-style-type: none"> - Status (in service, isolated, out of commission) - Usage - Phase Conductor Material - Phase Cross Sectional Area - Neutral Cross Section Area - Construction Type - Termination Type - No of Wires - Computed Length - Date Constructed - Date Removed - Circuit - Inspection Zone • Fault / failure records: <ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 		

Table 4-68 provides the information initiatives required to provide the future information requirements identified in Table 4-67. Included within this table is the risk to the Asset Class from not completing the initiative.

Table 4-68: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information capture	Ability to capture all relevant asset attributes from the field through mobility solution.	High	Complete, Current, Accurate attribution
Improve/review MAT Code definitions	Ability to align to AER service classification structure.	High	Precise definition
Improved Asset Attributes	Review current asset attribution fields to ensure attributes being collected are asset specific.	Medium	Appropriate and Accurate attribution
Increased Timeliness	Decrease latency between fault/maintenance delivery and fault/maintenance record capture.	High	Complete, Current, Accurate attribution
Improved fault information capture	Ability to capture all relevant asset failure information from the field through mobility solution and photos.	High	Complete, Current, Accurate fault information

4.9 PUBLIC LIGHTING SUB-ASSET CLASS

4.9.1 INTRODUCTION

Public lighting has long been recognised as contributing to public safety and as a road accident counter-measure by enhancing the visibility of pedestrians, vehicles, objects and hazards. To achieve this, lighting has to enable a relatively crude visual task, without the need to distinguish fine detail and colours, but by merely providing contrast.

The major road lighting system mainly caters for the motorist, whilst the minor road or residential street lighting system principally caters for pedestrians. As pedestrians move slower than vehicles, they have more time to adapt to changes in brightness, therefore requiring lower lighting levels and lower uniformity of lighting than that required by motorists.

JEN owns, operates and maintains over 70,000 public lighting luminaires across the JEN territory. JEN manages all public lighting infrastructure on behalf of public lighting customers. The two major customer groups are Municipal Councils and the state's Road Authority. The AER has issued an industry guideline which describes the relationship between major electricity distributors (e.g. JEN) and all public lighting customers. JEN's technical standard, i.e. the Public Lighting Technical Standard - JEN PR 0026, describes the commonly used and Jemena approved assets such as luminaires and poles. It also provides guidance for public lighting customers who wish to utilise approved non-standard public lighting poles and lanterns fitted with standard lamps and Photo Electric (PE) cells, on the public lighting system. All poles and lanterns are owned and maintained by Jemena for a fee set by the AER. Public lighting customer are required to hold approved non-standard spares, in lieu of the additional administrative effort required by Jemena to procure these assets. Public lighting customers may elect to own and maintain public light infrastructure by installing metered electricity supplies for their schemes, e.g. parks, barbeque areas, freeways and major roads.

4.9.2 ASSET PROFILE

4.9.2.1 *Life Expectancy*

As described in ELE PR 0012 – Network Asset Useful Lives Procedure, the applicable useful life for major and non-major public lighting lanterns and public lighting support structures is as follows:

- Public Lighting Lanterns - Major Rd 20 years*;
- Public Lighting Lanterns - Non-major Rd 20 years*;
- Wooden Pole LV/Street lighting – 54 years;
- Steel Pole LV/Street lighting – 35 years;
- Concrete Pole LV/Street lighting – 70 years;
- LV OH public lighting services – 40 years; and
- LV UG public lighting services – 50 years.

*For new lantern types such as the T5 and LED type, an asset life of 20 years is applicable. For conventional street lighting lanterns such as those using MV80 lamps, the asset life is 30 years.

The Network Asset Useful Lives Procedure prescribes asset lives based on good industry practice and specific Jemena Electricity Network experience and represents the lives of assets at which end-of-life replacement will be considered. JEN has referenced a number of reviews of asset useful lives

by consulting agencies and discussions with other Electricity Distribution Businesses to inform this process.

4.9.2.2 Age Profile

The population of public lights can be characterised as follows:

- Public Lighting Lanterns - Major Rd; and
- Public Lighting Lanterns - Minor Rd;




Figure 4-66 Public Lighting Luminaire - Age Profile

Table 4-69 Analysis - Public Lighting Luminaire - Age Profile

Test	Analysis/Comments
The installation of minor road luminaires has increased in the last 10 years	This is consistent with the installation of new residential estates and the widespread replacement of old technologies with new high efficiency luminaires and lamps.

4.9.2.3 Utilisation

The public lighting sub-asset class functions to meet Jemena's obligations in relation to the provision of public lighting services on major and minor roads and in public open spaces in accordance with the requirements of the Essential Services Commissions Public Lighting Code. Each public lighting luminaire operates for approximately 4,400 hours per year to provide a safe visual environment for pedestrian and vehicular movement during times of inadequate natural light.

All public lighting asset information is recorded and maintained in the GIS system. Jemena charges an agreed reasonable fee set by AER to own and maintain these assets on behalf of its public lighting customers.

4.9.3 PERFORMANCE

Jemena's Public Lighting Technical Standard - JEN PR 0026, contains the current standards in regards to public lighting within the Jemena Electricity Network. This document outlines the approved standard and non-standard fittings available for use by customers within the Jemena Electricity Network.

4.9.3.1 Requirements

The requirements for the performance of public lighting assets relate to:

- Dedicated public lighting poles; and
- Public lighting lanterns and lamps

4.9.3.1.1 Dedicated Public Lighting Poles

The requirements for the performance of these poles includes;

- The maintenance of structural integrity under all normal operating conditions and loads;
- The security and safety of the poles and the prevention of access to live parts installed in or on the poles (particularly in relation to the security of access covers); and
- The correct operation of frangible and slip based poles (dependent upon the correct installation procedures) in the event of vehicle impact.

The requirements for all new Public Lighting Poles are set out in the following Jemena material specifications:

- Steel Public Lighting Pole Specification;
- Concrete Pole Specification; and
- Wood Poles and Logs Specification.

The requirements for the installation of these poles are set out in the Distribution Construction Manual – JEN MA 0006 and the Public Lighting Technical Standard – JEN PR 0026.

4.9.3.1.2 Major and Minor Road Lanterns

The requirements for public lighting luminaires are set out in following Jemena material specifications:

- Public Lighting - Luminaires, Technical Specification;
- Public Lighting – Photo Electric Control Switches and Bases, Technical Specification; and
- Public Lighting – Electric Discharge Lamps, Technical Specification.

The requirements for the installation of these assets is set out in the Distribution Construction Manual – JEN MA 0006 and the Public Lighting Technical Standard – JEN PR 0026

The requirements for these lanterns is the maintenance of the public lighting of major roads, minor roads, intersections and public open spaces in accordance with the public lighting standards and associated lighting levels. The lanterns are required to operate reliably on a daily basis with light outputs that remain in the allowable design range over the maintenance interval.

Regular main road streetlight patrols are undertaken to identify and pro-actively repair faulty main road lighting equipment thus ensuring defective lights do not remain on the system for prolonged periods of time.

Minor road lighting relies on the reporting of failed luminaires to drive repair and maintenance. Guaranteed Service Levels (GSL) dictate a response time of less than two days to repair a fault, unless otherwise agreed to between the authorised body and the member of public who reported the fault if they are an immediately neighbouring resident (Public Lighting Code clause 2.5).

Bulk relamping programs are used where appropriate to maintain the light output of public lighting luminaires at the required design levels.

These specifications and manuals set out the performance standards to be met and the design features required of public lighting assets. The specifications reference a number of Australian Standards. Unless otherwise specified, all public lighting assets shall be designed, manufactured and tested in accordance with the following principal Australian Standards (refer to Table 4-70).

Table 4-70 Public Lighting - Relevant Australian Standards

	Title
AS 2878	Timber Classification into Strength Groups
AS 3818.1	Timber-Heavy Structural Products-Visually Graded, Part 1 General
AS 3818.11	Timber-Heavy Structural Products-Visually Graded, Part 11 Utility Poles
AS 5604	Timber – Natural Durability Ratings
AS/NZS 4065	Concrete Utility Service Poles
AS/NZS 4676	Structural Design Requirements for Utility Service Poles
AS 4680	Hot Dipped Galvanised Coatings on Ferrous Articles;
AS/NZ 1163	Cold-formed Structural Steel Hollow Sections.
AS/NZS 1158 (series)	Lighting for Roads and Public Spaces
AS/NZS 60598.1	Luminaires – Part 1 – General Requirements and Tests
JIS C 8369	Photoelectric controls for public lighting
SA/SNZ TS 1158.6	Lighting for Roads and Public Spaces
SA/SNZ TS 1158.6	Part 6: Luminaires - Performance

4.9.3.2 Assessment

The performance of public lighting poles is assessed via the pole and line inspection program. Routine inspection of public lighting poles is consistent with inspections carried out on power poles. The prime purpose of pole inspection is to identify defects that could potentially lead to health and safety incidents affecting the general public and JEN personnel if left unchecked. JEN has had a number of incidents of damaged and or missing pole access cover plates resulting in the potential for unauthorised access to live wires.

The correct installation of frangible poles is essential to ensure the pole behaves as it is intended in a car collision. This is another example where routine inspections will ensure any incorrectly installed poles are identified and rectified.

The performance of electricity distribution power poles which also support public lights is detailed within the Poles sub-asset Class Strategy. It documents the frequency of breakdowns and in service pole failures. It applies to poles whether they have public lighting assets attached or otherwise.

4.9.3.2.1 Metrology Auditing

On an annual basis, JEN is required by AEMO to undertake metrology audits of its public lighting data. This audit ensures that the energy consumption charged to public lighting customers from the data held in our GIS system matches the actual field inventory. The number and size of audits is dependent on previous audit results. For more information refer to the AEMO Metrology Procedure.

4.9.3.2.2 Public Lighting Performance Reporting

The monitoring and optimisation of the performance of public lights is achieved via the preparation of the following reports:

- Quarterly Public Lighting Performance Report; and
- Annual Public Lighting Performance Report

The data included in Table 4-71 is extracted from the annual public lighting performance reports.

Table 4-71: Performance of Public Lighting from 2012 to 2018

Measure	2012	2013	2014	2015	2016	2017	2018
Total lights reported out (GSL Applicable)	762	952	1320	1159	1620	2293	2432
Total Lights reported out (Not GSL Applicable)	2693	2102	2396	3803	4235	3566	2978
Total Lights reported out – All Lights	3455	3035	3716	4962	5855	5859	5410
Total GSL applicable not repaired within 2 working days	9	2	20	3	1	10	8
Total Not GSL applicable not repaired within 7 working days	3	2	139	17	22	16	21
Monthly average number of days to repair – All faults	3.30	3.30	3.40	2.4	2.9	2.9	3

4.9.3.2.3 Major Road Lantern Patrols

Major road lantern patrols occur three times per year as per Public Lighting Code clause 2.3.1(f).

The results of the patrols can be seen in Table 4-72 .

Table 4-72: Number of Defective Lanterns Identified During Patrol

Measure	2012	2013	2014	2015	2016	2017	2018
Number found out	1355	1155	907	690	1108	1093	927
Number fixed	1305	1136	844	948	1027	1025	740




Figure 4-67: Luminaires Volume Maintained by Year




Figure 4-68 Luminaires Volume Replaced by Year

4.9.4 RISK

4.9.4.1 Criticality

An asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A.

The public lighting sub-asset class has an asset criticality score of AC1 (Low) due to the low cost of replacement of public lighting luminaires and lamps.

Public lighting contributes to pedestrian and vehicular safety within the JEN area through the maintenance of lighting levels on both major and minor roads and in public open space. Public lighting assets are installed in accordance with the requirements of the Jemena's Overhead Line Design Manual and the Distribution Construction Manual. Street lighting spacing tables derived from Australian Standard AS1158 are used to determine the maximum spacing between lanterns. This is dependent upon the type of lantern, the height of the pole and width of the road.

For minor road lighting installations an average spacing of 70 metres is required to provide sufficient lighting levels. Therefore in the event of a single minor road lantern failure, vehicular traffic and pedestrians would transition through a non-uniform lit section of road or path for approximately 140 metres. Consequently the failure of an individual lantern can be considered as having a low health and safety impact and therefore low criticality. As a whole the public lighting system performs well and is considered very reliable at a system level.

4.9.4.2 Failure Modes

Failure modes for this sub-asset class include:

- The light output levels of mercury vapour lamps reduce with time and eventually fall below levels prescribed by standards;
- PE cell failure occurs resulting in either the lamp not turning on or the lamp not turning off;
- Control gear failure resulting in no light output;
- Lantern failure involving a component failure such as a lens, mounting bracket or fixing point breakage or corrosion of the lantern housing;
- Pole failure at the ground line due to corrosion or vehicle impact or severe leaning due to foundation deterioration; and

- Lantern fires due to fusion of internal components.

There have been a number of incidents of lantern fires that occurred between 2011 to 2012. These failures have been attributed to the lighting control gear in the lantern overheating due to repeated attempts to re-strike an arc in the high pressure sodium lamp. This is associated with the end of life failure mode for high pressure sodium lamps (HPS). As the lamps age the operating pressure in the arc tube increases and this results in cycling where the lamp turns off due to the high arc tube pressure. The lamp then cools down and the arc tube pressure drops allowing the lamp to re-strike. The lamp continues to cycle in this way.

The manufacturer of these lanterns, Sylvania is aware of the issue and Jemena now specify a new requirement of power factor correction metal can type capacitors together with timed igniters that are restricted in the number of times they will attempt to re-strike an arc in the lamps to prevent any future failures of this type.

4.9.4.3 *Current Risks*

Risks associated with the management of public lighting are documented in JCARS and reviewed regularly.

Some of these risks include:

- Live unearthed street lighting brackets on timber poles caused by control gear failure of insulation failure;
- Steel pole ground line failure due to corrosion;
- Missing access cover plates on public lighting poles exposing live apparatus
- The existence of redundant bare switch wire results in a safety and bushfire risk as conductors and insulators are not maintained and the conductor continues to age; and
- Redundant switchwire can be mistaken for a neutral conductor resulting in reverse polarity hazards.

4.9.4.4 *Existing Controls*

The controls in place to manage the risks associated with the management of the public lighting system include:

- A planned switchwire removal program initiated in 2011. This is ongoing;
- The Major Road public lighting patrol program;
- The GSL requirements for the repair of minor road lighting;
- The bulk MV relamping program;
- The Linesman Handbook and refresher training for testing and handling unearthed streetlight brackets; and
- The pole and line asset inspection program (AIM)

4.9.4.5 *Future Risks and Opportunities*

There are approximately 29,000 lights installed on the minor road network, of which the majority are 80W Mercury Vapour (MV) type. Public lighting customers, through the actions of organisations such as the City for Climate Protection Organisation are increasingly seeking alternative, more efficient lighting to replace the existing MV lights on the minor road network. Jemena has approved the use of a number of high efficiency luminaires and lamps on its public lighting system including the following:

- T5 - 2 x 14W;
- T5 - 2 x 24W;

- 32W CFL (compact fluorescent lamp);
- 42W CFL; and
- 18/22W LED.

During the next regulatory period LED technology is expected to supersede all existing technologies with improved efficiency, quality of lighting and lifespan. Technology involving fault detection is also being developed within PE cells which transmit data about the luminaire back to a central location.

Currently there is a change proposed by Standards Australia to revise AS/NZS 1158.6:2010 to separate the safety requirements and product performance requirements for road lighting luminaires into two documents, AS/NZS IEC 60598.2.3 and SA/SNZ TS 1158.6.

The adoption of IEC 60598.2.3 is proposed without amendment and will contain minimum safety requirements. The SA/SNZ TS 1158.6 document will include requirements for solid state lighting (SSL). When the documents are finalised, there may be implications for public lighting luminaire specifications which will need to be considered.

4.9.5 LIFE CYCLE MANAGEMENT

The strategy applied to the life cycle management of this sub-asset class includes time based inspections followed by condition based maintenance and replacement, as well as in-service failure based reactive maintenance (some degree of a run to failure strategy).

4.9.5.1 *Creation*

The Jemena Public Lighting Technical Standard – JEN PR 0026 specifies the standard public lighting luminaires, lamps and poles that are approved for use on the JEN public lighting system.

In accordance with the Public Lighting code, a public lighting customer is required to provide a design brief that is consistent with the Jemena Public Lighting Technical Standard for Jemena to construct new public lighting assets on their behalf. Jemena is responsible for the necessary design work and documentation required to translate the design brief to the construction stage. Alternatively a public lighting customer can choose a party other than Jemena to prepare design documentation but they must liaise with Jemena to ensure the relevant standards are met.

Open tenders are issued to which suppliers must provide solutions aligned to the requirements of JEN PR 0026. All items are typically purchased under period contracts in accordance with the requirements of the specification.

4.9.5.2 *Asset Operation and Maintenance*

There are three (3) life cycle management strategies applied to the operation and maintenance of the public lighting system:

- Asset Inspection;
- Preventative Maintenance – This takes the form of periodic bulk re-lamping based on council areas. This is only applied to minor road lamps and is a requirement of the Public Lighting Code clause 2.3.1(c). This is consistent with the characteristic loss of light output associated with the ageing of MV lamps; and
- Corrective Maintenance - Lamps that fail outside of the periodic bulk re-lamping scheme are replaced as they fail on an ad-hoc basis. Guaranteed Service Levels drive the response time to repairs. Major road luminaires are also patrolled at least 3 times yearly in accordance with the Public Lighting Code clause 2.3.1(f) and are repaired or replaced as they are identified.

4.9.5.2.1 Asset Inspection

The inspection of public lighting assets includes the following:

4.9.5.2.1.1 Pole and lantern inspection

This occurs in accordance with the requirements of Section 6 of the Asset Inspection Manual - JEN MA 0500. This details the requirements for the inspection of steel public lighting poles, concrete poles and frangible poles. All poles are inspected to the same criteria as power poles and incorporated into the normal power pole inspection cycle, 3-yearly in HBRA and 5-yearly in LBRA.

4.9.5.2.1.2 Major Road Lantern Patrols

Routine patrols of major road lanterns are programmed to occur three times per year across the Jemena Electricity Network. The patrols are intended to identify defective lamps or sections of lights, lanterns, poles, brackets and access cover plates, which may otherwise remain defective for prolonged periods. If damaged or missing access cover plates are found during a major road patrol, replacement access cover plates secured with “band it” straps are to be installed immediately.

4.9.5.2.1.3 Low Voltage (LV) Supply

The LV supply to most lanterns on the overhead system has been upgraded to 6mm² Cu cables as part of the 80W MV replacement projects and no inspection of this is required. However, if there are any lanterns identified that have their LV supply via 2.5mm² Cu cables these should be noted for replacement as part of other works or maintenance projects.

There are no known issues with LV supply from underground LV distribution systems and no specific inspection or testing is required.

4.9.5.2.1.4 Asbestos and PCBs in Public Lighting Equipment

The control gear (remote ballast boxes) associated with older major road MV lanterns can contain asbestos and PCB's. The replacement of major road MV lanterns will result in the removal of any asbestos and PCB's associated with this equipment. These are to be disposed of in accordance with JAM PR 0060 WI 04 - Disposal of Public Lighting Equipment.

4.9.5.2.1.5 Metrology Audits

Auditing to check the accuracy of the public lighting metrology is carried out in accordance with the AEMO Metrology Procedure – Part A. This random auditing of street lights is carried out to confirm the accuracy of the Jemena asset record in relation to the physical inventory of public lighting assets and the billing systems. These audits are based on the inventory for each National Meter Identifier (NMI) in a randomly selected geographic area.

Any defective items identified during inspections are captured in maintenance notifications raised in SAP and are programmed for repair in a timeframe commensurate with the priority assigned to the defect.

4.9.5.2.2 Preventative Maintenance

Preventative maintenance is applied to the public lighting sub-asset class in the form of the bulk replacement of some types of lamps and their associated PE cells. This is a requirement of the Public Lighting Code and it is designed to maintain the light output of minor road lighting systems at code levels.

The preventive maintenance regime involves a bulk re-lamping cycle of 4 years and is applied to minor road lamps only (e.g. MV, T5 fluorescent, compact fluorescent and a small quantity of HPS). Bulk Photoelectric (PE) switch changes are programmed to coincide with the bulk lamp changes to minimise costs. PE switches are to be changed every second bulk lamp cycle (8-yearly).

The program for minor road bulk re-lamping over a 4 yearly cycle is shown in Table 4-73 below.

Bulk re-lamping programs shall be conducted in the first half of each calendar year to ensure optimum level of lighting for the period of maximum darkness.

4.9.5.2.2.1 Optimum Preventative Maintenance Interval

The majority of public light lamps within JEN fall into two broad categories namely 80W Mercury Vapour (MV) lamps and T5 energy efficient lamps for minor road lighting and 150/250W High Pressure Sodium (HPS) lamps for major road lighting. The ageing characteristics of these two lamp types is very different. MV and Fluorescent type lamps suffer a reduction in light output as they age that means they require replacement to maintain the performance of the lighting system at desired levels. HPS lamps on the other hand maintain their light output over the life of the lamp. For these reasons MV lamps are suited to a preventative bulk replacement program to maintain performance whereas HPS lamps are suited to a run to failure management strategy.

The selection of the optimum re-lamping cycle is based upon the maintenance of minimum lighting standards in accordance with AS1158. AS1158 stipulates that for a complying lighting system to remain compliant the light output of lamps should not fall below 70% of initial levels. Test data indicates that the lumen output of 80W MV lamps falls below 70% after 3 to 4 years and HPS (twin arc tube) lamps past 7 years. The average life of twin arc tube HPS lamps based on manufacturer's data is 7 years.

For these reasons the bulk re-lamping of major road lamps is not a requirement of the Public Lighting Code due to the superior lumen maintenance of twin arc HPS lamps. These lamps are likely to fail before their lumen output falls below 70%.

Based on the above data a 4 year re-lamping cycle for minor road lamps will ensure the maintenance of lighting levels in accordance with AS1158. Bulk PE cell changes are to coincide with bulk lamp changes to minimise costs. PE cells are changed every second bulk lamp change. HPS lamps are run to failure.

Approval has been given for the use of the T5 - 2 x 14W, T5 - 2 x 24 W, 32W CFL, 42W CFL and 18/22W LED energy efficient lights on minor roads to replace the 80W MV luminaires. These lights are subject to the same preventive maintenance regime as 80W MV lights.

4.9.5.2.3 Corrective Maintenance Regime

Corrective maintenance of the public lighting system is driven by:

- The Guaranteed Service Levels defined under the Public Lighting Code. In accordance with these Jemena is required to respond to and repair reports of faulty public lights in the nominated time frames; and
- Main Road Lighting Patrols (at least 3 times a year) are conducted to identify and drive the corrective maintenance and repair of faulty main road lighting equipment. This ensures that defective lights do not remain on the system for prolonged periods of time as per Public Lighting Code clause 2.3.1(f).

Table 4-73 Residential Bulk Re-Lamping Sectors

Year	Municipalities	Energy Efficient Lamps Replaced	Non-Energy Efficient & Decorative Lamps Replaced	T5 Lamps Replaced
2018	Moonee Valley (south of Tullamarine Fwy), Brimbank	Lamp	Lamp	Lamp

Year	Municipalities	Energy Efficient Lamps Replaced	Non-Energy Efficient & Decorative Lamps Replaced	T5 Lamps Replaced
2019	Maribyrnong, Melton, Moonee Valley (north of Tullamarine Fwy), Banyule	Lamp		Lamp
2019	Whittlesea, Macedon Ranges	Lamp + PE cell	Lamp + PE cell	
2019	Maribyrnong, Melton, Moonee Valley (north of Tullamarine Fwy)		Lamp + PE cell	
2020	Hobson's Bay (CFL), Hume.	Lamp	Lamp + PE cell	
2020	Yarra	Lamp + PE cell	Lamp + PE cell	Lamp + PE cell
2020	Melbourne, Moreland		Lamp + PE cell	
2021				
2022	Moonee Valley (South of Tulla Fwy), Brimbank	Lamp + PE cell	Lamp + PE cell	Lamp + PE cell
2023	Maribyrnong, Melton, Moonee Valley (North of Tulla Fwy), Banyule	Lamp + PE cell	Lamp	Lamp + PE cell
2023	Whittlesea, Macedon Ranges	Lamp	Lamp	
2024	Melbourne, Darebin, Moreland	PE Cell only (LED lights)	Lamp	
2024	Hobsons Bay (CFL)	Lamp + PE cell		
2024	Hobson's Bay, Hume	Lamp + PE cell	Lamp	Lamp + PE cell
2024	Yarra	Lamp	Lamp	Lamp

This list will evolve over the next few years to include the preventative maintenance of the energy efficient lighting schemes that public lighting customers can choose to adopt. The program involves the bulk replacement of Mercury Vapour lanterns with energy efficient T5 lanterns which will affect the lamp replacement cycles above.

4.9.5.3 Asset Replacement

The proposed asset replacement strategies including forecast replacement volumes and maintenance strategies are derived after consideration of the public lighting asset age profile (life expectancy/age), historical failure trends, risk profile (failure modes) and asset performance objectives.

Public Lighting asset replacement is being driven by changes in technology and the availability of new energy efficient lighting technologies. The current standard equipment suite used on the JEN has been adopted to take advantage of new technologies offering;

- Long lamp life;
- Low lamp cost;

- High light output stability; and
- High efficiency lamps.

4.9.5.3.1 Obsolete Lantern Replacements

A number of obsolete lanterns remain in service on the JEN public lighting system. In the minor road lighting category they are predominantly 50W MV lanterns. In addition there are a range of obsolete major road lighting luminaires as indicated in Table 4-75 below. These are being replaced opportunistically when they are identified with the current standard equivalent lantern as part of the bulk re-lamping and maintenance programs.

4.9.5.3.2 Minor Roads Mercury Vapour Luminaires

Jemena is planning for the phase out (via targeted bulk replacement) of the existing population of 80W Mercury Vapour (MV80) luminaires and their replacement with an equivalent LED luminaire over the next regulatory period.

The primary driver for the replacement of these assets being the likelihood of Australia signing onto the resolution developed at the Minamata Convention that would ban the import and manufacture of high pressure mercury vapour luminaires from 1 January 2021. Hence it is incumbent on Jemena to consider alternatives to mercury vapour technology in the event that the resolution is signed.

4.9.5.3.3 Replaced Asset Standards

The assets listed below are the current standards for public lighting. Also listed are the obsolete assets with their corresponding equivalent replacements.

It is common practice to change both the PE cell and lamp when only one may be defective.

4.9.5.3.3.1 Standard Lanterns

The current standard lanterns within Jemena Electricity Network are shown in Table 4-74 below. Each lantern is complete with integral PE switch.

Table 4-74: Standard Lanterns for JEN

Residential (Minor) Roads	Major Roads
80W & 125W Mercury Vapour (maintenance only)	70W, 155W and 275W L1 LED
70W & 100W High Pressure Sodium	150W, 250W & 400W Metal Halide
70W & 100W Metal Halide	118W/130W Light Emitting Diode
2 x 14W & 2 x 24W T5 Fluorescent	
32W & 42W CFL	
18W/22W Light Emitting Diode	

4.9.5.3.3.2 Obsolete Lanterns

Table 4-75 lists the obsolete major road lanterns on the JEN public lighting system, together with the equivalent current standard replacement.

Table 4-75: Obsolete Major Road Lanterns and their Standard Replacement

Lantern	To be replaced with
250W MV and 150W HPS	L1 70W LED Cat V
400W MV and 250W HPS	L2 155W LED Cat V
400W HPS	L4 275W LED Cat V

The relatively small quantity of obsolete minor road lanterns remaining on the system will be replaced as they are encountered during bulk re-lamping of any given area as indicated in Table 4-76.

Table 4-76: Obsolete Minor Road Lanterns and their Standard Replacement

Lantern	To be replaced with
2 x 20W Fluorescent	18/22 W LED Cat P
3 x 20W Fluorescent	18/22 W LED Cat P
50W Mercury Vapour	18/22 W LED Cat P
150W Incandescent	18/22 W LED Cat P
700W Incandescent	18/22 W LED Cat P

It is preferable that the lantern is replaced with one that is similar to the adjoining lanterns to ensure uniformity of lighting output.

4.9.5.3.3 Standard Poles

The current standard range of public lighting poles used by JEN are shown in Table 4-77 below. Refer to JEN PR 0026 – Public Lighting Technical Standard for further detail.

Table 4-77: Standard Poles for Major and Minor Roads

Major Road	Non-major Road
Concrete (spigot top), 10 metre/1.5kN, Ground setting (10 metre luminaire mounting height)	URD steel 7 metre/1kN, Ground setting (5.5 metre luminaire mounting height)
Concrete (spigot top), 13 metre/3 KN, Ground setting (12.5 metre luminaire mounting height)	URD steel 9 metre/1kN, Ground setting (7.5 metre luminaire mounting height)
Concrete (spigot top), 15 metre/3 KN, Ground setting (12.5 metre luminaire mounting height)	URD steel 10.8 metre/1kN, Ground setting (9 metre luminaire mounting height)
Centre hinged, 12.5 metre, plate setting	
Centre hinged, 15 metre, plate setting	

Jemena is responsible for the construction and maintenance of standard public lighting poles as outlined in the Public Lighting Code and JEN PR 0026 – Public Lighting Technical Standard.

4.9.5.3.4 Non-Standard Poles

Public lighting customers may choose to use approved non-standard public lighting equipment in a VESI public lighting scheme. This includes poles, streetlighting brackets and luminaires. The public lighting customer is responsible for the supply of replacement parts for all approved non-standard equipment and any associated costs. This includes the supply of the non-standard equipment (pole and luminaire) both for the initial installation and for all subsequent maintenance requirements. For further details refer to Public Lighting Code clause 3.3 and JEN PR 0026 – Public Lighting Technical Standard Clause 8.0.

4.9.5.3.4 Public Lighting - Forecast Replacement Volumes

The proposed replacement volumes and the associated capital forecasts for the 2020 to 2025 period is relatively stable. A step change in the replacement strategy for obsolete luminaires on major roads is forecast for the next regulatory period. This is due to the change in strategy from current like-for-like replacement to the proposed LED replacement program to align with customer expectation and new technology. In addition, a CAPEX allocation is proposed for the proactive replacement of all minor road high pressure mercury vapour luminaires (MV80) in JEN.

Table 4-78 lists the forecast replacement volumes for public lighting from 2020 to 2025.

Table 4-78 Public Lighting Forecast Replacement Volumes

Service Code	Public Lighting	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RLG	Sustainable Public Lighting Replacement	1,059	1,376	1,391	1,408	1,425	1,084
RLJ	Public lighting Replacement - Major Rd	402	496	494	492	490	384
RLM	Public lighting Replacement - Minor Rd	134	229	228	227	227	135
RLN	Single Lantern and Bracket Replacement - Major Rd	7	7	7	8	8	8
RLO	Single Lantern and Bracket Replacement - Minor Rd	66	114	114	115	116	73
RPA	Public lighting Pole Replacement - Major Roads	107	112	117	122	128	133
RPB	Public lighting Pole Replacement - Minor Roads	153	159	166	173	181	189

4.9.5.4 Asset Retirement and Disposal

Due to the hazardous nature of some of the materials used in public lighting equipment particular attention is paid to their disposal. When replaced, obsolete public lighting assets will be disposed of in accordance with JAM PR 0060 WI 04 - Disposal of Public Lighting Equipment.

4.9.5.4.1 Overhead Public Lighting Switch Wire

A dedicated overhead switched active wire was historically used for the on-off control of the public lighting system. The “switch wire” is now obsolete as on-off control is now provided by PE cells integrated into modern luminaires. A significant amount of this “switch wire” remains installed on the JEN overhead network and there have been a number of incidents where it has been incorrectly identified. Its continued presence on the network constitutes a safety hazard.

Obsolete switch wire is to be removed on both an opportunistic basis during major maintenance works and via a planned program of removal. A program to remove switch wire was commenced by JEN in the previous regulatory period. The objective of this program is to remove the remaining public lighting switch wire to reduce operating inefficiencies and eliminate the risk associated with the incorrect identification of this conductor and the ongoing degradation of unmaintained assets.

4.9.5.5 Spares

As part of the criticality assessment consideration is given to appropriate holdings of spare equipment. Spares requirements for critical assets are assessed by following Critical Spares Assessment Procedure (JEM AM PR 0015). It has been determined that adequate spares are maintained at the Tullamarine depot and stock holdings are managed by the Services and Projects team.

Standard public lighting equipment is kept in JEN stores with the quantities replenished as required. Stock is then acquired by the contractor from the stores when required.

Non-standard approved items are supplied by the customer free of charge.

4.9.6 INFORMATION

Jemena's AMS provides a hierarchical approach to understanding the information required to achieve Jemena's business objectives at the Asset Class level. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and the Asset Class Strategy (ACS) all provide the context for and determine the information required to manage and operate an Asset Class.

From these business objectives, it is possible to identify at a high-level the business information systems' content required to support these objectives (Table 4-79).

Information required to support asset strategies, performance and risks is recorded in SAP, Geographic Information System (GIS) and ECMS. Additional fault related data is available in the Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

Table 4-79: Public Lighting Sub-Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Information Sources	Externally Sourced Data
<p>Operational Excellence</p> <ul style="list-style-type: none"> • Manage assets throughout their lifecycle in safe and environmentally responsible manner • Maintain assets in accordance with RCM principals • Maintain asset information/knowledge to enable efficient and effective decision making • Embed continuous improvement throughout asset lifecycle <p>Customer</p> <ul style="list-style-type: none"> • Maintain our current service levels • Incorporate customer feedback in our decision making process <p>Growth</p> <ul style="list-style-type: none"> • Acquire/install/maintain assets to meet future demand requirements <p>People</p> <ul style="list-style-type: none"> • Maintain safe work environment • Engage team leaders in assessment of new assets • Training 	<p>GIS/JEN Viewer</p> <ul style="list-style-type: none"> • Geospatial representation of the JEN Network • Asset attributes <p>SAP</p> <ul style="list-style-type: none"> • Work schedule & status • Planned and corrective (faults) maintenance records • Asset inspection measurements • Financial information <p>ECMS</p> <ul style="list-style-type: none"> • Asset Inspection Manual, inspection methods & criteria • Policies, procedures and guidelines • General asset audits/surveys not stored in SAP • Incident investigations <p>Drawbridge</p> <ul style="list-style-type: none"> • Standards • Operations diagrams • Line design manual • Construction manual <p>SCADA/RTS</p> <ul style="list-style-type: none"> • Outage Management System (OMS) & SCADA (DMS) 	<ul style="list-style-type: none"> • Current cadastre (including land ownership) for JEN's geographical extent. • DELWP - HBRA and LBRA area boundaries • CFA for fires, warnings and restrictions, incidents • Emergency Management Common Operating Picture (EM-COP) • Aerial Imagery for JEN's geographical extent (NearMap) • Google 'Street View' • Melway • SAI global (Australian and International Standards) • ESV / ESC / AER for regulatory obligations

	<ul style="list-style-type: none"> Planned and Unplanned outages JEN Analytics <ul style="list-style-type: none"> Power quality data Energy consumption 	
--	---	--

Table 4-80 identifies the current and future information requirements to support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-80: Public Lighting Sub-Asset Class Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
Public lighting acquisition and application	<ul style="list-style-type: none"> Purchase specification (ECMS) Distribution Design Manual (ECMS) Distribution Construction Manual (ECMS) Period contracts (ECMS) Logistics system (SAP) 		<ul style="list-style-type: none"> High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.
Life cycle management: <ul style="list-style-type: none"> Asset identification Condition monitoring Condition assessment Replacement / retirement strategy Disposal 	<ul style="list-style-type: none"> Each asset identified by geospatial representation in GIS and equipment ID in SAP Asset Inspection Manual (ECMS) Maintenance plan (SAP) JEN Analytics (e.g. deteriorated neutral) Measurement record (SAP / ECMS) PM Notifications/Orders (SAP) Strategy detailed in this document GIS asset attributes: <ul style="list-style-type: none"> Asset status (e.g. existing/historical) Status (in service, isolated, out of commission) Installation Use Shared Cost Indicator Maintained By Road Class Tariff Type Feeder Primary Customer Date Commissioned Date Lamp Changed Zone Ownership Inspection Zone Fault / failure records: 	<ul style="list-style-type: none"> Lantern model Near real time updating of asset record Photos database of all failed assets Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
	<ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 		

Table 4-81 provides the information initiatives required to provide the future information requirements identified in Table 4-80. Included within this table is the risk to the Asset Class from not completing the initiative.

Table 4-81: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information capture	Ability to capture all relevant asset attributes from the field through mobility solution.	High	Complete, Current, Accurate attribution
Improve/review MAT Code definitions	Ability to align to AER service classification structure.	High	Precise definition
Improved Asset Attributes	Review current asset attribution fields to ensure attributes being collected are asset specific.	Medium	Appropriate and Accurate attribution
Increased Timeliness	Decrease latency between fault/maintenance delivery and fault/maintenance record capture.	High	Complete, Current, Accurate attribution
Improved fault information capture	Ability to capture all relevant asset failure information from the field through mobility solution and photos.	High	Complete, Current, Accurate fault information

4.10 EARTHING SUB-ASSET CLASS

4.10.1 INTRODUCTION

The primary functions of an earthing system are as follows:

- To provide a voltage reference for the associated distribution system;
- To facilitate the passage of fault current at a level that will ensure the correct operation of network protection systems; and
- To mitigate the hazards associated with step, touch and transfer potentials that can occur under network fault conditions.

There are two performance criteria applied to the design of earthing systems. They are:

- The withstand strength; and
- The safety performance.

The withstand strength of an earthing system has to match the networks maximum designed fault level and longest protection clearance time. The safety performance of the earthing is assessed using a risk based approach and considers the probability of coincidence and the probability of a fatality occurring under normal network operating conditions.

Earthing systems are installed at:

- Every distribution substation;
- Every zone substation;
- All conducting structures and poles that house or support high voltage conductors or equipment;
- In conjunction with all high voltage cable heads and terminations;
- In conjunction with all high voltage surge diverter installations; and
- All high voltage metering structures and poles.

A variety of earthing systems have been historically used across the JEN distribution substation network and these have included:

- Separate HV and LV earthing systems;
- Combined HV and LV earthing systems; and
- Common HV and LV earthing systems.

In order to improve the safety performance of distribution earthing systems generally JEN has adopted the Combined Multiple Earthed Neutral (CMEN) system of HV earthing wherever possible. This system uses the low voltage (MEN) neutral conductor to link all earthing systems and thus create a widespread low impedance earthing system to which all HV earths are bonded. This is combined with the installation of neutral earthing resistors at zone substations to reduce phase to ground fault levels and thus to improve the overall safety performance of the HV earthing system.

The CMEN system has been deployed, as far as is possible, in all of the urban neighbourhoods across JEN on the HV network. That is wherever the interconnected LV MEN neutral runs. In the remote parts of the network CMEN cannot be deployed as it requires the existence of an interconnected MEN neutral. In these locations the traditional earthing systems are deployed. It is acknowledged that these systems are not as effective as CMEN in the management of the hazards of step and touch potentials but this is offset by the fact that these assets are located remotely and the

probability of coincidence (the probability that someone is in a hazardous location at the time a fault occurs) is very low.

JEN has further extended the CMEN earthing system and bonded it to the zone substation earth grids. This has improved the safety performance of the zone substation earthing systems by lowering their impedance as well as improved the performance of the CMEN network by providing a direct path for the return of earth fault current on the HV network to the source zone substation. This reduces the magnitude of earth fault current in the ground and this mitigates earth potential rise.

This sub-asset Class Strategy for Earthing Systems is intended to ensure the ongoing performance of the Jemena Electricity Network and to mitigate the network risk associated with the safety performance of earthing systems. Earthing and electrical protection systems must safely manage abnormal supply network conditions to avoid risk to people, or damage to property.

4.10.2 ASSET PROFILE

4.10.2.1 Life Expectancy

Table 4-82 outlines the useful life of earthing systems on JEN.

Table 4-82: Useful Life of Earthing Systems

JEN Asset	Useful Life of Earthing Systems
Earth Grids	50
NER (Neutral Earthing Resistor)	40

4.10.2.2 Age Profile

CMEN has been implemented at all sites on the Jemena Electricity Network where JEN is the owner of the source zone substation.

A summary of the zone substation regions where and when CMEN has been introduced are listed in Table 4-83.

Table 4-83: CMEN implementation in the Zone Substation Regions

Year	Zone Substation Region
2015	Tullamarine Airport (TMA), Broadmeadows South (BMS)
2013	Heidelberg (HB), North Essendon (NS)
2011	Pascoe Vale (PV), Essendon (ES), Fairfield (FF)
2010	Footscray East (FE)
2008	Flemington (FT), Sydenham (SHM)
2007	North Heidelberg (NH)
2006	Coburg South (CS)
2004	Sunbury (SBY), Somerton (ST) Coolaroo (COO)
2003	Footscray West (FW), Tottenham (TH), Newport (NT)

Year	Zone Substation Region
2001	Airport West (AW), Braybrook (BY)
2000	Broadmeadows (BD), Coburg North (CN),

There are also small areas within the JEN distribution network (i.e., St Albans, Sunbury, Sydenham and Somerton) that are either supplied from adjacent Distribution Network Service Provider's zone substations that do not have NER's installed or are primarily in rural areas where no interconnected LV neutral conductor exists, and CMEN implementation has not occurred.

4.10.2.3 Utilisation

Earthing Systems are designed and installed to, as far as is possible, manage and control Earth Potential Rise (EPR) on the electrical apparatus they are connected to. On the Jemena network they are passive devices that normally conduct little or no electrical current except under fault conditions. They are designed and installed in contact with the general mass of earth utilising corrosion resistant materials that have a low impedance and a very long design life. They are generally comprised of a combination of stakes and conductor bonded together using reliable long life connection systems and laid out in a grid or pattern designed to spread the area of influence of the earthing system and achieve the desired earthing system impedance and thus manage any EPR.

4.10.3 PERFORMANCE

4.10.3.1 Requirements

Earthing systems must be made of corrosion resistant, high conductivity materials, specifically manufactured for the earthing of electrical installations. These materials include copper, copper alloy, brass and stainless steel. It should be noted that aluminium and steel are not suited for use in the construction of earthing systems as they readily corrode when in direct contact with the earth.

All metal and concrete structures located within 2.4 metres of the ground that support high voltage conductors and can be made alive in the event of primary insulation failure must be effectively earthed.

Table 4-84 outlines the earth resistance values that shall be achieved for various earthing installations as stated in the JEN internal standards.

Table 4-84: Earth Resistance Installations

Equipment	Maximum Resistance of Earth System to Ground			Maximum Resistance to Ground with Neutral Connected		Testing Requirements	
	HV	LV	Common	Common Earth System	Separate Earth System	Common Earth System	Separate Earth System
Pole/Ground/Indoor Substation	10Ω	10Ω >50 kVA	10Ω	1Ω*	10Ω	Common earth Common earth with neutral connected	HV earth LV earth
		30Ω <50 kVA			30Ω		
Kiosk Substation	10Ω	10Ω	10Ω	1Ω*	10Ω	Common earth Common earth with neutral connected	HV earth LV earth
HV Switch	10Ω	N/A	N/A	N/A	N/A	N/A	HV Earth
HV Fuse/Isolator/Sectionalizer	10Ω	N/A	N/A	N/A	N/A	N/A	HV Earth
HV Surge Arrester	10Ω	N/A	N/A	N/A	N/A	N/A	HV Earth
HV Cable Termination	10Ω	N/A	N/A	N/A	N/A	N/A	HV Earth
ACR	10Ω	N/A	N/A	N/A	N/A	N/A	HV Earth
HV Concrete Pole	10Ω	N/A	N/A	N/A	N/A	N/A	HV Earth
HV Line Capacitors	10Ω	N/A	N/A	N/A	N/A	N/A	HV Earth

*In CMEN systems the maximum resistance to ground of the common earth system prior to the neutral connection is 10Ω.

The requirements for the design, installation and performance of earthing systems on JEN are set out in the following manuals, standards and reports:

- The Distribution Construction Manual – JEN MA 0006
- The Earthing Design Manual - SECV June 1995
- Strategic Planning Paper – Earthing Systems, Doc No. ST-PPDS-2013-087
- JEN Earthing Systems Report – 19/2/2019
- ZCMEN Program of Works
- HV Earth Testing Program in Non-CMEN Areas - JEN PR 2504

These JEN standards and reports are based on and reference a number of Australian Standards. Unless otherwise specified, all earthing systems shall be designed, manufactured and tested in accordance with the following principal Australian Standards and industry guides (refer to Table 4-85).

Table 4-85 Earthing Systems - Relevant Standards

Standard	Title
AS 2067 - 2016	Substations and High Voltage Installations Exceeding 1kV AC
AS/NZS 7000 - 2106	Overhead Line Design

Standard	Title
ENA - EG-0	Power System Earthing Guide
IEEE 80:2000	IEEE Guide for Safety in AC Substation Grounding

4.10.3.2 Assessment

The CMEN system is being continually enhanced as new HV and LV assets are installed on the network and their associated earthing systems are bonded to the established CMEN system. There is no requirement to test the performance of earthing systems that are bonded to the CMEN earthing system. The requirements for the safety performance of the CMEN earthing system can be assessed using the criteria set out in AS 2067 and the ENA EG-0 guideline.

Non-CMEN earthing systems are tested every 10 years to ensure that the earth resistances comply with the performance criteria set out in Table 4-84 above. The safety performance of these standalone earthing systems can be assessed using the criteria set out in AS 2067 and the ENA EG-0 guideline.

The performance of Zone substation earth grids are tested every 10 years to ensure they comply with the safety requirements set out in AS 2067 and IEEE 80.

4.10.4 RISK

4.10.4.1 Criticality

An asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A. The asset criticality score was then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This is used to rank importance of dissimilar sub-asset classes (e.g. transformers and buildings and grounds) to identify areas where risk should be managed first and control measures implemented.

The earthing system sub-asset class has an asset criticality score of AC4 (High) due health and safety risk to staff and the general public associated with EPR and step and touch potentials.

4.10.4.2 Failure Modes

Failure modes include:

- Conductor corrosion causing high resistance or reduced fault current carrying capacity; and
- Conductor breakage due excavation, damage by machinery

Failure of earthing systems can also cause damage to equipment if protection systems are unable to operate in the manner in which the system was designed.

For details of the risk assessment, refer to relevant section in the Jemena Compliance and Risk System (JCARS).

4.10.4.3 Current Risks

The following table provides a summary of the current risks for earthing systems.

Table 4-86: Current Risks : Earthing Systems

Driver	Risk/Opportunity Description	Risk/Opportunity Description
Environment, Safety and Health	Earth potential rise (EPR)	This poses a risk to the public and employees and is something that needs to be actively managed on an ongoing basis, to ensure that changes in short circuit levels are managed appropriately.
Asset Integrity	Issues with theft of copper	On an annual basis, theft of copper (earthing) raises integrity issues for earthing systems that need to be managed on an ongoing basis.

For details of the risk assessment, refer to relevant section in Jemena's Compliance and Risk System (JCARS).

4.10.4.4 Existing Controls

There is no requirement to inspect and test HV earthing installations that form part of a CMEN system. The integrity of the CMEN earthing system relies on the application of construction standards that ensure all new high voltage installations are effectively connected to the CMEN network.

The inspection and testing of standalone HV earthing systems installed outside of the CMEN earthing system and zone substation earth grids is required at 10-yearly intervals in accordance with the requirements of the Electricity Safety (Network Assets) Regulations 1999 and Jemena's Electricity Safety Management Scheme (ESMS). Any non-compliant earth grid or system found by test is reinstated to ensure the maintenance of compliant earthing systems.

4.10.4.5 Future Risks

Significant changes in network fault levels have the potential to impact upon the safety performance of JEN's earthing systems.

The maintenance of the engineered connections from zone substation earth grids to the surrounding CMEN earthing system needs to be monitored to ensure the safety performance of the ZCMEN systems.

4.10.5 LIFE CYCLE MANAGEMENT

The strategy applied to the life cycle management of this sub-asset class includes time based inspections followed by condition based maintenance and repair, as well as in-service failure based reactive maintenance (some degree of a run to failure strategy).

The earthing systems installed on JEN are designed, constructed and maintained in accordance with the requirements of the Electricity Safety (Network Assets) Regulations 1999 which have been incorporated in JENS Electricity Safety Management Scheme (ESMS). JEN has conducted a Formal Safety Assessment as part of its ESMS submission to Energy Safe Victoria (ESV) which incorporated a risk assessment of the adequacy of JEN's current internal technical standards, in particular the requirement for inspection and testing of earthing systems in zone substations and non CMEN areas every 10 years. ESV has reviewed and approved JEN's ESMS.

4.10.5.1 *Creation*

Earthing systems are installed as part of any new installation of distribution and zone substation assets. New earthing systems are tested to ensure they meet the performance criteria specified for standalone earthing systems prior to bonding to the CMEN network.

4.10.5.2 *Asset Operation and Maintenance*

There are three (3) life cycle management strategies applied to the operation and maintenance of JEN's earthing systems:

- Asset Inspection;
- Preventative Maintenance; and
- Reactive and Corrective Maintenance.

4.10.5.2.1 *Asset Inspection*

The strategy for the maintenance of earthing systems through periodic inspections and tests is driven principally by:

- A duty of care requirement for the safety of our personnel and members of the public;
- A requirement for the business to comply with the JEN ESMS; and
- The need for correct and effective operation of network protection systems in the event of an earth fault, by ensuring there is sufficient fault current.

In general, with the exception of zone substation earthing systems, there is no requirement to inspect and test HV earthing installations that form part of a CMEN system. The inspection and testing of HV earthing systems installed outside CMEN schemes and zone substations are required at 10-yearly intervals.

4.10.5.2.1.1 *Inspection and Testing - Non-CMEN Distribution Assets*

Physical inspection of non-CMEN distribution assets (excluding non-pole distribution substations) is carried out every 3 years in the HBRA and every 5 years in the LBRA, to coincide with and as part of the standard asset inspection program. Refer to the JEN MA 0500 - Asset Inspection Manual for details.

Physical inspection of non-pole distribution substations is carried out every 3 years in the HBRA and every 5 years in the LBRA as part of the Enclosed Distribution Substation Inspection Program. Refer to the JEN MA 0695 – Enclosed Distribution Substations Inspection Manual for details.

The testing of these earths is required at 10-yearly intervals as part of the HV Earth Testing Program. Refer to JEN PR 2504 – HV Earth Testing Program in Non-CMEN Areas for details.

4.10.5.2.1.2 *Inspection and Testing - Zone Substations*

At 10-year intervals the following shall be undertaken to ensure earth grids continue to comply with safety criteria:

- Current injection tests to assess the impedance of the earth grid, the magnitude of the EPR under fault conditions, the magnitude and presence of any transfer hazards and the magnitude of any step and touch potentials;
- Sample inspections of underground conductors & conductor joints to check for any corrosion or damage.;

- A grid continuity test shall be conducted. This test measures the resistance between a main earth grid reference connection and each structure earthing point. This is particularly important for high energy dissipation points such as at surge arresters, portable earth points, and earth switch connection points;
- The condition of any crushed rock inside the substation for thickness and cleanliness. If the rock layer is filled with soil or grit its insulating properties may be compromised;
- Verify the integrity of all primary plant neutral earth connections; and
- Verify the integrity of engineered ZCMEN connections.

An annual physical integrity inspection shall be undertaken of all above ground structure earths, flexible earthing braids and bonds to equipment such as transformers, switchgear, cable sheaths, support framework and cubicles for all HV and LV equipment.

These earth tests are required even with the new strategy of bonding the zone substation earth grid to the CMEN network.

4.10.5.2.2 Preventative Maintenance

Condition based replacement or refurbishment is the preferred lifecycle management option for JEN's earthing systems.

Replacement or augmentation of earthing system equipment results from the generation of maintenance notifications following asset inspection. Degradation can take the form of conductor and connector corrosion, vandalism or inadvertent damage due to excavation.

Earthing system augmentation is also undertaken when an earth resistance test result exceeds the maximum specified limits.

4.10.5.2.3 Reactive and Corrective Maintenance

Reactive and corrective maintenance is undertaken on earthing systems when inspection and testing activities have revealed that the system is damaged or degraded, or when a notification is received that an incident has damaged the earthing system (e.g. earths damaged by an excavator or vandalism).

The required earthing resistance for the various earthing arrangements shall be as specified on the appropriate earthing diagram for the particular installation and equipment.

4.10.5.3 Asset Replacement

There is no proactive replacement program for earthing systems.

4.10.5.4 Earthing Systems Forecast Replacement Volumes

Table 4-87 lists the forecast replacement volumes for earthing systems from 2020 to 2026.

Table 4-87: Earthing Systems Forecast Replacement Volumes

Service Code	Earthing Systems	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RHH	Project Step & Touch Stage 4	360	-	-	-	-	-
RHH	Project Step & Touch Stage 5	-	266	-	-	-	-
RHH	Project Step & Touch Stage 6	-	-	274	-	-	-
RHH	Step & Touch - New cycle	-	-	-	-	-	137

4.10.5.5 Asset Disposal

Earthing systems are typically not removed from service, however should disposal be required; it is scrapped according to the scrap material policy. Refer to JEM PO 1066 – Scrap Materials Policy for details.

4.10.5.6 Spares

As part of criticality assessment consideration is given to appropriate levels of spare equipment. Spares requirements for critical assets are assessed by following Critical Spares Assessment Procedure (JEM AM PR 0015). It was determined that adequate spares are maintained at Tullamarine depot and stock holdings are managed by the Service and Projects team.

4.10.6 INFORMATION

Jemena's AMS provides a hierarchical approach to understanding the information required to achieve Jemena's business objectives at the Asset Class level. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and the Asset Class Strategy (ACS) all provide the context for and determine the information required to manage and operate an Asset Class.

From these business objectives, it is possible to identify at a high-level the business information systems' content required to support these objectives (Table 4-88).

Table 4-88: Earthing Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Information Sources	Externally Sourced Data
Operational Excellence <ul style="list-style-type: none"> Manage assets throughout their lifecycle in safe and environmentally responsible manner Maintain assets in accordance with RCM principals Maintain asset information/knowledge to enable efficient and effective decision making Embed continuous improvement throughout asset lifecycle Customer <ul style="list-style-type: none"> Maintain our current service levels Incorporate customer feedback in our decision making process Growth <ul style="list-style-type: none"> Acquire/install/maintain assets to meet future demand requirements People <ul style="list-style-type: none"> Maintain safe work environment Engage team leaders in assessment of new assets Training 	GIS/JEN Viewer <ul style="list-style-type: none"> Geospatial representation of the JEN Network Asset attributes SAP <ul style="list-style-type: none"> Work schedule & status Planned and corrective (faults) maintenance records Asset inspection measurements Financial information ECMS <ul style="list-style-type: none"> Asset Inspection Manual, inspection methods & criteria Policies, procedures and guidelines General asset audits/surveys not stored in SAP Incident investigations Drawbridge <ul style="list-style-type: none"> Standards Operations diagrams Line design manual Construction manual SCADA/RTS	<ul style="list-style-type: none"> Current cadastre (including land ownership) for JEN's geographical extent. DELWP - HBRA and LBRA area boundaries CFA for fires, warnings and restrictions, incidents Emergency Management Common Operating Picture (EM-COP) Aerial Imagery for JEN's geographical extent (NearMap) Google 'Street View' Melway SAI global (Australian and International Standards) ESV / ESC / AER for regulatory obligations

Business Objectives	Jemena Information Sources	Externally Sourced Data
	<ul style="list-style-type: none"> • Outage Management System (OMS) & SCADA (DMS) • Planned and Unplanned outages JEN Analytics <ul style="list-style-type: none"> • Power quality data • Energy consumption 	

Table 4-89 identifies the current and future information requirements to support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-89: Earthing Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
Earthing materials acquisition and application	<ul style="list-style-type: none"> • Purchase specification (ECMS) • Distribution Design Manual (ECMS) • Distribution Construction Manual (ECMS) • Period contracts (ECMS) • Logistics system (SAP) 		<ul style="list-style-type: none"> • High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.
Life cycle management: <ul style="list-style-type: none"> • Asset identification • Condition monitoring • Condition assessment • Replacement / retirement strategy • Disposal 	<ul style="list-style-type: none"> • Each asset identified by geospatial representation in GIS and equipment ID in SAP • Asset Inspection Manual (ECMS) • Maintenance plan (SAP) • JEN Analytics (e.g. deteriorated neutral) • Measurement record (SAP / ECMS) • PM Notifications/Orders (SAP) • Strategy detailed in this document • GIS asset attributes: <ul style="list-style-type: none"> - Asset status (e.g. existing/historical) - Status (in service, isolated, out of commission) - Feeder - CMEN - HV/LV - Ownership - Inspection Zone • Fault / failure records: <ul style="list-style-type: none"> - Root Cause 	<ul style="list-style-type: none"> • Lantern model • Near real time updating of asset record • Photos database of all failed assets • Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> • High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
	<ul style="list-style-type: none"> • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 		

Table 4-90 provides the information initiatives required to provide the future information requirements identified in Table 4-89. Included within this table is the risk to the Asset Class from not completing the initiative.

Table 4-90: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information	Field collection of incomplete asset attribution and assets	High	Complete, Current, Attribution Accurate
Planned and responsive asset maintenance costs	Ability to see the maintenance costs for an asset or asset type	Medium	Complete, Current, Attribution Accurate, Consistent (GIS Asset ID to SAP Asset ID)
Network Performance Data	Ability to 'view' asset performance data from the GIS user interface or access an asset's historical performance data.	Medium	Complete, Current, Attribution Accurate, Consistent (GIS Asset ID to SAP Asset ID)
Improved Asset Attribution	Review of asset attribution fields to ensure attributes being collected are business specific	Medium	Attribution Accurate
Increased Timeliness	Latency between maintenance delivery and maintenance record capture decreased	High	Complete, Current, Attribution Accurate

Information required to support asset strategies, performance and risks is recorded in SAP, Geographic Information System (GIS) and ECMS. Additional fault related data is available in the Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

4.11 HIGH VOLTAGE OUTDOOR OVERHEAD FUSE SUB-ASSET CLASS

4.11.1 INTRODUCTION

This section includes information about the type, specifications, life expectancy and age profile of the HV outdoor overhead fuses in service across the Jemena Electricity Network.

HV outdoor fuses are a simple and effective method of providing fuse protection. They are primarily employed as the protective device on pole type transformers, ground type substations and in some instances for the protection of indoor substations on cable head poles. They are also utilized to protect spur lines mainly in the rural areas and under rated overhead conductor (fault level reduction).

The three types of HV outdoor fuses used on the JEN on the 22kV, 11kV and 6.6kV distribution networks are expulsion drop out (EDO), powder filled (PF) and boric acid (BA) fuses (refer to Table 4-91). The majority of fuses installed on the network are the BA type fuse, this is also the preferred fuse type. New EDO fuses are not installed on the network however stocks of fuse links are maintained to ensure ongoing operation of the existing population of EDO fuses. Where fault levels exceed the capabilities of BA fuses, PF fuses are used.

Table 4-91: HV Overhead Fuse Types

HV Overhead Fuse Type	Operating Volume			Total
	22kV	11kV	6.6kV	
Boric Acid (BA)	2921	377	105	3406
Expulsion Drop Out (EDO)	270	15	23	308
Powder Filled (PF)	2436	260	37	2739
Total	5627	652	165	6444

4.11.2 ASSET PROFILE

4.11.2.1 Life Expectancy

As prescribed in ELE PR 0012 – Network Asset Useful Lives Procedure, the applicable useful life for HV Outdoor Fuses is 40 years.

The above procedure considers asset lives based on good industry practice and specific Jemena Electricity Network experience and represents the lives of assets at which end-of-life replacement will be considered. JEN has undertaken a number of reviews of asset useful lives with consulting agencies and held discussions with other Distribution Businesses to ensure assigned asset lives are realistic.

4.11.2.2 Age Profile

As of December 2018, there are a total of 6,444 sets of HV outdoor overhead fuses in service on the network. These consists of 3,403 BA, 308 EDO and 2,739 PF fuses. Figure 4-69 HV Outdoor Overhead Fuse Age Profile shows the age profile of HV outdoor fuses in service on the distribution network.




Figure 4-69 HV Outdoor Overhead Fuse Age Profile

4.11.2.3 Utilisation

Approximately 50% of all HV outdoor overhead fuses in service on JEN are BA fuses, while EDOs only account for 8%. As per the JEN Fusing Guideline (JEN GU 0050), EDO type fuses are not to be used for new construction and replacement work. Any damaged EDO fuse mount shall be replaced with a new set of BA type fuses and mounts.

4.11.2.3.1 Expulsion Drop Out (EDO) Fuses

EDO fuses have been used in the Victorian Electricity Supply Industry (VESI) since 1952. An EDO fuse is a wire fuse (fuse wire in air) and consists of three parts; the fuse mount, the fuse holder or tube and the fusible link. When an EDO fuse operates, the molten fuse element is expelled explosively from the bottom of the fuse tube. These incendiary particles can result in the ignition of a fire when they hit the ground. Consequently EDO fuses installed in the high bush fire risk areas (HBRA) have a fire choke designed to catch and cool these particles to make the devices fire safe. Only EDO fuses fitted with fire chokes are permitted to remain in service in the HBRA.

Once an EDO fuse has operated, the fuse tube is unlatched and swings down providing clear indication of fuse operation and isolation of the faulted equipment. They are inexpensive and when operated, the fusible links can be easily removed and replaced. Only three types of EDO fusible links are approved for use. They are Stanger "AK1", ABB "Prolink" and AEM "Ultrafuse". At very low fault levels EDO's have been known to "hang-up" and candle. Candling occurs when the wire fuse element melts but the fuse tube fails to drop. This results in the tube being electrically stressed and the resulting leakage current causes the fuse tube to burn.

As a result of the Ash Wednesday fires in 1983, 'unacceptable' EDO fuses were identified for replacement throughout the VESI to mitigate fire risk. Since 1985, double vented EDO fuses were replaced by single venting fuses to reduce fire risks. EDO fuses have a limited fault interrupting capability and cannot be used where fault levels exceed 2kA. If these fuses are used in areas with fault levels in excess of 2kA, there is an increasing risk that the fuse tube will burst when attempting to interrupt fault current which will result in a possible feeder outage.

4.11.2.3.2 Power Filled (PF) Fuses

High Rupture Capacity (HRC) powder filled fuses have been used historically where the interruption of higher fault levels is required. A PF fuse consists of two parts, the fuse mount and the fuse body. The fusible elements are embedded in sand filler and are fully sealed in porcelain housings which

therefore make the PF fuses significantly heavier than EDO fuses. Once the fuse has operated, the melting of the fusible elements turns the sand into glass and interrupts the fault current. The fault energy is all managed within the fuse with no molten material expelled from the fuse. For this reason PF fuses are fire safe. The fuse is not rewirable and when blown the fuse must be replaced.

Although PF fuses are fully fault rated devices, care must be taken with their specification, selection and application. Full-range PF fuses offer fuse protection at all fault levels but are only available in a limited range of current ratings. General purpose PF fuses have a minimum breaking current limitation which means that if required to interrupt fault currents at levels below their minimum breaking current, then fuse candling and failure can occur. Fuse candling does have the potential to start a fire.

PF fuses do expel a small mechanical striker pin when they have operated to indicate that the fuse is blown. The fuse mounts that fit PF fuses are designed to use the explosion of the striker pin to unlatch the fuse holder, so that when the fuse has operated the fuse swings down out on the holder in the same way as an EDO fuse, providing clear indication of a fuse operation. The problem with this design is that the momentum associated with this action often causes the heavy PF fuse to be displaced from the mount and fall to the ground with the associated significant risk of injury. As a consequence PF fuses are installed upside down in the fuse mounts so that when the fuse operates, the striker pin does not cause the unlatching of the fuse mount. This overcomes the safety issue but makes the identification of a blown fuse very difficult. The operation of these fuses is also difficult due to their weight and handling them on the end of a long HV operating stick can be hazardous as it is easy to lose control of the fuse and drop it during operations.

4.11.2.3.3 Boric Acid (BA) Fuses

Boric acid FSDs were introduced in the mid 1980's. The majority of fuses currently installed on JEN are boric acid fuses. BA fuses are a wire fuse that combines the advantages of EDO fuses with some of the capabilities of PF fuses. A BA fuse consists of two parts, the fuse mount and the fuse body or tube. BA fuses are not rewirable and when blown the fuse tube has to be replaced.

A BA fuse operates in the same way as an EDO fuse in that when the fuse operates, the wire fusible element melts and the molten products are expelled out of the bottom of the fuse tube. However, unlike an EDO fuse the BA fuse tube is lined with a solid boric acid material which cools the incendiary particles and makes the fuse safe for use in the HBRA. Similar to a PF fuse, when the BA fuse element blows a mechanical striker pin is expelled from the top of the fuse and unlatches the fuse holder. This causes the fuse tube to swing down and hang in this position providing clear indication that the fuse has blown and isolation of the faulted equipment. The BA fuse tubes are light weight and this makes operation with a HV operating stick the same as for an EDO fuse.

BA fuses are full range fuses and have no minimum breaking current limitations. There is an upper limit on their interrupting capacity of 10kA. This means that these fuses can be installed in almost all parts of the network. A restriction has been placed on their use within 1km of a zone substation where a PF fuse should be used in these locations instead.

Fuse links with ratings up to 40 amps and manufactured prior to 1990 are particularly susceptible to "candling" and "hang-ups" with low current faults. The failures of these fuses result in burning of the fuse tube creating a fire hazard. These links can be readily identified, as they do not have green reflective tape or year of manufacture labels.

Moisture causes the Boric Acid liner to expand and in turn the operating rod to jam inside the tube resulting in the fuse tube not dropping out. This can lead to hang-ups and candling (slow burn). Hence fuse tubes are NOT to be stored hanging upside down in an open position in the fuse mounts for more than a day or left exposed to the weather e.g. awaiting commissioning. For details, refer to the Plant Bulletin for Handling of Boric Acid Fuses.

4.11.3 PERFORMANCE

4.11.3.1 Requirements

Unless otherwise specified, the HV fuses shall be designed, manufactured and tested in accordance with the following Australian Standards (refer to Table 4-92):

Table 4-92: Relevant Australian Standards

Standard	Title
AS 1033.1	High Voltage fuses (for rated voltages exceeding 1000V – Part 1: Expulsion type
AS 1033.2	High Voltage fuses (for rated voltages exceeding 1000V – Part 1: Current-Limiting (Powder-Filled) Type
AS/NZS 1852(441)	Switchgear, control gear and fuses

The equipment must be able to operate within the required performance parameters when exposed to climatic conditions in the state of Victoria.

For HV fusing technical requirements and fusing application tables, refer to JEN-AM-PO-001 Fusing Policy document.

AS 1033.1 specifies the requirements for expulsion type fuses and this includes both Expulsion Drop Out and Boric Acid fuses. All fuses deployed in the HBRA parts of the JEN must be Class A type (sparkless) in accordance with the requirements of the standard and Jemena's Bushfire Mitigation Plan. Powder Filled fuses are sparkless by virtue of their design and operating characteristics.

4.11.3.2 Assessment

Inspection of HV fuses is carried out as part of the standard asset inspection program. All poles and lines in the Hazardous Bushfire Risk Areas are inspected every 3 years, and in the Low Bushfire Risk Areas every 5 years. A thermal survey of HV fuses is also performed to assist in the detection of potential failures before they occur and is aligned with the regular overhead line thermal survey cycle.

For details of the activities involved in the inspection program, refer to the JEN MA 0500 - Asset Inspection Manual.

On average maintenance notifications are raised on approximately 1.5% of the outdoor fuse population each year. In the main these relate to the operation of fuses. Asset replacement data reveals that as a result of these notifications approximately 0.2% to 0.3% (12 to 20 sets) of the population are replaced each year. This replacement rate points to a very reliable group of assets that are likely to have a service life that exceeds the forecast useful life.

4.11.4 RISK

4.11.4.1 Criticality

Asset criticality is a measure of the risk of specified undesired events faced when utilising equipment. Asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A. The asset criticality score is then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This is also used to rank importance of dissimilar sub-asset classes (e.g. transformers and buildings and grounds) to identify areas where risk should be managed first and control measures implemented.

The HV outdoor fuses sub-asset class has an asset criticality score of AC1 (Low) due to the consequence rating being minor.

4.11.4.2 *Failure Modes*

Common failure modes for HV outdoor fuses include:

- Insulator flashover due to deterioration, cracks or breakage of insulators and bird/animals;
- “Candling” which involves the overheating of fuse elements, particularly at low fault currents or overload currents, due to the fuse element not interrupting the current and continuing to conduct. These leads to failure of the fuse porcelain body or fuse tube;
- Failure of pivoting fuse holder to de-latch (hang up) on EDO and Boric Acid types; and
- Failure due to third party (e.g. weather and animal contact).

The major risks associated with HV outdoor overhead fuses are safety to people during maintenance and operation, supply reliability due to equipment failure or animals and the risk of fire start.

For details of the risk assessment, refer to the relevant section in Jemena Risk and Compliance System (JCARS).

4.11.4.3 *Current Risks*

This section provides information about HV outdoor overhead fuses, as well as general information about other potential issues. For details of the risk assessment, refer to relevant section in Jemena's Compliance and Risk System (JCARS).

There are currently no known systemic issues regarding HV outdoor overhead fuses. The performance of boric acid fuses is being monitored as there have been a small number of hang up failures related to failure of the striker pin to cause the fuse to drop out.

4.11.4.4 *Existing Control*

HV outdoor fuses are inspected as part of the standard asset inspection program. All poles and lines in the Hazardous Bushfire Risk Areas are inspected every 3 years, and in the Low Bushfire Risk Areas every 5 years. A thermal survey of HV fuses is also performed to assist in the detection of potential failures before they occur and is aligned with the regular overhead line thermal survey cycle.

4.11.4.5 *Future Risks*

No future risks associated with HV outdoor overhead fuses have been identified.

4.11.5 LIFE CYCLE MANAGEMENT

The options available for asset lifecycle management reflect a trade-off between capital and operating expenditure. The aim is to achieve predictable and sustainable OPEX and CAPEX programs that manage the network risk and deliver improved safety outcomes that are associated with the replacement of unserviceable assets and the deployment of new technologies. The preferred asset lifecycle management option involves condition based replacement.

The strategy covers time based inspections followed by condition based maintenance and replacement, as well as in-service failure based reactive maintenance.

4.11.5.1 *Creation*

HV outdoor fuses are installed for the protection of distribution transformers and overhead spur lines. Every pole top transformer has a set of fuses installed to protect the distribution network from a fault on a transformer and its associated equipment and they serve as the HV isolating device for the transformer. The size and detail of the fuses to be installed at each location is described in Jemena's fusing guide. For details, refer to JEN-AM-PO-001 Fusing Guideline.

4.11.5.2 *Asset Operation and Maintenance*

The lifecycle management options of HV outdoor overhead fuses are:

- Asset Inspection;
- Proactive Maintenance;
- Reactive and Corrective Maintenance; and
- Run to Failure.

4.11.5.2.1 *Asset Inspection*

Inspection of HV fuses is carried out as part of the standard asset inspection program. All poles and lines in the HBRA are inspected every 3 years, and in the LBRA every 5 years. A thermal survey of HV fuses is also performed to assist in the detection of potential failures before they occur and is aligned with the regular overhead line thermal survey cycle.

For details of the activities involved in the inspection program, refer to the JEN MA 0500 - Asset Inspection Manual.

When opportunities arise, such as repair of overhead conductor faults, all fuses should be inspected for cleanliness, signs of tracking, cracks on fuse mounts and carriers and that the lead connections, and bird and animal covers are secured.

4.11.5.2.2 *Proactive Maintenance*

4.11.5.2.2.1 *Condition Based Replacement or Refurbishment*

Fuses are replaced according to the JEN GU 0010 – JEN Planned and Opportunistic Maintenance and Workmanship Guidelines and JEN MA 0500 – Asset Inspection Manual. This includes but is not limited to:

- signs of tracking, cracks on fuse mounts and carriers;
- unacceptable EDO fuses, e.g. old brown porcelain EDO;
- as part of planned work such as pole or HV fuse crossarm changes, EDO fuses are to be replaced with the current standard i.e. BA or PFF;
- as part of planned work such as pole or HV fuse crossarm changes, any BA fuse mounts within 1 km of a zone substation shall be changed to PFF; and
- as part of planned work such as pole or HV fuse crossarm changes, any PFF fuse mounts more than 1 km of a zone substation shall be changed to BA.

4.11.5.2.2.2 *Proactive Replacement Program*

There are no proactive replacement programs currently for the replacement of HV outdoor overhead fuses. Opportunistic replacement in accordance with the above requirements will occur in conjunction with network augmentation or redevelopment.

4.11.5.2.3 Reactive and Corrective Maintenance

Corrective maintenance shall be used to repair defects and faults identified during inspections or problems that occur during service.

When blown fuses are replaced or repaired the following should be inspected:

4.11.5.2.3.1 EDO Fuses

- Mounts;
- Excess fuse link tails are cut off and not poked back in the fuse carrier;
- Carriers or tubes are clear of obstructions such as mud wasp nests;
- Check the carriers for warping, bowing, tracking and arcing damage and are not therefore prone to “hang-up” or candling; and
- Note: (EDO fuse mounts are not maintained, they are replaced with BA fuses)

4.11.5.2.3.2 Powder Filled Fuses

- Mounts;
- Contacts on the top and bottom clamping rings are in line and are clean;
- Striker pin is facing down (at the bottom clamping ring); and
- Correct size clamping rings are selected to fit the fuse link.

4.11.5.2.3.3 Boric Acid Fuses

- Mounts;
- Top and bottom clamping fittings are located on the fuse link correctly, (spigots are fitted on the fuse link to ensure correct location), and securely tightened;
- Breaking latch on the top contact of the mount hinges freely;
- Travel of the de-latching pin is not impeded (check the hole in the top of the top fitting is not blocked);
- When link is closed, the red plastic vent cover points down; and
- Fuse Links should have red plastic vent cover fitted.

4.11.5.2.3.4 All Fuses

- Porcelain is undamaged, free of tracking, cracking and chipping;
- Fixed contacts are clean and lightly graphite greased;
- Line connections are tight; and
- Fuse carrier hinges freely in the bottom mount and latches properly when closed.

4.11.5.2.4 Run to Failure

Apart from opportunistic replacement to ensure acceptable fuses are used, fuses are consumable assets and are designed for run to failure. Whenever fuse elements operate, they are replaced once a patrol establishes the likely cause of the fault.

4.11.5.2.5 HV Outdoor Overhead Fuse Forecast Replacement Volumes

Table 4-93 lists the forecast replacement volumes for HV outdoor overhead fuses from 2020 to 2026, based on condition.

Table 4-93: HV Outdoor Overhead Fuse Forecast Replacement Volumes

Service Code	HV Outdoor Overhead Fuses	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RXF	Fuse unit replacement	17	17	17	17	17	17

4.11.5.3 Disposal

HV outdoor overhead fuses are typically not repaired but instead are replaced as required. HV outdoor overhead fuses should be disposed of in accordance with JEM PO 1600 – Scrap Materials Policy.

4.11.5.4 Spares

Fuse mounts and components are stocked in the stores and replenished based on historical purchase orders and 75% of 6 month usage for summer preparation.

4.11.6 INFORMATION

Jemena's AMS provides a hierarchical approach to understanding the information required to achieve Jemena's business objectives at the Asset Class level. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and the Asset Class Strategy (ACS) all provide the context for and determine the information required to manage and operate an Asset Class.

The Electricity Distribution Asset Class Strategy facilitates the safe, efficient and reliable delivery of electricity to JEN's customers.

From these business objectives, it is possible to identify at a high-level the content of the business information systems required to support these objectives (Table 4-94).

Table 4-94: HV outdoor Overhead Fuses Sub-Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Sources	Information	Externally Sourced Data
Operational Excellence <ul style="list-style-type: none"> Manage assets throughout their lifecycle in safe and environmentally responsible manner Maintain assets in accordance with RCM principals Maintain asset information/knowledge to enable efficient and effective decision making Embed continuous improvement throughout asset lifecycle Customer <ul style="list-style-type: none"> Maintain our current service levels Incorporate customer feedback in our decision making process Growth	GIS/JEN Viewer <ul style="list-style-type: none"> Geospatial representation of the JEN Network Asset attributes SAP <ul style="list-style-type: none"> Work schedule & status Planned and corrective (faults) maintenance records Asset inspection measurements Financial information ECMS <ul style="list-style-type: none"> Asset Inspection Manual, inspection methods & criteria 		<ul style="list-style-type: none"> Current cadastre (including land ownership) for JEN's geographical extent. DELWP - HBRA and LBRA area boundaries CFA for fires, warnings and restrictions, incidents Emergency Management Common Operating Picture (EM-COP) Aerial Imagery for JEN's geographical extent (NearMap) Google 'Street View' Melway

<ul style="list-style-type: none"> Acquire/install/maintain assets to meet future demand requirements People <ul style="list-style-type: none"> Maintain safe work environment Engage team leaders in assessment of new assets Training 	<ul style="list-style-type: none"> Policies, procedures and guidelines General asset audits/surveys not stored in SAP Incident investigations Drawbridge <ul style="list-style-type: none"> Standards Operations diagrams Line design manual Construction manual SCADA/RTS <ul style="list-style-type: none"> Outage Management System (OMS) & SCADA (DMS) Planned and Unplanned outages JEN Analytics <ul style="list-style-type: none"> Power quality data Energy consumption 	<ul style="list-style-type: none"> SAI global (Australian and International Standards) ESV / ESC / AER for regulatory obligations
--	---	---

Table 4-95 identifies the current and future information requirements to support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-95: HV Outdoor Overhead Fuses Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
HV outdoor fuse acquisition and application	<ul style="list-style-type: none"> Purchase specification (ECMS) Distribution Design Manual (ECMS) Distribution Construction Manual (ECMS) Period contracts (ECMS) Logistics system (SAP) 		<ul style="list-style-type: none"> High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.
Life cycle management: <ul style="list-style-type: none"> Asset identification Condition monitoring Condition assessment Replacement / retirement strategy Disposal 	<ul style="list-style-type: none"> Each asset identified by geospatial representation in GIS and equipment ID in SAP Asset Inspection Manual (ECMS) Maintenance plan (SAP) JEN Analytics (e.g. deteriorated neutral) Measurement record (SAP / ECMS) PM Notifications/Orders (SAP) Strategy detailed in this document GIS asset attributes: <ul style="list-style-type: none"> Asset status (e.g. existing/historical) 	<ul style="list-style-type: none"> Fuse rating Manufacturer Phase Near real time updating of asset record Photos database of all failed assets Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
	<ul style="list-style-type: none"> - Status (in service, isolated, out of commission) - Use - Type (e.g. EDP, BA) - Physical Location (Melway reference, closest address / intersection) - Feeder - Operational Tag - Ownership - Inspection Zone • Fault / failure records: <ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 		

Table 4-96 details the information initiatives required to provide the future information requirements identified in Table 4-95. Included within this table is the risk to the Asset Class from not completing the initiative.

Information required to support asset strategies, performance and risks is recorded in SAP, Geographic Information System (GIS) and ECMS. Additional fault related data is available in the Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

Table 4-96: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information	Field collection of incomplete asset attribution and assets	High	Complete, Current, Attribution Accurate
Planned and responsive asset maintenance costs	Ability to see the maintenance costs for an asset or asset type	Medium	Complete, Current, Attribution Accurate, Consistent (GIS Asset ID to SAP Asset ID)
Network Performance Data	Ability to 'view' asset performance data from the GIS user interface or access an asset's historical performance data.	Medium	Complete, Current, Attribution Accurate, Consistent (GIS Asset ID to SAP Asset ID)
Improved Asset Attribution	Review of asset attribution fields to ensure attributes being collected are business specific	Medium	Attribution Accurate

Increased Timeliness	Latency between maintenance delivery and maintenance record capture decreased	High	Complete, Current, Attribution Accurate
-----------------------------	---	------	---

4.12 DISTRIBUTION SURGE ARRESTERS SUB-ASSET CLASS

4.12.1 INTRODUCTION

This section includes information about the type, specifications, life expectancy and age profile of the distribution surge arresters in service across JEN.

Surge arresters are a non-intelligent distribution equipment overvoltage protection device that is typically mounted on pole mounted distribution substations, automatic circuit reclosers (ACR's), gas insulated switches and cable head poles. They are installed for the protection of these devices in the event of network overvoltage's.

Table 4-97 shows the in service Distribution Surge Arresters by type and application. It should be noted that data quality issues has resulted in a large number of surge diverter sets being listed as "other" in the list of applications below. It is reasonable to assume that the majority of these are in fact associated with pole top transformers as there are 4,100 of these installations on the JEN and the vast majority are fitted with surge diverters. The data indicates that only 2,360 sets are located on pole top transformers.

Table 4-97: Distribution Surge Arresters by Type

Type	Applications							Total
	ABC	Overhead	Regulator	Switches	Transformer	Underground	Others	
Blue Porcelain	0	9	0	1	13	5	3	31
Brown Porcelain	0	4	0	2	12	19	0	37
Expulsion	0	0	0	0	1	0	0	1
Grey Porcelain	1	88	0	24	380	143	20	656
Polymeric	10	452	2	301	1954	1083	2036	5838
Total	11	553	2	328	2360	1250	2059	6563

4.12.2 ASSET PROFILE

4.12.2.1 Life Expectancy

As prescribed in ELE PR 0012 – Network Asset Useful Lives Procedure, the applicable useful life for Distribution Surge Arrestors is as follows:

Surge Arrester - 25 years;

The above procedure considers asset lives based on good industry practice and specific Jemena Electricity Network experience and represents the lives of assets at which end-of-life replacement will be considered. JEN has undertaken a number of reviews of asset useful lives with consulting agencies and held discussions with other Distribution Businesses to ensure assigned asset lives are realistic.

4.12.2.2 Age Profile

As of December 2018, there are a total of 6,563 sets of distribution surge arresters in service on the JEN. Furthermore, as shown in Table 4-97, approximately 89% of the total population of distribution surge arrester are the Polymeric housed type. This is because of a number of large programs that

targeted the replacement of 'unacceptable' surge arrestors. The principle driver of these replacement programs has been the commissioning of Neutral Earthing Resistors at zone substations located across the entire JEN and the requirement for the installation of Class A surge arrestors in the HBRA.




Figure 4-70 Age Profile Surge Arrester (All types)

4.12.2.3 Utilisation

HV surge arresters are passive devices that do not operate or function under normal operating conditions. Modern surge arresters are non-linear varistors activated by over-voltage conditions that result from network switching or lightning events. They are design to provide overvoltage protection of network assets by shunting overvoltages to earth.

Historically, various over-voltage protection devices have been installed. Rod gaps and silicon carbide type surge arresters were used on the State Electricity Commission of Victoria (SECV) system. Prior to 1975, silicon carbide surge arresters were not fitted with pressure relief devices and their failures were known to be explosive. Subsequently, pressure relief devices and earth lead disconnects were introduced to mitigate this safety hazard and to assist with fault location. Earth lead disconnects were fitted to 5kA rated arresters and not 10kA rated arresters as these arresters had higher energy handling capabilities. These have not been installed since 2000 on the JEN network.

In 1985, zinc oxide type surge arresters were accepted for the first time as their operating voltages were more accurate and more reliable than silicon carbide units. Their residual voltages were also lower than silicon carbide units, offering greater protection for network assets.

Whilst the electrical characteristics of surge arresters were improving, it was recognised that structural weakness still remained. Some surge arresters employing porcelain as the housing medium were failing explosively with the resulting hazard associated with shattered flying pieces of porcelain. To reduce the potential safety hazard, surge arresters utilising a polymeric housings were introduced in 1994. In general the polymeric surge arresters are proving to be far more reliable than their old porcelain counterparts as they better seal the active components from the ingress of moisture.

As of December 2014, there are 2 types of surge arresters approved for installation as standard within the 22kV network. These are Class A, ABB Polim K21-70 for the HBRA and Class C, TE Tyco BOW-DA1-27H-B7F0N0-I-212 for the LBRA. A third type of surge arrester is used as standard for the 11kV and 6.6kV network, these are Class C, AK Power CA 12/05.0D.

In early 2015, the supplier notified Jemena of performance issues associated with the 22kV Class C TE Tyco surge arresters. Thereafter, this model of surge arrester was no longer installed on JEN and all stock was placed under quarantine. In the interim, 22kV Class A surge arresters are being installed instead of the 22kV Class C surge arresters.

4.12.3 PERFORMANCE

Distribution surge arresters are designed, manufactured and tested in accordance with the following Australian Standards (refer to Table 4-98):

Table 4-98: Applicable Australian Standards - Distribution Surge Diverters

Standard	Title
AS 1037.2	1996 Metal-oxide surge arresters without gaps for AC systems
AS 1768	1991 Lightning Protection
AS 1018	1985 Partial Discharge Measurements

The equipment must satisfy the required performance parameters when exposed to climatic conditions in the state of Victoria.

All new surge diverter housings are polymeric thus reducing the risk rating for public safety and liability. Furthermore, distribution surge arresters are specified pressure relief category “NS” (Non-Shattering) as per AS 1307.2.

4.12.3.1 Requirements

The monitoring and optimisation of the performance of HV surge arresters is achieved through the following metrics:

- Operations risk mitigation through the creation and completion of notifications in alignment with the Network Maintenance Delivery Program;
- Minimisation of customers off supply in the event of network outages, as a result of surge arrester mal-operation or failure, and subsequent failure of a distribution transformer or other distribution supply equipment, contributing to customer reliability and service target performance incentive scheme (STPIS) targets;
- Minimisation of fire starts, as a result of surge arrester failure, and subsequent discharge of sparks or molten metal, contributing to Jemena fire performance incentive scheme (F-Factor) targets; and
- Network incidents reportable to Electricity Safety Victoria (ESV).

Each of these targets is reported on a monthly basis in the JEN Customer & Asset KPI's at an aggregate level, to which performance of HV surge arresters contribute.

These targets align with the JEN Strategic Objectives under Customer, Safety & Asset Management.

4.12.3.2 Assessment

4.12.3.2.1 Notifications

HV surge arresters are condition monitored via the asset inspection programs to ensure that they remain in a serviceable and operable condition. They are inspected as a part of the asset inspections that occur every 3 years in Hazardous Bushfire Risk Areas (HBRA) and 5 years in the Low Bushfire Risk Areas (LBRA). Consequently maintenance notifications are raised when defects are detected via inspection and corrective maintenance or replacement tasks are scheduled to ensure the safety, operability, and reliability of this group of assets.

Table 4-99 shows the SAP notifications and the corresponding cause descriptions.

Table 4-99: HV Surge Arrester SAP Notifications

Cause (SAP)	Notification Date						Total
	2013	2014	2015	2016	2017	2018	
Animal/Bird	3	2	5	7	2	9	28
Unidentified	2	2	1	0	1	1	7
Asset (Electrical/Mechanical Failure)	16	10	7	8	5	3	49
Third Party (e.g. Vehicle, weather)	0	0	0	1	2	1	4
Total	21	14	13	16	10	14	88

4.12.3.2.2 Fire Starts

After the bushfires in the late 1970's and early 1980's, reports indicated that surge arresters were related to a number of fire starts and many arresters were deemed 'unacceptable'. These arresters have been removed from service as part of bushfire mitigation strategy. A small percentage of 'unacceptable' surge arresters may still exist in non-bushfire areas. A complete list of unacceptable surge arresters can be found in the 'Acceptable HV Fuse and Surge Arrester' handbook. Document number: SP 4147 (Sept 1997). Table 4-100 shows the population of surge arresters.

Table 4-100: HV Surge Arrester Location

Type	Total
Blue Porcelain	31
Brown Porcelain	37
Expulsion	1
Grey Porcelain	656
Polymeric	5838
Total	6563

4.12.4 RISK

This chapter includes information about surge arrester risk profiles involving the way that asset class criticality is established, the risks posed by surge arrester failure (including the various failure types and their possible consequences), other measures being introduced to manage asset risk, and a list of the various issues currently confronting surge arresters.

This information specifically involves:

- asset class criticality;
- failure risks, types, and consequences; and
- asset issues

4.12.4.1 Criticality

Asset criticality is a measure of the risk of specified undesired events faced when utilising equipment. An asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A. The asset criticality score is then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This is also used to rank importance of dissimilar sub-asset classes (e.g. transformers and buildings and grounds) to identify areas where risk should be managed first and control measures implemented. Distribution surge arrester sub-asset class has an asset criticality score of AC2 (Moderate).

Surge arresters contribute to the Jemena Electricity Network (JEN) overall service level and network performance via the overvoltage protection they provide to the distribution asset class. There are approximately 6,563 surge arresters sets installed on the JEN, of which, approximately 4,000 sets are protecting transformers. The failure of the surge arrester to operate correctly exposes an in service transformer to network over-voltages which if left undetected could potentially result in a catastrophic transformer failure and subsequent network outages.

4.12.4.2 Failure Modes

Surge arrester failures include:

- External flashover of housing;
- Internal flashover, causing housing rupture, often due to moisture ingress in porcelain housed units;
- Internal conduction of 50Hz current, often with housing rupture; and
- Operation of earth lead disconnect device due to either 50Hz internal current flow to earth or conduction of impulse spike which exceeds the fault current rating of the surge arrester.

The major risks associated with surge arresters relate to public safety associated with airborne shattered porcelain following explosive failure and external liability due to litigation claims for property damage and/or personal injury. Other risks include equipment failure resulting in bushfire start, which further results in financial impact to JEN under the new regulatory bushfire F-Factor scheme.

For details of the risk assessment, refer to the relevant section in Jemena Risk and Compliance System (JCARS).

4.12.4.3 *Current Risks*

After bushfires in the late 1970's and early 1980's, reports indicated that surge arresters were related to a number of fire starts and many arresters were deemed 'unacceptable'. These arresters have been removed from service as part of bushfire mitigation strategy. A small percentage of 'unacceptable' surge arresters may still exist in non-bushfire areas. A complete list of unacceptable surge arresters can be found in the 'Acceptable HV Fuse and Surge Arrester' handbook. Document number: SP 4147 (Sept 1997).

Historically, Neutral Earth Resistors (NERs) were introduced into the network to improve the quality of supply, reduce the risk of bushfire ignition during phase to ground faults, and reduce hazardous step and touch potentials present during fault conditions. The risk of bushfire ignition is proportional to the amount of energy let through during the fault (or I^2t). The NER limits the available phase to ground fault current to approximately 2kA, representing a significant reduction in the fault energy and therefore the risk of bushfire ignition.

The NER and related CMEN program was completed in 2010. In areas supplied by NER substations, temporary over-voltages experienced by the arresters increased significantly when the areas were changed from an effectively earthed to resistance earthed system. The 'unacceptable' surge arresters were particularly prone to failure due to the extra phase to earth voltages experienced under fault conditions. These surge arresters were actively identified and replaced prior to commissioning. To mitigate the bushfire risk from surge arrester failure as a result of the deployment of NER's in the HBRA, the policy of replacing unacceptable surge arresters has been actively pursued.

The use of Ground Fault Neutraliser (GFN) technology to further mitigate bushfire risk by reducing phase to earth fault current has further implications for the performance of surge diverters under fault conditions. Surge diverters installed along the feeders associated with zone substations where a GFN is installed requires that surge diverters are able to withstand high phase to earth voltages for a minimum duration of 30 seconds under fault conditions. In preparation for the implementation of GFN systems new surge arrester specifications were necessary. The current specification for surge diverters of 22kV Class A and 22kV Class C surge diverters meet this criterion.

4.12.4.4 *Existing Control*

HV distribution surge arresters are inspected as part of the standard asset inspection program. All poles and lines in the Hazardous Bushfire Risk Areas are inspected every 3 years, and in the Low Bushfire Risk Areas every 5 years. A thermal survey program of HV feeders is also performed cyclically to assist in the detection of potential failures before they occur.

Pro-active Replacement - A key objective of Jemena's Asset Management strategy focuses on maintaining network reliability and safety. The replacement of "unacceptable" surge arresters is related to successfully achieving this.

4.12.4.5 *Future Risks*

Resonant earthing technology provides a significant improvement in reducing the risk of bushfire start. As outlined in the JEN Strategic Planning Paper 'Adopting Fault Current Limiter Technology to Reduce the Risk of Bushfire Ignition', JEN has committed to establishing a program that will introduce resonant earthing technology to all new and high exposure bushfire zone substations over a period of 5 years. The deployment of resonant earthing technology for low exposure bushfire zone substations will be completed over the next 10 years.

Consequently, as indicated above, the specification of distribution surge diverters for use on the JEN has been modified to ensure they are matched to the changed operating conditions that exist when a GFN is installed. Proactive programs to replace surge diverters located in these areas will be required before a GFN can be commissioned.

4.12.5 LIFE CYCLE MANAGEMENT

The options available for asset lifecycle management reflect a trade-off between capital and operating expenditure. The aim is to achieve predictable and sustainable OPEX and CAPEX programs that manage the network risk and deliver improved safety outcomes that are associated with the replacement of unserviceable assets and the deployment of new technologies. The preferred asset lifecycle management option involves condition based replacement.

The strategy covers time based inspections followed by condition based maintenance and replacement, as well as in-service failure based reactive maintenance.

4.12.5.1 *Creation*

Distribution surge arresters are installed on the network in conjunction with new distribution substations, cable head poles and overhead conductors according to current JEN standards. They are also purchased with minimum stock levels designed to support the network development and maintenance requirements.

Currently JEN purchases one Class A (ABB Polim K21-70) and one Class C (AK Power CA 12/05.0D for 11kV and 6.6kV networks) distribution surge diverter.

Note: As of early 2015, the 22kV Class C TE Tyco surge arrester (TE BOW_DA1-27H-B7F0N0-I-212) is no longer being procured or installed on the JEN.

Three scenarios trigger the need to acquire and connect new surge arresters:

- Installation of new equipment requiring overvoltage protection;
- Replacement due to failure or damage; and
- As a part of routine maintenance as a result of overhead line inspection programs

The various types of distribution surge diverters are typically purchased under period contracts in accordance with the Distribution Construction Manual and equipment specification requirements. Incorporation of the elements of this document, particularly opportunities for future improvements, will determine the requirements of the plant specification.

Prior to the current contract arrangements 22kV Class A surge arresters were purchased from Cooper Power Systems (UHS2410Z0001). These surge arresters are compatible with GFN technology however the contract expired in 2012 and ABB won the new contract. 22kV Class C surge arresters were previously supplied by Siemens (3EK4 240-1CR4-ZM81). These were identified as not compatible with GFN technology and thus the new contract was awarded to Tyco for the supply of their TE BOW-DA1-27H-B7F0N0-I-212 Class C surge diverter.

The Class C 11kV surge arresters are still being supplied by AK Power Solutions with a model update from EQ10.5 to their CA 12/05.0D.

4.12.5.2 *Asset Operation and Maintenance*

There are four (4) life cycle management strategies applied to the operation and maintenance of JEN's distribution surge arresters:

- Asset Inspection;
- Preventative Maintenance;
- Reactive Maintenance; and
- Run to Failure.

4.12.5.2.1 Asset Inspection

As well as routine asset inspection programs, when opportunities arise such as repair of pole top structures, all surge arresters should be inspected to ensure that:

- Signs of tracking, cracks on porcelain or polymeric housing are reported;
- Earth lead disconnect devices (where fitted) are of the acceptable type and have not operated;
- Pressure relief device has not operated;
- Line and earth lead connections are secured;
- Bowthorpe fault indicators have not operated; and
- Bird and animal covers are fitted correctly with no bare HV exposed (except on cable head pole installations where there is an earth attachment point) and have not perished

Notifications are raised against each of the above listed criteria in accordance with the Asset Inspection Manual. Identification of “unacceptable” surge arresters are also raised as a notification and designated as requiring replacement under a proactive asset replacement program.

In addition to asset inspection infra-red (thermal) surveys are conducted on 1-2-3 year cycle and a notification will be raised to replace surge arrester based on these surveys for proactive replacement.

4.12.5.2.2 Preventative Maintenance

4.12.5.2.2.1 Proactive Replacement

A number of programs of proactive replacement of distribution surge arresters has occurred over the past 10 years to address various performance issues. In each case the targeted surge diverters have been replaced with the current standard polymeric surge arresters. The prime drivers for these replacement programs have been the replacement of “unacceptable” surge diverters in the HBRA and the replacement of distribution surge arresters that were not compatible with the roll out of NER's. – The Asset Inspection Manual (JEN MA 0500), defines a list of “unacceptable” surge arresters, and the suitable replacement devices dependent on location (within or outside of the HBRA).

“Unacceptable” arresters, are also shown in the document titled “HV Fuses & Surge Arresters Handbook”, and these are to be replaced to mitigate the public safety risk due to the potentially explosive nature of their failure mode.

When surge arresters are replaced, the following should be checked and modified if necessary.

4.12.5.2.2.1.1 ABB Surge Arrester TVI

Between 1997 and 1998, some arresters type MVK and MWK supplied by ABB were found to cause Television Interference (TVI). The problem was attributed to the use of a new type of resistor in the earth lead disconnect to replace parts that were no longer produced. When identified, all three surge arresters of this type shall be replaced.

4.12.5.2.2.1.2 Old ABB CHP Polymeric Surge Arresters – Horizontally Mounted

ABB CHP polymeric arresters are to be mounted on the correct bracket at an angle to ensure that the pollutants on the arresters will be washed and cleaned by rain. Horizontally mounted surge arresters and their mounting brackets are to be replaced when they are identified.

4.12.5.2.2.1.3 Surge Arresters on Transformers

For best protection, arresters on transformers are to be mounted directly on the tank. As an indication, for a separation of every metre between the arrester and the transformer, the residual voltage on the transformer can rise by 5kV.

For substations with arresters mounted on the pole top and some distance away from the transformer HV bushings, where opportunity exists, reposition the surge arresters downstream of the HV fuse on the transformer tank and adjacent to the transformer bushings.

4.12.5.2.2.1.4 *Surge Arrester Clearance on Cable Head Poles*

When surge arresters are replaced, the existing cluster brackets must be removed and new mounting brackets (Distribution Construction Manual SP9/7029/15) must be used to increase the phase to phase clearance of the arresters. If space is restricted, use an adaptor bracket arrangement (Drawing No SP17/115/38).

4.12.5.2.2.1.5 *Review Following a Fault on a Line*

If surge arrester disconnects have operated at an installation, they must be isolated to avoid TVI and the risk of feeder outage and replaced.

If an installation is known to have experienced a recent 66kV injection, then all three arresters are to be replaced regardless of their physical condition.

4.12.5.2.2.1.6 *Unacceptable Surge Arresters*

In 1997 a recommendation was made to initiate a program to replace “unacceptable” surge arresters which were displaying evidence of increased failure rates. There were brown porcelain, single vented grey porcelain and Cooper polymeric (early polymeric versions) types of surge arresters.

In 1999 the program to replace the “unacceptable” surge arresters was completed. At the time Bowthorpe surge arresters were installed as replacements. Subsequently, approximately 18 months after their installation it was found that the Bowthorpe HEB24 & EGB24 series of EDPM type polymeric surge arresters were failing. As a consequence these too were added to the “unacceptable” surge arrester list; refer to Table 4-101.

For visual identification of “unacceptable” arresters, refer to JEN MA 0500 - Asset Inspection Manual.

Table 4-101: Unacceptable Distribution Surge Arresters

Type	Comment
Brown Porcelain	Typically installed in the 50's and 60's when the feeders were constructed.
Grey porcelain	Exhibited elevated failure rates due to a fundamental design flaw.
Cooper Polymeric (1992 versions)	Identified with inadequate voltage ratings on stations where NERs are installed.
Bowthorpe HEB24 & EGB24	Failing due to a surface tracking problem caused by a build-up of air borne pollutants on sheds of the surge arresters

It is essential that all “unacceptable” surge arresters identified in the bushfire areas are replaced as priority items (within 12 weeks). In non-HBRA areas, the surge arresters are to be replaced during substation maintenance or as part of targeted replacement programs.

4.12.5.2.2.2 *Condition Based Replacement*

As distribution surge arresters are a component of HV overhead structures, inspection of surge arresters is conducted as part of the overhead line inspection program. Inspection criteria are documented in JEN MA 0500 - Asset Inspection Manual. Condition assessment of distribution surge arresters is conducted to identify defects in the electrical connections, evidence of tracking, cracks, splits and heavy build-up of pollution during which time notifications are raised for the rectification of defects or replacement of assets as identified.

The identification of defects and the raising of maintenance notifications against the distribution surge arresters is only possible via visual and physical inspection of the asset. Early identification and

replacement of damaged or failed surge arresters is crucial to maintain the overvoltage protection of distribution asset class. Ongoing asset inspections will identify any physical signs of asset failure before they occur. This is the preferred method of lifecycle management of distribution surge arresters.

4.12.5.2.3 Reactive And Corrective Maintenance

Surge arresters are not normally repaired as they are not maintainable.

Surge arresters are considered to be maintenance free. They have an expected useful life of 40 years provided they are correctly installed. No preventive maintenance is undertaken for this asset class.

4.12.5.2.4 Run to Failure

Run to failure is a replacement strategy typically employed on low cost / high volume and consumable assets, in which the consequence of failure is low; and spare asset and staff resources, including network response to resultant outages or replacement activity, can be promptly addressed at a relatively low cost.

From the data, since 2003 until December 2018, 123 sets of HV surge arresters have had notifications raised against them due to network incidents related to the following damage codes:

- Failed mechanical integrity (mechanical failure/deterioration);
- Failed required insulation level;
- Failed required mechanical support;
- Failed to carry load;
- Failed to contain insulating medium;
- Failed to provide lightning protection;
- Open circuit; and
- Short circuit.

These codes provide an indication of the manner in which surge arresters have failed in service or have failed electrically due to an over voltage event.

As surge arresters are a passive device that does not operate until a transient overvoltage event, it is hard to analyse a unit's condition apart from any visual abnormalities including surface tracking and cracks in the sheds.

4.12.5.3 Surge Arrester Forecast Replacement Volumes

Surge diverters are to be replaced at a rate aligned with historical expenditure which covers fault replacement and asset inspection notifications.

Table 4-102: Surge Arrester Forecast Replacement Volumes

Service Code	Surge Arresters	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RXD	Surge Diverter Replacement	16	16	16	16	16	15

The age profile of this group of assest reflects the large amount of work that has been done to rid the network of underspecified or unacceptable types of surge diverters. The vast majority of the remaining population are polymeric housed surge diverters which has addressed the risks associated with the explosive failure mode associated with porcelain surge diverter housings. Given that the

oldest surge diverters on the network are only 25 years old then it is not anticipated that large scale replacement programs will be needed for the next 10 to 15 years and replacement rates will remain modest and driven by the asset inspection programs.

4.12.5.4 Disposal

Surge arresters are not normally repaired they are always replaced after a surge arrester fault.

Surge arresters do not contain hazardous materials and should be disposed of in accordance with JEM PO 1600 – Scrap Materials Policy.

4.12.5.5 Spares

As part of criticality assessment consideration is given to appropriate levels of spare equipment. Spares requirements for critical assets are assessed by following Critical Spares Assessment Procedure (JEM AM PR 0015). It was determined that adequate spares are maintained at Tullamarine depot and stock holdings are managed by the Service and Projects team.

4.12.6 INFORMATION

Jemena's AMS provides a hierarchical approach to understanding the information requirement to achieve Jemena's business objectives at the Asset Class. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and Asset Class Strategy (ACS) all provide the context for and determine the information required to deliver an Asset Class's business.

The Electricity Distribution Asset Class manages the Jemena Electricity Network (JEN) to safely, efficiently and reliably deliver electricity to its customers.

From these business objectives, it is possible to identify at a high-level the business information systems' content required to support these objectives (Table 4-103).

Table 4-103: Distribution Surge Arresters Sub-Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Sources	Information	Externally Sourced Data
Operational Excellence <ul style="list-style-type: none">• Manage assets throughout their lifecycle in safe and environmentally responsible manner• Maintain assets in accordance with RCM principals• Maintain asset information/knowledge to enable efficient and effective decision making• Embed continuous improvement throughout asset lifecycle Customer <ul style="list-style-type: none">• Maintain our current service levels• Incorporate customer feedback in our decision making process Growth <ul style="list-style-type: none">• Acquire/install/maintain assets to meet future demand requirements People <ul style="list-style-type: none">• Maintain safe work environment	GIS/JEN Viewer <ul style="list-style-type: none">• Geospatial representation of the JEN Network• Asset attributes SAP <ul style="list-style-type: none">• Work schedule & status• Planned and corrective (faults) maintenance records• Asset inspection measurements• Financial information ECMS <ul style="list-style-type: none">• Asset Inspection Manual, inspection methods & criteria• Policies, procedures and guidelines• General asset audits/surveys not stored in SAP	<ul style="list-style-type: none">• Current cadastre (including land ownership) for JEN's geographical extent.• DELWP - HBRA and LBRA area boundaries• CFA for fires, warnings and restrictions, incidents• Emergency Management Common Operating Picture (EM-COP)• Aerial Imagery for JEN's geographical extent (NearMap)• Google 'Street View'• Melway• SAI global (Australian and International Standards)• ESV / ESC / AER for regulatory obligations	

<ul style="list-style-type: none"> Engage team leaders in assessment of new assets Training 	<ul style="list-style-type: none"> Incident investigations <p>Drawbridge</p> <ul style="list-style-type: none"> Standards Operations diagrams Line design manual Construction manual <p>SCADA/RTS</p> <ul style="list-style-type: none"> Outage Management System (OMS) & SCADA (DMS) Planned and Unplanned outages <p>JEN Analytics</p> <ul style="list-style-type: none"> Power quality data Energy consumption 	
---	---	--

Table 4-104 identifies the current and future information requirements to support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-104: Distribution Surge Arresters Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
Distribution surge arrester acquisition and application	<ul style="list-style-type: none"> Purchase specification (ECMS) Distribution Design Manual (ECMS) Distribution Construction Manual (ECMS) Period contracts (ECMS) Logistics system (SAP) 		<ul style="list-style-type: none"> High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.
Life cycle management: <ul style="list-style-type: none"> Asset identification Condition monitoring Condition assessment Replacement / retirement strategy Disposal 	<ul style="list-style-type: none"> Each asset identified by geospatial representation in GIS and equipment ID in SAP Asset Inspection Manual (ECMS) Maintenance plan (SAP) JEN Analytics (e.g. deteriorated neutral) Measurement record (SAP / ECMS) PM Notifications/Orders (SAP) Strategy detailed in this document GIS asset attributes: <ul style="list-style-type: none"> Asset status (e.g. existing/historical) Status (in service, isolated, out of commission) Manufacturer Model 	<ul style="list-style-type: none"> Surge arrester class Near real time updating of asset record Photos database of all failed assets Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
	<ul style="list-style-type: none"> - Rating - Voltage - Usage - Type - No of units - Earth Lead Disconnect Device - Feeder - Date Installed - Date Removed - Inspection Zone • Fault / failure records: <ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 		

Table 4-105 provides the information initiatives required to provide the future information requirements identified in Table 4-104. Included within this table is the risk to the Asset Class from not completing the initiative.

Information required to support asset strategies, performance and risks is recorded in SAP, Geographic Information System (GIS) and ECMS. Additional fault related data is available in the Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

Table 4-105: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information	Field collection of incomplete asset attribution and assets	High	Complete, Current, Attribution Accurate
Planned and responsive asset maintenance costs	Ability to see the maintenance costs for an asset or asset type	Medium	Complete, Current, Attribution Accurate, Consistent (GIS Asset ID to SAP Asset ID)
Network Performance Data	Ability to 'view' asset performance data from the GIS user interface or access an asset's historical performance data.	Medium	Complete, Current, Attribution Accurate, Consistent (GIS Asset ID to SAP Asset ID)
Improved Asset Attribution	Review of asset attribution fields to ensure attributes being collected are business specific	Medium	Attribution Accurate
Increased Timeliness	Latency between maintenance delivery and maintenance record capture decreased	High	Complete, Current, Attribution Accurate

4.13 AUTOMATIC CIRCUIT RECLOSERS SUB-ASSET CLASS

4.13.1 INTRODUCTION

This section includes information about the type, specifications, life expectancy and age profile of the ACR's in service across the JEN.

ACR's are self-contained light duty circuit breakers complete with overcurrent, earth fault and sensitive earth fault protection and automatic reclose functionality. They are typically used on the overhead sections of high voltage distribution feeders which have a high frequency of both permanent and transient faults.

Upon detecting a fault current greater than its programmed setting, the ACR will open and reclose automatically in order to attempt to restore supply. If the fault is permanent, the ACR will lock open after a pre-set number of reclose operations (rural 2-3, elsewhere 1) and isolate the faulted section of line from the remaining system. ACR's do not replace feeder circuit breakers but are an additional protection device.




Figure 4-71: Single Line Diagram of Distribution Feeder

Due to the high cost of ACR's, all ACR's are protected by surge diverters on both sides of the device, irrespective of whether it is located at a normally open (N/O) or normally closed (N/C) point on the network. For details, refer to JEN PR 0011 HV OH Switchgear & Cable Head Pole Surge Arrester Installation and Earthing Procedure. Table 4-106 shows the number of in service ACR's in the JEN network.

Table 4-106: Automatic Circuit Reclosers

Operating Voltage	2000-2002	2003-2005	2006-2008	2009-2011	2012-2014	2015-2018	Total
11kV	0	1	0	7	3	0	11
22kV	29	15	22	22	17	8	113
Total	29	16	22	29	20	8	124

4.13.2 ASSET PROFILE

4.13.2.1 Life Expectancy

As detailed in ELE PR 0012 – Network Asset Useful Lives Procedure, the applicable useful life for overhead line switchgear assets is 50 years.

The above procedure considers asset lives based on good industry practice and specific Jemena Electricity Network experience and represents the lives of assets at which end-of-life replacement will be considered. JEN has undertaken a number of reviews of asset useful lives with consulting agencies and held discussions with other Distribution Businesses to ensure assigned asset lives are realistic.

A number of ACR's have been replaced due to low SF6 gas pressure. These replacements are categorised as premature failures due to manufacturing defects and do not represent the typical life expectancy of an ACR.

4.13.2.2 Age Profile

ACR's have been installed in significant numbers since 2000. As at December 2018, there were 124 Whipp & Bourne (W&B) three phase ACR's in service on the network.




Figure 4-72: ACR Age Profile

4.13.2.3 Utilisation

ACR's are utilised on the JEN as remote controlled sectionalising circuit breakers. They provide remote control and data acquisition capabilities to the JEN Control and Dispatch Centre and automate the protection of targeted HV feeder segments. Their deployment has resulted in significant improvement to the overall performance of the JEN in terms of a number of network reliability measures. In conjunction with remote controlled HV switches they have made a significant contribution to the automation of the JEN and limited the impact of network outages on JEN's customers. The utilisation of these assets is very high. Typically an ACR is not in service for a day or two every four years as a result of maintenance activities. Faults with battery alarms, communications etc. are generally rectified within a couple of days, however these faults do not require that the ACR be taken out of service.

4.13.3 PERFORMANCE

4.13.3.1 Requirements

Unless otherwise specified, Automatic Circuit Reclosers shall be designed, manufactured and tested in accordance with the following Australian Standards (refer to Table 4-107):

Table 4-107: Relevant Australian Standards – ACR's

Standard	Title
AS 62271.1	Common specifications for High Voltage AC Switchgear and Control Gear standards
AS 62271.100	High-Voltage Switchgear and Control gear – Alternating current circuit-breakers
AS 62271.200	High Voltage Switchgear and Control gear – AC Metal Enclosed Switchgear and Control gear for rated voltages above 1kV up to and including 52kV

The ACR shall be designed and manufactured to achieve a service life of at least 50 years with minimum maintenance. The equipment must also be able to operate within the required performance parameters when exposed to climatic conditions in the state of Victoria.

W&B ACR's are designed with a vacuum interrupters for the arc interrupting process and the SF6 gas provides insulation of the live parts in the body of the unit. W&B ACR's are tested to meet a 150kV impulse withstand level at a pressure of 1bar (absolute).

4.13.3.2 Assessment

The performance of these assets is monitored via the asset inspection programs, both visual and infra-red. In addition there is a degree of on-line monitoring of ACR condition via the SCADA system, this includes gas pressure monitoring. Maintenance notifications are raised for any defect detected and these are used as inputs to the CBRM model.

Initial CBRM results for the current (Year 0) health index are shown in Figure 4-73. The total risk for all failure scenarios at Year 0 is calculated to be \$76k with a current failure rate of 3 per annum. These failures can range from a minor failure where maintenance work is required such as communications failure, to a major failure that includes replacement of the unit. The ACR's themselves have, to date, performed reliably with few significant failures.




Figure 4-73: Year 0 Health Index Profile, ACR's

If replacement is deferred until 2025 (Year 7) the health index changes as shown in Figure 4-74. Total risk for all failure scenarios at Year 7 is calculated to be \$98k with a predicted failure rate of 4 per annum at Year 7.




Figure 4-74: Year 7 Health Index Profile, ACR's

ACR's are critical to the control and operation of the distribution network. The failure of an ACR affects the networks ability to isolate and recover from network outages. Consequently the failure of an ACR has a large impact on network reliability and the associated risk is indicated in Figure 4-75.




Figure 4-75: Risk Profile for Year 0 & Year 7, ACR's

The CBRM modelling indicates that one (1) ACR is required to be replaced per annum over the coming 7 years to maintain the risk level at current (Year 0) levels. Assets identified as being in poor condition at Year 7 will be prioritised for replacement.

4.13.4 RISK

4.13.4.1 Criticality

Asset criticality is a measure of the risk of specified undesired events faced when utilising equipment. Asset criticality assessment was conducted at sub-asset class level by following the Asset Criticality Assessment Procedure (JEM AM PR 0016). Results of this assessment are presented in Appendix A. The asset criticality score was then utilised to rank critical assets which have the potential to significantly impact on the achievement of Jemena's operational objectives. This is used to rank importance of dissimilar sub-asset classes (e.g. transformers and buildings and grounds) to identify areas where risk should be managed first and control measures implemented.

ACR's has an asset criticality score of AC1 (Low) due to the consequence rating being minor. Consequence of ACR failure may include SF6 gas leaks, cost of replacing failed/damaged asset and STPIS impact.

4.13.4.2 Failure Modes

There are several possible failure modes for ACR's which are summarised below:

- Fail to operate – either trip or close, possibly due to seized mechanism or worn components;
- Fail to interrupt – responds to signal but does not interrupt current, can be due to slow or incomplete operation, badly eroded contacts, ineffective insulation medium; could lead to thermal overheating and explosive failure;
- Fail to carry load – due to deteriorated or high resistance internal components; could lead to thermal overheating and explosive failure;
- Overheating- due to high resistance external connections/components; could lead to thermal overheating and damage;

- Insulation breakdown- internally, due to contamination or lack of SF6 or lightning impulse greater than LIWL rating, externally, bushing failure; and
- Auxiliary components failure- items such as auxiliary supply transformers, CTs protection relays, controllers, battery, radio and communication systems.

Whipp & Bourne (W&B) are the manufacturers of all of the ACR's installed on JEN. These ACR's employ vacuum interrupters for interrupting fault and load currents. The vacuum interrupters are housed in a controlled environment filled with SF6 gas. This gas facilitates the compact design of the ACR. All units are equipped with Schweitzer SEL electronic control relays.

With the exception of some issues with SF6 gas loss, the ACR's are generally very reliable devices with no evidence of field failure in the past.

For details of the risk assessment, refer to the relevant section in Jemena Risk and Compliance System (JCARS).

4.13.4.3 *Current Risks*

This section provides information about ACR's, as well as general information about other potential issues. For details of the risk assessment, refer to relevant section in Jemena's Compliance and Risk System (JCARS).

4.13.4.3.1 SF6 Gas Loss

In recent years, there has been a trend of the SF6 pressure levels declining in the ACR units. W&B are aware of the loss of SF6 gas however their investigations have been unable to determine the cause of the leak. Since the SF6 gas is involved in the arc interrupting process, minor reduction in SF6 gas pressure does not pose an immediate problem to the reliable operation of the unit. The SF6 pressure level for all in-service ACR's is monitored remotely via alarms in the SCADA system and the gas pressure data is analysed every quarter.

4.13.4.3.2 Sympathy Tripping

A small number of instances of sympathy tripping have occurred with the existing population of ACR's where an adjacent feeder to a faulted feeder has incorrectly tripped due to the capacitive currents associated with underground cables. This is currently unavoidable as the protection system is not directional or designed to differentiate sympathy trips to actual faults on the network.

4.13.4.4 *Existing Control*

Automatic Circuit Reclosers are inspected as part of the standard asset inspection program. All poles and lines in the HBRA are inspected every 3 years, and in the LBRA every 5 years. A thermal survey of HV fuses is also performed to assist in the detection of potential failures before they occur and is aligned with the regular overhead line thermal survey cycle.

4.13.4.5 *Future Risks*

ACR's from various manufacturers are currently under review with a preference for a unit that provides directional sensitive earth fault protection as this extra functionality will address the issue of sympathy tripping (refer to paragraph above). There is also a preference for an ACR that does not utilise SF6 gas as this would eliminate the current maintenance issues associated with the gas loss and be consistent with Jemena's desire to reduce the use of SF6 wherever possible given its properties as a greenhouse gas.

AS 61850 is new standard communications protocol for the interface of power system elements and intelligent electronic devices (IED's) and is currently being evaluated prior to adoption on JEN. As

such an AS 61850 compatible device will facilitate the future integration of these devices into a smart network.

4.13.5 LIFE CYCLE MANAGEMENT

The options available for asset lifecycle management reflect a trade-off between capital and operating expenditure. The aim is to achieve predictable and sustainable OPEX and CAPEX programs that manage the network risk and deliver improved safety outcomes that are associated with the replacement of unserviceable assets and the deployment of new technologies. The preferred asset lifecycle management option involves condition based replacement.

The strategy covers time based inspections followed by condition based maintenance and replacement, as well as in-service failure based reactive maintenance.

4.13.5.1 *Creation*

ACR's are deployed on JEN to facilitate the automation of the network and to maintain network reliability and address network performance issues. Installation of ACR's is driven by the identification and quantification of localised network reliability problems. They are sited so as to facilitate the sectionalisation of the HV network and to provide relief to underperforming parts of the HV distribution network. They are pole mounted devices where the majority of network faults occur and as such are an important part of the HV overhead distribution network. Currently there are no similar devices deployed for the underground portion of the network.

4.13.5.2 *Asset Operation and Maintenance*

There are four (4) life cycle management strategies applied to the operation and maintenance of JEN's ACR's:

- Asset Inspection and Condition Monitoring;
- Preventative Maintenance; and
- Reactive and Corrective Maintenance.

A run to failure replacement strategy is not appropriate for ACR's as an in service failure can have a large impact on network reliability and result in potential health and safety consequences.

4.13.5.2.1 *Asset Inspection and Condition Monitoring*

Inspection of ACR's is carried out as part of the standard asset inspection program. All poles and lines in the HBRA are inspected every 3 years, and in the LBRA every 5 years. A thermal survey of each ACR is also performed to assist in the detection of potential failures before they occur and is aligned with the regular overhead line thermal survey cycle.

For details of the activities involved in the inspection program, refer to the JEN MA 0500 - Asset Inspection Manual.

The gas pressure level for all in-service ACR's is monitored remotely via alarms in the SCADA system and the gas pressure data is analysed every quarter.

ACR duty levels are also monitored. The vacuum interrupter's operating life is mainly dependent upon the number and magnitude of short-circuit operations. W&B estimates the life of the vacuum interrupter to be at least 20 years from the date of manufacture and the recommended maximum number of light load current switching operations to be 30,000. For details, refer to the manufacturer's manual.

The contact wear of the vacuum interrupter is calculated by accumulating the duty of the ACR which is remotely monitored and an alarm is triggered in SCADA when it reaches 100%. The ACR's are not expected to reach their duty threshold during the operating life of the ACR.

4.13.5.2.2 Preventative Maintenance

4.13.5.2.2.1 Condition Based Replacement or Refurbishment

ACR's are replaced on condition as determined by inspection and the monitoring of SF6 gas pressure. When an ACR is found to have low gas pressure it is replaced with a spare ACR and the "low gas" ACR is returned to the manufacturer (if it is still under warranty - within 12 months) or inspected in the JEN workshop where the leak will be rectified before it is stored as a spare unit.

4.13.5.2.2.2 Proactive Replacement

There is no proactive condition based replacement of ACR's planned, as there are no known indicators of systemic or age related failure. There is however, a plan to replace the protection systems associated with the ACR's so as to address the risk of sympathy tripping and implement directional earth fault protection on these devices. This may involve the replacement of the entire ACR rather than just the protection and control. The proposed volumes and associated capex are included in the forecast replacements listed below.

4.13.5.2.3 Reactive and Corrective Maintenance

As indicated above SF6 pressure levels in ACR's are remotely monitored as part of condition monitoring. Where the gas pressure of an ACR has dropped below 1bar (absolute), the unit is replaced / swapped with a spare ACR and the defective unit is taken to the JEN workshop and re-gassed.

W&B ACR's are fully enclosed and designed to be a maintenance free unit. With the exception of the SF6 gas loss, the ACR's are generally very reliable devices with no evidence of field failure in the past.

4.13.5.3 ACR Forecast Replacement Volumes

The forecast replacement volumes indicated in Table 4-108 are based on the output of the CBRM modelling and the maintenance of network reliability. In addition the volumes associated with the implementation of directional protection and control systems are included.

Table 4-108: Forecast Replacement Volumes – ACR's

Service Code	Remote Controllable ACRs	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RHH	ACR Replacement (Fault)	-	1	1	1	1	1
RHH	ACR Replacement (Directional E/F)	4	6	6	7	7	7

4.13.5.4 Asset Disposal

ACR's have not been disposed of to date. They are generally stored in a workshop and used for testing or salvaged for spare parts. Faulty or defective ACR's should be repaired where it is economically practical.

Procedures for handling, storing and disposing of SF6 gas are detailed in accordance with JAM PR 0060 WI 16 – SF6 Gas – Identification, Storage, Handling and Disposal.

4.13.5.5 Spares

The lead time to order a new ACR is approximately six months however there is a spare (refurbished) ACR available at Tullamarine depot. The probability of an in service ACR failure is extremely low and there is no historical evidence of this occurring.

4.13.6 INFORMATION

Jemena's AMS provides a hierarchical approach to understanding the information required to achieve Jemena's business objectives at the Asset Class level. In summary, the combination of Jemena's Business Plan, the individual Asset Business Strategy (ABS) and the Asset Class Strategy (ACS) all provide the context for and determine the information required to manage and operate an Asset Class.

The Electricity Distribution Asset Class Strategy facilitates the safe, efficient and reliable delivery of electricity to JEN's customers.

From these business objectives, it is possible to identify at a high-level the content of the business information systems required to support these objectives (Table 4-109).

Table 4-109: Automatic Circuit Reclosers Sub-Asset Class Business Objectives and Information Requirements

Business Objectives	Jemena Sources	Information	Externally Sourced Data
Operational Excellence <ul style="list-style-type: none">• Manage assets throughout their lifecycle in safe and environmentally responsible manner• Maintain assets in accordance with RCM principals• Maintain asset information/knowledge to enable efficient and effective decision making• Embed continuous improvement throughout asset lifecycle Customer <ul style="list-style-type: none">• Maintain our current service levels• Incorporate customer feedback in our decision making process Growth <ul style="list-style-type: none">• Acquire/install/maintain assets to meet future demand requirements People <ul style="list-style-type: none">• Maintain safe work environment• Engage team leaders in assessment of new assets• Training	GIS/JEN Viewer <ul style="list-style-type: none">• Geospatial representation of the JEN Network• Asset attributes SAP <ul style="list-style-type: none">• Work schedule & status• Planned and corrective (faults) maintenance records• Asset inspection measurements• Financial information ECMS <ul style="list-style-type: none">• Asset Inspection Manual, inspection methods & criteria• Policies, procedures and guidelines• General asset audits/surveys not stored in SAP• Incident investigations Drawbridge <ul style="list-style-type: none">• Standards• Operations diagrams• Line design manual• Construction manual SCADA/RTS <ul style="list-style-type: none">• Outage Management System (OMS) & SCADA (DMS)	<ul style="list-style-type: none">• Current cadastre (including land ownership) for JEN's geographical extent.• DELWP - HBRA and LBRA area boundaries• CFA for fires, warnings and restrictions, incidents• Emergency Management Common Operating Picture (EM-COP)• Aerial Imagery for JEN's geographical extent (NearMap)• Google 'Street View'• Melway• SAI global (Australian and International Standards)• ESV / ESC / AER for regulatory obligations	

Business Objectives	Jemena Sources	Information	Externally Sourced Data
	<ul style="list-style-type: none"> Planned and Unplanned outages JEN Analytics <ul style="list-style-type: none"> Power quality data Energy consumption 		

Table 4-110 identifies the current and future information requirements to support the Asset Class's critical decisions and their value to the Asset Class.

Table 4-110: Automatic Circuit Reclosers Critical Decisions Business Information Requirements

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
Automatic Circuit Recloser acquisition and application	<ul style="list-style-type: none"> Purchase specification (ECMS) Distribution Design Manual (ECMS) Distribution Construction Manual (ECMS) Period contracts (ECMS) Logistics system (SAP) 		<ul style="list-style-type: none"> High – strict control of quality of supplied poles and detailed, repeatable installations appropriate to application.
Life cycle management: <ul style="list-style-type: none"> Asset identification Condition monitoring Condition assessment Replacement / retirement strategy Disposal 	<ul style="list-style-type: none"> Each asset identified by geospatial representation in GIS and equipment ID in SAP Asset Inspection Manual (ECMS) Maintenance plan (SAP) JEN Analytics (e.g. deteriorated neutral) Measurement record (SAP / ECMS) PM Notifications/Orders (SAP) Strategy detailed in this document GIS asset attributes: <ul style="list-style-type: none"> Asset status (e.g. existing/historical) Status (in service, isolated, out of commission) Type/Manufacturer Switch No. Operating State Normal State Physical Location (Melway reference, closest address / intersection) 	<ul style="list-style-type: none"> Lantern model Near real time updating of asset record Photos database of all failed assets Appropriate fault/failure data by failure mode (e.g. material degradation, age, workmanship, third party etc) 	<ul style="list-style-type: none"> High – allows more accurate, efficient management of assets through performance trends and cost monitoring

Critical Business Decision	Current Information Usage	Future Information Requirement	Value to Asset Class (High, Medium, Low with justification)
	<ul style="list-style-type: none"> - Operational Tag - Controller Type • Fault / failure records: <ul style="list-style-type: none"> - Root Cause • Performance trends (shared network drive) • Customers impact • Maintenance costs (SAP) • Disposal procedure 		

Table 4-111 details the information initiatives required to provide the future information requirements identified in Table 4-110. Included within this table is the risk to the Asset Class from not completing the initiative.

Information required to support asset strategies, performance and risks is recorded in SAP, Geographic Information System (GIS) and ECMS. Additional fault related data is available in the Outage Management System (OMS). Data from SAP can be extracted and analysed using SAP Business Objects.

Table 4-111: Information Initiatives to Support Business Information Requirements

Information Initiative	Use Case Description	Asset Class Risk in not Completing	Data Quality Requirement
Improved asset information	Field collection of incomplete asset attribution and assets	High	Complete, Current, Attribution Accurate
Planned and responsive asset maintenance costs	Ability to see the maintenance costs for an asset or asset type	Medium	Complete, Current, Attribution Accurate, Consistent (GIS Asset ID to SAP Asset ID)
Network Performance Data	Ability to 'view' asset performance data from the GIS user interface or access an asset's historical performance data.	Medium	Complete, Current, Attribution Accurate, Consistent (GIS Asset ID to SAP Asset ID)
Improved Asset Attribution	Review of asset attribution fields to ensure attributes being collected are business specific	Medium	Attribution Accurate
Increased Timeliness	Latency between maintenance delivery and maintenance record capture decreased	High	Complete, Current, Attribution Accurate

5 CONSOLIDATED PLAN

This chapter provides the following information for each sub-asset class:

- Capital requirements;
- Operational requirements; and
- Expenditure assessment and recommendation.

Implementation of this Asset Class Strategy is achieved using the following tools and resources;

- Jemena's SAP system is used to:
 - Provide an asset register;
 - Facilitate scheduling of both Operational and Capital works;
 - Record the cost of works against assets;
 - Enable the reporting of work progress and costs;
 - Record defects and schedule repairs; and
 - Record asset condition monitoring results.
- Services and Projects:
 - Provides the field work force and associated organisation required to deliver the activities as defined by Asset Management, and documented in the Asset Investment Plan (AIP) ELE AM PL 0012 and Capital and Operational Work Plan (COWP) ELE PL 0102.
- Project Management Methodology:
 - All projects and programs of work are controlled utilising a standardised Project Management Methodology. Procedures are detailed in the Project Management Procedure JEM PMM PR 2500.
- Project Ranking:
 - An internal business process is used to rank projects that are proposed for inclusion in the annual capital works program. This process forms part of a framework for the application of specific risk management techniques and methodologies to the development of the wider program of capital works.

JEN looks at the specific asset class drivers for the particular capital/operational programs, including identifying the consequences of not completing the proposed volumes of work. The volumes of work required and associated capital and operational expenditure ensure that the consequences identified in the “Specific Drivers” tables (Section 5.2) associated with each sub-asset class are addressed to maintain network performance and manage risk.

The replacement volumes are derived using knowledge of:

- The proactive replacement programs planned to address known asset performance issues;
- The historic rates of asset replacement;
- The failure trends and factors effecting asset life;
- Asset age profiles and condition indicators;

- The results of the use of models designed to assist with the forecasting of asset replacement rates required to maintain asset integrity, manage risk and address the asset class specific drivers; and
- The regulatory requirements.

5.1 CAPITAL FORECAST

5.1.1 POLES SUB-ASSET CLASS

In response to the drivers listed in Section 5.2.1, the ongoing capital replacement of poles, based upon their condition, is required to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-1 lists the programs and their associated forecast pole replacement and reinstatement volumes for poles from 2020 to 2025.

Table 5-1: Forecast Replacement Volumes – Poles

Service Code	Poles	Replacement Volumes – Poles					
		CY20	CY21	CY22	CY23	CY24	CY25
RPH	Pole Repl. (Incl. Pole Top) - HV	51	45	45	45	45	45
RPH	Pole Repl. (Incl. Pole Top) - HV - HBRA	-	5	5	5	5	5
RPL	Undersize Pole Replacement	32	65	65	65	65	65
RPL	Pole Repl. (Incl. Pole Top) - LV	80	76	76	76	76	76
RPS	Pole Repl. (Incl. Pole Top) - ST	7	5	5	5	5	5
RPS	Pole Repl. (Incl. Pole Top) - ST - HBRA	-	4	4	4	4	4
RRH	Pole Reinforcement - HV	159	151	151	157	164	157
RRL	Undersize Pole Reinforcement	-	366	443	443	443	366
RRL	Pole Reinforcement - LV	392	373	373	375	376	375
RRS	Pole Reinforcement - ST	40	38	38	38	38	38

Table 5-2 lists the forecast capital expenditure (CAPEX) for poles from 2020 to 2025 associated with the volumes listed above.

Table 5-2: Forecast Capital Expenditure 2020-2025 – Poles

Service Code	Poles	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RPH	Pole Repl. (Incl. Pole Top) - HV	1,043	848	844	855	882	888
RPH	Pole Repl. (Incl. Pole Top) - HV - HBRA	-	89	89	90	92	93
RPH	Undersize Pole Replacement	-	706	703	712	729	734
RPL	Pole Repl. (Incl. Pole Top) - LV	1,024	832	828	840	854	860
RPS	Pole Repl. (Incl. Pole Top) - ST	247	202	201	203	206	207
RPS	Pole Repl. (Incl. Pole Top) - ST - HBRA	-	89	88	89	91	92
RRH	Pole Reinforcement - HV	261	212	210	212	234	235
RRH	Undersize Pole Reinforcement	-	384	585	591	603	605
RRL	Pole Reinforcement - LV	612	496	491	496	509	510

Service Code	Poles	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RRS	Pole Reinforcement - ST	82	66	65	66	68	69
	Total	3,269	3,924	4,104	4,154	4,268	4,293

These forecasts are based on unit rates used during the estimation process undertaken as part of the standard Jemena Project Management Methodology.

All capital requirements are identified above for the next 7 years. We employ a condition based approach to the replacement and refurbishment of Poles, but use a combination of age and condition to forecast volume of replacements required. Poles that are deemed unserviceable are either staked (reinforced) or replaced. The condition of the pole is the primary driver for staking or replacement. The decision to either stake or replace a pole is based on condition using defined criteria outlined in the AIM. Poles that have previously been staked and have further deteriorated so that it is no longer safe for the pole to remain in service are also replaced. JEN requires that unserviceable poles are actioned within 12 weeks of identification.

Other options considered, but not recommended, as they are less effective and more expensive include:

- Inspection and treatment plus budget constrained replacement levels. This increases the backlog of replacements (Limited Life), creating an increasing failure risk and transferring escalating expenditure to future years. Increased reactive replacements and increased costs are very likely;
- Inspection and treatment plus replacement of all poles classified as unserviceable(US). This incurs much higher costs than life-extending staking;
- Age based replacement. As pole life is extremely variable, to select an age to replace poles would need to be conservative to try and minimise the risk of in-service pole failures; thus many poles would be replaced when significant life remaining with associated greatly increased costs; and
- Run-to-failure. This approach involves excessive risks for safety and customer service plus increased costs associated with large numbers of reactive emergency pole replacements.

Beyond 2026, based on the the assessment of performance demonstrated in Section 4.1.5.1, both the age profile and CBRM analysis of Health Index and risk value, show a dramatically increasing proportion of assets will be in end of life phase, even after replacements and reinforcements are completed in the next few years. Therefore it can be expected that continuing increased investment will be required in the longer term.

5.1.2 POLE TOP STRUCTURES SUB-ASSET CLASS

Based on the drivers listed in Section 5.2.2, a number of programs have been identified to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-3 lists these programs and their associated forecast replacement volumes for pole top structures from 2020 to 2025.

Table 5-3: Forecast Replacement Volumes - Pole Top Structures

Service Code	Pole Top Structures	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RXG	ST Insulators Replacement	10	10	10	10	10	10
RXI	HV Insulators Replacement	51	49	49	49	49	49
RXH	HV Crossarm Replacement	380	362	362	364	365	364
RXH	Pole top fire mitigation	586	459	459	459	459	459
RXL	LV Crossarm Replacement	526	606	606	606	606	606

Service Code	Pole Top Structures	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RXS	ST Crossarm Replacement	20	19	19	20	21	20
PDS	Bird/Animal Proofing Net Assets	13	18	18	18	18	18

Table 5-4 lists the forecast CAPEX for pole top structures from 2020 to 2025, based on the volumes listed above.

Table 5-4: Forecast Capital Expenditure from 2020 to 2025 – Pole Top Structures

Service Code	Pole Top Structures	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RXG	ST Insulators Replacement	21	19	18	19	19	19
RXI	HV Insulators Replacement	109	89	89	90	93	94
RXH	HV Crossarms Replacement	1,820	1,481	1,476	1,499	1,548	1,560
RXH	Pole top fire mitigation	3,257	1,876	1,870	1,899	1,947	1,962
RXL	LV Crossarm Replacement	1,622	1,981	1,976	2,009	2,061	2,080
RXS	ST Crossarm Replacement	209	173	170	172	197	198
PDS	Bird/Animal Proofing Net Assets	17	34	34	35	35	36
	Total	7,055	5,653	5,633	5,723	5,900	5,949

These forecasts are based on unit rates used during the estimation process undertaken as part of the standard Jemena Project Management Methodology.

All capital requirements are identified above for the next 7 years. We employ a condition based approach to the replacement of pole top structures, but use a combination of age and condition to forecast the volume of replacements required.

Other options considered, but not recommended, as they are less effective and more expensive include:

- Budget constrained replacement levels. This increases the backlog of replacements, creating an increasing failure risk and transferring escalating expenditure to future years. Increased reactive replacements and increased costs are very likely;
- Age based replacement. As pole top assets, particularly wood cross arms' life is extremely variable, to select an age to replace cross arms would need to be conservative to try and minimise the risk of in-service failures; thus many assets would be replaced with significant life remaining with associated greatly increased costs; and
- Run-to-failure. This approach involves excessive risks for safety and customer service plus increased costs associated with large numbers of reactive emergency pole top replacements

Beyond 2026, based on the the assessment of performance demonstrated in Section 4.2.3.2, both the age profile and CBRM analysis of Health Index and risk value, show an increasing proportion of assets will be in end of life phase, even after replacements are completed in the next few years. At present an estimated 42% of ST/HV wood crossarms and 33% of wood LV cross arms are beyond their nominal useful life. Therefore it can be expected that a similar level of investment will be required for ST/HV crossarms and an increased investment (more than double) will be required for LV cross arms in the longer term.

5.1.3 CONDUCTORS AND CONNECTORS SUB-ASSET CLASS

Based on the drivers listed in Section 5.2.3, a number of programs have been identified to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-5 lists these programs and their associated forecast replacement volumes for conductors and connectors from 2020 to 2025.

Table 5-5: Conductors and Connectors Forecast Replacement Volumes

Service Code	Conductors and Connectors	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
PDA	Ampact Connectors	95	95	95	95	94	95
PDB	Ampact Switch Lugs and Connection	59	60	60	64	68	64
PDH	HV Line Clash Mitigation	15	12	12	12	12	12
PDL	LV Line Clash Mitigation	15	12	12	12	12	12
ROH	HV Open Wire Conductor Repl. (km)	3	3	3	3	3	3
ROH	Steel Conductor Repl. (km)	-	-	-	3	4	-
ROL	LV Open Wire Conductor Repl. (km)	3	3	3	3	3	3
ROL	Electric Line Clearance Solutions	1	1	2	2	2	2
ROL	LV Mains Removal in HBRA (km)	-	8	8	8	8	8
ROH	Vibration Dampers and Armour Rods	271	-	-	-	-	-

Table 5-6 lists the forecast CAPEX for conductors and connectors from 2020 to 2025, based on the volumes listed above.

Table 5-6: Forecast Capital Expenditure from 2020 to 2025 – Conductors and Connectors

Service Code	Conductors and Connectors	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
PDA	Ampact Connectors	79	71	70	72	73	74
PDB	Ampact Switch Lugs and Connection	49	44	44	45	53	53
PDH	HV Line Clash Mitigation	51	33	33	33	34	35
PDL	LV Line Clash Mitigation	9	6	6	6	6	6
ROH	HV Open Wire Conductor Repl	546	469	468	401	488	493
ROH	Steel Conductor Repl	-	-	-	487	500	-
ROL	LV Open Wire Conductor Repl	498	405	404	410	423	426
ROL	Electric Line Clearance Solutions	134	306	305	310	317	320
ROL	LV Mains Removal in HBRA	-	1,136	1,132	1,149	1,178	1,187
ROH	Vibration Dampers and Armour Rods	110	-	-	-	-	-
	Total	1,476	2,470	2,462	2,913	3,072	2,594

These forecasts are based on unit rates used during the estimation process undertaken as part of the standard Jemena Project Management Methodology

The removal of LV Mains in the HBRA will:

- Be a cost effective way of reducing customer's exposure to bushfire risk;

- Progressively remove all bare LV mains conductors and substitute with alternative LV distribution solutions such as ABC (aerial bundled conductor), underground cable and additional transformers; and
- At the same time, LV wooden cross-arms will be removed, reducing Jemena's need to maintain these aging assets as well as further reducing the exposure to bushfire starts through falling conductors.

Furthermore:

- The proposed works are a logical progression from the removal of SWER systems, replacement of all HV wooden crossarms, replacement of all non-tension conductor connections and replacement of non-preferred overhead services in the HBRA; and
- The program has commenced with the removal of 1.5km of LV mains in Sunbury, Bulla, Gisborne, Gisborne South and Meadow Heights.

The implementation of this program will further reduce the risk of fire ignition associated with electricity assets in the HBRA, therefore enhancing customer safety and avoiding damage to customer property.

Beyond 2025, based on the the assessment of performance demonstrated in Section 4.2.3.2, the age profile, where presently approximately 2% of conductors are beyond nominal useful life, show a increasing proportion of assets will be in end of life phase, even after replacements are completed in the next few years. In 10 years time approximately 17% of conductors will be beyond nominal useful life. Therefore it can be expected that continuing increased investment will be required in the longer term.

5.1.4 UNDERGROUND DISTRIBUTION SYSTEMS SUB-ASSET CLASS

Based on the drivers listed in Section 5.2.4, a number of programs have been identified to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-7 lists these programs and their associated forecast replacement volumes from 2020 to 2025.

Table 5-7: Underground Distribution Systems Forecast Replacement Volumes

Service Code	Underground Distribution Systems	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RUA	HV U/G Cable Replacement (m)	952	1,228	1,228	1,233	1,239	1,233
RUA	Replace Metal Trifurcating Boxes	6	6	6	6	6	6
RUC	LV U/G Cable Replacement (m)	385	363	363	365	365	365
RUF	Pillar to Pillar	5	5	5	5	5	5
RUH	HV U/G Termination Replacement	15	14	14	14	14	14
RUL	LV U/G Termination Replacement	47	45	45	44	44	44
RUS	ST U/G Cable Replacement - BTS-FF Oil Filled Cables (m)	505	-	-	-	-	-

Table 5-8 lists the forecast CAPEX from 2020 to 2025, based on the volumes above.

Table 5-8: Forecast Capital Expenditure from 2020 to 2025 – Underground Distribution Systems

Service Code	Underground Distribution Systems	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RUA	HV U/G Cable Replacement	622	1,010	1,004	1,016	1,048	1,053
RUA	Replace Metal Trifurcating Boxes	286	271	270	273	279	280
RUC	LV U/G Cable Replacement	303	242	240	244	251	252
RUF	Pillar to Pillar	58	47	47	47	48	48
RUH	HV U/G Termination Replacement	325	253	252	255	260	261
RUL	LV U/G Termination Replacement	311	253	251	255	259	260
RUS	ST U/G Cable Replacement - BTS-FF Oil Filled Cables	943	-	-	-	-	-
	Total	2,848	2,076	2,064	2,090	2,145	2,154

These forecasts are based on unit rates used during the estimation process undertaken as part of the standard Jemena Project Management Methodology.

Where cables have multiple faults within a short period of time, they are considered for replacement as this demonstrates a reduction in the integrity of the cable system. These projects are forecast to be consistent with historical replacement levels. Cable terminations and pillar to pillar replacements are also projected to be consistent with historical replacement levels.

A safety driven project relating to the replacement of trifurcating boxes (11kV HV CABUS) has been identified for the next 6 years. This will lead to the removal of the associated safety issue over the longer term.

Beyond 2025, once the safety related cable terminations and specific ST PL oil cable projects are completed it is expected that a level of investment will be required in the longer term similar to the historical level.

5.1.5 POLE TYPE TRANSFORMERS SUB-ASSET CLASS

Based on the drivers listed in Section 5.2.5, a number of programs have been identified to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-9 lists these programs and their associated forecast replacement volumes for pole type transformers from 2020 to 2025.

Table 5-9: Forecast Replacement Volumes - Pole Type Transformers

Service Code	Pole Type Transformers	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RHA	Transformer Pole Mounted	22	22	21	22	23	22
RHA	Transformer Platform Rectification	-	10	10	10	10	10

Table 5-10 lists the forecast CAPEX for pole type transformers from 2020 to 2025, based on the volumes above.

Table 5-10: Forecast Capital Expenditure from 2020 to 2025 – Pole Type Transformers

Service Code	Pole Type Transformers	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RHA	Trans Pole Mounted Replacement	282	247	245	229	270	271
RHA	Transformer Platform Rectification	-	866	860	870	889	893
	Total	282	1,113	1,105	1,099	1,159	1,164

These forecasts are based on unit rates used during the estimation process undertaken as part of the standard Jemena Project Management Methodology.

When transformers are removed from service for reasons other than defect repair, such as load growth, load decrease, noise, redundancy or maintenance, they are assessed using the criteria set out in the Distribution Transformer Refurbishment Policy – ELE PO 0600. Transformers that satisfy the criteria shall be refurbished and returned to stock for future use.

Apart from safety and regulatory driven proactive transformer platform replacements; the above replacement projections are based on asset condition end-of-life estimates, in line with historical performance.

Another option is to replace based on expected useful life; however it is anticipated many assets will be replaced with some remaining life not utilised. As risks associated with transformer failure are low, this is a more expensive option.

The data on pole type transformer age profile (section 4.5.3.2) indicates that approximately 6% of all pole transformers are beyond their nominal useful life and that an increasing proportion of these assets will be in the end of life phase, even after replacements are completed over the next few years. The CBRM analysis indicates that 28 transformer replacements p.a. are required to maintain risk at current levels. Therefore, beyond 2026 it can be expected that increased investment (triple) will be required in the longer term to manage risk levels.

5.1.6 NON-POLE TYPE DISTRIBUTION SUBSTATIONS SUB-ASSET CLASS

Based on the drivers listed in Section 5.2.6, a number of programs have been identified to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-11 lists these programs and their associated forecast replacement volumes for non-pole type distribution substations from 2020 to 2025.

Table 5-11: Forecast Replacement Volumes - Non Pole Type Distribution Substations

Service Code	Non-Pole Type Distribution Substations	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RHD	Transformer Ground/Indoor	10	10	10	9	9	9
RHE	Indoor/Kiosk Switchgear, RMU Age & Fault Replacement	3	9	6	6	6	3
RHK	Transformer/Substation Failure Kiosk	11	11	11	11	11	11
RHM	Kiosk Refurbishment	16	12	12	12	12	12
RHF	LV Switchgear Replacement	2	1	1	2	2	2

Table 5-12 lists the forecast CAPEX for non-pole type distribution substations from 2020 to 2025, based on the volumes above.

Table 5-12: Forecast Capital Expenditure from 2020 to 2025 – Non Pole Type Distribution Substations

Service Code	Non-Pole Type Distribution Substations	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RHD	Trans Ground/Indoor Replacement	306	256	254	257	261	263
RHE	Indoor/Kiosk Switch Replacement	107	360	239	242	247	124
RHK	Transformer/Subs Kiosk Failure Replacement	29	24	24	24	31	32
RHM	Kiosk Refurbishment	365	312	310	313	318	319
RHF	LV Switchgear Replacement	176	144	143	146	151	152
	Total	983	1,096	970	982	1,008	890

These forecasts are based on unit rates used during the estimation process undertaken as part of the standard Jemena Project Management Methodology.

The forecast transformer replacements needed to maintain reliability and risk levels are based on the CBRM methodology.

The forecast RMU replacements are similarly derived using the CBRM methodology and are those replacements deemed necessary to maintain reliability and risk levels.

It is expected that the CRO'd Switch replacement program will continue to ensure that all problematic switches are removed from the system. The costs forecast for this program are for the replacement of 6 switches per annum to address inoperable and failed switches. The total costs of this program have been split between overhead switches and indoor switches. The expenditure above is for the indoor switch proportion of the total CRO'd switch replacement program.

The remaining programs listed above are aligned with historic expenditure to ensure the maintenance of the performance of this asset class.

Another option considered is replacement based on expected asset useful life. This would result in many assets being replaced with some remaining life not utilised and consequently replacement based on asset condition is a far more efficient method.

The data on age profile for the sub-asset class (section 4.6.2) indicates that approximately 13% of ground substations, 32% of indoor substations and 2% of kiosk substations are beyond their nominal useful life. The CBRM analysis indicates that 13 transformer and 109 RMU replacements p.a. are required to maintain risk at current levels. Therefore, beyond 2025 it can be expected that greatly increased investment will be required in the longer term to manage risk levels.

5.1.7 OVERHEAD LINE SWITCHGEAR SUB-ASSET CLASS

Based on the drivers listed in Section 5.2.7, a number of projects have been identified to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-13 lists these programs and their associated forecast asset replacement volumes for overhead line switchgear from 2020 to 2025.

Table 5-13: Forecast Replacement Volumes - Overhead Line Switchgear

Service Code	Overhead Line Switchgear	Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RHG	Gas Switch Replacement	22	26	26	26	26	26
RHG	Replace CRO'd Switches - Stage 9	7	-	-	-	-	-

Service Code	Overhead Line Switchgear	Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RHH	HV Isolators	47	44	43	44	48	46
RHL	LV Isolators	39	38	36	36	39	38

Table 5-14 lists the forecast CAPEX for overhead line switchgear from 2020 to 2025, based on the volumes above.

Table 5-14: Forecast Capital Expenditure from 2020 to 2025 – Overhead Line Switchgear

Service Code	Overhead Line Switchgear	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RHG	Gas Switch Replacement	337	417	415	420	430	433
RHG	Replace CRO'd Switches - Stage 9	175	-	-	-	-	-
RHH	HV Isolators Replacement	440	358	357	332	400	403
RHL	LV Isolator Replacement	136	114	117	104	123	124
	Total	1,088	889	889	856	953	960

These forecasts are based on unit rates used during the estimation process undertaken as part of the standard Jemena Project Management Methodology.

It is expected that the CRO'd switch replacement program will continue to ensure that all problematic switches are removed from the system. The costs for this project have been split between overhead switches and indoor switches.

The allocation indicated in Table 5-14 for the CRO'd switch replacement program is for the outdoor switch proportion of the total CRO'd switch replacement program.

The ABB Isolator replacement program is expected to continue in 2020-26 period to replace the remaining 57 identified problematic isolators. The condition of this remaining population will be monitored via the Asset Inspection Program.

Gas switch and HV isolator replacements have been forecasted using the CBRM methodology so as to maintain network reliability. A gas switch is used to replace any defective air break type HV switchgear and the forecast CAPEX addresses this requirement. There is no anticipated like for like replacement of gas switches during the forecast period as the population is in the early stages of its lifecycle.

LV isolator replacements have been aligned with previous historic expenditure to ensure the ongoing maintenance of the performance of this asset.

Another option that has been considered is replacement based on expected useful life. However it is anticipated that this would result in many assets being replaced with some remaining life not utilised. As risks associated with overhead switchgear failure are relatively low and asset condition can be assessed visually and via thermographic survey, this option has not been adopted as it is more expensive.

Beyond 2026, based on:

- The assessment of performance indicated in Section 4.7.3;
- The age profile, where presently approximately 40% of air break switches, 10% of HV disconnectors and 3% of gas switches are beyond nominal useful life; and
- The CBRM analysis which indicates that the replacement of 21 air break switches p.a. , 27 HV disconnectors p.a. and 2 gas switches p.a. are required to maintain risk at current levels.

Once the CRO'd switch replacement program is complete, it can be expected that a similar level of investment to that proposed above will be required in the longer term.

5.1.8 LOW VOLTAGE OVERHEAD SERVICES SUB-ASSET CLASS

In response to the drivers listed in Section 5.2.8, a number of programs have been identified to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-15 lists these programs and their associated forecast replacement volumes for LV overhead services from 2020 to 2025.

Table 5-15: Forecast Replacement Volumes – LV Overhead Services

Service Code	LV Overhead Services	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RMF	Service Fault Replacement	651	604	604	606	607	606
RMJ	Replace Service and Alter Terminations	86	82	82	82	83	82
RML	Install Disconnect Device	53	49	49	50	50	50
RMP	Replace Services - Planned	324	322	322	324	326	324
RMP	Service Rectification Program (Non-Preferred Service)	3,651	4,310	4,310	4,310	4,310	4,310
RMU	OH to UG Serv Replaced with UG	18	17	17	17	17	17

Table 5-16 lists the forecast CAPEX for LV overhead services from 2020 to 2025, based on the replacement volumes above.

Table 5-16: Forecast Capital Expenditure from 2020 to 2025 – LV Overhead Services

Service Code	LV Overhead Services	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RMF	Service Fault Replacement	684	531	530	540	558	564
RMJ	Replace Serv and Alter Terms	149	121	120	122	126	126
RML	Install Disconnect Device	12	10	9	10	10	10
RMP	Replace Services - Planned	299	264	262	264	273	274
RMP	Service Rectification Program	2,750	3,530	3,503	3,541	3,613	3,625
RMU	OH to UG Serv Replaced with UG	142	115	114	115	118	118
	Total	4,036	4,571	4,538	4,592	4,698	4,717

These forecasts are based on unit rates used during the estimation process undertaken as part of the standard Jemena Project Management Methodology.

Beyond 2026, after the non-preferred service replacement project is completed, it can be expected that future investment should return to historical levels.

5.1.9 PUBLIC LIGHTING SUB-ASSET CLASS

Based on the drivers listed in Section 5.2.9, a number of programs have been identified to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-17 lists these programs and their associated forecast replacement volumes for public lighting from 2020 to 2025.

Table 5-17: Forecast Replacement Volumes – Public Lighting

Service Code	Public Lighting	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RLG	Sustainable Public Lighting Replacement	1,059	1,376	1,391	1,408	1,425	1,084
RLJ	Public lighting Replacement - Major Rd	402	496	494	492	490	384
RLM	Public lighting Replacement - Minor Rd	134	229	228	227	227	135
RLN	Single Lantern and Bracket Replacement - Major Rd	7	7	7	8	8	8
RLO	Single Lantern and Bracket Replacement - Minor Rd	66	114	114	115	116	73
RPA	Public lighting Pole Replacement - Major Roads	107	112	117	122	128	133
RPB	Public lighting Pole Replacement - Minor Roads	153	159	166	173	181	189

The forecast volumes included in the above table have been sourced from the Jemena Public Lighting model and have been used to derive the associated capex expenditure as detailed below. These volumes include both Alternative Control Services (ACS) and negotiated regulatory category volumes.

Table 5-18 lists the forecast CAPEX for public lighting from 2020 to 2025, based on the above volumes.

Table 5-18: Forecast Capital Expenditure from 2020 to 2025 – Public Lighting

Service Code	Public Lighting	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RLG	Sustainable Lighting Replacement	746	1,276	1,292	1,313	1,336	1,361
RLJ	Public lighting Replacement - Major Rd	566	772	761	753	745	737
RLM	Public lighting Replacement - Minor Rd	42	134	133	133	133	132
RLN	Single Lantern & Bkt Main Rd	16	15	15	16	16	17
RLO	Single Lantern & Bkt Minor Rd	47	151	152	154	156	158
RPA	Pole Replace P/L - Main Roads	412	388	407	428	451	476
RPB	Pole Replace P/L - Minor Roads	531	496	516	539	563	588
	Total	2,360	3,232	3,276	3,336	3,400	3,469

The assessment of asset age and performance included in Sections 4.9.2 and 4.9.3, indicates that only a small proportion of public lighting luminaires are beyond their nominal useful life. With an ongoing program of bulk relamping and patrols it is expected that a similar age profile will be maintained in the future. Therefore, beyond 2026, it is expected that the maintenance of investment at similar levels to that indicated above will be required in the longer term to maintain asset performance.

5.1.10 EARTHING SYSTEMS SUB-ASSET CLASS

Based on the drivers listed in Section 5.2.10, a number of programs have been identified to ensure the maintenance of network performance and also address Jemena's compliance requirements.

Table 5-19 lists these programs and their associated forecast replacement volumes for earthing systems from 2020 to 2025.

Table 5-19: Forecast Replacement Volumes – Earthing Systems

Service Code	Earthing Systems	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RHH	Project Step & Touch Stage 4	360	-	-	-	-	-
RHH	Project Step & Touch Stage 5	-	266	-	-	-	-
RHH	Project Step & Touch Stage 6	-	-	274	-	-	-
RHH	Step & Touch - New cycle	-	-	-	-	-	137

Table 5-20 lists the forecast CAPEX for earthing systems from 2020 to 2025, based on the above volumes.

Table 5-20: Forecast Capital Expenditure from 2020 to 2025 – Earthing Systems

Service Code	Earthing Systems	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RHH	Project Step & Touch Stage 4	527	-	-	-	-	-
RHH	Project Step & Touch Stage 5	-	370	-	-	-	-
RHH	Project Step & Touch Stage 6	-	-	368	-	-	-
RHH	Step & Touch - New cycle	-	-	-	-	-	185
	Total	527	370	368	-	-	185

Beyond 2026, based on the assessment of performance included in Section 4.10.3 and once the step and touch projects are completed, future investment should be at lower levels and be linked to condition based defect rectification.

5.1.11 HIGH VOLTAGE OUTDOOR OVERHEAD FUSES SUB-ASSET CLASS

Based on the drivers listed in Section 5.2.11, a program has been identified to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-21 lists this program and its associated forecast replacement volumes for HV outdoor overhead fuses from 2020 to 2025.

Table 5-21: Forecast Replacement Volumes - HV Outdoor Overhead Fuses

Service Code	HV Outdoor Overhead Fuses	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RXF	Fuse unit replacement	17	17	17	17	17	17

Table 5-22 lists the forecast CAPEX for HV outdoor overhead fuses from 2020 to 2025, based on the above volumes.

Table 5-22: Forecast Capital Expenditure from 2020 to 2025 – HV Outdoor Overhead Fuses

Service Code	HV Outdoor Overhead Fuses	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RXF	Fuse unit replacement	56	50	50	51	52	52

These forecasts are based on unit rates used during the estimation process undertaken as part of the standard Jemena Project Management Methodology.

As the asset age profile indicates (Section 4.11.2.2) approximately 14% of the HV fuses population are older than their nominal useful life. To maintain the network risk at current levels an increased

replacement rate will be required. Therefore beyond 2025 it can be expected that an increased level of investment will be required over the historic levels.

5.1.12 DISTRIBUTION SURGE ARRESTERS SUB-ASSET CLASS

In response to the drivers listed in Section 5.2.12, a program has been identified to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-23 lists this program and its associated forecast replacement volumes for surge arrestors from 2020 to 2025.

Table 5-23: Forecast Replacement Volumes- Surge Arresters

Service Code	Surge Arresters	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RXD	Surge Diverter Replacement	16	16	16	16	16	15

Table 5-24 lists the forecast CAPEX for surge arrestors from 2020 to 2025, based on the above volumes.

Table 5-24: Forecast Capital Expenditure from 2020 to 2025 – Surge Arrestors

Service Code	Surge Arresters	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RXD	Surge Diverter Replacement	72	65	65	66	67	67

These forecasts are based on unit rates used during the estimation process undertaken as part of the standard Jemena Project Management Methodology.

Surge diverters are to be replaced based on asset condition as they are identified. The forecast expenditure is aligned with historic replacement expenditure associated with fault replacement and asset inspection maintenance notifications.

Beyond 2025, it is expected that an increasing proportion of the surge arrestor population will reach the end of life phase and thus the likelihood of failure will be greater. Asset age data in Section 4.12.3.2 indicates that approximately 50% (3,400) of the surge arrestor population are of the porcelain housed type or unknown type and likely to be in excess of 24 years old. This is when the installation of polymeric housed surge arrestors commenced. A replacement rate of 170 sets p.a. is needed to replace this quantity over 20 years. Therefore it can be expected that an increased level of investment will be required in the longer term.

5.1.13 AUTOMATIC CIRCUIT RECLOSERS SUB-ASSET CLASS

In response to the drivers listed in Section 5.2.13, a program has been identified to ensure the maintenance of network performance, and also address Jemena's compliance requirements.

Table 5-23 lists this program and its associated forecast replacement volumes for automatic circuit reclosers from 2020 to 2025.

Table 5-25: Forecast Replacement Volumes- ACR's

Service Code	Remote Controllable ACRs	Forecast Replacement Volumes					
		CY20	CY21	CY22	CY23	CY24	CY25
RHH	ACR Replacement (Fault)	-	1	1	1	1	1
RHH	ACR Replacement (Directional E/F)	4	6	6	7	7	7

Volumes are based on the year of commencement of installation

Table 5-26 lists the forecast CAPEX for ACR's from 2020 to 2025, based on the above volumes.

Table 5-26: Forecast Capital Expenditure from 2020 to 2025 – ACR's

Service Code	Remote Controllable ACRs	Forecast Capital Expenditure (\$2019 '000s, direct escalated cost, including overheads)					
		CY20	CY21	CY22	CY23	CY24	CY25
RHH	ACR Replacement - all	-	310	309	313	321	323

These forecasts are based on unit rates used during the estimation process undertaken as part of the standard Jemena Project Management Methodology.

As it will be another 30 years until the oldest ACR's installed on the JEN reach their expected useful life, replacement ACR expenditure is expected to continue at the present low level.

5.2 OPERATING AND MAINTENANCE FORECAST

The forecast OPEX expenditure for all sub-asset classes is included in Table 5-27. The specific drivers of the sub-asset class strategies and the consequences of not completing the programs of work detailed in each sub-asset class strategy are set out in the following sections. Note, vegetation management is outside the scope of this strategy and is detailed in Jemena's Electric Line Clearance Management Plan 2020-2026 (JEN PL 0101). The OPEX forecasts for vegetation management are included in the table below for completeness.

Table 5-27: OPEX Forecast

Service Code	Description	OPEX Forecast (\$2019, 000's)					
		CY20	CY21	CY22	CY23	CY24	CY25
MOL	Straightening Leaning Poles	128	131	134	137	141	144
NPD	Termite Treatment	6	6	6	7	7	7
NOF	Subtransmission/Feeder Thermal Surveys	266	273	279	286	293	300
MLF	Public Light Main Road Faults	853	873	893	915	936	958
MLP	Public Light Maintenance – Patrol	113	115	118	121	124	127
MLR	Public Light Pole Repairs – Main Road	45	46	47	48	50	51
MRB	Bulk Replacement Lamp - Minor Roads	1,271	830	849	869	890	911
MRC	Removal of Security Beam	3	3	3	3	3	3
MRF	Public Light Minor Road Faults	1,155	1,182	1,210	1,239	1,268	1,298
MRR	Public Light Pole Repairs – Minor Roads	95	96	99	101	104	106
MRR	Public Lighting Switch Wire Removal	426	435	446	456	467	478
MRW	Security Beam Maintenance	43	44	45	46	47	48
MHA	Distribution HV Installation Maintenance	60	62	63	65	66	68
MOM	Overhead Line Maintenance – Pole Top Structure	750	767	785	804	823	842
NOA	Overhead Asset Inspection	1,911	1,956	2,002	2,050	2,099	2,148
NXS	Transformer Load Testing	2	2	2	2	2	2
MEB	Transformer/Kiosk Refurbishment	38	39	40	41	42	43
MHD	Distribution Substation Defect Maintenance	21	21	21	22	23	23
MHO	Distribution Sub Oil Sample and Testing	19	19	19	20	20	21
MHR	Distribution Substation Maintenance	215	220	225	231	236	242
MHT	Distribution Subs Thermal Survey	2	2	2	2	2	2
NOE	Earth Testing	23	23	24	24	25	25
MUB	Pits Maintained	18	18	18	19	19	20
MUD	Underground Cable Testing	18	18	18	19	19	20
MUG	Pillar Maintenance	12	13	13	13	14	14
MUI	LV Cable and Joint Repairs	15	16	16	16	17	17
MUJ	HV Cable and Joint Repairs	31	31	32	33	34	35
MOS	Overhead Service Adjustment	29	29	30	31	32	32
NOD	Service Inspection	3	3	3	3	3	3
MSA	Distribution Switchgear Maintenance	69	70	72	74	75	77
MHC	ACR Inspection and Maintenance	15	15	15	15	16	16
MHG	Distribution Substation Grounds Maintenance	170	174	178	182	187	191
NGA	Vegetation Management	4,637	4,745	4,857	4,973	5,091	5,212
	Total	12,462	12,277	12,564	12,867	13,175	13,484

5.2.1 POLES SUB-ASSET CLASS

The criteria for the condition assessment of wood, concrete and steel poles, is defined in Jemena's Asset Inspection Manual (AIM) – JEN MA 0500. The condition monitoring of poles is a time based activity.

This forms the foundation for the implementation of an effective condition based asset management system. This minimises the number of in-service failures and the unnecessary replacement of healthy poles when compared with a time based lifecycle management system.

Pole and Pole Top maintenance is driven by the asset inspection process. All work carried out beyond inspection and treatment (by the asset inspector) occurs as a result of the raised notifications or inspection reports. Minor maintenance as defined in the AIM is performed by the Asset Inspector and details recorded in a maintenance notification. Full details of asset inspection operations, including wood pole preservative application, are contained in the AIM.

Operational expenditure (OPEX) for the poles sub-asset class does not vary much from year to year on a per unit basis. Annual OPEX however will vary depending on the volume of poles inspected in any year. Depending on the inspection cycle the annual number of poles inspected can vary from 20,000 to 30,000 in any year. However the total operational expenditure in any five year inspection cycle (all poles inspected once) will only vary by the marginal increase in the cost of labour.

The capital expenditure that occurs involving the poles sub-asset class does not negate or influence the requirement for operational expenditure. Pole replacement, either planned or post fault, is a capital activity with the post fault replacement being significantly more expensive than planned replacement. Operational expenditure associated with any new or replacement pole continues in the mandated inspection cycle.

Table 5-28: Asset Class Specific Drivers: Poles

Driver	Risk/Opportunity Description	Consequence
Asset Integrity, Health, Safety and Environment, Regulatory compliance	Significant numbers of undersized poles due to previous network ownership. Until 2011, undersized poles were allowed to remain in service provided there was sufficient sound wood and no external decay	Failure of three undersized LV poles in wind storm in 2008 indicated replacement/staking required 10-20 years sooner than previously identified
Asset Integrity, Health, Safety and Environment, Regulatory compliance	Wood poles suffer ground line fungal timber rot	Primary failure mode for wood pole leading to loss of supply, fire start etc.
Asset Integrity, Health, Safety and Environment, Regulatory compliance	Ground line corrosion of steel poles is increasing, despite recent increase in replacement	Many of these poles are used in public lighting poles in estates, the security of the cable access cover is a high priority to prevent access to the public. Increasing replacement required over the next five years
Asset Integrity	Some supply reliability risks associated with concrete poles installed due to historic use of the same insulation system as wood poles when initially rolled out despite the conductive nature of concrete poles	Poor supply reliability (mostly resolved)
Regulatory compliance	Inspection of private overhead electric lines on a regulated 37 month interval mandated by ESV since 2010	Increase in inspection activity

Driver	Risk/Opportunity Description	Consequence
Technological Developments	Improvements in preservation of hardwood through manufacturing (CCA), helping to extend asset lives	Marginal extension in asset lives.

5.2.2 POLE TOP STRUCTURES SUB-ASSET CLASS

Asset Inspectors monitor the condition of the pole and every asset attached to the pole. The scope of the condition assessment includes the climbing animal guards on timber poles, transformer bushings, crossarms, crossarm braces, bolts, insulators, conductor, bird and animal covers, HV fuses and fuse brackets, cable terminations, service cables and surge arrestors.

These inspections drive the preventive maintenance activities and the planned replacement of items that frequently fail causing line outages. Different inspection programs and cycles are applied dependent on whether the pole lines are located in the HBRA or the LBRA.

All defects are allocated a priority and repaired on that basis. Defects are usually identified during inspection or audit and occasionally result from temporary fault repairs.

Defects that pose a health and safety risk will be corrected immediately using live-line techniques wherever possible.

Table 5-29: Asset Class Specific Drivers: Pole Top Structures

Driver	Risk/Opportunity Description	Consequence
Asset Integrity	Pin Insulators - Particular insulators (both line pin and switch insulators) have been identified as prone to failure by cracking of the upper or lower porcelain components.	Insulator glazing (predominantly brown and grey porcelain type) is also deteriorating (generally accepted as the older cohort), resulting in a build-up of contaminants contributing to current leakage which may develop into pole top fires.
Asset Integrity	Extension of the life of wood poles (through reinstatement and preservation treatment) has led to increased rate of pole top structure replacements	Increased replacement of pole top structures due to pole maintenance and refurbishment programs.
Asset Integrity, Health, Safety and the Environment, Regulatory compliance	Wooden cross arm failure due to deterioration in wood due to weather, fungal attack and occasionally termite attack	Failure leading to loss of supply, voltage injections, pole top fires, and ground fire starts.
Asset Integrity, Health, Safety and the Environment, Regulatory Compliance	Pole/Cross arm arcing due to combined effect of environmental condition (weather and particle build up on insulators) and wooden pole tops	Ignition of the pole or pole top structure

5.2.3 CONDUCTORS AND CONNECTORS SUB-ASSET CLASS

Thermal surveys are conducted on annual, two-year and three-year cycles. HV feeders are allocated to each group on the basis of a risk ranking. High risk feeders, which are surveyed annually, include all feeders supplying commercial loads, highly loaded feeders (> 80% feeder capacity) and feeders with greater than 2,500 customers. Feeders with an average fault history of greater than 3 faults per annum will be surveyed on a 2-year cycle. All other low risk feeders are to be surveyed on a 3-year

cycle. If a feeder is deemed a “rogue” feeder then an additional survey may be ordered. In addition to the HV feeder inspections all subtransmission lines are to be thermally surveyed on 2 year cycle.

This regime enables any faults detected by asset inspections and thermal surveys to be recorded and packaged into logical groups for maintenance rectification in the same electrical area. A complete list of all the feeders and their survey cycles can be found in the SAP Maintenance Plans.

On a routine five-year cycle steel conductor in the HBRA is visually assessed for the extent of corrosion. High quality aerial photographic techniques are utilised to provide accuracy, consistency and confidence in the assessment. This technique has been implemented successfully for steel conductor, a program is currently being developed to test this technique on other conductor materials (i.e. other than steel) in the HBRA.

During the Steel Conductor Assessment Program (SCAP) the conductor is assigned a condition category from 1 to 10; where 10 is new conductor and 1 is severely rusted conductor. Steel conductor assessed with condition categories between 1 and 5 inclusive will be planned for replacement (projects are initiated) during the five-year period before the next inspection. Locations with Conductor Categories of 6 (CC6) may also be considered for replacement by the project initiator.

As required by JEN standards:

- All open wire LV spans in the HBRA will be fitted with spreaders (maximum 75m spacing between spreaders or spreader and crossarm) (NB. JEN is currently in the process of removing all LV open wire conductor in the HBRA);
- All HV steel conductors on intermediate crossarms in the HBRA will be retrofitted with armour rods and vibration dampers; and
- All other conductor construction types (e.g. AAC, ACSR, Cu etc.) on intermediate crossarms in the HBRA will be retrofitted with armour rods and vibration dampers in accordance with the requirement of JEN standards.

Table 5-30 : Asset Class Specific Drivers: Conductors and Connectors

Driver	Risk/Opportunity Description	Consequence
Health, Safety and Environment	JEN pole top structure in the vicinity of third party assets	Serious due to financial claims (\$100k to \$1M) associated with voltage injection to third party assets (damage to equipment).
Asset Integrity	Conductors - Induction	Impact on H&S for staff or contractors.
Asset Integrity Health, Safety and Environment	Conductor joint failure Conductor clashing Mechanical failure of conductor ties and insulators	Hot spots, outages, fires, low conductors, electrocutions, fatality, high voltage injections, and shocks. Electricity supply could be lost to upwards of 1000 Customers over a 6 hour period Annually, there is one or more event on the network of this nature.
Asset Integrity Health, Safety and Environment	Vegetation programs of councils insufficient	Vegetation contacting conductors, causing loss of supply, public proximity

Driver	Risk/Opportunity Description	Consequence
		<p>The risk of loss of supply, fire starts, public access- electrocution, and shocks.</p> <p>Electricity supply could be lost to in excess of 3000 for durations longer than 6 hours.</p>

5.2.4 UNDERGROUND DISTRIBUTION SYSTEMS SUB-ASSET CLASS

The ability to monitor the condition of underground distribution system assets is limited to the inspections of those parts of the network that are visible. The following condition monitoring programs are in place:

- On line monitoring of oil levels in 66kV oil filled cables;
- Visual inspection of all visible parts of the subtransmission cable system on a two year cycle;
- Visual inspection of HV and LV cable heads via the Pole and Line inspection program in accordance with the criteria set out in the AIM – JEN MA 0500;
- Visual inspection of HV and LV cable terminations in indoor and kiosk substations in accordance with the criteria set out in the Enclosed Distribution Substation Inspection Manual - JEN MA 0695;
- The visual inspection of all LV pillars and cabinets on a on a 3-year cycle in the Hazardous Bushfire Risk Areas (HBRA) and a 5-year cycle in the Low Bushfire Risk Areas (LBRA); and
- All cable terminations are included in the thermal survey program.

The low voltage underground cable network makes extensive use of pillars and pits to terminate cables and provide service connections. Pillars are prone to damage by vehicles and vandals.

In order to minimise third party damage to cables, cable locating services and the “Dial before you Dig” service are proactively promoted to contractors.

No other specific operating expenditure is allocated to inspections. These inspections that are undertaken are all part of a larger maintenance program and as such no specific operating expenditure is allocated to individual underground cable inspections.

Table 5-31: Asset Class Specific Drivers: Underground Cable Systems

Driver	Risk/Opportunity Description	Consequence
Asset Integrity, Health, Safety and Environment	HV metal clad trifurcating box in service explosive failures (HV CABUS Terminations)	Failures pose high risk to public safety
Asset Integrity	Known issues with early XLPE manufactured cables (water treeing of the insulation due to steam curing, instead of gas curing during manufacture)	Customer supply interruption, network reliability
Technology	Improved condition monitoring techniques	Increased knowledge of the asset condition leading to more efficient management in the long term.

Driver	Risk/Opportunity Description	Consequence
Asset Integrity	Third party damage (dig ins) - Increase in number	Asset failure leading to customer reliability, and also risk to safety

5.2.5 POLE TYPE TRANSFORMERS SUB-ASSET CLASS

The condition assessment of pole type transformers is conducted through inspections and audit programs such as the standard asset inspection program and thermal surveys. Based on the results of these condition monitoring activities maintenance notifications are raised for the rectification of defects or replacement of assets as identified. The replacement of pole type transformers is largely driven by the need to upgrade transformers to meet increasing capacity requirements.

Inspection of transformers is carried out as part of the standard asset inspection program. All assets in the HBRA are inspected every 3 years, and in the LBRA every 5 years. A thermal survey of transformers and connections are also performed to assist in the detection of potential failures. This is carried out as part of the regular overhead line thermal survey cycle which occurs every 1, 2, or 3 years depending on asset criticality.

Inspection activities include checks for general cleanliness, oil level, signs of oil leaks, corrosion of tank/cooler/conservator, tank distortion, broken porcelain, tracking on bushings and surge arresters if fitted on transformers, bushing leads and animal shields are secured, droppers are free from vegetation interference, and clearances between live conductors are maintained.

Table 5-32: Asset Class Specific Drivers: Pole Type Transformers

Driver	Risk/Opportunity Description	Consequence
Regulatory Compliance	Mounting height of Pole Type Transformer is too low	Does not meet minimum clearance requirements as set out in the ESMS
Asset Integrity	Deteriorating asset condition	Failure leading to environmental/safety issues
Health, Safety and Environment		Customers off supply

5.2.6 NON-POLE TYPE DISTRIBUTION SUBSTATIONS SUB-ASSET CLASS

The condition assessment of non-pole type distribution substations is conducted through inspection and audit programs. As a result of this condition monitoring activity maintenance notifications are raised for the rectification of defects or replacement of assets as identified.

All non-pole type distribution substations are inspected in accordance with the criteria set out in the Enclosed Distribution Substation Inspection Manual - JEN MA 0695 on a three year cycle. All assets within the substations are inspected.

The inspection includes as a minimum:

- visual inspection of SF6 gas gauges and photographs of pressure gauges with abnormal levels;
- thermal scanning;
- inspection for the effects of corrosion;
- detection of abnormal audible discharge;
- inspection of cable and cable termination conditions;
- checks of transformer and switchgear oil leaks and oil levels;

- site security; and
- Site cleanliness and vegetation.

Drainage systems are inspected and maintained annually. Any repairs necessary to fences and gates are identified and reported to Jemena contract officers, who negotiate with the responsible site owner and inform the contractor of any works that he should undertake.

Table 5-33: Asset Class Specific Drivers: Non Pole Type Distribution Substations

Driver	Risk/Opportunity Description	Consequence
Asset Integrity	Failure of distribution substation	In some cases (at least once every two years) a fire results from a kiosk substation failure. Supply interruption
Health, Safety and Environment	Failure leading to SF6 leak	SF6 is a powerful greenhouse gas. The by-products of an arc occurring in SF6 are corrosive and hazardous and pose a risk to the environment as well as to public and employee safety.
Asset Integrity, Safety, Health and Environment	Mal-operation of plant due to leaking roof	Risk to employee safety and asset integrity

5.2.7 OVERHEAD LINE SWITCHGEAR SUB-ASSET CLASS

All overhead line switchgear is inspected in conjunction with the pole and line asset line inspection program (AIM).

The inspection criteria for HV gas insulated switchgear includes the following elements:

- bushing condition;
- position indicators;
- tank condition;
- mounting hardware;
- operating arm;
- gas pressure indication; and
- connections.

Gas insulated switches with remote control facilities are inspected and functionally checked at 5 yearly intervals as part of the battery maintenance program. These units are monitored on line via the NOC's SCADA system.

In addition to the 3 - 5 yearly visual inspection, all switches and isolators are included in the thermal survey program for overhead lines.

As overhead line switchgear is routinely operated due to its role within the network, condition assessment of overhead line switchgear is conducted as part of routine use via the network

operators. Any defects found result in the application of a CRO tag on the switch and the generation of a maintenance notification.

These programs help identify and resolve minor issues with the overhead switch population to prevent in service failures.

Table 5-34 Asset Class Specific Drivers: Overhead Line Switchgear

Driver	Risk/Opportunity Description	Consequence
Asset Integrity	Bird and animal strike	Network outage and supply interruption
Asset Integrity Health, Safety and Environment	Deteriorating asset condition	Failure to carry load. Failure to break load current resulting in flashover, network outage and H&S risk for operator and public. Manual handling issue for operators.

5.2.8 LOW VOLTAGE OVERHEAD SERVICES SUB-ASSET CLASS

All LV overhead services are visually inspected for mechanical integrity as part of the standard asset inspection program, every 3 years in the Hazardous Bushfire Risk Areas and every 5 years in the Low Bushfire Risk Areas. Refer to JEN MA 0500 – Asset Inspection Manual for details. Visual inspections of overhead services are also conducted as part of vegetation management, height measurements and opportunistically during maintenance.

Asset Inspection activities include:

- Check service integrity from the pole end to the premise end (e.g. tree damage, UV degradation, broken/wrong fittings, etc);
- Low voltage overhead services shall be visually inspected from ground level during any fault investigation;
- Service Clearance Inspections as specified in the JEN Electricity Safety Management Scheme (ESMS) for low services and;
- Testing of the service with a Neutral & Supply Tester at the supply metering equipment.

The initial NST program was completed at the end of 2009. The program was suspended for the duration of the advanced interval metering (AMI) roll out because the obligation for the 10 year periodic test (2010 to 2019) was met by the AMI program. Work is in progress on the constant monitoring of the integrity of service neutrals via the AMI meter data. This work has reached the stage where the neutral integrity of all services that are metered via an AMI meter are being constantly monitored. Reports are now being generated identifying suspect service neutrals for follow-up by field crews. The aim is to embed this technology in the way Jemena manages these assets.

Table 5-35: Asset Class Specific Drivers: LV Overhead Services

Driver	Risk/Opportunity Description	Consequence
Asset Integrity Health, Safety and Environment	Failure of neutral screen	Shocks from high impedance neutral service connections. Currently there are on average three shocks per month reported.

5.2.9 PUBLIC LIGHTING SUB-ASSET CLASS

The Asset Inspection Manual - JEN MA 0500 details the inspection criteria for steel, concrete and frangible public lighting poles.

Any defective items identified during inspections shall be programmed for repair and in a timeframe commensurate with the severity of the defect. Any missing or damaged access cover plates found during pole inspections are to be rectified immediately with replacement access cover plates secured with “band it” straps.

As part of the 4 yearly bulk re-lamping regime, non-major road lighting poles are to be inspected to confirm if there are any damaged or missing pole access cover plates. Any such defective plates are to be rectified immediately with replacement access cover plates secured with “band it” straps.

Routine patrols of major road lanterns shall be programmed to occur three times per year across the Jemena Electricity Network. The patrols are intended to identify defective lamps or sections of lights, lanterns, poles, brackets and access cover plates, which may otherwise remain defective for prolonged periods. If damaged or missing access cover plates are found during a major road patrol, replacement access cover plates secured with “band it” straps are to be installed immediately.

Table 5-36: Asset Class Specific Drivers: Public Lighting

Driver	Risk/Opportunity Description	Consequence
Regulatory Compliance	Equipment failure	Not meeting requirements for public lighting of major/minor roads

5.2.10 EARTHING SYSTEMS SUB-ASSET CLASS

In general, with the exception of zone substation earthing systems, there is no requirement to inspect and test HV earthing installations that form part of a CMEN system. The inspection and testing of HV earthing systems installed outside CMEN schemes and in zone substations are required at 10-yearly intervals. Refer to JEN PR 2504 – HV Earth Testing Program in Non-CMEN Areas for details.

Table 5-37: Asset Class Specific Drivers: Earthing Systems

Driver	Risk/Opportunity Description	Consequence
Environment, Safety and Health	Earth potential rise under fault conditions	This poses a risk to the public and employees and is something that needs to be actively managed on an ongoing basis, to ensure that changes in short circuit levels are managed appropriately.
Asset Integrity	Issues with theft of copper	On an annual basis, theft of copper (earthing) raises integrity issues for earthing systems that need to be managed on an ongoing basis.

5.2.11 HIGH VOLTAGE OUTDOOR OVERHEAD FUSES SUB-ASSET CLASS

Inspection of HV fuses is carried out as part of the pole and line asset inspection program. All poles and lines in the Hazardous Bushfire Risk Areas are inspected every 3 years, and in the Low Bushfire Risk Areas every 5 years. A thermal survey of HV fuses is also performed to assist in the detection of potential failures before they occur and is aligned with the regular overhead line thermal survey cycle.

For details of the activities involved in the inspection program, refer to the JEN MA 0500 - Asset Inspection Manual.

When opportunities arise, such as repair of overhead conductor faults, all fuses should be inspected for cleanliness, signs of tracking, cracks on fuse mounts and carriers and that the lead connections, and bird and animal covers are secured.

Table 5-38: Asset Class Specific Drivers: HV Outdoor Overhead Fuses

Driver	Risk/Opportunity Description	Consequence
Asset Integrity Safety, Health and the Environment	Plant failure	Isolate an electrical fault so that the system remains safe to personnel and the public Minimise damage to customer and distribution assets. A typical outdoor substation consists of a transformer, cables, and surge arresters Minimise disruption to customers and the effect of a fault

5.2.12 DISTRIBUTION SURGE ARRESTERS SUB-ASSET CLASS

In accordance with the AIM all surge arresters should be inspected to ensure that:

- Signs of tracking or cracks on porcelain or polymeric surge arrestor housings are reported;
- Any earth lead disconnecter (where fitted) is of an acceptable type and has not operated;
- Any pressure relief device has not operated;
- Line and earth lead connections are secured;
- Bowthorpe fault indicators have not operated; and
- Bird and animal covers are fitted correctly with no bare HV exposed (except on cable head pole installations where there is an earth attachment point) and have not perished.

Notifications are raised against each of the above listed criteria in accordance with the Asset Inspection Manual. Identification of “unacceptable” surge arresters are raised as a notification and designated as requiring replacement under a proactive asset replacement program.

Surge arresters cannot be repaired. Damaged or defective units must be replaced.

Table 5-39: Asset Class Specific Drivers: Surge Arresters

Driver	Risk/Opportunity Description	Consequence
Regulatory Compliance Health, Safety and the environment	Surge arresters from batches identified as requiring to be removed from service due to identified failure trends still remain in some parts of the JEN Hazardous Bushfire Risk Area.	Non-compliant with internal standards as set out in the Electricity Safety Management Scheme. An in service failure could result in a fire start.
Asset Integrity	Failure equipment/damage	Early versions of porcelain surge arrestors can fail catastrophically and pose a risk to employee and public safety.

Driver	Risk/Opportunity Description	Consequence
		However, the likelihood of this is low.

5.2.13 AUTOMATIC CIRCUIT RECLOSERS SUB-ASSET CLASS

ACR's are managed on a run to failure basis because their condition is monitored on-line via SCADA. The main issue with the existing ACR population is the loss of SF6 gas pressure.

SF6 pressure levels of ACR's are remotely monitored as part of condition monitoring. Where the gas pressure of the ACR has dropped below 1bar (absolute), the unit is replaced / swapped with a spare ACR and the "empty" unit is taken to the JEN workshop and re-gassed.

Table 5-40: Asset Class Specific Drivers: ACR's

Driver	Risk/Opportunity Description	Consequence
Asset Integrity, Health, Safety and Environment, Regulatory Compliance	Known ongoing issue of gas leaks in ACR's	SF6 gas impacts environment, albeit at a minimal level.
Asset Integrity	Failure of an ACR	Customer impact of transient & permanent feeder faults due to non-isolation of a faulted section from the remainder of the feeder Slower response to transient faults thus increasing the probability of secondary damage

6 GLOSSARY

6.1 ZONE SUBSTATION ABBREVIATIONS

Substation	Suburb
AW	Airport West
BD	Coolaroo
BMS	Broadmeadows
BY	Maidstone
CN	Coburg Nth
COO	Coolaroo
CS	Coburg Nth
EP	Preston
EPN	Preston
ES	Essendon
FE	Yarraville
FF	Fairfield
FT	Flemington
FW	Yarraville
HB	Heidelberg
MAT	Melbourne Airport
NEI	Heidelberg West
NH	Macleod
NS	Essendon
NT	Newport
PTN	Preston
PV	Pascoe Vale
SBY	Sunbury
SHM	Sydenham
SSS	Somerton
ST	Somerton
TH	Tottenham
TMA	Tullamarine
VCO	Coolaroo
YVE	Yarraville

6.2 ACRONYMS

ABS	Asset Business Strategy
AC	Alternating Current
ACR	Automatic Circuit Recloser
ACS	Asset Class Strategy
AEMC	Australian Energy Market Commission
AEMO	Australian Energy Market Operator
AER	Australian Energy Regulator
AMI	Advanced Metering Infrastructure
AMS	Asset Management System
BAU	Business As Usual
BI	Business Intelligence
CATS	Customer Administration Transfer System
CBRM	Condition Based Risk Management
COWP	Capital Operating Works Program
CPU	Central Processing Unit
CT	Current Transformer
DAPR	Distribution Annual Planning Report
DC	Direct Current
DNBP	Distribution Network Service Provider
DMD	Diversified Maximum Demand
EDPR	Electricity Distribution Price Review
ENA	Energy Networks Association
EOL	End of Life
EPA	Environment Protection Authority
ERP	Enterprise Resource Planning
ESCV	Emergency Services Commission of Victoria
ESMS	Energy Safe Management Scheme
ESV	Energy Safe Victoria
EUSE	Expected Unserved Energy
GPS	Global Positioning System
HSE	Health, Safety and Environment
HV	High Voltage
I/O	Input/Output
IED	Intelligent Electronic Device (typically a digital protection relay)
JCAR	Jemena Compliance & Risk System
JEN	Jemena Electricity Networks (Vic) Ltd
JSAP	Jemena SAP
KPI	Key Performance Indicator
kV	kilovolt
KVAR	Kilo-Amps-Volts-Reactive
KW	Kilowatt
LCD	Liquid Crystal Display
LV	Low Voltage
MAMS	Metering Asset Management Strategy
MDM	Meter Data Management
MIB	Management Information Base
MTBF	Mean Time Between Failure
MW	Megawatt
NER	National Electricity Regulator
NIC	Network Interface Card

NMS	Network Management Systems
PQCA	Power Quality Compliance Audit
PQM	Power Quality Meter
PSCN	Power Supply Control Network
RAM	Random Access Memory
RIN	Regulatory Information Notice
ROM	Read Only Memory
RTS	Real Time System
RTU	Remote Terminal Unit
SAP	Proprietary name for ERP software
SCADA	Supervisory Control and Data Acquisition
SMR	Switch Mode Rectifier
VEDC	Victorian Electricity Distribution Code
VESC	Victorian Electricity System Code
VT	Voltage Transformer
ZSS	Zone Substation

6.3 TERMS AND DEFINITIONS

capital expenditure (CAPEX)	Expenditure to buy fixed assets or to add to the value of existing fixed assets to create future benefits.
operating expenditure (OPEX)	Expenditure (ongoing) for running a product, business, or system.
Asset	Refers to the collection of tangible and non-tangible assets required to provide a product or service to its customers. Jemena consists of the following Assets: Jemena Electricity Network (JEN), Jemena Gas Network (JGN), Queensland Gas Pipeline (QGP), Eastern Gas Pipeline (EGP), Colongra Gas Pipeline (CGP), ActewAGL and Northern Gas Pipeline (NGP).
Asset Class	A separation of the Assets into smaller manageable components that enable decision-making relating to implementing broader strategies in a meaningful way. E.g. Primary Plant.
Asset Management Plan (AMP)	The Asset Management Plan provides the optimised plan to manage the assets, understanding the existing and future customer requirements and operating environments, balancing the competing requirements of financial constraints, commercial & business objectives, regulatory requirements, and asset condition (including risk/opportunities). It informs the 7 year operational and capital expenditure and the two-year plan of work.
Asset Management Policy	A short statement that sets out the principles by which Jemena intends to apply asset management to achieve its objectives.
Sub-asset Class	A separation of an asset class into smaller manageable components that enable decision-making relating to implementing broader strategies in a meaningful way. An example is "Surge Diverters".
Sub-asset Class Element	A further separation of an sub-asset class into smaller manageable components that enable decision-making relating to implementing broader strategies in a meaningful way. An example is a Boric Acid Fuse.

7 APPENDICES

7.1 APPENDIX A – ASSET CRITICALITY ASSESSMENT



ASSET CRITICALITY ASSESSMENT WORKSHEET

ASSET AND BACKGROUND INFORMATION	
Site Name	General
Asset Class	Electricity Distribution
Sub-Asset Class	All
Date of Original Assessment	15-May-18
Date of Last Review	15-May-18
Reviewed By (where applicable):	

Risk Ref. No.	Description of Asset or Asset Grouping	Description of Risk	Consequence Category (Operational, HSE, Reputation etc.)	Description of Consequence and Likelihood	Current Controls	Criticality Score	Criticality Rating
1	Earthing Systems	The risk of electric shock to internal employees, contractors or the public caused by inadequate pole distribution substation HV earthing system (i.e. high resistance earth, step & touch potential under fault conditions, non-operation of HV protection)	HSE	Major due to potential life-threatening injuries to staff, contractors or member(s) of the public Likelihood: Possible due to a chance that it could happen in the next 5 years and increasing incidence of theft.	As per ACS	AC4	High
2	Conductor (switchwire)	The risk associated with accidental connection with switch wire, resulting in safety hazard to (public or employee), loss of supply and/or shocks	HSE	Major due to potential for: • Total permanent disability (staff or contractors) • Multiple hospitalisations, permanent disability and/or life threatening injuring members(s) of the public • Electrocution Likelihood: Rare due to absence of incidents within the last 10 years.	As per ACS	AC4	High
3	Underground Cable	The risks associated with underground cable records not updated or recorded accurately in GIS or Dial Before You Dig (DBYD) to reflect current condition, resulting in third-party dug-ups.	Regulatory & Compliance / Financial	Severe due to: • Moderate stakeholder concern / interest • Regulator requires formal explanations & remedial action plans Likelihood: Possible due to: • 26-50% probability of occurrence (might occur at some time within the next 5 years) • History on the JEN network for these type of incidents to occur	As per ACS	AC3	Significant
4	Overhead Service Line	Broken neutrals in services cables or mains neutrals	HSE	The risk associated with broken neutrals in services cables or mains neutrals, resulting in: • Electrocution • Minor shock • Flashover • Damage to third party property Major due to potential for: • Total permanent disability (staff or contractors) • Multiple hospitalisations, permanent disability and/or life threatening injuries affecting member(s) of the public Likelihood: Unlikely due to: • Lack of incidents occurring on JEN network within the last 10 years • Event could occur at some time within the next 10 years	As per ACS	AC4	High



ASSET CRITICALITY ASSESSMENT WORKSHEET

ASSET AND BACKGROUND INFORMATION	
Site Name	General
Asset Class	Electricity Distribution
Sub-Asset Class	All
Date of Original Assessment	15-May-18
Date of Last Review	15-May-18
Reviewed By (where applicable):	

Risk Ref. No.	Description of Asset or Asset Grouping	Description of Risk	Consequence Category (Operational, HSE, Reputation etc.)	Description of Consequence and Likelihood	Current Controls	Criticality Score	Criticality Rating
6	Pole Top	Crossarm failure (assisted / unassisted)	Operational / Health & Safety	Minor due to a feeder outage for less than 6 hours (note: it is possible to replace a crossarm within 6 hours) Minimal impact on health and safety of staff, contractors or member(s) of the public Likelihood: Almost Certain because JEN has a history of unassisted in-service crossarm failures annually.	As per ACS	AC1	Low
7	Distribution Substations (Pole Type / None Pole Type)	The risk of distribution substation equipment failure or damage e.g. distribution transformer or switchgear failure resulting in damage to assets, fires, third party property, medical treatment or lost time injury	HSE	Serious due to: • Medical treatment injury or lost time injury (staff or contractors) • On-site first aid to a small number of member(s) of the public Likelihood: Possible as the event will probably occur at some time within the next 5 years	As per ACS	AC2	Moderate
8	Pole (Steel / Concrete)	Conductive pole becoming live	HSE	Major due to: • Hospitalisations, permanent disability and/or life-threatening injuries affecting member(s) of the public Likelihood: Rare due to <5% probability of occurrence	As per ACS	AC4	High
9	Overhead Line Switchgear	Switch Failure	Operational	Minor due to a feeder outage for less than 6 hours (note: it is possible to replace a switch or reconfigure the network within 6 hours) Minimal impact on health and safety of staff, contractors or member(s) of the public Likelihood: Likely because JEN has a history of switch failures Across each of the 210 zone substation feeders on the JEN, of which each feeder supplies an average of 1614 customers, each feeder has an average of 5 air break switches, 10 sets of isolators and 4 gas switches; therefore a failure to operate, or loss of communication (remote controlled switch), can adversely affect the ability to operate the network and potentially impact 85 customers.	As per ACS	AC1	Low



ASSET CRITICALITY ASSESSMENT WORKSHEET

ASSET AND BACKGROUND INFORMATION	
Site Name	General
Asset Class	Electricity Distribution
Sub-Asset Class	All
Date of Original Assessment	15-May-18
Date of Last Review	15-May-18
Reviewed By (where applicable):	

Risk Ref. No.	Description of Asset or Asset Grouping	Description of Risk	Consequence Category (Operational, HSE, Reputation etc.)	Description of Consequence and Likelihood	Current Controls	Criticality Score	Criticality Rating
10	HV Fuse	The risk associated with the candling of fuses, resulting in overheating, explosion, maloperation, fire, damage to property and/or minor injury.	HSE	Minor due to: • JEN equipment damage under \$100k (metal clad switchgear) • Minimal impact on health and safety of staff, contractors or member(s) of the public Likelihood: Possible due to similar incidents having occurred within the last 5 years.	As per ACS	AC1	Low
11	Surge Arrester	Surge arrestor failure/damage	Financial	Minor due to: • JEN equipment damage under \$100k • Public safety to people through shattered porcelain associated with explosive failure and external liability due to litigation claims for property damage and personal injury. Likelihood: Unlikely, JEN has previous history with one incident within 10 years.	As per ACS	AC2	Moderate
12	ACR	ACR failure/damage.	HSE	Minor due to: • Environmental impact due to SF6 gas leak • Replacement of equipment is significantly less than \$100k (excludes STIPIS) Likelihood: Almost Certain JEN has history of gas leaks every year (gas pressure slowly trending down).	As per ACS	AC1	Low
13	Public Lighting	Public lighting lantern failure	Financial	Minor due to: • Replacement of equipment significantly less than 100k Likelihood: Almost Certain, there is previous history of public lighting lantern failing within JEN every year.	As per ACS	AC1	Low

7.2 APPENDIX B - ASSET OBJECTIVES KPI ALIGNMENT

Business Objectives (key focus areas, for detail refer to ABS)	ABS Objectives	ACS Objectives and KPIs to deliver ABS objectives	ACS Strategy to deliver ACS objectives	Performance Assessment / Monitoring
People Maintain safe work environment and safe asset operation Ensure we have the right people and capability to deliver the plan	<ul style="list-style-type: none"> Never compromising employees', contractors' and the public's safety; Apply the Jemena risk management approach; and Facilitate continual improvement in asset safety and performance. 	Meet key safety indicators (annually): <ul style="list-style-type: none"> No death or injury⁴ to a person (Alert Level: death or injury > 0) No significant disruption⁵ to the community (Alert Level: major disruption > 0) Total network initiated fires (Alert Level: network fires > 60) Maintain public safety and act as a road accident counter-measure by enhancing the visibility of pedestrians, vehicles, objects and hazards 	Manage all assets throughout their lifecycle in a safe and environmentally responsible manner: <ul style="list-style-type: none"> Complete scheduled asset inspection Asset replacement programs Conduct annual risk assessments and audits For specific assets: <ul style="list-style-type: none"> Pole reinforcement Preventative treatments of wood poles Replace HV wood crossarms with steel crossarms Thermal surveys of overhead equipment Earth testing Implementation of Bushfire Mitigation Plan and Electric Line Clearance Management plan 	ACS objectives and KPIs are supported through establishment of: Policies: <ul style="list-style-type: none"> Asset Management Policy Health and Safety Policy Environmental Policy Jemena's Asset Management System Employee Engagement Survey Plans and procedures: <ul style="list-style-type: none"> Asset Management Plan and COWP Incident Investigation Process Asset Inspection Manual Bushfire Mitigation Plan Electric Line Clearance Plan Electricity Safety Management Scheme (ESMS) Analysis and reporting: <ul style="list-style-type: none"> Asset performance monitoring Bushfire mitigation reporting Vegetation management reporting RIN reporting ESV reporting Incident investigation reporting
	<ul style="list-style-type: none"> Comply with applicable law, regulations, codes and reporting requirements at all times 	Comply with all relevant regulatory and legislative requirements including: <ul style="list-style-type: none"> Comply with Electricity Distribution Code Leverage F-factor scheme 	<ul style="list-style-type: none"> Management commitment for Jemena to meet all legal and regulatory obligations Establishment of ESMS Audit and compliance programs 	

⁴ Injury to a person means bodily harm requiring or appearing likely to require medical attention

⁵ Any event that: (i) qualifies for exemption under "S" factor scheme or (ii) results in supply interruption that has significant media interest or (iii) asset failure resulting in significant disruption to vehicle or public transport traffic or (iv) results in interruption to 50,000 customers or 100 MW due to an outage event.

Business Objectives (key focus areas, for detail refer to ABS)	ABS Objectives	ACS Objectives and KPIs to deliver ABS objectives	ACS Strategy to deliver ACS objectives	Performance Assessment / Monitoring
		<ul style="list-style-type: none"> Meet all of JEN's statutory obligations required under the Electricity Safety Act 1998 Electricity Safety (Bushfire Mitigation) Regulations 2013 Electricity Safety (Electric Line Clearance) Regulations 2015 ESMS regulation Meet the required standards for public lighting (major roads - AS1158.1.1 and non-major roads AS1158.3.1) 	<ul style="list-style-type: none"> Report any serious and other incidents according to the ESV reporting guidelines 	<ul style="list-style-type: none"> ESMS reporting OHS&E reporting Field auditing ESV audit reports Budget reporting <p>Performance review committees:</p> <ul style="list-style-type: none"> Asset performance monitoring Bushfire mitigation ESMS management OHS&E <p>These policies, plans, reports and committees are used to assess the performance of the asset to support the delivery of the ACS Objectives and KPIs.</p>
	<ul style="list-style-type: none"> Improve the linkage of people development activity to succession planning needs and skills gaps in Asset Management 	<ul style="list-style-type: none"> Identify people development opportunities to address any skill gaps in Asset Management Promote continual improvement initiatives through training, knowledge sharing and mentoring Implement Jemena's Talent Strategy 	<ul style="list-style-type: none"> Employee engagement surveys Employees are encouraged to contribute to development of improvement initiatives (forums, management updates etc.) Performance Management and Development Plans Secondments and rotation opportunities Training and development programs and courses Succession Planning Support in obtaining / maintaining Chartered Engineer Accreditation 	

Business Objectives (key focus areas, for detail refer to ABS)	ABS Objectives	ACS Objectives and KPIs to deliver ABS objectives	ACS Strategy to deliver ACS objectives	Performance Assessment / Monitoring
Operational Excellence Build efficient operations with the capacity to grow	<ul style="list-style-type: none"> • Maintain our current service levels • Maintain and improve asset information/knowledge to enable efficient and effective decision making • Embed continuous improvement throughout the asset lifecycle • Utilise technology to drive efficiency 	<ul style="list-style-type: none"> • Maintain network SAIDI, SAIFI, MAIFI annual targets (monitor monthly performance reports for asset failures) • Maintain the time taken to respond to faults/incidents (Average Dispatch Time, Average Onsite Time) • Complete incident investigations within 20 business days • Complete all scheduled asset inspection and maintenance plans within documented intervals • Review Electricity Distribution ACS at least every 3 years 	<ul style="list-style-type: none"> • Identification and timely replacement of assets based on condition • Re-inspection or reinforcement of limited life assets (poles) • Monthly performance monitoring • Incident investigations and follow up actions to improve performance • Deliver capital and operational projects in line with the budget • Manage assets in accordance with Jemena's internationally accredited Asset Management System 	
	<ul style="list-style-type: none"> • Ensure capital program for each Jemena asset is within budget while also delivering planned or equivalent scope of work 	Measure and benchmark physical and financial results and achieve financial targets: <ul style="list-style-type: none"> • Successfully deliver asset replacement and/or reinforcement (as applicable) program • Deliver asset replacement programs to agreed unit rates 	<ul style="list-style-type: none"> • Jemena portfolio management • Annual review of projects to be included in COWP • Business case approval process 	

Business Objectives (key focus areas, for detail refer to ABS)	ABS Objectives	ACS Objectives and KPIs to deliver ABS objectives	ACS Strategy to deliver ACS objectives	Performance Assessment / Monitoring
Customer Have our customers advocate for us based on their experience of our products	<ul style="list-style-type: none"> • Incorporate Customer expectations and outcomes into our Asset Management plans and documents • Engage with customer focus groups. determining the most cost-effective means of developing the network to meet future loading 	Jemena has the following customer service KPIs for the electricity network: <ul style="list-style-type: none"> • SAIDI, MAIFI • % Faults Calls answered within 30 seconds • Reduction of Ombudsman referrals • Public lighting repair timeframes (2 days unless agreed to alternative timeframe) • Customer connections made on agreed date • Achieve KPIs • Deliver safe and reliable service to customers • Review equipment and design specification to improve procurement options to reduce asset lifecycle costs 	<ul style="list-style-type: none"> • Meet all above mentioned safety and performance measures • Attendance at customer forums to obtain feedback • Perform Regulatory Investment Tests for Electricity Distribution Investment (RIT-D) • Review of relevant design, testing and commissioning standards within documented intervals • Maintain condition based asset replacement strategy • Undertake network analysis and modelling 	In addition to the above, ACS objectives and KPIs are supported through establishment of: <ul style="list-style-type: none"> • Customer Charters • Customer Focus Groups • Regulatory Investment Tests • Customer Experience Team
Growth Grow profitability and scalability	<ul style="list-style-type: none"> • Support business development projects 	<ul style="list-style-type: none"> • Procure, build, maintain and dispose of, any new assets required due to growth, in accordance with this ACS. 	<ul style="list-style-type: none"> • Deliver projects in accordance with Project Management Methodology • Review demand forecasts and Customer Initiated Capital (CIC) forecasts annually 	ACS objectives and KPIs are supported through establishment of: <ul style="list-style-type: none"> • Timely delivery of customer projects and network augmentations • Meeting budget requirements <ul style="list-style-type: none"> - Budget reporting - Jemena Portfolio Management Governance