

Network Performance Report 2016

Korumburra HP Networks (SG2/SG4/SG5)



Issued 19/12/2016

Document. No. MG-PR-2016-02

Version 2.0

Owner Multinet Gas

Gas Network – Asset Management

Preparation Record


Controlled Copy Register

Issue:	Version 2.0
Operative Date:	19/12/2016
Document Number:	MG-PR-2016-02

Amendment Record

Version	Date	Amended by	Description of Change
1.0	30/06/2016	Elsie Zhao	Initial 2016 draft
1.1	19/12/2016	Anja Trifkovic	Issue 2016 draft – for review
2.0	19/12/2016	Troy Praag	Final version – issued for use

Originated By

Title	Name	Signature	Date
Senior Engineer Network Planning	Elsie Zhao		30/06/2016

Reviewed & Approved By




	Title	Name	Signature	Date
Reviewer	Network Planning Engineer	Anja Trifkovic		19/12/2016
Endorsed	Asset Development Manager	Mark Cooper		19/12/2016
Approved	Head of Gas Network Strategy and Performance	Troy Praag		19/12/2016

Table of contents

1. Executive Summary.....	4
2. Introduction.....	4
3. Analysis	5
4. Legend.....	5
5. Results and Recommendations.....	5
Appendix A Reference Files and Models	9
Appendix B Forecast Regulator Flow.....	9

1. Executive Summary

Korumburra HP (high pressure) networks will require reinforcement to maintain minimum system pressure above 140 kPa as required by the Gas Distribution System Code:

2018

- Construct a monitor fringe RTU at Burra Food.


2019

- Lay approximately 500 m of 100 mm steel main and 1.9 km of 125 P10 main from Korumburra City Gate; and
- Construct a monitor fringe RTU in Inverloch.

2. Introduction

Korumburra HP network is an isolated high pressure network in South Gippsland region and supplied solely by Korumburra City Gate P4-290. It supplies towns of Korumburra, Wonthaggi and Inverloch. These areas have been experiencing higher than average growth in the past few years.

Figure 2-1 Overview of Korumburra HP



3. Analysis

This review is based on the latest available matched model from 2015. Forecast load growth data by postcode provided by NIEIR in June 2016 was used to forecast network capacity and augmentation works for next regulatory period from 2018 to 2022.






Forecast growth rate:

Postcode	Suburb	2016	2017	2018	2019	2020	2021	2022
3950	Korumburra	6.1%	6.2%	4.8%	4.4%	3.6%	3.2%	3.2%
3995	Wonthaggi	7.8%	8.0%	6.3%	5.8%	4.7%	4.0%	3.9%
3996	Inverloch	7.3%	7.5%	6.1%	5.6%	4.8%	4.4%	4.3%

4. Legend

The report includes schematics of the networks to visualise the network before reinforcement and the effects after reinforcement.

The legend depicting the colours for pressure ranges has been used throughout this report. The legend is as follows:

	Below 140 kPa
	Between 140 and 250 kPa
	Between 250 and 350 kPa
	Between 350 and 450 kPa
	Greater than 450 kPa


5. Results and Recommendations

Winter 2018

Burra Foods in Korumburra is a large Tariff D customer. Its load accounts for 70% of the total demand for the township of Korumburra.

Construct a monitor fringe RTU at Burra Food as shown in the Figure 5-1 in order to effectively monitor the minimum network pressure.

Figure 5-1 Burra Foods Fringe RTU Location



Winter 2019

As shown in Figure 5-2, the Korumburra network will be experiencing main's pressure less than 140 kPa. In order to maintain pressure above 140 kPa (Refer to Figure 5-3), the following reinforcement is recommended:

- Lay approximately 500 m of 100 mm¹ steel main in Clancys Rd from the existing 150 mm steel main at the intersection of Scott And Faheys Rd and Clancys Rd, and continue this main with 125 mm P10 along Clancys Rd northwards to the intersection of Clancys Rd and Korumburra – Wonthaggi Rd, and northwards towards the intersection of Korumburra – Wonthaggi Rd and Jumbunna Rd and tie in to the existing 63 mm main (Refer Figure to 5-4 for details).
- Built a monitor fringe RTU in Cape Paterson – Inverloch Rd in Inverloch as shown in the Figure 5-5.

¹ The length of steel required will be dependent on the calculation results determining the minimum length of steel for temperature recovery

Figure 5-2 Pressure Profiles before Reinforcement




Figure 5-3 Pressure Profiles after Reinforcement





Figure 5-4 Proposed Main's Detail




The following table shows the forecast minimum network pressure for the regulatory period:

2018	2019	2019R	2020	2021	2022
147	112	252	248	244	240

R denotes Reinforcement

Figure 5-5 Inverloch New Fringe RTU Location



Appendix A Reference Files and Models

All SynerGEE models are saved under folder: \1. Asset Planning & Strategy\1.0 System Planning Synergee\HP_GAAR2016\SGP\

Matching spreadsheet is saved under folder: \3.0 System Planning_Annual Planning\Winter Testing\Winter Testing Spreadsheet\GAAR

Forecast growth by postcode can be accessed via folder: \1. Asset Planning & Strategy\3.0 System Planning_Annual Planning\Winter Testing\Winter Testing Spreadsheet\GAAR

Appendix B Forecast Regulator Flow

Regulator No	Reg. Name	Forecast Network Flow m3/h				
		2018	2019	2020	2021	2022
P4-290	Korumburra City Gate	3,523	3,625	3,714	3,796	3,877