- 4 MAR 2008

DATE RECEIVED



3 March 2008

. . .

Mr Ian Cribb Director and Chief Operating Officer Oaky Creek Coal Mine GPO Box 1 Tieri QLD 4709

Dear Ian,

## REVIEW OF OAKY CREEK COAL DISTRIBUTION LOSS FACTOR FOR 2008/09

Intelligent Energy Systems Pty Ltd has undertaken a review (audit) of the Distribution Loss Factor (DLF) for 2008/09 financial year calculated by HMA Consulting for Oaky Creek Coal (OCC). OCC has been registered and admitted by NEMMCO as a Distribution Network Provider. It operates a 66kV network which supports its mine operation in central Queensland. The network is connected to Ergon Energy's distribution network at its Lilyvale substation.

Envirogen (Oaky) Pty Ltd (Envirogen) has established a 12MW power station on the Oaky Creek mining lease. As stipulated by the Rules', the registered power station requires a site specific DLF.

HMA Consulting submitted for review a spreadsheet that details the results of its load flow studies, the workings of the DLF calculation, and the final DLF value. A report titled "Distribution Loss Factor Calculation Methodology" was also submitted for review by HMA Consulting. Both the report and spreadsheet were well structured and concise and allowed an audit of the calculated DLF to be examined in a logical manner.

IES confirms that the Envirogen embedded generator meets the Rules' requirements for a site specific DLF, that is, its generation is expected to exceed 10 MW during financial year 2008/09.

The relevant published methodology operating in Queensland as at 31 December 2007 is the methodology approved by the Queensland Competition Authority (QCA) as described in Report NCM 17699 Determination of Distribution

Intelligent Energy Systems Pty Ltd ACN 002 572 090 ABN 51 002 572 090

Head Office – Sydney Level 2: 10-12 Clarke Street: Crows Nest NSW 2065 Australia: PO Box 931: Crows Nest NSW 1585 Telephone : 61:2:9436:2555 Facsimile 61:2:9436:1218: Email.ies@iesys.com.au; Web www.iesys.com.au

MelbourneLevel 8 45 William StreetMelbourne VIC 3000 AustraliaPO Box 405Collins Street WestMelbourne VIC 8007Telephone61 3 9614 6200Facsimile 61 3 9614 6255Email ies@iesys.com.auWeb www.iesys.com.au

Loss Factors for Embedded/Local Generators. A copy of this report is provided in the HMA Consulting submission.

The DLF proposed for the Envirogen embedded generator is 0.9984. IES is of the opinion that the value of 0.9984 has been calculated in accordance with the published methodology and is an appropriate DLF value to use for the Environgen generator.

Yours Sincerely

Bryan Whitlock Senior Energy Analyst