

Wishart Non-network and DM Investment Analysis

Memo

22 November 2018

Confidential version




Table of Contents

Introduction

Section 1 – Identification

Section 2 – Selection

Addressing the AER findings

About this report

The sole purpose of this report and the associated services provided by CutlerMerz is to document our analysis and findings related to Power and Water’s Non-network and Demand Management Investment proposal to the Australian Energy Regulator for Wishart Substation.

In producing this report, we have relied upon, and presumed accurate, any information (or confirmation of the absence thereof) provided by Power and Water, and from other sources. Except as otherwise stated in the report, we have not attempted to verify the accuracy or completeness of any such information. If the information is subsequently determined to be false, inaccurate or incomplete then it is possible that our observations and conclusions as expressed in this report may change.

We derived the analysis in this report from information sourced from data and information available in the public domain and provided by network operators. The passage of time, manifestation of latent conditions or impacts of future events may require re-examination, further data analysis, and re-evaluation of the findings, observations and conclusions expressed in this report. We have prepared this report in accordance with the usual care and thoroughness of the consulting profession, for the sole purpose described above and by reference to applicable standards, guidelines, procedures and practices at the date of issue of this report. For the reasons outlined above, however, no other warranty or guarantee, whether expressed or implied, is made as to the data, observations and findings expressed in this report, to the extent permitted by law.

This report has been prepared on behalf of, and for the exclusive use of, Power and Water, and is subject to, and issued in accordance with, the provisions of the contract between CutlerMerz and Power and Water. We accept no liability or responsibility whatsoever for, or in respect of, any use of, or reliance upon, this report by any third party. No responsibility is accepted by CutlerMerz for use of any part of this report in any other context.

Rev	Date	Description	By	Review	Approve
1	30/10/2018	Draft	GJ	RD	RD
2	16/11/2018	Final	GJ	RD	RD
3	22/11/2018	Minor editorials	GJ	RD	RD

Background

A temporary NOMAD mobile substation was installed at Wishart in 2015 to improve the voltage profile in the 11kV network at East Arm. PWC determined a temporary solution was preferable to a permanent substation given the load uncertainty at the time. The Wishart substation reduced the transformer loadings at the Berrimah substation.

In their regulatory proposal, PWC forecast capital expenditure for a permanent substation at Wishart.

The AER raised concerns in its draft determination regarding the need for a new zone substation at Wishart in the 2019-24 regulatory period. The basis for the AER's concern included:

- Uncertainty in respect to the load growth forecast for the Berrimah/Wishart area, particularly regarding the timing of spot loads
- Insufficient consideration of non-network and/or demand management (DM) options to defer or avoid the proposed augmentation at Wishart
- The scope and timing of the Wishart zone substation being driven by a proposed reduction of the capacity at Berrimah substation

The AER proposed a substitute investment estimate to maintain the existing capacity at Berrimah and therefore reduce or defer the potential need for augmentation at Wishart.

CulterMerz has been engaged to analyse several growth scenarios (including loads and embedded generation) to determine the likelihood that additional non-network and/or DM investment could defer the construction of Wishart ZS indefinitely or otherwise.

What we did

1. Review – We reviewed the project business case and previous non-network and DM analysis for the Wishart zone substation in conjunction with PWC's planners to confirm the non-network and DM options to be analysed.
2. Demand Forecast – We developed a bottom up demand forecast and scenarios including for base load, committed and uncommitted spot loads, and embedded generation growth to determine the load at risk.
3. Analysis – We undertook an options study considering non-network and DM options and produced an NPC estimate to enable decision making with respect to the proposed investment.
4. Reflect – We compiled this report to document the outcomes of our findings

Section 1 - Identification

This stage of the analysis developed a concise overview of the key investment driver, to ensure that the proposed non-network and/or DM investment is consistent with, and supports, the business objectives of prudent and cost efficient investment.

Demand forecast

We reviewed the spatial load forecast prepared by AEMO in September 2017 that was used in PWC’s regulatory proposal. The forecast comprised existing loads, committed loads, and committed embedded generation data available at the time. AEMO provided a revised forecast in November 2018 addressing mainly connection growth based on more recent connection data.

The load at Wishart has been increasing over the last 3 years and is forecast to continue to grow under all demand forecast scenarios (refer Figure 1). Two main scenarios were considered. The **base forecast** scenario include:

- Underlying demand growth based on the latest connection growth forecast for the Darwin-Katherine area as determined by AEMO in its Forecasting Advice for the revised Regulatory Submission, November 2018.
- Committed and uncommitted spot loads based on expected likelihood of occurrence as assessed by PWC planners
- Committed embedded generation (Solar PV) growth based on AEMO growth forecast and likelihood adjusted uncommitted embedded generation, offsetting the forecast maximum demand

The analysis reflected in this report has been based on a **reduced growth** forecast scenario to align with the AEMO forecast for the initial regulatory proposal. The difference between the AEMO forecast and the proposed forecast appears to be the timing of the committed load and generator connections as reflected in the latest available data from the PWC planners.




Figure 1 – Wishart load growth

Key investment driver

There is no supply redundancy for the load supplied from Wishart substation. Accordingly, the distribution network is currently in breach of the requirements of the network planning criteria relating to the restoration of power following a single contingency. The planning criteria requires that urban loads:

- Over 5 MVA and up to 50 MVA be restored within 60 minutes
- Over 1 MVA and up to 5 MVA be restored within 3 hours, and
- The remaining loads up to 1MVA to be restored within 8 hours

The planning criteria is not achievable following a transformer failure at the Wishart substation. Whilst some load can be supplied from Berrimah substation following a transformer failure at Wishart, the remaining load would need to be restored within 3 hours. There are no current options available to restore supply within this timeframe.

The load at risk is shown in Figure 2 and includes:

- Increasing load at risk as result of 11kV voltage constraints, exacerbated by demand growth at the extremities of the 11kV network in the East Arm area, and
- Increasing load at risk due to diminishing capacity to transfer load to Berrimah substation as result of demand growth in the Berrimah substation supply area and based on the existing capacity at Berrimah.

The load at risk increases from around 1.7MW to around 2.4MW over the regulatory period and is expected to increase markedly from 2025 as result of demand growth and associated transfer capacity constraints at Berrimah substation. Therefore, it is advisable that action be taken to comply with the planning criteria requirements.




Figure 2 – Wishart-Berrimah load at risk




Figure 3 – Proposed Wishart investment profile

Expenditure forecast	2020	2021	2022	2023	2024	Total
Number of Generators	2	-	-	-	1	3
Capital investment	[Redacted]					
Operational expenditure	[Redacted]					
Total expenditure	[Redacted]					

Table 1 – Regulatory period forecast

Addressing the AER findings

The outcomes of the Wishart non-network and DM options analysis in context of the AER's key concerns:

1. AER's concern:

- *Uncertainty in respect to the load growth forecast for the Wishart/Berrimah area, particularly regarding the timing of spot loads*

Key Finding: The demand forecast for Wishart has been based AEMO's revised assessment of connections growth, and PWC's assessment of the likelihood of committed and known but uncommitted loads realising over the next regulatory period. It includes an offset in peak demand growth based on AEMO's forecast of solar PV penetration, and PWC's assessment of the likelihood of committed and uncommitted embedded generation connections realising.

The demand forecast applied in the assessment of the load at risk at Wishart has been reduced to align with the AEMO forecast included in the initial regulatory proposal and is considered to be a conservative approximation of the demand that can be expected to realise over the next regulatory period.

2. AER's concern:

- *Insufficient consideration of non-network and/or demand management options to defer or avoid the proposed augmentation at Wishart*

Key finding: Available non-network and DM options were considered in the analysis. The majority of these available options do not provide a viable alternative security of supply solution. The proposed investment option provides a marginally lower net present cost in comparison with the network augmentation investment, however provides a more conservative investment approach that allows for the close monitoring of demand growth and assessment of investment need over the regulatory period.

The proposed investment option defers the network augmentation investment until after the regulatory period.

3. AER concern:

- *The scope and timing of the Wishart zone substation being driven by a proposed reduction of the capacity at Berrimah substation.*

Key finding: The main investment driver for Wishart substation is compliance with the Network Planning Criteria for security of supply to the existing and future loads in the Wishart supply area. Under a single transformer contingency an initial 1.7MW and up to 2.4MW of load at Wishart will not be able to be restored within the required timeframes. This risk assumes that the existing capacity at Berrimah substation is maintained.

The proposed non-network investment profile provides an interim security of supply solution deferring the need for establishing Wishart zone substation until after the regulatory period.

Disclaimer

The material in this document has been prepared by CutlerMerz.

Copyright and other intellectual property rights in this presentation vest exclusively with CutlerMerz. Apart from any use permitted under applicable copyright legislation, no part of this work may in any form or by any means (electronic, graphic, mechanical, photocopying, recording or otherwise) be reproduced, copied, stored in a retrieval system or transmitted without prior written permission.

© CutlerMerz Pty Ltd. All rights reserved.