

Instructions

This template must be used by **TasNetworks** to report service performance information for **2016** (1 Jul - 31 Dec 2016)

Inputs

- Blue, yellow and green worksheets are for inputs, including performance and exclusion information. The TNSP only needs to enter data on these worksheets.
 - To add more rows in the Inputs-exclusions tabs please insert rows after row 4.
- Cells where TNSP input is required are shaded orange:
- Cells where the input is sourced from the revenue proposal are shaded green:

TNSP input required
revenue proposal

Calculations

- Purple worksheets are the s-factor results based on the performance inputs entered by the TNSP. These are automatically calculated.
- cells where a calculation occurs are shaded grey with orange text:

calculation cell

Outcomes

- The red worksheet shows the total performance, s-factor and financial incentive results based on the TNSP's performance inputs.

										Performance				Number of events pa - 2016				Number of events pa - 2015				Average (2015, 2016)							
										without exclusions		with exclusions		without exclusions		with exclusions		No. of defined circuits		without exclusions		with exclusions		No. of defined circuits					
s1	Average circuit outage rate (%)					64.59	31.17	13.39	0.2	Unit	average circuit outage rate (%)				25.8	23.9	31	30	1	106	24	21	3	107					
s2	line outage - fault					17.28	11.60	7.03	0.2		average circuit outage rate (%)				8.3	8.3	10	10	0	109	8	8	0	109					
s3	transformer outage - fault					9.99	3.33	0.17	0.1		average circuit outage rate (%)				4.2	4.2	0	0	0	12	1	1	0	12					
s4	reactive plant - fault					17.62	9.99	2.67	0.0		average circuit outage rate (%)				14.1	12.2	20	19	1	106	10	7	3	107					
s5	line outage - forced					4.37	2.82	1.28	0.0		average circuit outage rate (%)				11.5	11.5	11	11	0	109	14	14	0	109					
s6	transformer outage - forced					32.82	14.00	1.07	0.0		average circuit outage rate (%)				12.5	12.5	0	0	0	12	3	3	0	12					
s6	reactive plant - forced																												
Loss of supply event frequency																													
s7	>0.10 system minutes					11	10	8	0.15	number of events per annum	1				1	0													
s8	>1.00 system minutes					5	3	0	0.15	number of events per annum	1				1	0													
Average outage duration																													
s9	Average outage duration					169.76	111.52	63.99	0.2	number of LOS events	13				12	1	13	11	2	12	12	0	13	12	1				
Proper operation of equipment																													
s10	Aggregate LOS minutes					530	524	5		Aggregate LOS minutes	44				44	3	176	166	10	883	883	0	530	524	5				
s11	Average outage duration					44	44	3		Average outage duration	1				1	0	14	15	5	74	74	0	44	44	3				
s12	number of events per annum					1	1	0		number of events per annum	2				2	0													
number of events per annum										6				6	0														
TNSP										TasNetworks																			
STPIS version										December, 2012																			
Regulatory Determination										2014/15 - 2017/18																			
Base Year Allowed Revenue										186,931,284																			
Base Year										2014-15																			
Commencement of regulatory year										1 Jul 2014																			
X factor										9.81%										2.31%									
Annual revenue (\$2014-15)										2014-15	2015-16	2016-17	2017-18	2018-19	Dec-13	Dec-14	Dec-15	Dec-16	Dec-17	Dec-18									
Annual revenue adjusted for CPI										186,931,284	171,494,719	170,366,992			CPI 104.8	106.6	108.4												
Calendar year reve										2H 2015	2016	2017	2018	1H 2019															
Revenue										85,747,359	170,930,855																		
Other inputs																													
Assessment Period										2016																			
Financial year to affect revenue:										2017/18																			
Date prepared:																													
Revision date:																													

Parameter	Average circuit outage rate	Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Count of circuit events	Circuits affected	Reasons for exclusion request	Further references	
	Name of any average circuit outage rate parameters applying to TasNetworks	Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	Identify the events that are to be excluded from the performance measure	Name of circuits affected	Full details of the reason/s for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg. Exclusion 1.2 Third party event.	A TNSP may provide further details of an exclusion event. Please provide reference to any attachments submitted.	AER staff assessme nt
S									
S1	Average circuit outage rate fault (%) - lines	IR2116 LI-WY 220 kV transmission circuit tripped at 9/02/2016 1:25:00 PM due to inter-trip from generation.	At the same time as GO–CS No 2 trip, a restricted earth fault relay (64R) installed on Hydro's generator transformer T5 at Wayatinah Substation mal operated and sent a permissive intertrip signal to Liapootah differential relay E187A and E187/121B and tripped circuit breaker E152 at Liapootah Substation disconnecting the Liapootah–Wayatinah 220 kV transmission circuit.	Intertrip		LI-WY 220 kV Transmission Circuit	outage primarily caused or initiated by a fault or other event on a third party system —e.g. intertrip signal, generator outage, customer installation	See investigation report IIR2115	Details match internal report provided . However link to third party email verifying event doesn't work (Hydro)
S2	Average circuit outage rate fault (%) - transformers				0				
S3	Average circuit outage rate fault (%) - reactive plant				0				
S4	Average circuit outage rate forced (%) - lines	Forced outage of PO-PM 5 220 kV Transmission Circuit at 27/01/2016 8:56:00 AM	Isolation Points:Open onlyWorkPlanned: Opened Off only for Hydro Transformer maintenance.	Generator request		PO-PM 5 220 kV Transmission Circuit	outage primarily caused or initiated by a fault or other event on a third party system — intertrip signal		??
S5	Average circuit outage rate forced (%) - transformers				0				
S6	Average circuit outage rate forced (%) - reactive plant				0				


Parameter	LOS event frequency	Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Start date	Start time	End date	End time	Quantitative impact	Demand shed and time	Circuits affected	Maximum system demand	Reasons for exclusion request	Further references	
	Name of any LOS event parameters applying to TasNetworks	Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	dd/mm/yy	hh:mm:ss	dd/mm/yy	hh:mm:ss	Hours+Minutes unavailable (min)	Impact of exclusion event on LOS parameter	The (MW) demand shed and the duration it was shed for.	Name of circuits or plant affected	The max system demand that occurred up until the time of the event	Full details of the reason/s for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg.	A TNSP may provide further details of an exclusion event. Please provide reference to any attachments submitted.
S															
	S7								0:00						
	S8								0:00						

Average Outage Duration	Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Start date	Start time	End date	End time	Hours+Minutes unavailable (min)	Quantitative impact of exclusion event on AOD Parameter	Capped impact of capped exclusion event on AOD	Circuits affected	Reasons for exclusion request	Further references	AER staff assessment	Follow-up
	Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	dd/mm/yy	hh:mm:ss	dd/mm/yy	hh:mm:ss					Full details of the reason for excluding this event. Should include a reference to the defined exclusions and explain how it meets this exclusion definition (see Exclusion definition tab). Eg. Exclusion 1.2 Third party event	A TNSP may provide further details of an exclusion event. Please provide reference to any attachments submitted.		
s9	Newton pumps	The Queenstown–Netwton 110 kV transmission circuit tripped and auto reclosed after dead time. The 11 kV feeder NT-D352 that supplies Newton pump at also tripped at the same time of the QT-NT 110 kV transmission circuit trip and was reclosed by Power System Coordinator after 2 minutes. Pumping load was approximately 3 MW at the time.	Adverse weather	13/08/16	19:01:00	13/08/16	19:03:00	0:02	1	0:02	Newton D352 11 kV feeder	interruption of infrequent, occasional load (such as pumping stations) where accurate estimate of load profiles is unreliable	See investigation report IR2149, and Newton schematic diagram		Details ve How does claim fit with exclusion definitions? Is it a
s9	TEMCO load block trip	See investigation report IR2135. Inappropriate configuration of TEMCO caused a load trip during protection testing.	Customer equipment configuration	17/05/16	10:13:00	17/05/16	10:21:00	0:08	1	0:08	TEMCO load shedding	outage primarily caused by equipment configuration on a third party system — customer installation	See investigation report IR2135 TEMCO UFLS trip		Details verified from internal report

99 - should not be included?


Performance Targets						Performance Outcomes			without exclusions	with exclusions
	Graph start	Collar	Target	Cap	Graph end					
line outage - fault	84.6%	64.6%	31.2%	13.4%	-1.4%	line outage - fault	=	26%	24%	
Weighting	-0.2000%	-0.2000%	0.0000%	0.2000%	0.2000%	S-Factor	=	0.06%	0.08%	

Performance Formulae						Performance Conditions			
	Formulae					Conditions			
Performance	=	-0.0020				64.6% < line outage			
	=	-0.0060	x	line outage	+ 0.0019	31.2% ≤ line outage	≤	64.6%	
	=	-0.0112	x	line outage	+ 0.0035	13.4% ≤ line outage	≤	31.2%	
	=	0.0020				line outage	<	13.4%	




Performance Targets						Performance Outcomes		without	with
	Graph start	Collar	Target	Cap	Graph end			exclusions	exclusions
transformer outage - fault	37.30%	17.28%	11.60%	7.03%	-13.00%	transformer outage - fault	=	8%	8%
Weighting	-0.2000%	-0.2000%	0.0000%	0.2000%	0.2000%	S-Factor	=	0.15%	0.15%

Performance Formulae						Conditions				S- Calc 1	S- Calc 2
Performance	=	Formulae									
	=	-0.0020				17.28% < transformers outage				-0.0020	-0.0020
	=	-0.0352	x	transformers ou	+	0.0041	11.6% ≤ transformers outage	≤	17.3%	0.0012	0.0012
	=	-0.0438	x	transformers ou	+	0.0051	7.0% ≤ transformers outage	≤	11.6%	0.0015	0.0015
	=	0.0020				transformers outage	<	7.0%		0.0020	0.0020



Performance Targets	Graph start		Collar	Target	Graph end		Performance Outcomes		without	with	
									exclusions	exclusions	
reactive plant - fault	30.00%	9.99%	3.33%	0.17%	0.00%		reactive plant - fault	=	4%	4%	
Weighting	-0.10%	-0.10%	0.00%	0.10%	0.10%		S-Factor	=	-0.01%	-0.01%	
Performance Formulae	Formulae						Conditions			S- Calc 1	S- Calc 2
Performance	=	-0.0010					9.99% ≤ reactive plant outage		-0.0010	-0.0010	
	=	-0.0150	x	reactive plant i	+	0.0005	3.3% ≤ reactive plant outage	≤ 10.0%	-0.0001	-0.0001	
	=	-0.0316	x	reactive plant i	+	0.0011	0.2% ≤ reactive plant outage	≤ 3.3%	-0.0003	-0.0003	
	=	0.0010					reactive plant outage	< 0.2%	0.0010	0.0010	



Performance Targets						Performance Outcomes			
	Graph start	Collar	Target	Cap	Graph end			without exclusions	with exclusions
line outage - forced	17.40%	17.62%	9.99%	2.67%	2.90%	line outage - forced	=	14%	12%
Weighting	0.00%	0.00%	0.00%	0.00%	0.00%	S-Factor	=	0.00%	0.00%

Performance Formulae						Performance Formulae			
						Conditions		S- Calc 1	S- Calc 2
Performance	=	0.0000				17.62% ≤ line outage (force)		0.0000	0.0000
	=	0.0000	x	line outage (fo	+	10.0% ≤ line outage (force)	≤ 17.6%	0.0000	0.0000
	=	0.0000	x	line outage (fo	+	2.7% ≤ line outage (force)	≤ 10.0%	0.0000	0.0000
	=	0.0000				line outage (force)	< 2.7%	0.0000	0.0000

TasNetworks - s5 - transformer outage - forced

Performance Targets		Graph start	Collar	Target	Cap	Graph end	Performance Outcomes		without exclusions	with exclusions
transformer outage - forced		4.20%	4.37%	2.82%	1.28%	1.50%	transformer outage - forced		= 11%	= 11%
Weighting		0.00%	0.00%	0.00%	0.00%	0.00%	S-Factor		= 0.00%	= 0.00%
Performance Formulae		Formulae					Conditions		S- Calc 1	S- Calc 2
Performance		=	0.0000				4.37% ≤ transformers outage (force)		0.0000	0.0000
		=	0.0000	x	transformers ou	+	0.0000	2.8% ≤ transformers outage (force ≤	4.4%	0.0000
		=	0.0000	x	transformers ou	+	0.0000	1.3% ≤ transformers outage (force ≤	2.8%	0.0000
		=	0.0000				transformers outage (force <		1.3%	0.0000

TasNetworks - s6 - reactive plant - forced

Performance Targets		Graph start	Collar	Target	Cap	Graph end	Performance Outcomes		without exclusions	with exclusions
reactive plant - forced		32.60%	32.82%	14.00%	1.07%	1.30%	reactive plant - forced		= 13%	= 13%
Weighting		0.00%	0.00%	0.00%	0.00%	0.00%	S-Factor		= 0.00%	= 0.00%
Performance Formulae		Formulae					Conditions		S- Calc 1	S- Calc 2
Performance		=	0.0000				32.82% ≤ reactive plant outage (force)		0.0000	0.0000
		=	0.0000	x	reactive plant o	+	0.0000	14.0% ≤ reactive plant outage (for ≤	32.8%	0.0000
		=	0.0000	x	reactive plant o	+	0.0000	1.1% ≤ reactive plant outage (for ≤	14.0%	0.0000
		=	0.0000				reactive plant outage (for <		1.1%	0.0000

TasNetworks - s7 - Loss of supply event frequency: >0.10 system minutes

Performance Targets
>0.10 system minutes
Weighting

Graph start	Collar	Target	Cap	Graph end
12	11.0	10.0	8.0	0
-0.00150	-0.00150	0.00000	0.00150	0.00150

Performance Formulae

Performance

Formulae

Performance Outcomes
>0.10 system minutes
S-Factor

	without exclusions	with exclusions
=	1	1
=	0.15%	0.15%

Conditions

S- Calc 1 S- Calc 2

When:
11.0

<

No. of events
No. of events
No. of events
No. of events

=

10


=

9

=

8

-0.0015	-0.0015
0.0000	0.0000
0.0008	0.0008
0.0015	0.0015



TasNetworks - s8 - Loss of supply event frequency: >1.00 system minutes

Performance Targets
>1.00 system minutes
Weighting

Graph start	Collar	Target	Cap	Graph end
5	5.0	3.0	0.0	0
-0.0015	-0.0015	0.0000	0.0015	0.0015

Performance Formulae

Performance

Formulae

Performance Outcomes
>1.00 system minutes
S-Factor

	without exclusions	with exclusions
=	1	1
=	0.10%	0.10%

Conditions

S- Calc 1 S- Calc 2

When:
5.0

<

No. of events
No. of events
No. of events
No. of events
No. of events
No. of events

=

4

=

3

=

2


=

1

=

0

-0.0015	-0.0015
-0.0008	-0.0008
0.0000	0.0000
0.0005	0.0005
0.0010	0.0010
0.0015	0.0015



TasNetworks - s9 - Average outage duration

Performance Targets

Average outage duration	300	170	112	64	0
Weighting	-0.00200	-0.00200	0.00000	0.00200	0.00200

Performance Formulae

Formulae					
Performance	=	-0.0020			
	=	0.0000	x	No. of events	+ 0.0038
	=	0.0000	x	No. of events	+ 0.0047
	=	0.0020			


Performance Outcomes

Average outage duration	=		
S-Factor	=		

Conditions

When:					
170	<	No. of events			
111.52	≤	No. of events	≤	170	
63.99	≤	No. of events	≤	112	
	=	No. of events	=	64	

without exclusions	with exclusions
44	44
0.20%	0.20%
-0.0020	-0.0020
0.0023	0.0023
0.0029	0.0028
0.0020	0.0020



TasNetworks - Performance outcomes

Aggregate outcome	
S-factor	0.665%
Financial Incentive	\$1,136,743
Financial year affected by financial incentive	
2015–16	

S	Performance parameter	Target	Performance without exclusions			Performance with exclusions			Impact of exclusions
			Performance	S-Factor	Final Incentive	Performance	S-Factor	Final Incentive	
s1	line outage - fault	31.17%	25.82%	0.06%	\$102,835	23.94%	0.08%	\$138,943	0.02%
s2	transformer outage - fault	11.60%	8.26%	0.15%	\$250,084	8.26%	0.15%	\$250,084	0.00%
s3	reactive plant - fault	3.33%	4.17%	-0.01%	-\$21,473	4.17%	-0.01%	-\$21,473	0.00%
s4	line outage - forced	9.99%	14.08%	0.00%	\$0	12.21%	0.00%	\$0	0.00%
s5	transformer outage - forced	2.82%	11.47%	0.00%	\$0	11.47%	0.00%	\$0	0.00%
s6	reactive plant - forced	14.00%	12.50%	0.00%	\$0	12.50%	0.00%	\$0	0.00%
s7	LOS >0.10 system minutes	10	1	0.15%	\$256,396	1	0.15%	\$256,396	0.00%
s8	LOS >1.00 system minutes	3	1	0.10%	\$170,931	1	0.10%	\$170,931	0.00%
s9	Average outage duration	111.52	44	0.20%	\$341,862	44	0.20%	\$341,862	0.00%
TOTALS				0.64%	\$1,100,635		0.67%	\$1,136,743	0.02%

Revenue calendar year:	\$170,930,855
------------------------	---------------