



TransGrid

**TransGrid Revenue Proposal
2018/19 – 2022/23**

Appendix X

WSP Parsons Brinckerhoff:

**STPIS: Fitting probability curves to
reliability data**

TRANSGRID

Fitting probability distribution curves to reliability data

2015/16

FOR INTERNAL USE

SEPTEMBER 2016

Fitting probability distribution curves to reliability data


2015/16

TransGrid

For internal use

REV	DATE	DETAILS
A	26/08/2016	Draft for review
B	7/09/2016	Final

AUTHOR, REVIEWER AND APPROVER DETAILS

Prepared by:	Abbie McQueen	Date:	1/09/2016		
Reviewed by:	Peter Walshe	Date:	7/09/2016		
Approved by:	Peter Walshe	Date:	7/09/2016	Signature:	

WSP | Parsons Brinckerhoff

Level 27, Ernst & Young Centre
680 George Street
Sydney NSW 2000
GPO Box 5394
Sydney NSW 2001

Tel: +61 2 9272 5100
Fax: +61 2 9272 5101

www.wsp-pb.com

Filename: 2265080A-STC-REP-001 RevB.docx



This document may contain confidential and legally privileged information, neither of which are intended to be waived, and must be used only for its intended purpose. Any unauthorised copying, dissemination or use in any form or by any means other than by the addressee, is strictly prohibited. If you have received this document in error or by any means other than as authorised addressee, please notify us immediately and we will arrange for its return to us.

TABLE OF CONTENTS

1	INTRODUCTION	1
1.1	Approach	1
1.2	Parameter data	3
2	RESULTS OF DISTRIBUTION FITTING.....	4
2.1	Average circuit outage rate	4
2.2	Loss of supply event frequency	13
2.3	Average outage duration	16
2.4	Proper operation of equipment – number of failure events	17
2.5	Summary of findings.....	23
3	VALUES FOR PARAMETERS.....	24
3.1	STPIS requirements for parameter values	24
3.2	Caps and collars	25
3.3	Recommended parameter values.....	27

1 INTRODUCTION

WSP | Parsons Brinckerhoff was engaged by TransGrid to assist with the determination of suitable attributes for the parameters of its service target performance incentive scheme (STPIS). The parameters and sub-parameters of the service component of TransGrid's STPIS included in the review are:

- Average circuit outage rate
 - lines outage rate - fault
 - transformer outage rate - fault
 - reactive plant outage rate - fault
 - lines outage rate - forced outage
 - transformer outage rate - forced outage
 - reactive plant outage rate - forced outage
- loss of supply event frequency
- average outage duration
- proper operation of equipment
 - failure of protection system
 - material failure of Supervisory Control and Data Acquisition (SCADA) system
 - incorrect operational isolation of primary or secondary equipment

We note that the Proper Operation of Equipment parameter has an incentive weighting of zero and hence has no financial impact.

WSP | Parsons Brinckerhoff determined a curve of best fit to TransGrid's reliability data from the past five years 2012-2016 (2016 data is currently forecast) for each of the parameters and calculated the 5th and 95th percentile values on which proposed caps and collars for this scheme are based. Recommended values for the parameter targets, caps and collars are proposed.

1.1 Approach

WSP | Parsons Brinckerhoff used the @RISK product, a risk analysis and simulation add-in tool for Microsoft Excel, to determine the types of probability distribution that best fit the reliability data.

Recognising the need to present the best fit distribution curve based on the nature of the reliability data, the following distribution parameters were chosen for this exercise:

- Average circuit outage rates are fitted with continuous probability distributions bounded at a lower limit of zero.
- Loss of supply event frequency are fitted with discrete probability distributions.
- Average outage duration data are fitted using continuous probability distributions bounded at a lower limit of zero.

Three key fit statistics were used to measure how well the probability distribution functions fit the input data. For discrete probability distributions, the Akaike Information Criterion (AIC) was used. For non-discrete distributions, the Kolmogorov-Smirnov (K-S) and the Anderson-Darling (A-D) fit statistics were used, based on the following rationale:

- Discrete data:

- For discrete probability distributions, tests relied on are the chi-square, the Akaike Information Criterion (AIC) and the Bayesian Information Criterion (BIC).
 - For the chi-square approximation to be valid the expected frequency in each interval bin should be at least 5. As this is not possible with only 5 values in the dataset (one value for each year 2011 to 2015), some uncertainty in the fitted distribution will occur.
 - AIC is a measure of the relative quality of a statistical model for a given set of data. AIC deals with the trade-off between the goodness of fit of the model and the complexity of the model. It is founded on information entropy: it offers a relative estimate of the information lost when a given model is used to represent the process that generates the data. As such, AIC provides a means for model selection.
 - BIC is closely related to the AIC, with a greater penalty for the number of parameters in the model. It is only valid for sample sizes much larger than the number of parameters in the model and is therefore likely to be inaccurate for small sample sizes.
 - AIC is considered to provide a more appropriate methodology for determining the curve of best fit to small datasets than the chi-square or BIC.
- Continuous data:
- For non-discrete distributions, tests relied on are the chi-square, the Kolmogorov-Smirnov (K-S), the Anderson-Darling (A-D), and the AIC and BIC.
 - The chi-square test, as discussed above, will have some uncertainty in the fitted distribution for small sample sizes.
 - The K-S fit statistic focuses on the differences between the middle of the fitted distribution and the input data. The A-D fit statistic focuses on the difference between the tails of fitted distribution and input data. Hence, where the input data is concentrated around the middle of a distribution curve the K-S fit statistic is preferred and where the data is near the tails the A-D fit statistic is preferred. The results from both were compared in each case. Where the input data was both in the middle and the tails of a distribution, the result from the A-D fit statistic was favoured, because the best fit of the data and the distribution curve at the tails improves the calculation of the scheme measures.
 - The AIC test, as discussed above, is a valid test and is preferred over the BIC for small sample sizes.
 - Given that the A-D test focusses on the goodness of fit in the tails of the distribution, the A-D test is preferred when the performance data has data in the tails as this is the part of the distribution of most interest in setting collars. Otherwise the K-S or AIC tests are appropriate.

Where the A-D and K-S tests identify different probability distribution functions of best fit, the shape of the distribution of the data is examined. Where it is distributed across both the middle and tails of the distribution, the A-D fit statistic is preferred, where it is distributed across only the middle of the distribution the K-S statistic is preferred.

Once the probability distribution function of best fit for the preferred fit statistic was verified for each parameter the standard deviation was examined against the standard deviation of the curve of second best fit. Because a probability distribution is being fitted to a dataset of five values only for each parameter, the fit statistics are typically low in value and the curve of best fit is sensitive to small changes in any of the five values. The standard deviation is a reasonable indicator about the similarity of the curves.

The curve of second best fit is examined to test for any large variations in the calculated values that might indicate that the curve of best fit should not have been used. Where standard deviation suggest that the curve of best fit should not have been used a number of other parameters may be examined:

- the 5th and 95th percentile values of the probability distribution functions- As these values were used to set the caps and collars, where the 5th and 95th percentile values of the curve of best fit and the curve of second best fit align, the curve of best fit is likely to be appropriate to use.
- the underlying data - A distribution may be chosen that best reflects the shape and spread of the underlying data,
- other fit statistics – The results of other fit statistics may indicate the use of another curve.
- longer run data to assist in improving the fit statistic.

Figure 1.1 shows where the information about the fit statistic and distribution is located on the charts that are produced by @RISK.




Figure 1.1 @Risk information locations

1.2 Parameter data

Table 1.1 shows the data used to calculate the parameter values.

The 2016 data has been estimated based on the 'year to date' values prorated until the end of the year.

Table 1.1 Reliability Data 2012-2016

PARAMETER	EST. 2016	2015	2014	2013	2012
LINES OUTAGE RATE – FAULT	13.27%	11.41%	10.23%	18.36%	16.65%
TRANSFORMERS OUTAGE RATE – FAULT	19.76%	13.06%	10.84%	18.14%	16.38%
REACTIVE PLANT OUTAGE RATE – FAULT	11.00%	9.47%	15.65%	9.90%	15.71%
LINES OUTAGE RATE - FORCED OUTAGE	7.58%	22.82%	17.05%	21.34%	8.07%
TRANSFORMERS OUTAGE RATE - FORCED OUTAGE	18.66%	31.02%	39.02%	23.64%	20.33%
REACTIVE PLANT OUTAGE RATE - FORCED OUTAGE	26.41%	26.96%	22.36%	24.38%	13.47%
NO. OF EVENTS >0.05 SYSTEM MINUTES	2	4	3	5	3
NO. OF EVENTS >0.25 SYSTEM MINUTES	0	3	0	0	1
AVERAGE OUTAGE DURATION	262.64	63.55	71.14	178.69	94.23
FAILURE OF PROTECTION SYSTEM	23	21	24	11	20
MATERIAL FAILURE OF SUPERVISORY CONTROL AND DATA ACQUISITION (SCADA) SYSTEM	5	3	6	3	21
INCORRECT OPERATIONAL ISOLATION OF PRIMARY OR SECONDARY EQUIPMENT	3	9	6	10	7

2 RESULTS OF DISTRIBUTION FITTING

This section contains an explanation of the fitting for each parameter, followed by a summary of the distribution fittings.

2.1 Average circuit outage rate

Average circuit outage rates represent measures of availability for components of transmission circuits. The optimal performance limit is 0%, which represents total availability for the component for the year; as such a lower limit of zero is set for fitting curves to the data.

2.1.1 Lines outage rate – fault performance

The data for Lines outage rate is best fitted with a Weibull distribution according to the K-S fit statistic (Figure 2.1) and best fitted with LogLogistic distribution according to the A-D fit statistic (Figure 2.2).

As the data is distributed across both the middle and tails of the distribution, the A-D fit statistic is preferred (LogLogistic), giving a standard deviation of 0.03642. The standard deviation for the curve of second best fit for the A-D fit statistic (Pearson 5) is 0.03216, being only slightly lower than for the preferred curve, indicating that LogLogistic is appropriate.

LogLogistic is also the curve of third best fit for the K-S fit statistic.




Figure 2.1 Lines – fault, comparison using K-S




Figure 2.2 Lines – fault, comparison using A-D

As shown in Figure 2.3, the 5th and 95th percentile parameters for the preferred curve are 9.1% and 20.4% respectively.

Fit	A-D	Value	Input	Loglogistic	Pearson5	Invgauss	Lognorm	Gamma	Weibull	Uniform	Expon	Levy	Triang
<input checked="" type="checkbox"/> Loglogistic		0.2501	5%	0.1023	0.0906	0.0962	0.0950	0.0949	0.09340	0.0850	0.0115	0.00717	0.0347
<input checked="" type="checkbox"/> Pearson5		0.2620	10%	0.1023	0.1005	0.1034	0.1029	0.1028	0.10218	0.0979	0.0230	0.0147	0.0492
<input type="checkbox"/> Invgauss		0.2661	15%	0.1023	0.1071	0.1087	0.1086	0.1086	0.10840	0.1066	0.0344	0.0227	0.0643
<input type="checkbox"/> Lognorm		0.2671	20%	0.1023	0.1123	0.1131	0.1133	0.1133	0.11354	0.1135	0.0459	0.0312	0.0811
<input type="checkbox"/> Gamma		0.2733	25%	0.1141	0.1169	0.1171	0.1176	0.1176	0.11807	0.1193	0.0574	0.0402	0.1007
<input checked="" type="checkbox"/> Weibull		0.2890	30%	0.1141	0.1210	0.1209	0.1215	0.1216	0.12224	0.1244	0.0689	0.0499	0.1240
<input type="checkbox"/> Uniform		0.9646	35%	0.1141	0.1248	0.1245	0.1253	0.1253	0.12620	0.1292	0.0803	0.0602	0.1525
<input type="checkbox"/> Expon		1.4272	40%	0.1141	0.1286	0.1281	0.1290	0.1291	0.13003	0.1336	0.0918	0.0714	0.1881
<input type="checkbox"/> Levy		1.9975	45%	0.1327	0.1322	0.1317	0.1327	0.1327	0.13381	0.1378	0.1033	0.0836	0.2335
<input type="checkbox"/> Triang		---	50%	0.1327	0.1359	0.1354	0.1365	0.1365	0.13760	0.1418	0.1148	0.0969	0.2929
<input type="checkbox"/> BetaGeneral		N/A	55%	0.1327	0.1397	0.1392	0.1403	0.1403	0.14146	0.1458	0.1262	0.1117	0.3729
<input type="checkbox"/> Pareto		N/A	60%	0.1665	0.1437	0.1432	0.1443	0.1443	0.14546	0.1498	0.1377	0.1281	0.4845
<input type="checkbox"/> Pearson6		N/A	65%	0.1665	0.1480	0.1475	0.1486	0.1486	0.14967	0.1539	0.1492	0.1468	0.6471
			70%	0.1665	0.1528	0.1523	0.1533	0.1532	0.15419	0.1581	0.1607	0.1684	0.8974
			75%	0.1665	0.1581	0.1576	0.1584	0.1584	0.15918	0.1625	0.1721	0.1939	1.3122
			80%	0.1665	0.1645	0.1639	0.1644	0.1643	0.16485	0.1674	0.1836	0.2251	2.0758
			85%	0.1836	0.1726	0.1716	0.1716	0.1716	0.17162	0.1729	0.1951	0.2653	3.7251
			90%	0.1836	0.1840	0.1820	0.1811	0.1811	0.18041	0.1796	0.2066	0.3220	8.4374
			95%	0.1836	0.2039	0.1990	0.1961	0.1962	0.19396	0.1891	0.2181	0.4189	33.8830

Figure 2.3 Lines – fault, distribution percentiles

2.1.2 Transformers outage rate – fault performance

The data for Transformer outage rate is best fitted with a Weibull distribution according to both the K-S statistic (Figure 2.4) and the A-D fit statistic (Figure 2.5).




Figure 2.4 Transformers – fault, comparison using K-S




Figure 2.5 Transformers – fault, comparison using A-D

As shown in Figure 2.6, the 5th and 95th percentile parameters for the preferred curve are 10.1% and 20.5% respectively.

Fit	Value	Percentiles	Input	Weibull	Gamma	Lognorm	Invgauss	Pearson6	Pearson5	BetaGeneral	Triang	Uniform	Expon	Levy
Weibull	0.2001	5%	0.1084	0.1011	0.10531	0.1063	0.1063	0.10709529	0.1071	0.0699	0.0442	0.0124	0.00802	0.0388
Gamma	0.2133	10%	0.1084	0.1146	0.11499	0.1152	0.1151	0.11521611	0.1152	0.0963	0.0625	0.0247	0.0165	0.0551
Lognorm	0.2241	15%	0.1084	0.1236	0.12185	0.1215	0.1214	0.12117004	0.1212	0.1150	0.0765	0.0371	0.0254	0.0719
Invgauss	0.2253	20%	0.1084	0.1306	0.12750	0.1269	0.1267	0.12620068	0.1262	0.1296	0.0884	0.0494	0.0349	0.0907
Pearson6	0.2348	25%	0.1306	0.1365	0.13249	0.1316	0.1315	0.13074246	0.1307	0.1415	0.0988	0.0618	0.0450	0.1126
Pearson5	0.2348	30%	0.1306	0.1417	0.13707	0.1361	0.1359	0.13500979	0.1350	0.1515	0.1082	0.0741	0.0558	0.1387
BetaGeneral	0.2654	35%	0.1306	0.1465	0.14142	0.1403	0.1401	0.13913218	0.1391	0.1598	0.1169	0.0865	0.0674	0.1706
Triang	0.3009	40%	0.1306	0.1509	0.14563	0.1444	0.1443	0.14320103	0.1432	0.1670	0.1250	0.0988	0.0799	0.2103
Uniform	0.4388	45%	0.1638	0.1551	0.14978	0.1486	0.1484	0.14729036	0.1473	0.1731	0.1326	0.1112	0.0935	0.2611
Expon	0.5001	50%	0.1638	0.1591	0.15394	0.1527	0.1526	0.15146836	0.1515	0.1783	0.1397	0.1235	0.1084	0.3275
Levy	0.6148	55%	0.1638	0.1631	0.15818	0.1570	0.1569	0.15580576	0.1558	0.1827	0.1466	0.1359	0.1249	0.4170
Loglogistic	N/A	60%	0.1814	0.1670	0.16257	0.1615	0.1614	0.16038399	0.1604	0.1864	0.1531	0.1482	0.1433	0.5418
Pareto	N/A	65%	0.1814	0.1710	0.16718	0.1663	0.1662	0.16530580	0.1653	0.1894	0.1593	0.1606	0.1642	0.7236
		70%	0.1814	0.1751	0.17214	0.1714	0.1714	0.17071201	0.1707	0.1919	0.1653	0.1729	0.1883	1.0035
		75%	0.1814	0.1795	0.17760	0.1772	0.1771	0.17681231	0.1768	0.1939	0.1711	0.1853	0.2168	1.4674
		80%	0.1814	0.1842	0.18381	0.1839	0.1838	0.18394954	0.1839	0.1954	0.1768	0.1976	0.2517	2.3212
		85%	0.1976	0.1896	0.19123	0.1919	0.1918	0.19275740	0.1928	0.1965	0.1822	0.2100	0.2966	4.1656
		90%	0.1976	0.1961	0.20084	0.2026	0.2025	0.20464740	0.2046	0.1972	0.1875	0.2223	0.3600	9.4350
		95%	0.1976	0.2053	0.21566	0.2195	0.2192	0.22410886	0.2241	0.1975	0.1926	0.2347	0.4684	37.8891

Figure 2.6 Transformers – fault, distribution percentiles

2.1.3 Reactive plant outage rate – fault performance

The data for Reactive plant unavailability due to fault is best fitted with a LogLogistic distribution according to both the K-S fit statistic (Figure 2.7) and the A-D fit statistic (Figure 2.8).




Figure 2.7 Reactive plant – fault, comparison using K-S




Figure 2.8 Reactive plant – fault, comparison using A-D

As shown in Figure 2.9, the 5th and 95th percentile parameters for the preferred curve are 7.9% and 17.9% respectively.

Fit	A-D	Value	Input	Loglogistic	Pearson6	Pearson5	Invgauss	Lognorm	Gamma	BetaGeneral	Weibull	Uniform	Expon	Levy
Loglogistic	5%	0.0947	0.0947	0.0788	0.08517295	0.0852	0.0840	0.0838	0.08226	0.0793	0.0743	0.00982	0.00633	0.0306
Pearson6	10%	0.0947	0.0947	0.0875	0.09148754	0.0915	0.0909	0.0908	0.09004	0.0885	0.0858	0.0196	0.0130	0.0435
Pearson5	15%	0.0947	0.0947	0.0933	0.09610877	0.0961	0.0959	0.0958	0.09556	0.0950	0.0936	0.0295	0.0201	0.0568
Invgauss	20%	0.0947	0.0947	0.0980	0.10000806	0.1000	0.1001	0.1001	0.10012	0.1002	0.0998	0.0393	0.0276	0.0716
Lognorm	25%	0.0990	0.0990	0.1020	0.10352437	0.1035	0.1038	0.1038	0.10414	0.1047	0.1050	0.0491	0.0355	0.0889
Gamma	30%	0.0990	0.0990	0.1056	0.10662477	0.1068	0.1073	0.1073	0.10784	0.1088	0.1096	0.0589	0.0440	0.1095
BetaGeneral	35%	0.0990	0.0990	0.1090	0.11001003	0.1100	0.1107	0.1107	0.11135	0.1127	0.1138	0.0687	0.0532	0.1347
Weibull	40%	0.0990	0.0990	0.1123	0.11315104	0.1132	0.1139	0.1139	0.11475	0.1163	0.1178	0.0786	0.0631	0.1661
Uniform	45%	0.1100	0.1100	0.1156	0.11630503	0.1163	0.1172	0.1172	0.11811	0.1199	0.1216	0.0884	0.0738	0.2062
Expon	50%	0.1100	0.1100	0.1189	0.11952457	0.1195	0.1205	0.1205	0.12148	0.1234	0.1252	0.0982	0.0856	0.2386
Levy	55%	0.1100	0.1100	0.1223	0.12286394	0.1229	0.1239	0.1239	0.12491	0.1269	0.1289	0.1080	0.0986	0.3293
Triang	60%	0.1565	0.1565	0.1258	0.12638550	0.1264	0.1275	0.1275	0.12846	0.1305	0.1325	0.1178	0.1131	0.4278
Pareto	65%	0.1565	0.1565	0.1296	0.13016774	0.1302	0.1312	0.1312	0.13220	0.1342	0.1361	0.1276	0.1296	0.5714
	70%	0.1565	0.1565	0.1338	0.13431802	0.1343	0.1353	0.1353	0.13622	0.1381	0.1399	0.1375	0.1487	0.7924
	75%	0.1565	0.1565	0.1386	0.13899599	0.1390	0.1399	0.1399	0.14064	0.1423	0.1439	0.1473	0.1712	1.1588
	80%	0.1565	0.1565	0.1443	0.14446238	0.1445	0.1451	0.1451	0.14568	0.1469	0.1483	0.1571	0.1987	1.8331
	85%	0.1571	0.1571	0.1515	0.15119862	0.1512	0.1515	0.1514	0.15171	0.1523	0.1533	0.1669	0.2343	3.2896
	90%	0.1571	0.1571	0.1616	0.16027575	0.1603	0.1599	0.1599	0.15951	0.1589	0.1594	0.1767	0.2843	7.4509
	95%	0.1571	0.1571	0.1793	0.17509485	0.1751	0.1731	0.1732	0.17156	0.1686	0.1680	0.1866	0.3699	29.9217

Figure 2.9 Reactive plant – fault, distribution percentiles

2.1.4 Lines outage rate – forced outage performance

The data for lines forced to be unavailable is best fitted with a Uniform distribution according to both the K-S fit statistic (Figure 2.10) and the A-D fit statistic (Figure 2.11).




Figure 2.10 Lines – forced, comparison using K-S




Figure 2.11 Lines – forced, comparison using A-D

As shown in Figure 2.12, the 5th and 95th percentile parameters for the preferred curve are 1.4% and 27.1% respectively.

Fit	Value	Percentiles	Input	Uniform	Lognorm	Gamma	Invgauss	Triang	Weibull	Pearson6	Pearson5	Expon	Levy
Uniform	0.2658	5%	0.0758	0.0143	0.0633	0.0601	0.0640	0.0510	0.0577	0.06574298	0.0657	0.00789	0.0321
Lognorm	0.2712	10%	0.0758	0.0285	0.0752	0.0743	0.0752	0.0722	0.0754	0.07572880	0.0757	0.0162	0.0456
Gamma	0.2715	15%	0.0758	0.0428	0.0845	0.0852	0.0841	0.0884	0.0885	0.08366420	0.0837	0.0250	0.0596
Invgauss	0.2741	20%	0.0758	0.0571	0.0927	0.0946	0.0920	0.1021	0.0996	0.09079514	0.0908	0.0343	0.0752
Triang	0.2748	25%	0.0807	0.0713	0.1004	0.1032	0.0995	0.1141	0.1095	0.09758230	0.0976	0.0442	0.0933
Weibull	0.2809	30%	0.0807	0.0856	0.1078	0.1114	0.1068	0.1250	0.1185	0.10427230	0.1043	0.0548	0.1149
Pearson6	0.2879	35%	0.0807	0.0998	0.1152	0.1194	0.1141	0.1350	0.1272	0.11103282	0.1110	0.0662	0.1413
Pearson5	0.2879	40%	0.0807	0.1141	0.1227	0.1273	0.1215	0.1443	0.1355	0.11800166	0.1180	0.0785	0.1743
Expon	0.2894	45%	0.1705	0.1284	0.1304	0.1353	0.1291	0.1531	0.1436	0.12531132	0.1253	0.0919	0.2163
Levy	0.5379	50%	0.1705	0.1426	0.1384	0.1435	0.1372	0.1614	0.1517	0.13310597	0.1331	0.1066	0.2713
BetaGeneral	N/A	55%	0.1705	0.1569	0.1470	0.1520	0.1457	0.1692	0.1599	0.14155818	0.1416	0.1228	0.3454
Loglogistic	N/A	60%	0.2134	0.1712	0.1562	0.1610	0.1550	0.1768	0.1683	0.15089071	0.1509	0.1409	0.4489
Pareto	N/A	65%	0.2134	0.1854	0.1663	0.1706	0.1651	0.1840	0.1770	0.16141050	0.1614	0.1614	0.5995
		70%	0.2134	0.1997	0.1777	0.1812	0.1766	0.1909	0.1862	0.17356824	0.1736	0.1851	0.8314
		75%	0.2134	0.2139	0.1908	0.1931	0.1898	0.1976	0.1963	0.18807444	0.1881	0.2131	1.2157
		80%	0.2134	0.2282	0.2067	0.2070	0.2056	0.2041	0.2074	0.20615372	0.2062	0.2474	1.9231
		85%	0.2282	0.2425	0.2267	0.2239	0.2256	0.2104	0.2205	0.23019652	0.2302	0.2916	3.4512
		90%	0.2282	0.2567	0.2548	0.2464	0.2533	0.2165	0.2370	0.26588389	0.2659	0.3540	7.8168
		95%	0.2282	0.2710	0.3029	0.2824	0.3000	0.2224	0.2613	0.33304990	0.3331	0.4605	31.3910

Figure 2.12 Lines – forced, distribution percentiles

2.1.5 Transformers outage rate – forced outage performance

The data for forced unavailability of transformers is best fitted with a LogLogistic distribution curve according to both the K-S fit statistic (Figure 2.13) and A-D fit statistic (Figure 2.14).




Figure 2.13 Transformers – forced, comparison using K-S




Figure 2.14 Transformers – forced, forced, comparison using A-D

As shown in Figure 2.15, the 5th and 95th percentile parameters for the preferred curve are 15.3% and 41.0% respectively.

Rank By	A-D	Value	Input	Logistic	Pearson5	Invgauss	Lognorm	Gamma	Weibull	BetaGeneral	Uniform	Expon	Levy	Triang
Fit														
Logistic	0.2634	5%	0.1866	0.1529	0.1672	0.1634	0.1628	0.1576	0.1338	0.1232	0.0244	0.0136	0.0641	0.0873
Pearson5	0.2705	10%	0.1866	0.1733	0.1822	0.1802	0.1779	0.1771	0.1620	0.1557	0.0488	0.0260	0.0911	0.1234
Invgauss	0.2830	15%	0.1866	0.1873	0.1934	0.1925	0.1923	0.1911	0.1817	0.1791	0.0732	0.0431	0.1189	0.1511
Lognorm	0.2840	20%	0.1866	0.1986	0.2029	0.2030	0.2029	0.2027	0.1976	0.1982	0.0976	0.0592	0.1500	0.1745
Gamma	0.3000	25%	0.2033	0.2094	0.2116	0.2124	0.2123	0.2131	0.2114	0.2148	0.1220	0.0763	0.1862	0.1951
Weibull	0.3196	30%	0.2033	0.2174	0.2199	0.2213	0.2212	0.2227	0.2238	0.2297	0.1463	0.0946	0.2294	0.2137
BetaGeneral	0.4335	35%	0.2033	0.2258	0.2279	0.2299	0.2298	0.2319	0.2352	0.2435	0.1707	0.1143	0.2821	0.2309
Uniform	0.6910	40%	0.2033	0.2341	0.2359	0.2384	0.2383	0.2409	0.2461	0.2563	0.1951	0.1355	0.3478	0.2468
Expon	1.2557	45%	0.2364	0.2422	0.2440	0.2469	0.2467	0.2497	0.2566	0.2684	0.2195	0.1586	0.4318	0.2618
Levy	1.8740	50%	0.2364	0.2505	0.2523	0.2556	0.2554	0.2587	0.2668	0.2801	0.2439	0.1839	0.5416	0.2759
Triang	...	55%	0.2364	0.2591	0.2610	0.2646	0.2643	0.2678	0.2770	0.2914	0.2683	0.2119	0.6895	0.2894
Pareto	N/A	60%	0.3102	0.2681	0.2703	0.2740	0.2737	0.2773	0.2873	0.3024	0.2927	0.2431	0.8960	0.3023
Pearson6	N/A	65%	0.3102	0.2779	0.2803	0.2841	0.2837	0.2874	0.2979	0.3133	0.3171	0.2786	1.1966	0.3146
		70%	0.3102	0.2887	0.2914	0.2952	0.2947	0.2983	0.3089	0.3242	0.3415	0.3195	1.6595	0.3265
		75%	0.3102	0.3012	0.3041	0.3076	0.3071	0.3103	0.3206	0.3352	0.3659	0.3679	2.4267	0.3380
		80%	0.3102	0.3160	0.3191	0.3220	0.3214	0.3241	0.3336	0.3465	0.3902	0.4271	3.8386	0.3490
		85%	0.3902	0.3350	0.3378	0.3396	0.3390	0.3407	0.3484	0.3583	0.4146	0.5034	6.8888	0.3598
		90%	0.3902	0.3621	0.3634	0.3631	0.3625	0.3623	0.3668	0.3711	0.4390	0.6110	15.6030	0.3702
		95%	0.3902	0.4104	0.4063	0.4006	0.4004	0.3959	0.3933	0.3860	0.4634	0.7949	62.6587	0.3804

Figure 2.15 Transformers - forced, distribution percentiles

2.1.6 Reactive plant outage rate – forced outage performance

The best fit distribution curve for Reactive plant forced outage performance data for the K-S fit statistic is the BetaGeneral distribution (Figure 2.16), while the A-D fit statistic indicates a Weibull distribution (Figure 2.17).

As the data is distributed across both the middle and tails of the distribution, the A-D fit statistic is preferred (Weibull), giving a standard deviation of 0.041. The standard deviation for the curve of second best fit using the A-D statistic (Gamma) is 0.054, 34% lower than the preferred curve.

As the comparison of the standard deviation of the curve of best fit and the curve of second best fit using the preferred fit statistics did not confirm the use of the curve of best fit, the 5th and 95th percentile parameters were examined. The 5th and 95th percentile parameters are 7% and 12% lower for the curve of second best fit, respectively. This suggests that the impact on the caps and collars for this parameter will not be significant if the Weibull distribution is chosen.

The Weibull distribution is also the curve of second best fit using the K-S statistic, confirming the use of the Weibull distribution.




Figure 2.16 Reactive plant – forced, comparison using K-S




Figure 2.17 Reactive plant – forced, comparison using A-D

As shown in Figure 2.18, the 5th and 95th percentile parameters for the preferred curve are 15.6% and 29.0% respectively.

Fit	A-D	Value	Input	Weibull	Gamma	Lognorm	Invgauss	Pearson6	Pearson5	Uniform	Expon	Levy	Triang	BetaGeneral
5%		0.5092	0.1347	0.1564	0.1454	0.1449	0.1445	0.14419508	0.1442	0.0168	0.0117	0.0554	0.0603	0.1153
10%		0.6194	0.1347	0.1745	0.1606	0.1590	0.1583	0.15719300	0.1572	0.0337	0.0239	0.0787	0.0852	0.1519
15%		0.6637	0.1347	0.1863	0.1714	0.1693	0.1685	0.16687017	0.1669	0.0505	0.0369	0.1027	0.1044	0.1766
20%		0.6761	0.1347	0.1955	0.1804	0.1779	0.1771	0.17514184	0.1751	0.0674	0.0507	0.1296	0.1206	0.1952
25%		0.7126	0.2236	0.2032	0.1883	0.1857	0.1848	0.18268327	0.1827	0.0842	0.0653	0.1608	0.1348	0.2099
30%		1.4655	0.2236	0.2099	0.1957	0.1930	0.1921	0.18983163	0.1898	0.1011	0.0810	0.1981	0.1477	0.2217
35%		1.4939	0.2236	0.2160	0.2026	0.1999	0.1990	0.19679409	0.1968	0.1179	0.0978	0.2436	0.1595	0.2315
40%		1.9745	0.2236	0.2216	0.2094	0.2068	0.2059	0.20372022	0.2037	0.1348	0.1160	0.3004	0.1705	0.2396
45%		---	0.2438	0.2270	0.2161	0.2136	0.2128	0.21073476	0.2107	0.1516	0.1358	0.3729	0.1808	0.2463
50%		---	0.2438	0.2321	0.2228	0.2206	0.2198	0.21795614	0.2180	0.1685	0.1574	0.4678	0.1906	0.2518
55%		---	0.2438	0.2372	0.2296	0.2278	0.2270	0.22551088	0.2255	0.1853	0.1814	0.5955	0.1999	0.2563
60%		---	0.2641	0.2422	0.2367	0.2354	0.2346	0.23354830	0.2335	0.2022	0.2081	0.7738	0.2088	0.2600
65%		---	0.2641	0.2472	0.2442	0.2434	0.2427	0.24226038	0.2423	0.2190	0.2285	1.0335	0.2173	0.2629
70%		---	0.2641	0.2524	0.2523	0.2522	0.2515	0.25191418	0.2519	0.2359	0.2735	1.4333	0.2255	0.2652
75%		---	0.2641	0.2578	0.2612	0.2621	0.2614	0.26291186	0.2629	0.2527	0.3149	2.0959	0.2335	0.2669
80%		---	0.2641	0.2637	0.2714	0.2735	0.2729	0.27591744	0.2759	0.2696	0.3656	3.3154	0.2411	0.2681
85%		---	0.2696	0.2704	0.2835	0.2875	0.2869	0.29216960	0.2922	0.2864	0.4309	5.9498	0.2485	0.2689
90%		---	0.2696	0.2785	0.2993	0.3061	0.3054	0.31445596	0.3145	0.3033	0.5230	13.4762	0.2557	0.2693
95%		---	0.2696	0.2898	0.3238	0.3358	0.3349	0.35177024	0.3518	0.3201	0.6805	54.1182	0.2628	0.2695

Figure 2.18 Reactive plant – forced, distribution percentiles

2.2 Loss of supply event frequency

Losses of supply events represent discrete occurrences of failure. In order to best fit the loss of supply events data, discrete distribution curves are used with equal interval binning.

2.2.1 Number of events > 0.05 system minutes

Using the AIC fit statistic, Figure 2.19 shows that the Poisson distribution is the best fit for the loss of supply events greater than 0.05 system minutes, providing a standard deviation of 1.14. The curve of second best fit is the IntUniform distribution, giving a standard deviation of 1.18, 2% lower, confirming that the curve of best fit is appropriate.




Figure 2.19 No. of events > 0.05 system minutes, curve of best fit

Rank By	AIC	Input	Poisson	IntUniform	Binomial	Geomet
Fit		Function =RiskPoisson(3.40.. =RiskIntUniform(2... =RiskBinomial(5,0... =RiskGeomet(0.22..				
Method		MLE MLE MLE MLE				
Rankings By Fit Statistic [4 Valid Fits]						
Akaike (AIC)		#1 #2 #3 #4				
Bayesian (BIC)		#3 #1 #2 #4				
Chi-Sq Statistic		#3 #1 #2 #4				
Parameters - [* Values unavailable without running a bootstrap]						
Num. Est. Parameters		1 2 2 1				
Fitted Parameter #1		lambda Min n p				
Fitted Value		3.4000 2 5 0.22727				
95% Lower Limit*		N/A N/A N/A N/A				
95% Upper Limit*		N/A N/A N/A N/A				
Conf. Interval Width*		N/A N/A N/A N/A				
Fitted Parameter #2		Max p				
Fitted Value		5 0.68000				
95% Lower Limit*		N/A N/A				
95% Upper Limit*		N/A N/A				
Conf. Interval Width*		N/A N/A				

Figure 2.20 No. of events > 0.05 system minutes, fit statistics

As shown in Figure 2.21, the 5th and 95th percentile parameters for the preferred curve are 1 and 7 respectively.

Rank By	AIC	Input	Poisson	IntUniform	Binomial	Geomet
Fit		Percentiles				
Value		2.0000 1.0000 2.0000 2.0000 0.0000				
5%		2.0000 1.0000 2.0000 2.0000 0.0000				
10%		2.0000 2.0000 2.0000 2.0000 0.0000				
15%		2.0000 2.0000 2.0000 3.0000 0.0000				
20%		2.0000 2.0000 2.0000 3.0000 1.0000				
25%		3.0000 2.0000 2.0000 3.0000 1.0000				
30%		3.0000 2.0000 3.0000 3.0000 1.0000				
35%		3.0000 3.0000 3.0000 3.0000 1.0000				
40%		3.0000 3.0000 3.0000 3.0000 1.0000				
45%		3.0000 3.0000 3.0000 3.0000 2.0000				
50%		3.0000 3.0000 3.0000 3.0000 2.0000				
55%		3.0000 3.0000 4.0000 4.0000 3.0000				
60%		3.0000 4.0000 4.0000 4.0000 3.0000				
65%		4.0000 4.0000 4.0000 4.0000 4.0000				
70%		4.0000 4.0000 4.0000 4.0000 4.0000				
75%		4.0000 5.0000 4.0000 4.0000 5.0000				
80%		4.0000 5.0000 5.0000 4.0000 6.0000				
85%		5.0000 5.0000 5.0000 4.0000 7.0000				
90%		5.0000 6.0000 5.0000 5.0000 8.0000				
95%		5.0000 7.0000 5.0000 5.0000 11.0000				

Figure 2.21 No. of events > 0.05 system minutes, distribution percentiles

2.2.2 Number of events > 0.25 system minutes

Using the AIC fit statistic, Figure 2.22 shows that the Geometric distribution is the best fit providing a standard deviation of 1.14. The Poisson is the second best fit with a standard deviation of 0.89, 25% lower. The relatively high variation in standard deviations indicates some uncertainty in the curve fitting.

Examining the dataset shows that only three values occurred – 0 occurring in three of the years and 1 occurring in one year and 3 occurring in one year. This is consistent with the shape of the Geometrical distribution with a large number of zero values tapping off for increasing values. This shape aligns with expected performance hence confirming that the Geometric is the preferred distribution. In contrast, the Poisson distribution typically starts at a low value rising to a maximum and then falling. This shape is not consistent with expected performance.




Figure 2.22 No. of events > 0.25 system minutes, curve of best fit

Rank By	AIC	Value	Input	Geomet	Poisson	NegBin	IntUniform
<input checked="" type="checkbox"/>	Geomet	15.6986					
<input checked="" type="checkbox"/>	Poisson	16.7020					
<input type="checkbox"/>	NegBin	22.3653					
<input type="checkbox"/>	IntUniform	23.8629					
<input type="checkbox"/>	Binomial	N/A					
- Fit							
Function		=RiskGeomet(0.55.. =RiskPoisson(0.80.. =RiskNegBin(1.0.5.. =RiskIntUniform(0...					
Method		MLE MLE MLE MLE					
- Rankings By Fit Statistic [4 Valid Fits]							
Akaike (AIC)		#1 #2 #3 #4					
Bayesian (BIC)		#1 #2 #3 #4					
Chi-Sq Statistic		#2 (Tie) #1 #2 (Tie) #4					
- Parameters - [* Values unavailable without running a bootstrap]							
Num. Est. Parameters		1 1 2 2					
Fitted Parameter #1		p lambda s Min					
Fitted Value		0.55556 0.80000 1 0					
95% Lower Limit*		N/A N/A N/A N/A					
95% Upper Limit*		N/A N/A N/A N/A					
Conf. Interval Width*		N/A N/A N/A N/A					
Fitted Parameter #2		p Max					
Fitted Value		0.55556 3					
95% Lower Limit*		N/A N/A					
95% Upper Limit*		N/A N/A					
Conf. Interval Width*		N/A N/A					

Figure 2.23 No. of events > 0.25 system minutes, fit statistics

As shown in Figure 2.24, the 5th and 95th percentile parameters for the preferred curve are 0 and 3 respectively.




Figure 2.24 No. of events > 0.25 system minutes, distribution percentiles

2.3 Average outage duration

The average outage duration is a measure of the response time to outages. The optimal performance limit is close to zero, which represents an immediate response; as such a lower limit of zero is set for fitting curves to the data.

The best fit is the LogLogistic distribution curve using both the K-S fit statistic (Figure 2.25) and the A-D fit statistic (Figure 2.26).




Figure 2.25 Average outage duration, comparison using K-S




Figure 2.26 Average outage duration, comparison using A-D

As shown in Figure 2.27, the 5th and 95th percentile parameters for the preferred curve are 40.7 and 299.1 respectively.

Fit	Value	Percentiles	Input	Loglogistic	Pearson6	Pearson5	Invgauss	Triang	Lognorm	Weibull	Gamma	Expon	Uniform	Levy	BetaGeneral
5%	63.5455	40.6551	51.330493	51.3305	48.1637	34.0005	46.6756	31.9879	40.5127	6.8758	16.4153	26.1309			
10%	63.5455	52.3702	59.698400	59.6984	57.8094	48.0840	56.9467	46.6929	53.2642	14.1235	32.8305	37.1020			
15%	63.5455	61.2590	66.425462	66.4255	65.6319	58.8906	65.1249	58.6346	63.3588	21.7856	49.2458	48.4405			
20%	63.5455	68.9337	72.525506	72.5255	72.7388	68.0010	72.4545	69.2626	72.2985	29.9123	65.6610	61.1194			
25%	71.1375	75.9924	78.377443	78.3774	79.5446	76.2469	79.3967	79.1536	80.6454	38.5637	82.0763	75.8563			
30%	71.1375	82.7479	84.187609	84.1876	86.2723	84.6821	86.1960	88.6190	88.6937	47.8121	98.4915	93.4477	1		
35%	71.1375	89.4027	90.099666	90.0997	93.0732	93.4244	93.0153	97.8602	97.6602	57.7463	114.9068	114.9237	1		
40%	71.1375	96.1131	96.235102	96.2351	100.0711	102.5099	99.9844	107.0279	104.6037	68.4760	131.3220	141.7157	1		
45%	94.2277	103.0203	102.713827	102.7138	107.3829	111.9825	107.2237	116.2494	112.7319	80.1398	147.7373	175.9058	1		
50%	94.2277	110.2697	109.669398	109.6694	115.1341	121.8965	114.8597	125.6455	121.1387	92.9161	164.1525	220.6483	1		
55%	94.2277	118.0292	117.264507	117.2645	123.4717	132.3198	123.0395	135.3436	129.9575	107.0397	180.5678	280.9295	1		
60%	178.6935	126.5114	125.711960	125.7119	132.5816	143.3401	131.9480	145.4908	139.3481	122.8284	196.9830	365.0271	1		
65%	178.6935	136.0072	135.308098	135.3080	142.7141	155.0737	141.8341	156.2718	149.5174	140.7283	213.3983	487.5225	1		
70%	178.6935	146.9452	146.491889	146.4918	154.2279	167.6798	153.0552	167.9366	160.7527	161.3921	229.8135	676.0941	1		
75%	178.6935	160.0081	159.961058	159.9610	167.6729	181.3882	166.1625	180.8520	173.4842	185.8323	246.2288	988.6724	1		
80%	178.6935	176.3929	176.928326	176.9283	183.9670	196.5511	182.0832	195.6061	188.4158	215.7446	262.6440	1563.9375	1		
85%	262.6440	198.4917	199.783552	199.7835	204.8318	213.7619	202.5760	213.2605	206.8419	254.3082	279.0593	2806.6198	1		
90%	262.6440	232.1817	234.274735	234.2747	234.1483	234.1770	231.6684	236.1085	231.6194	308.6607	295.4745	6356.9363	1		
95%	262.6440	299.0870	300.830433	300.8305	284.4013	260.7825	282.6473	271.1216	271.6876	401.5768	311.8898	25528.3243	1		

Figure 2.27 Average outage duration, distribution percentiles

2.4 Proper operation of equipment – number of failure events

Proper operation of equipment events represent discrete occurrences of failure. In order to best fit the failure events data, discrete distribution curves are used with equal interval binning.

2.4.1 Failure of protection system

Using the AIC fit statistic, Figure 2.19 shows that the Poisson distribution is the best fit for the failure of protection systems, providing a standard deviation of 4.450. The curve of second best fit is the IntUniform, giving a standard deviation of 4.031, 9% lower, confirming that the use of the curve of best fit is appropriate.




Figure 2.28 Failure of protection system, curve of best fit

Rank By	AIC	Fit	Value	Function	Method	Rankings By Fit Statistic [4 Valid Fits]	Parameters - [* Values unavailable without running a bootstrap]
<input checked="" type="checkbox"/>	Poisson	33.3872		=RiskPoisson(19.8..	MLE	Akaike (AIC) #1	Num. Est. Parameters 1
<input checked="" type="checkbox"/>	IntUniform	36.3906		=RiskIntUniform(1..	MLE	Bayesian (BIC) #2	Fitted Parameter #1
<input type="checkbox"/>	NegBin	40.0352		=RiskNegBin(197...	MLE	Chi-Sq Statistic #1 (Tie)	Fitted Value 19.800
<input type="checkbox"/>	Geomet	43.4385		=RiskGeomet(0.04..	MLE		95% Lower Limit* N/A
<input type="checkbox"/>	Binomial	N/A					95% Upper Limit* N/A
							Conf. Interval Width* N/A
							Fitted Parameter #2
							Fitted Value 24
							95% Lower Limit* N/A
							95% Upper Limit* N/A
							Conf. Interval Width* N/A

Figure 2.29 Failure of protection system, fit statistics

As shown in Figure 2.30, the 5th and 95th percentile parameters for the preferred curve are 13 and 27 respectively.

Rank By		AIC	Percentiles				
Fit	Value		Input	Poisson	IntUniform	NegBin	Geomet
<input checked="" type="checkbox"/> Poisson	33.3872	5%	11.0000	13.0000	11.0000	12.0000	1.0000
<input checked="" type="checkbox"/> IntUniform	36.3906	10%	11.0000	14.0000	12.0000	14.0000	2.0000
<input type="checkbox"/> NegBin	40.0352	15%	11.0000	15.0000	13.0000	15.0000	3.0000
<input type="checkbox"/> Geomet	43.4385	20%	11.0000	16.0000	13.0000	16.0000	4.0000
<input type="checkbox"/> Binomial	N/A	25%	20.0000	17.0000	14.0000	17.0000	5.0000
		30%	20.0000	17.0000	15.0000	17.0000	7.0000
		35%	20.0000	18.0000	15.0000	18.0000	8.0000
		40%	20.0000	19.0000	16.0000	18.0000	10.0000
		45%	21.0000	19.0000	17.0000	19.0000	12.0000
		50%	21.0000	20.0000	17.0000	20.0000	14.0000
		55%	21.0000	20.0000	18.0000	20.0000	16.0000
		60%	21.0000	21.0000	19.0000	21.0000	18.0000
		65%	23.0000	21.0000	20.0000	21.0000	21.0000
		70%	23.0000	22.0000	20.0000	22.0000	24.0000
		75%	23.0000	23.0000	21.0000	23.0000	28.0000
		80%	23.0000	23.0000	22.0000	24.0000	32.0000
		85%	24.0000	24.0000	22.0000	25.0000	38.0000
		90%	24.0000	26.0000	23.0000	26.0000	46.0000
		95%	24.0000	27.0000	24.0000	28.0000	60.0000

Figure 2.30 Failure of protection system, distribution percentiles

2.4.2 Material failure of Supervisory Control and Data Acquisition (SCADA) system

Using the AIC fit statistic, Figure 2.19 shows that the Geometric distribution is the best fit for the material failure of SCADA systems, providing a standard deviation of 8.08. The curve of second best fit is the IntUniform distribution, giving a standard deviation of 5.477, 32% higher. The high variation in standard deviations indicates some uncertainty in the curve fitting.

Examining the dataset shows that four values occurred – 21, 5 and 6 each occurring in one year and 3 occurring in two years. This is consistent with the choice of the Geometric distribution, indicating inconsistent service performance.




Figure 2.31 Material failure of Supervisory Control and Data Acquisition (SCADA) system, curve of best fit

Rank By		AIC	Input	Geomet	IntUniform	NegBin	Poisson
Fit	Value	=RiskGeomet(0.11... =RiskIntUniform(3... =RiskNegBin(2,0.2... =RiskPoisson(7.60..					
<input checked="" type="checkbox"/>	Geomet	34.2456		MLE	MLE	MLE	MLE
<input checked="" type="checkbox"/>	IntUniform	39.4444					
<input type="checkbox"/>	NegBin	39.9244					
<input type="checkbox"/>	Poisson	45.8549					
<input type="checkbox"/>	Binomial	N/A					
- Fit							
Function							
Method							
- Rankings By Fit Statistic [4 Valid Fits]							
Akaike (AIC)				#1	#2	#3	#4
Bayesian (BIC)				#1	#2	#3	#4
Chi-Sq Statistic				#1 (Tie)	#1 (Tie)	#1 (Tie)	#1 (Tie)
- Parameters - [* Values unavailable without running a bootstrap]							
Num. Est. Parameters				1	2	2	1
Fitted Parameter #1				p	Min	s	lambda
Fitted Value				0.11628	3	2	7.6000
95% Lower Limit*				N/A	N/A	N/A	N/A
95% Upper Limit*				N/A	N/A	N/A	N/A
Conf. Interval Width*				N/A	N/A	N/A	N/A
Fitted Parameter #2					Max	p	
Fitted Value					21	0.20833	
95% Lower Limit*					N/A	N/A	
95% Upper Limit*					N/A	N/A	
Conf. Interval Width*					N/A	N/A	

Figure 2.32 Material failure of Supervisory Control and Data Acquisition (SCADA) system, fit statistics

As shown in Figure 2.33, the 5th and 95th percentile parameters for the preferred curve are 0 and 24 respectively.

Rank By		AIC	Input	Geomet	IntUniform	NegBin	Poisson
Fit	Value	=RiskGeomet(0.11... =RiskIntUniform(3... =RiskNegBin(2,0.2... =RiskPoisson(7.60..					
<input checked="" type="checkbox"/>	Geomet	34.2456		MLE	MLE	MLE	MLE
<input checked="" type="checkbox"/>	IntUniform	39.4444					
<input type="checkbox"/>	NegBin	39.9244					
<input type="checkbox"/>	Poisson	45.8549					
<input type="checkbox"/>	Binomial	N/A					
- Percentiles							
5%		3.0000	0.0000	3.0000	1.0000	3.0000	
10%		3.0000	0.0000	4.0000	1.0000	4.0000	
15%		3.0000	1.0000	5.0000	2.0000	5.0000	
20%		3.0000	1.0000	6.0000	3.0000	6.0000	
25%		3.0000	2.0000	7.0000	3.0000	7.0000	
30%		3.0000	2.0000	8.0000	4.0000	8.0000	
35%		3.0000	3.0000	9.0000	4.0000	9.0000	
40%		3.0000	4.0000	10.0000	5.0000	10.0000	
45%		5.0000	4.0000	11.0000	6.0000	11.0000	
50%		5.0000	5.0000	12.0000	6.0000	12.0000	
55%		5.0000	6.0000	13.0000	7.0000	13.0000	
60%		5.0000	7.0000	14.0000	8.0000	14.0000	
65%		6.0000	8.0000	15.0000	9.0000	15.0000	
70%		6.0000	9.0000	16.0000	9.0000	16.0000	
75%		6.0000	11.0000	17.0000	11.0000	17.0000	
80%		6.0000	13.0000	18.0000	12.0000	18.0000	
85%		21.0000	15.0000	19.0000	13.0000	19.0000	
90%		21.0000	18.0000	20.0000	16.0000	20.0000	
95%		21.0000	24.0000	21.0000	19.0000	21.0000	

Figure 2.33 Material failure of Supervisory Control and Data Acquisition (SCADA) system, distribution percentiles

2.4.3 Incorrect operational isolation of primary or secondary equipment

Using the AIC fit statistic, Figure 2.19 shows that the Poisson distribution is the best fit for the incorrect operational isolation of primary or secondary equipment, providing a standard deviation of 2.65. The curve of

second best fit is the IntUniform distribution, giving a standard deviation of 2.29, 13% lower. The high variation in standard deviations indicates some uncertainty in the curve fitting.

Examining the dataset shows that five different values occurred. This is consistent with the choice of the Poisson distribution, which typically starts at a low value, rising to a maximum and then falling. In contrast, the IntUniform distribution is typically a constant value, which does not reflect the expected performance.




Figure 2.34 Incorrect operational isolation of primary or secondary equipment, curve of best fit

Rank By	AIC	Fit	Value
<input checked="" type="checkbox"/>	Poisson	26.7244	
<input checked="" type="checkbox"/>	IntUniform	30.7944	
<input type="checkbox"/>	Binomial	33.3217	
<input type="checkbox"/>	Geomet	33.4749	
<input type="checkbox"/>	NegBin	N/A	

	Input	Poisson	IntUniform	Binomial	Geomet
Function		=RiskPoisson(7)	=RiskIntUniform(3,10)	=RiskBinomial(41,0.125)	=RiskGeomet(0.125)
Method		MLE	MLE	MLE	MLE
Rankings By Fit Statistic [4 Valid Fits]					
Akaike (AIC)		#1	#2	#3	#4
Bayesian (BIC)		#2	#1	#3	#4
Chi-Sq Statistic		#1 (Tie)	#1 (Tie)	#1 (Tie)	#1 (Tie)
Parameters - [* Values unavailable without running a bootstrap]					
Num. Est. Parameters		1	2	2	1
Fitted Parameter #1		lambda	Min	n	p
Fitted Value		7.0000	3	41	0.12500
95% Lower Limit*		N/A	N/A	N/A	N/A
95% Upper Limit*		N/A	N/A	N/A	N/A
Conf. Interval Width*		N/A	N/A	N/A	N/A
Fitted Parameter #2			Max	p	
Fitted Value			10	0.17073	
95% Lower Limit*			N/A	N/A	
95% Upper Limit*			N/A	N/A	
Conf. Interval Width*			N/A	N/A	

Figure 2.35 Incorrect operational isolation of primary or secondary equipment, fit statistics

As shown in Figure 2.36, the 5th and 95th percentile parameters for the preferred curve are 4 and 13 respectively.

Rank By		AIC	Input	Poisson	IntUniform	Binomial	Geomet
Fit	Value	Percentiles					
<input checked="" type="checkbox"/> Poisson	26.7244	5%	3.0000	3.0000	3.0000	3.0000	0.0000
<input checked="" type="checkbox"/> IntUniform	30.7944	10%	3.0000	4.0000	3.0000	4.0000	0.0000
<input type="checkbox"/> Binomial	33.3217	15%	3.0000	4.0000	4.0000	5.0000	1.0000
<input type="checkbox"/> Geomet	33.4749	20%	3.0000	5.0000	4.0000	5.0000	1.0000
<input type="checkbox"/> NegBin	N/A	25%	6.0000	5.0000	4.0000	5.0000	2.0000
		30%	6.0000	5.0000	5.0000	6.0000	2.0000
		35%	6.0000	6.0000	5.0000	6.0000	3.0000
		40%	6.0000	6.0000	6.0000	6.0000	3.0000
		45%	7.0000	7.0000	6.0000	7.0000	4.0000
		50%	7.0000	7.0000	6.0000	7.0000	5.0000
		55%	7.0000	7.0000	7.0000	7.0000	5.0000
		60%	7.0000	8.0000	7.0000	8.0000	6.0000
		65%	9.0000	8.0000	8.0000	8.0000	7.0000
		70%	9.0000	8.0000	8.0000	8.0000	9.0000
		75%	9.0000	9.0000	8.0000	9.0000	10.0000
		80%	9.0000	9.0000	9.0000	9.0000	12.0000
		85%	10.0000	10.0000	9.0000	9.0000	14.0000
		90%	10.0000	10.0000	10.0000	10.0000	17.0000
		95%	10.0000	12.0000	10.0000	11.0000	22.0000

Figure 2.36 Incorrect operational isolation of primary or secondary equipment, distribution percentiles

2.5 Summary of findings

Table 2.1 summarises the probability distribution functions that have been chosen to best fit the parameter data (Table 1.1). In WSP | Parsons Brinckerhoff's view this approach is robust and does not seem to be sensitive to the choice of distribution function, because the results were either close for the next best fit distributions or confirmed through analysis of the data. The approach is also consistent with the Australian Energy Regulator's previous regulatory decisions to use a curve of best fit approach.

Table 2.1 Summary of best fit distributions

PARAMETER	BEST FIT DISTRIBUTION	STANDARD DEVIATION	5% POE	95% POE
LINES OUTAGE RATE - FAULT	Loglogistic	0.036	9.1%	20.4%
TRANSFORMERS OUTAGE RATE - FAULT	Weibull	0.032	10.1%	20.5%
REACTIVE PLANT OUTAGE RATE – FAULT	Loglogistic	0.032	7.9%	17.9%
LINES OUTAGE RATE - FORCED OUTAGE	Uniform	0.082	1.4%	27.1%
TRANSFORMERS OUTAGE RATE - FORCED OUTAGE	Loglogistic	0.085	15.3%	41.0%
REACTIVE PLANT OUTAGE RATE - FORCED OUTAGE	Weibull	0.041	15.6%	29.0%
NO. OF EVENTS >0.05 SYSTEM MINUTES	Poisson	1.14	1	7
NO. OF EVENTS >0.25 SYSTEM MINUTES	Geometric	1.20	0	3
AVERAGE OUTAGE DURATION	Loglogistic	112	41	299
FAILURE OF PROTECTION SYSTEM	Poisson	4.5	13	27
MATERIAL FAILURE OF SUPERVISORY CONTROL AND DATA ACQUISITION (SCADA) SYSTEM	Geometric	8.1	0	24
INCORRECT OPERATIONAL ISOLATION OF PRIMARY OR SECONDARY EQUIPMENT	Poisson	2.7	3	12

3 VALUES FOR PARAMETERS

3.1 STPIS requirements for parameter values

STPIS Clause 3.2 sets out the requirements for parameter values. For each parameter, the TNSP must propose values for:

- a performance target
- a collar
- a cap

Specific requirements are:

- A performance target may take the form of a deadband (3.2(c)).
- Proposed performance targets must be equal to average performance over the most recent five years (3.2(g)).
- Proposed performance targets may be subject to reasonable adjustment to allow for statistical outliers, volume of capital works, changes in the age and ratings of the assets and changes in regulatory obligations.
- A proposed cap and collar may result in symmetric or asymmetric incentives (3.2(f)).
- Proposed values must be consistent with the objectives for the scheme (3.2(m)).

WSP | Parsons Brinckerhoff's views on these requirements are summarised in Table 3.1.

Table 3.1 Recommendations on scheme requirements for parameter values

REQUIREMENT	DISCUSSIONS	RECOMMENDATION
DEADBANDS	Deadbands are used to remove the impact of small variations in performance around the average performance. Because performance in a 5-year period is most often four "good" years with a single year of lower performance, deadbands most often have the effect of removing a net positive value.	Don't apply
MOST RECENT 5-YEAR PERIOD	The years 2012-2016 meet the requirement.	2012 to 2016 data is acceptable.
ADJUSTMENTS	Statistical outliers – these must be in the underlying reliability data rather than one of the 5 years of performance. WSP Parsons Brinckerhoff has not undertaken any audit of this data. Removal of outliers can have a small but material impact on a single year's performance, but little effect on the 5-year average. As outliers are typically related to poor performance, removing them has the impact of making targets harder to achieve, noting that the same outliers should they occur in future performance are not removed. Volume of capital works – applies only where the parameter includes planned outages. As all of the service component parameters exclude planned outages, no adjustment applies. Change in age/ratings – would require a material change, not usually evident in aggregated reliability performance.	No adjustments
ASYMMETRIC INCENTIVES	Symmetric incentives are consistent with the objectives for the scheme, as they usually provide a cost neutral position for natural variation around the average. Where better performance is more difficult (costly) to achieve than a decline, the incentive to improve is weakened. This may be inconsistent with NER clause 6A.7.4(b)(ii), which requires that the scheme should "provide incentives ...to:	Symmetric incentives should be adopted unless this results in an incentive that is inconsistent with scheme objectives.

(i) provide greater reliability of the transmission system ... at all times when Transmission Network Users place greatest value on the reliability of the transmission system; and

(ii) improve and maintain the reliability of those elements of the transmission system that are most important to determining spot prices;”

The counter argument is that improvements should only be made when economic to do so.

3.2 Caps and collars

The following factors are considered when setting caps and collar values:

- The expected range of performance should be within the cap and collar values, 5th and 95th percentile, meaning that the probability of performance being outside of the cap/collar is approximately 1 in 20 years.
- Performance should be bounded at zero where the curve of best fit has been bounded at zero.
- The loss of supply event frequency parameters should be rounded to an integer before applying a standard deviation, in accordance with the AER’s recent determinations.

Table 3.2 compares the caps and collars set at 5th and 95th percentile with the maximum and minimum performance in the 2012 to 2016 period. It demonstrates that caps and collars are best set at 5th and 95th percentile.

Table 3.2 Caps and collars comparisons with 2012 to 2016 data

PARAMETER	TARGET	COLLAR	CAP	MAX	MIN	COMMENT	RECOMMENDATION
LINES OUTAGE RATE - FAULT	14.0%	20.4%	9.1%	18.4%	10.2%		
TRANSFORMER OUTAGE RATE - FAULT	15.6%	20.5%	10.1%	19.8%	10.8%		
REACTIVE PLANT OUTAGE RATE - FAULT	12.4%	17.9%	7.9%	15.7%	9.5%		
LINES OUTAGE RATE - FORCED OUTAGE	15.4%	27.1%	1.4%	22.8%	7.6%		
TRANSFORMER OUTAGE RATE - FORCED OUTAGE	26.6%	41.0%	15.3%	39.0%	18.7%		
REACTIVE PLANT OUTAGE RATE - FORCED OUTAGE	22.7%	29.0%	15.6%	27.0%	13.5%	The minimum performance in 2012-2016 is 16% under the collar. The performance during 2012 is significantly lower than the other 4 years of the period and is likely to be an anomaly.	Utilise the calculated caps and collars
LOSS OF SUPPLY EVENT FREQUENCY (EVENTS > 0.05 SYSTEM MINUTES)	3	7	1	5	2		
LOSS OF SUPPLY EVENT FREQUENCY (EVENTS > 0.25 SYSTEM MINUTES)	1	3	0	3	0		
AVERAGE OUTAGE DURATION	134	299	41	263.00	63.55		
FAILURE OF PROTECTION SYSTEM	20	27	13	23	11	The minimum performance in 2012-2016 is 18% under the collar. The performance during 2013 is significantly lower than the other 4 years of the period and is likely to be an anomaly.	Utilise the calculated caps and collars
MATERIAL FAILURE OF SUPERVISORY CONTROL AND DATA ACQUISITION (SCADA) SYSTEM	8	24	0	21	3		
INCORRECT OPERATIONAL ISOLATION OF PRIMARY OR SECONDARY EQUIPMENT	7	12	3	10	3		

3.3 Recommended parameter values

The recommended parameter values are shown in Table 3.3. These are based on:

- Targets set at the average of 5-year performance
- Caps and collars set at 5% and 95% POE for all parameters and bounded at zero where appropriate
- Loss of supply targets, caps and collars rounded to nearest integer.

Weightings as set out in STPIS clause 3.4 are also shown in the table.

Table 3.3 Parameter values

PARAMETER	COLLAR	TARGET	CAP	WEIGHTING
LINES OUTAGE RATE - FAULT	20.4%	14.0%	9.1%	0.20
TRANSFORMER OUTAGE RATE - FAULT	20.5%	15.6%	10.1%	0.20
REACTIVE PLANT OUTAGE RATE - FAULT	17.9%	12.4%	7.9%	0.10
LINES OUTAGE RATE - FORCED OUTAGE	27.1%	15.4%	1.4%	0.00
TRANSFORMER OUTAGE RATE - FORCED OUTAGE	41.0%	26.6%	15.3%	0.00
REACTIVE PLANT OUTAGE RATE - FORCED OUTAGE	29.0%	22.7%	15.6%	0.00
LOSS OF SUPPLY EVENT FREQUENCY (EVENTS > 0.05 SYSTEM MINUTES)	7	3	1	0.15
LOSS OF SUPPLY EVENT FREQUENCY (EVENTS > 0.25 SYSTEM MINUTES)	3	1	0	0.15
AVERAGE OUTAGE DURATION	299	134	41	0.20
FAILURE OF PROTECTION SYSTEM	27	20	13	0
MATERIAL FAILURE OF SUPERVISORY CONTROL AND DATA ACQUISITION (SCADA) SYSTEM	24	8	0	0
INCORRECT OPERATIONAL ISOLATION OF PRIMARY OR SECONDARY EQUIPMENT	12	7	3	0