

TEMPLATE EXPLANATION



These templates form part of the information requirements of the AER as part of its annual compliance review against the service standards in TransGrid's revenue cap decision.

Yellow worksheets ('Inputs- Performance' and 'Inputs- Exclusions') are for inputs, including performance and exclusion information. TransGrid only needs to enter data on these sheets.

Purple worksheets '**S1**' to '**S6**' are the s-factors results based on the performance inputs from the 'Inputs - Performance' sheet.

Blue worksheet '**Revenue Calculation**' quantifies the appropriate revenue to be applied to the s-factor results adjusted for CPI.

Red worksheet '**Outcomes**' shows the total performance, s-factor and financial incentive results based on the TNSP's performance in 'Inputs-Performance' and 'Revenue Calculation' sheets.

Orange worksheet '**Exclusion Definitions**' are the defined exclusions for TransGrid which should form the basis of exclusion requests under 'Inputs-Exclusions' sheet.

TRANSGRID - SERVICE STANDARDS PERFORMANCE 2006

PERFORMANCE MEASURE	S	<i>Performance (Without exclusions)</i>	<i>Performance (With exclusions)</i>
Transmission line availability	S1	99.563127%	99.565846%
Transformer availability	S2	98.837670%	98.837889%
Reactive plant availability	S3	98.922566%	98.922566%
Reliability (Events > 0.05 and <=0.4 system minutes)	S4	2	2
Reliability (Events > 0.4 system minutes)	S5	0	0
Average outage restoration time	S6	857	824

NOTES:

Pink cells- Input performance without exclusions from performance data

Orange cells- Input performance with exclusions from performance data

Green cell (C14) input date that template data was entered. Enter date of any revisions from original version (C15).

Performance should be based on 2006 calendar year data

Date prepared:	18 January 2006
Revision date:	

TRANSGRID - Proposed exclusions

CIRCUIT AVAILABILITY MEASURES	Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Start date	Start time	End date	End time	Circuits affected	Reactive plant or transformer	Quantitative impact	Reasons for exclusion request	Further references
Name of any circuit availability measures applying to TransGrid	Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	Start date and time of event	Start time	End date and time of event	End time	Name of circuits affected	Name of any reactive plant or transformer affected	Number of hours, mins etc interrupted	Reason for excluding this event. Should include a reference to the defined exclusions (see Exclusion definition tab). Eg. Exclusion 1.3 Third party event	A TNSP may provide further details of an exclusion event. TNSP to provide reference.
S1 Transmission line availability	0-2006-F0006	TransGrid's staff were to perform in service intertrip checks. Victorian staff had advised intertrips isolated before work commenced. An intertrip signal was sent which tripped the circuit breaker for this line at Wodonga.	Victorian TNSP staff had not isolated intertrip links for this circuit.	20/06/06	19:52:00	20/06/06	10:59:00	O60		0.1	3rd party outage	
	1-2006-F0214	Contractor injured EnergyAustralia's pilot cable at Vera St, Mayfield. Circuit Breaker for this line tripped. He did dial before digging and EnergyAustralia gave clearance to dig. No loss of load.	Contractor injured pilot cable; either cable was located in the wrong place or contractor identified wrong cable location.	4/12/06	13:55:00	4/12/06	16:23:00	96X		2.47	3rd party outage	
	3-2006-F0176	Snowy Hydro Ltd staff working on auto-synchronous circuit current transformers caused unplanned opening of circuit breakers controlling this line at TransGrid's Upper Tumut substation. Generator Unit 2 was in service at 80MW at the time.	Snowy Hydro Ltd staff error.	21/06/06	10:37:00	21/06/06	10:42:00	U1		0.08	3rd party outage	
	3-2006-F0179	A fault on Snowy Hydro Ltd's 17kV busbar on Unit 11 at their Murray power station caused unplanned opening of circuit breakers controlling this line at TransGrid's Murray substation. Snowy Hydro Ltd generation 55MW at time of trip.	Fault on Snowy Hydro Ltd's 17kV Busbar.	26/06/06	22:11:00	27/06/06	19:00:00	M11		20.82	3rd party outage	
	3-2006-F0208	A blown voltage transformer secondary fuse on Snowy Hydro Ltd's Transformer Group at Murray 2 power station caused their protection to operate resulting in unplanned tripping of circuit breakers controlling this line at TransGrid's Murray substation. No generation in-service at time of trip.	Snowy Hydro Ltd's blown Voltage Transformer secondary fuse.	22/11/06	13:24:00	22/11/06	22:05:00	M11		2.68	3rd party outage	
	1-2006-F0177	Lightning/Storm.	Lightning on Queensland's portion of line.	13/11/06	19:21:00	13/11/06	19:21:00	8M		0	3rd party outage	
	2-2006-F0105	A fault in EnergyAustralia's system caused 760MW of load loss which included 910,90F,241 feeders to their Green Park and Sefton substations which resulted in a system over-voltage. TransGrid's circuit breakers at Beaconsfield West substation controlling cable 41 opened following cable 41 protection detecting the system over-voltage. Investigation showed the cable 41 protection operated correctly.	A fault in EnergyAustralia's system caused system over-voltage.	22/11/06	16:35:00	22/11/06	16:41:00	41		0.1	3rd party outage	

		3-2006-F0010	A bushfire was present along a length of line 991 in very hot and windy weather. Eight (8) poles on the line were found burnt down or damaged. Vegetation in the easement is managed in a regulated and timed manner including regular inspections. TransGrid is not responsible for vegetation adjacent to easements, except where trees could fall and damage lines.	Bushfire.	2/01/06	05:44:00	3/01/06	16:40:00	991		34.93	Force Majeure	
S2	Transformer availability	2-2006-F0117	Integral Energy staff were removing temporary protection at their West Liverpool substation following service voltage testing of Integral Energy's new No.4 Transformer. Line 93R No.2 protection operated and tripped direct connected No.3 Tx at TransGrid's Liverpool substation.	Integral Energy staff error at their West Liverpool substation.	17/12/06	16:05:00	17/12/06	19:09:00		Tx No3 Liverpool	3.07	3rd party outage	
S3	Reactive plant availability												

LOSS OF SUPPLY EVENT FREQUENCY		Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Start date	Start time	End date	End time	Circuits affected	Maximum system demand	Quantitative impact	Demand shed and time	Reasons for exclusion request	Further references
Name of any loss of supply measures applying to TransGrid		Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	Start date and time of event		End date and time of event		Name of circuits or plant affected	The max system demand that occurred up until the time of the event	Number of hours, mins etc interrupted	The (MW) demand shed and the duration it was shed for.	Reason for excluding this event. Should include a reference to the defined exclusions (see Exclusion definition tab). Eg. Exclusion 1.3 Third party event	A TNSP may provide further details of an exclusion event. TNSP to provide reference.
S4	Reliability (events > 0.05 and <=0.4 system minutes)													
S5	Reliability (events > 0.4 system minutes)													

AVERAGE OUTAGE DURATION		Event proposed for exclusion	Description of the event and its impact on the network and performance	Cause of the event	Start date	Start time	End date	End time	Circuits affected	Quantitative impact	Capped impact (if applicable)	Reasons for exclusion request	Further references
Name of any average outage duration measures applying to TransGrid		Name of the event	Detail of the event. Such as: the action of any third parties, the actions of the TNSP, assets damaged or interrupted.	A description of the cause of the event	Start date and time of event		End date and time of event		Name of circuits or plant affected	Number of hours, mins etc interrupted	Impact following any applicable cap	Reason for excluding this event. Should include a reference to the defined exclusions (see Exclusion definition tab). Eg. Exclusion 1.3 Third party event	A TNSP may provide further details of an exclusion event. TNSP to provide reference.
		0-2006-F0006	TransGrid's staff were to perform in service intertrip checks. Victorian staff had advised intertrips isolated before work commenced. An intertrip signal was sent which tripped the circuit breaker for this line at Wodonga.	Victorian TNSP staff had not isolated intertrip links for this circuit.	20/06/06	19:52:00	20/06/06	10:59:00	O60	0.1	3rd party outage		

S6	Average outage restoration time	1-2006-F0214	Contractor injured EnergyAustralia's pilot cable at Vera St, Mayfield. Circuit Breaker for this line tripped. He did dial before digging and EnergyAustralia gave clearance to dig. No loss of load.	Contractor injured pilot cable; either cable was located in the wrong place or contractor identified wrong cable location.	4/12/06	13:55:00	4/12/06	16:23:00	96X		2.47	3rd party outage	
		3-2006-F0176	Snowy Hydro Ltd staff working on auto-synchronous circuit current transformers caused unplanned opening of circuit breakers controlling this line at Transgrid's Upper Tumut substation. Generator Unit 2 was inservice at 80MW at the time.	Snowy Hydro Ltd staff error.	21/06/06	10:37:00	21/06/06	10:42:00	U1		0.08	3rd party outage	
		3-2006-F0179	A fault on Snowy Hydro Ltd's 17kV busbar on Unit 11 at their Murray power station caused unplanned opening of circuit breakers controlling this line at TransGrid's Murray substation. Snowy Hydro Ltd generation 55MW at time of trip.	Fault on Snowy Hydro Ltd's 17kV Busbar.	26/06/06	22:11:00	27/06/06	19:00:00	M11		20.82	3rd party outage	
		3-2006-F0208	A blown voltage transformer secondary fuse on Snowy Hydro Ltd's Transformer Group at Murray 2 power station caused their protection to operate resulting in unplanned tripping of circuit breakers controlling this line at TransGrid's Murray substation. No generation in-service at time of trip.	Snowy Hydro Ltd's blown Voltage Transformer secondary fuse.	22/11/06	13:24:00	22/11/06	22:05:00	M11		2.68	3rd party outage	
		1-2006-F0177	Lightning/Storm.	Lightning on Queensland's portion of line.	13/11/06	19:21:00	13/11/06	19:21:00	8M		0	3rd party outage	
		2-2006-F0105	A fault in EnergyAustralia's system caused 760MW of load loss which included 910,90F,241 feeders to their Green Park and Sefton substations which resulted in a system over-voltage. TransGrid's circuit breakers at Beaconsfield West substation controlling cable 41 opened following cable 41 protection detecting the system over-voltage. Investigation showed the cable 41 protection operated correctly.	A fault in EnergyAustralia's system caused system over-voltage.	22/11/06	16:35:00	22/11/06	16:41:00	41		0.1	3rd party outage	
		3-2006-F0010	A bushfire was present along a length of line 991 in very hot and windy weather. Eight (8) poles on the line were found burnt down or damaged. Vegetation in the easement is managed in a regulated and timed manner including regular inspections. TransGrid is not responsible for vegetation adjacent to easements, except where trees could fall and damage lines.	Bushfire.	2/01/06	05:44:00	3/01/06	16:40:00	991		34.93	Force Majeure	
		2-2006-F0117	Integral Energy staff were removing temporary protection at their West Liverpool substation following service voltage testing of Integral Energy's new No.4 Transformer. Line 93R No.2 protection operated and tripped direct connected No.3 Tx at TransGrid's Liverpool substation.	Integral Energy staff error at their West Liverpool substation.	17/12/06	16:05:00	17/12/06	19:09:00		Tx No3 Liverpool	3.07	3rd party outage	

--	--	--	--	--	--	--	--	--	--	--	--	--	--

NOTES:

This spreadsheet should include a list all events that are proposed for exclusion. This is consistent with the reporting information requirements contained in section 4.2 of the AER's Service Standards Guidelines.

Each proposed exclusion event should include a description of the event, a description of the impact and quantification of the impact on the network and performance. The descriptive elements should also include reasons for the exclusion request making reference to the "Exclusion Definitions" tab.

Each exclusion should be entered onto one row for each measure. Where one exclusion event applies to more than one measure, the relevant details of the event should be entered under each of the measure headings.

The TNSP must provide details for all events requested for exclusion in this template. In the event that the TNSP wishes to provide further details of an exclusion, this should be provided with the TNSP's performance report. The source of information should be referenced in this template.

Green cells - input description impact

Orange cells - input reasons for the exclusion request

TRANSGRID- S1 - Transmission line availability

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Transmission line availability	99.90%	99.00%	99.50%	99.70%	99.90%
Measure Weighting	-0.20%	-0.20%	0.00%	0.20%	0.20%

Performance Formulae	Formulae						Conditions	S- Calc 1	S- Calc 2
Performance	=	-0.002000					Where: Availability < 99.00%	-0.002000	-0.002000
	=	0.400000	x	Availability	+	-0.398000	99.00% ≤ Availability ≤ 99.50%	0.000253	0.000263
	=	1.000000	x	Availability	+	-0.995000	99.50% ≤ Availability ≤ 99.70%	0.000631	0.000658
	=	0.002000					99.70% < Availability	0.002000	0.002000

Performance Outcomes		Performance (Without Exclusions)	Performance (Exclusions)
Transmission line availability	=	99.563127%	99.565846%
S-Factor Result	=	0.063127%	0.065846%

NOTES:


This sheet will automatically update based on data in input sheets.

Blue cells show TransGrid's performance targets (C4:E4) and measure weightings (C5:E5) [See Table 9.8.1 of revenue cap]

Yellow/Green cells (Rows 8:11) show TransGrid's performance formulae and related formula conditions based on performance targets and measure weightings

Pink cells (C14, C15) show TransGrid's performance outcomes without any events excluded from performance data

Orange cells (D14, D15) show TransGrid's performance outcomes with events excluded from performance data



TRANSGRID- S2 - Tranformer availability

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Transformer availability S2	98.00%	98.20%	99.00%	99.50%	100.00%
	-0.15%	-0.15%	0.00%	0.15%	0.15%

Performance Formulae	Formulae					Conditions	S- Calc 1	S- Calc 2
Performance	=	-0.001500				Where: Availability < 98.20%	-0.001500	-0.001500
	=	0.187500	x	Availability	+	-0.185625 98.20% ≤ Availability ≤ 99.00%	-0.000304	-0.000304
	=	0.300000	x	Availability	+	-0.297000 99.00% ≤ Availability ≤ 99.50%	-0.000487	-0.000486
	=	0.001500				99.50% < Availability	0.001500	0.001500

Performance Outcomes		Performance (Without Exclusions)	Performance (Exclusions)
Transformer availability	=	98.837670%	98.837889%
S-Factor	=	-0.030437%	-0.030396%

NOTES:


This sheet will automatically update based on data in input sheets.

Blue cells show TransGrid's performance targets (C4:E4) and measure weightings (C5:E5) [See Table 9.8.1 of revenue cap]

Yellow/Green cells (Rows 8:11) show TransGrid's performance formulae and related formular conditions based on performance targets and measure weightings

Pink cells (C14, C15) show TransGrid's performance outcomes without any events excluded from performance data

Orange cells (D14, D15) show TransGrid's performance outcomes with events excluded from performance data



TRANSGRID- S3 - Reactive plant availability

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Reactive plant availability S3	96.80%	97.00%	98.60%	99.30%	100.00%
	-0.10%	-0.10%	0.00%	0.10%	0.10%

Performance Formulae	Formulae					Conditions	S- Calc 1	S- Calc 2
Performance	=	-0.001000				Where: Availability < 97.00%	-0.001000	-0.001000
	=	0.062500	x	Availability	+	-0.061625 97.00% ≤ Availability ≤ 98.60%	0.000202	0.000202
	=	0.142857	x	Availability	+	-0.140857 98.60% ≤ Availability ≤ 99.30%	0.000461	0.000461
	=	0.001000				99.30% < Availability	0.001000	0.001000

Performance Outcomes		Performance (Without Exclusions)	Performance (Exclusions)
Reactive plant availability	=	98.922566%	98.922566%
S-Factor	=	0.046081%	0.046081%


NOTES:
 This sheet will automatically update based on data in inputs sheets.

Blue cells show TransGrid's performance targets (C4:E4) and measure weightings (C5:E5) [See Table 9.8.1 of revenue cap]

Yellow/Green cells (Rows 8:11) show TransGrid's performance formulae and related formular conditions based on performance targets and measure weightings

Pink cells (C14, C15) show TransGrid's performance outcomes without any events excluded from performance data

Orange cells (D14, D15) show TransGrid's performance outcomes with events excluded from performance data



TRANSGRID- S4 - Reliability (Events > 0.05 and <=0.4 system minutes)

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Reliability (Events > 0.05 and <=0.4 system minutes)	10	8	5	3	0
S4	-0.25%	-0.25%	0.00%	0.25%	0.25%

Performance Formulae	Formulae					Conditions			S- Calc 1	S- Calc 2			
Performance	=	-0.002500				8	<	Reliability		-0.002500	-0.002500		
	=	-0.000833	x	Reliability	+	0.004167	5	≤	Reliability	≤	8	0.002500	0.002500
	=	-0.001250	x	Reliability	+	0.006250	3	≤	Reliability	≤	5	0.003750	0.003750
	=	0.002500							Reliability	<	3	0.002500	0.002500

Performance Outcomes		Performance (Without Exclusions)	Performance (Exclusions)
Reliability (Events > 0.05 and <=0.4 system minutes)	=	2	2
S-Factor	=	0.250000%	0.250000%

NOTES:


This sheet will automatically update based on data in input sheets.

Blue cells show TransGrid's performance targets (C4:E4) and measure weightings (C5:E5) [See Table 9.8.1 of revenue cap]

Yellow/Green cells (Rows 8:11) show TransGrid's performance formulae and related formular conditions based on performance targets and measure weightings

Pink cells (C14, C15) show TransGrid's performance outcomes without any events excluded from performance data

Orange cells (D14, D15) show TransGrid's performance outcomes with events excluded from performance data



TRANSGRID- S5 - Reliability (Events > 0.4 system minutes)

Performance Targets	Graph start	Collar	Target	Cap	Graph end
Reliability (Events > 0.4 system minutes)	3	2	1	0	0
S5	-0.20%	-0.20%	0.00%	0.20%	0.20%

Performance Formulae	Formulae						Conditions			S- Calc 1	S- Calc 2		
Performance	=	-0.002000					Where:	Reliability	>	2	-0.002000	-0.002000	
	=	-0.002000	x	Reliability	+	0.002000	1	≤	Reliability	≤	2	0.002000	0.002000
	=	-0.002000	x	Reliability	+	0.002000	0	≤	Reliability	≤	1	0.002000	0.002000
	=	0.002000							Reliability	<	0	0.002000	0.002000

Performance Outcomes		Performance (Without Exclusions)	Performance (Exclusions)
Reliability (Events > 0.4 system minutes)	=	0	0
S-Factor	=	0.200000%	0.200000%

NOTES:


This sheet will automatically update based on data in input sheets.

Blue cells show TransGrid's performance targets (C4:E4) and measure weightings (C5:E5) [See Table 9.8.1 of revenue cap]

Yellow/Green cells (Rows 8:11) show TransGrid's performance formulae and related formular conditions based on performance targets and measure weightings

Pink cells (C14, C15) show TransGrid's performance outcomes without any events excluded from performance data

Orange cells (D14, D15) show TransGrid's performance outcomes with events excluded from performance data



TRANSGRID- S6 - Average outage restoration time

Performance Targets	Graph start	Collar	Knee Bend	Target	Knee Bend	Cap	Graph end
Average outage restoration time	1900	1800	1600	1500	1400	800	700
S6	-0.10%	-0.10%	-0.05%	0.00%	0.05%	0.10%	0.10%

Performance Formulae	Formulae				Conditions	S- Calc 1	S- Calc 2
Performance	=	-0.001000			Where: Average time > 1800	-0.001000	-0.001000
	=	-0.000003	x	Average Time	+ 1600 ≤ Average time ≤ 1800	0.001357	0.001440
	=	-0.000005	x	Average Time	+ 1400 ≤ Average time ≤ 1600	0.003214	0.003380
	=	-0.000001	x	Average Time	+ 800 ≤ Average time ≤ 1400	0.000952	0.000980
	=	0.001000			Average time < 800	0.001000	0.001000

Performance Outcomes		Performance (Without Exclusions)	Performance (Exclusions)
Average outage restoration time	=	857	824
S-Factor	=	0.095235%	0.098008%

NOTES:


This sheet will automatically update based on data in input sheets.

Blue cells show TransGrid's performance targets (C4:G4) and measure weightings (C5:G5) [See Table 9.8.1 of revenue cap]

Yellow/Green cells (Rows 8:11) show TransGrid's performance formulae and related formular conditions based on performance targets and measure weightings

Pink cells (C15, C16) show TransGrid's performance outcomes without any events excluded from performance data

Orange cells (D15, D16) show TransGrid's performance outcomes with events excluded from performance data



TRANSGRID - Revenue calculation

<i>Revenue cap information</i>	
Base revenue	\$432,750,000
Base year	2004-05
X-factor	-2.93%
Decision CPI	2.49%

<i>Annual revenue adjusted for CPI</i>	Mar-04	Mar-05	Mar-06
CPI	144.1	147.5	151.9
	2004-05	2005-06	2006-07
AR	\$432,750,000	\$455,939,364	\$483,297,797

<i>Calendar year revenue</i>	2004	2005	2006
Revenue	\$216,375,000	\$444,344,682	\$469,618,580

NOTES:

This sheet will automatically update based on data on input sheets.

Grey cells show calendar year revenue

Green cells are for formula

Blue cells are a drop down menu

TRANSGRID- Performance outcomes 2006

Revenue calendar year 2006 (\$) **\$469,618,580**

Performance measure	S	Target	Performance without exclusions			Performance with exclusions			Impact of exclusions
			Performance	S-Factor	Final Incentive	Performance	S-Factor	Final Incentive	
Transmission line availability	S1	99.500000%	99.563127%	0.063127%	\$296,454	99.565846%	0.065846%	\$309,224	0.002719%
Transformer availability	S2	99.000000%	98.837670%	-0.030437%	-\$142,937	98.837889%	-0.030396%	-\$142,744	0.000041%
Reactive plant availability	S3	98.600000%	98.922566%	0.046081%	\$216,404	98.922566%	0.046081%	\$216,404	0.000000%
Reliability (Events > 0.05 and <=0.4 system minutes)	S4	5	2	0.250000%	\$1,174,046	2	0.250000%	\$1,174,046	0.000000%
Reliability (Events > 0.4 system minutes)	S5	1	0	0.200000%	\$939,237	0	0.200000%	\$939,237	0.000000%
Average outage restoration time	S6	1500	857	0.095235%	\$447,240	824	0.098008%	\$460,263	0.002773%
TOTALS				0.624005%	\$2,930,444		0.629539%	\$2,956,430	0.005533%

NOTE:
This sheet will automatically update based on data in input sheets.

Grey cell (C3) shows relevant calendar year revenue

Green cells (C7:C12) show performance measure targets

Pink cells (Rows D:F) show performance, s-factor results and financial incentive without exclusions

Orange cells (Rows G:I) show performance, s-factor results and financial incentive with exclusions

Blue cells show the impact of exclusions on revenue

Aggregate outcome 2006	
S-factor	0.629539%
Bonus (penalty)	\$2,956,430
Financial year to affect revenue	2007-08

TRANSGRID - Defined exclusions

Measure 1- Transmission Circuit Availability			
No.	Defined exclusions	Further description of exclusion	Reference
1.1	Unregulated transmission assets		Service standards guidelines p.4
1.2	3rd party outage	Any outages shown to be caused by a fault or other event on a '3rd party system' e.g. intertrip signal, generator outage, customer installation (TNSP to provide list)	Service standards guidelines p.4
1.3	Force majeure		Service standards guidelines p.4
1.4	Transient interruptions less than one (1) minute		Historical exclusion applied by TransGrid
1.5	Switching to control voltages and fault levels	Switching to control voltages and fault levels within required limits, both as directed by NEMMCO and where NEMMCO does not have direct oversight of the network (in both cases only where the element is available for immediate energisation if required)	Historical exclusion applied by TransGrid
1.6	The opening of one end of a transmission circuit	The opening of only one end of a transmission circuit (eg where the transmission circuit remains energised and available to carry power with immediate manual or automatic return to service).	Historical exclusion applied by TransGrid
Measure 2- Transformer Availability			
No.	Defined exclusions	Further description of exclusion	Reference
2.1	Unregulated transmission assets		Service standards guidelines p.4
2.2	3rd party outage	Any outages shown to be caused by a fault or other event on a '3rd party system' e.g. intertrip signal, generator outage, customer installation (TNSP to provide list)	Service standards guidelines p.4
2.3	Force majeure		Service standards guidelines p.4
2.4	Transient interruptions less than one (1) minute		Historical exclusion applied by TransGrid
2.5	Auxiliary transformers		Historical exclusion applied by TransGrid
2.6	Static Var Compensator transformers	Static Var Compensator Transformers (which are counted as part of the SVC)	Historical exclusion applied by TransGrid
2.7	Switching to control voltages and fault levels	Switching to control voltages and fault levels within required limits, both as directed by NEMMCO and where NEMMCO does not have direct oversight of the network (in both cases only where the element is available for immediate energisation if required)	Historical exclusion applied by TransGrid
2.8	The opening of only one or both sides of a transformer for operational purposes	The opening of only one or both sides of a transformer for operational purposes, such as to control losses, fault levels, incompatibility of tap charges etc but where the transformer remains available to carry power on immediate manual or automatic return to service.	Historical exclusion applied by TransGrid
2.9	Transformer not switched in but available for service	The period where a transformer is made available for service, but not switched in, at the end of each day of a multi-day planned outage.	Historical exclusion applied by TransGrid
Measure 3- Reactive Plant Availability			
No.	Defined exclusions	Further description of exclusion	Reference
3.1	Unregulated transmission assets		Service standards guidelines p.4
3.2	3rd party outage	Any outages shown to be caused by a fault or other event on a '3rd party system' e.g. intertrip signal, generator outage, customer installation (TNSP to provide list)	Service standards guidelines p.4
3.3	Force majeure		Service standards guidelines p.4
3.4	Transient interruptions less than one (1) minute		Historical exclusion applied by TransGrid
3.5	Capacitor banks and reactors operating less than 66 kV		Historical exclusion applied by TransGrid
3.6	Reactive plant switched out by System Operations	Reactive plant switched out by System Operations, or left out after repairs that make it available for service for operational purposes	Historical exclusion applied by TransGrid
Measure 4- Events > 0.05 system mins (No.)			
No.	Defined exclusions	Further description of exclusion	Reference

4.1	Unregulated transmission assets		Service standards guidelines p.5
4.2	3rd party outage	Any outages shown to be caused by a fault or other event on a '3rd party system' e.g. intertrip signal, generator outage, customer installation (TNSP to provide list)	Service standards guidelines p.5
4.3	Planned outages		Service standards guidelines p.5
4.4	Force majeure		Service standards guidelines p.6
4.5	Transient interruptions less than one (1) minute		Historical exclusion applied by TransGrid
4.6	Where TransGrid protection operates correctly due to a fault on a customer's or a third party system		Historical exclusion applied by TransGrid
4.7	Pumping station supply interruption	Pumping station supply interruptions (such as Barnard River, Burrawang, Bendeela, Kangaroo Valley and Jindabyne). These interruptions were excluded from historical data used for target setting as there being no effective loss of supply due to their ability to obtain the pumping load at a later time after restoration of supply	Historical exclusion applied by TransGrid
4.8	Outage caused by customer's own control system during a transient voltage fluctuation	Where a customer's own control/protection system trips their plant during a transient voltage fluctuation or other quality of supply event, whether caused by TransGrid or otherwise	Historical exclusion applied by TransGrid
Measure 5 - Events > 0.40 system mins (No.)			
	Defined exclusions	Further description of exclusion	Reference
5.1	Unregulated transmission assets		Service standards guidelines p.5
5.2	3rd party outage	Any outages shown to be caused by a fault or other event on a '3rd party system' e.g. intertrip signal, generator outage, customer installation (TNSP to provide list)	Service standards guidelines p.5
5.3	Planned outages		Service standards guidelines p.5
5.4	Force majeure		Service standards guidelines p.5
5.5	Transient interruptions less than one (1) minute		Historical exclusion applied by TransGrid
5.6	Where TransGrid protection operates correctly due to a fault on a customer's or a third party system		Historical exclusion applied by TransGrid
5.7	Pumping station supply interruption	Pumping station supply interruptions (such as Barnard River, Burrawang, Bendeela, Kangaroo Valley and Jindabyne). These interruptions were excluded from historical data used for target setting as there being no effective loss of supply due to their ability to obtain the pumping load at a later time after restoration of supply	Historical exclusion applied by TransGrid
5.8	Outage caused by customer's own control system during a transient voltage fluctuation	Where a customer's own control/protection system trips their plant during a transient voltage fluctuation or other quality of supply event, whether caused by TransGrid or otherwise	Historical exclusion applied by TransGrid

Measure 6 - Average Outage Restoration Time			
	Defined exclusions	Further description of exclusion	Reference
6.1	Transient interruptions less than one (1) minute		Service standards guidelines p.6
6.2	Unregulated transmission assets		Service standards guidelines p.6
6.3	Planned outages		Service standards guidelines p.6
6.4	Outage duration longer than 7 days	The portion of outage duration longer than 7 days (168 hours.) That is, each individual outage is capped at 7 days.	TransGrid revenue cap p.173
6.5	Force majeure		Service standards guidelines p.6
6.6	3rd party outage	Any outages shown to be caused by a fault or other event on a '3rd party system' e.g. intertrip signal, generator outage, customer installation, customer request or NEMMCO direction	Historical exclusion applied by TransGrid
6.7	Outages for capacitor banks and reactors operating at <66kV		Historical exclusion applied by TransGrid