

OPTIONS EVALUATION REPORT (OER)



Line 14 330kV Transmission Line Renewal

OER 000000001280 revision 5.0

Ellipse project no.: P0005451

TRIM file: [TRIM No]

Project reason: Capability - Asset Replacement for end of life condition

Project category: Prescribed - Replacement

Approvals

| | | |
|-----------------------------|--------------------|---|
| Author | Edward Luk | Transmission Lines and Cables Analyst |
| Endorsed | Steve Stavropoulos | Transmission Lines and Cables Asset Manager |
| | Azil Khan | Investment Analysis Manager |
| Approved | Lance Wee | Manager/Asset Strategy |
| Date submitted for approval | 2 December 2016 | |

Change history

| Revision | Date | Amendment |
|----------|-------------------|---|
| 0 | 19 June 2016 | Initial Issue |
| 1 | 19 June 2016 | No Revision. Republished due to Technical Error |
| 2 | 22 June 2016 | Revised for Updated Commercial Evaluation |
| 3 | 20 September 2016 | Revised for Updated Risk Cost |
| 4 | 27 October 2016 | Revised for New SFAIRP/ALARP Methodology |
| 5 | 2 December 2016 | Update to format |

1. Need/opportunity

Line 14 is a steel tower 330kV transmission line between Kemps Creek and Sydney North 330kV Substations, with a route length of 50.6km. The transmission line links generation entering Kemps Creek to Sydney metro area. The single circuit section of this line covered in this document was constructed in 1963 and consists of 132 structures, a route length of 48.4km. The line passes through urban areas of Sydney.

Network Asset Condition Assessment (NACA) [NACA 1280](#) performed in November 2015 has identified a number of corrosion related issues with Line 14 which require rectification in the short – medium term (within the 2018-2023 Regulatory Control Period) to ensure that asset risk levels remain within an acceptable level in the longer term.

In addition to the condition issues identified, the single circuit transmission line structures used on Line 14 are known to contain particular deficiencies due to the design philosophies used at the time of its installation. Although the structures were designed to the standards at that time, following a number of structure failures in extreme wind events, investigations found that the towers were designed to a lower set of criteria with inadequacies in the governing load combinations when compared to more recent design philosophies and standards. A program to strengthen structures with utilisation over 85% at road crossings and public areas has occurred; however, not all structures have been strengthened. Due to this, it is considered essential that condition issues on these towers be addressed so that their capacity, and as a consequence, the security of supply, are not further reduced.

2. Related Needs/opportunities

No related Needs/opportunities have been identified.

3. Options

All dollar values in this document are expressed in un-escalated 2016/17 dollars.

Base Case

Network Asset Condition Assessment (NACA) [NACA 1280](#) has identified existing issues with the line which require rectification. A summary of these can be found in Need/Opportunity Statement (NOS) [NS 1280](#).

Under a base case 'run-to-fail' option, the associated risk cost from the issues identified in Table 1 is \$1.05m per annum. A breakdown of the Base Case risk cost by category is shown in Table 1.

Table 1 – Base Case risk cost by category (\$ million)

| Risk Category | Annual Risk Cost |
|------------------------|------------------|
| Reliability (System) | 0 |
| Financial | 0.01 |
| Operational/Compliance | 0 |
| People (Safety) | 0.32 |
| Environment | 0.72 |
| Reputation | 0 |
| Total | 1.05 |

It can be seen from Table 1 that the category with the highest risk cost is 'environment', mainly due to the significant consequences of a bushfire event resulting from conductor drop. The other substantial contributor to the overall risk cost is the 'people (safety)' category, again mostly due to the consequences of a conductor drop event.

The risk cost per kilometre of line is \$0.022 million per annum.

Option A — Line Refurbishment [[OFR 1280A](#), [OFS 1280A](#)]

This option involves the refurbishment of Line 14 including treatment of corrosion and replacement of components which have reached end of life and could lead to asset failure due to corrosion. The scope of this option is summarised in Table 2.

Table 2 – Transmission Line 14 Option A scope of works

| Issue | Qty | Remediation |
|---|--------------------------|--|
| Buried concrete foundations | 13 towers | > Dig out tower legs, abrasive blast cleaning of steelwork to remove any corrosion product, application of Zinga paint and establishment of drainage channel |
| Corrosion of earth wire attachment fittings | 16 fittings | > Replacement of earthwire fittings |
| Insulator pin corrosion | 167 insulator strings | > Replacement with composite longrod insulators |
| Corrosion of earth wire | 10 km of earthwire | > Like for like replacement of SC/GZ earthwire |
| Damaged earthwire vibration damper | 5% of line 27 dampers | > Replacement of spiral vibration dampers > Assumed 2 vibration dampers per full tension span per earthwire/OPGW |

It is estimated that the capital expenditure associated with the refurbishment outlined in this option is \$1.08m ±25%. Details can be found in Section 6 of Option Feasibility Study (OFS) [OFS 1280A](#).

Following the refurbishment under this option, the risk cost associated with the remediated line is \$0.17m per annum. A breakdown of the Option A risk cost by category is shown in Table 3.

Table 3 – Option A Risk cost by category (million \$)

| Risk Category | Annual Risk Cost |
|------------------------|------------------|
| Reliability (System) | 0 |
| Financial | 0.01 |
| Operational/Compliance | 0 |
| People (Safety) | 0.04 |
| Environment | 0.12 |
| Reputation | 0 |
| Total | \$0.17 |

The total projected risk reduction as a result of implementing Option A is \$0.881m per annum. It can be seen from Table 3 that largest component of the reduction is in the ‘environment’ category, due to the reduced likelihood of the conductor drop event. Risk costs in the ‘people (safety)’ category have also substantially decreased.

The total projected risk reduction per kilometre of line is \$0.018m per annum.

Both the Base Case option and Option A outlined in Section 3 are considered to be technically feasible¹.

4. Evaluation

4.1 Commercial evaluation

The commercial evaluation of the technically feasible options is set out in Table 4. Details of the Net Present Value (NPV) calculation for Option A are provided in Attachment 1.

Table 4 — Commercial evaluation (\$ million)

| Option | Description | Total capex | Annual opex | Annual post project risk cost | Economic NPV @10% | Financial NPV @10% | Rank |
|-----------|--------------------|-------------|-------------|-------------------------------|-------------------|--------------------|------|
| Base Case | Run-to-fail | N/A | N/A | 1.05 | N/A | N/A | 2 |
| A | Line refurbishment | 1.08 | - | 0.17 | 4.82 | 4.82 | 1 |

The commercial evaluation is based on:

- > A 10% discount rate
- > A life of the investment of 20 years and a corresponding residual/terminal value

Discount rate sensitivities based on TransGrid’s current AER-determined pre-tax real regulatory Weighted Average Cost of Capital (WACC) of 6.75% and 13% appear in Table 5.

Table 5 — Discount rate sensitivities (\$ million)

| Option | Description | Economic NPV @13% | Economic NPV @6.75% |
|--------|--------------------|-------------------|---------------------|
| A | Line refurbishment | 3.53 | 6.94 |

4.2 SFAIRP/ALARP evaluation

In the context of the Network Asset Risk Assessment Methodology, the SFAIRP (So Far As Is Reasonably Practicable)/ALARP (As Low As Reasonably Practical) principle is applicable to the following Key Hazardous Events:

- > Structure failure
- > Conductor / earthwire drop

¹ An option is technically feasible if TransGrid reasonably considers that there is a high likelihood that the option, if developed, will provide the relevant service while complying with all relevant laws.

Options to reduce the network safety risk as per the risk treatment hierarchy have been considered in other lifecycle stages of the asset, and it has been determined that no reasonably practicable options exist to reduce the risk further than those capital investment options listed in Table 6.

Evaluation of the proposed options has been completed against the SFAIRP (So Far As Is Reasonably Practicable)/ALARP (As Low As Reasonably Practical) obligation, as required by the Electricity Supply (Safety and Network Management) Regulation 2014 and the Work Health and Safety Act 2011. The Key Hazardous Events and the disproportionality multipliers considered in the evaluation are as follows:

- > Structure failure – 6 times the environment (bushfire) risk, 6 times the safety risk and 10% of the reliability risk (applicable to safety)
- > Conductor / earthwire drop – 6 times the environment (bushfire) risk, 6 times the safety risk and 10% of the reliability risk (applicable to safety)

Table 6 – Feasible options (\$ thousand)

| Option | Description | CAPEX | Expected Life | Annualised CAPEX |
|-------------|--------------------|-------|---------------|------------------|
| Base | Run-to-fail | N/A | N/A | N/A |
| A | Line refurbishment | 1,080 | 20 years | 54 |

Table 7 – Annual risk calculations (\$ thousand)

| Option | Annual Residual Risk | | | Annual Risk Savings | | |
|-------------|----------------------|------------------|---------------|---------------------|------------------|---------------|
| | Safety Risk | Reliability Risk | Bushfire Risk | Safety Risk | Reliability Risk | Bushfire Risk |
| Base | 318 | 0 | 716 | N/A | N/A | N/A |
| A | 44 | 0 | 119 | 274 | 0 | 597 |

Table 8 – Reasonably practicable test (\$ thousand)

| Option | Network Safety Risk Reduction ² | Annualised CAPEX | Reasonably practicable ³ ? |
|----------|--|------------------|---------------------------------------|
| A | 5,228 | 54 | Yes |

From the above evaluation, it is considered that Option A is reasonably practicable.

4.3 Preferred option

From the SFAIRP/ALARP evaluation, Option A is considered to be reasonably practicable and is required to be undertaken in order to satisfy the organisation's SFAIRP/ALARP obligations. Option A is also considered to be commercially viable (as per the commercial evaluation). For the aforementioned reasons, it is proposed that Option A be scoped in further detail.

² The Network Safety Risk Reduction is calculated as 6 x Bushfire Risk Reduction + 6 x Safety Risk Reduction + 0.1 x Reliability Risk Reduction

³ Reasonably practicable is defined as whether the annualised CAPEX is less than the Network Safety Risk Reduction

Capital and operating expenditure

The estimated capital expenditure associated with the refurbishment outlined in this option is \$1.08m \pm 25%. The vast majority of this expenditure is proposed to be carried out in 2019-2020.

Should the Option A (Line Refurbishment) works not occur by the need date, an increase in corrective maintenance and subsequent operating expenditure is expected.

Regulatory Investment Test

No Regulatory Investment Test for Transmission (RIT-T) analysis is required as the works are condition based.

5. Recommendation

From the above SFAIRP/ALARP evaluation in accordance with the regulatory requirements, and the commercial and technical evaluation of the available options, it is recommended that detailed scoping for the refurbishment of Line 14 as outlined under Option A is undertaken.

Attachment 1 – Commercial evaluation report

Option A NPV calculation

Project_Option Name

Line 14 Refurbishment

1. Financial Evaluation (excludes VCR benefits)

| | | | | |
|-------------------------------|--------|---------|-----------------------|----------|
| NPV @ standard discount rate | 10.00% | \$4.82m | NPV / Capital (Ratio) | 4.46 |
| NPV @ upper bound rate | 13.00% | \$3.53m | Pay Back Period (Yrs) | 0.74 Yrs |
| NPV @ lower bound rate (WACC) | 6.75% | \$6.94m | IRR% | 74.06% |

2. Economic Evaluation (includes VCR benefits but excludes tax benefits from non-cash transactions, ENS penalty and overall tax cost)

| | | | | |
|-------------------------------|--------|---------|-----------------------|----------|
| NPV @ standard discount rate | 10.00% | \$4.82m | NPV / Capital (Ratio) | -1.61 |
| NPV @ upper bound rate | 13.00% | \$3.53m | Pay Back Period (Yrs) | 1.23 Yrs |
| NPV @ lower bound rate (WACC) | 6.75% | \$6.94m | IRR% | 74.08% |

Benefits

| | | | | | |
|---------------------------------|---------|---------|---------|--------------------------------|---------|
| Risk cost | As Is | To Be | Benefit | VCR Benefit | \$0.00m |
| Systems (reliability) | \$0.00m | \$0.00m | \$0.00m | ENS Penalty | \$0.00m |
| Financial | \$0.01m | \$0.01m | \$0.01m | All other risk benefits | \$0.88m |
| Operational/compliance | \$0.00m | \$0.00m | \$0.00m | Total Risk benefits | \$0.88m |
| People (safety) | \$0.32m | \$0.04m | \$0.27m | Benefits in the financial NPV* | \$0.88m |
| Environment | \$0.72m | \$0.12m | \$0.60m | *excludes VCR benefits | |
| Reputation | \$0.00m | \$0.00m | \$0.00m | Benefits in the economic NPV** | \$0.88m |
| Total Risk benefits | \$1.05m | \$0.17m | \$0.88m | **excludes ENS penalty | |
| Cost savings and other benefits | | | \$0.00m | | |
| Total Benefits | | | \$0.88m | | |

Other Financial Drivers

| | | | |
|--|----------|-----------------------------------|-----------|
| Incremental opex cost pa (no depreciation) | \$0.00m | Write-off cost | \$0.00m |
| Capital - initial \$m | -\$1.08m | Major Asset Life (Yrs) | 20.00 Yrs |
| Residual Value - initial investment | \$0.05m | Re-investment capital | \$0.00m |
| Capitalisation period | 3.00 Yrs | Start of the re-investment period | 0.00 Yrs |