

OPTIONS EVALUATION REPORT (OER)



Line 17 330kV Transmission Line Renewal

OER 000000001352 revision 3.0

Ellipse project no.: P0007971

TRIM file: [TRIM No]

Project reason: Capability - Asset Replacement for end of life condition

Project category: Prescribed - Asset Renewal Strategies

Approvals

Author	Edward Luk	Transmission Lines and Cables Analyst
Endorsed	Steve Stavropoulos	Transmission Lines and Cables Asset Manager
	Mark Jones	Secondary Systems Asset Manager
	Azil Khan	Investment Analysis Manager
Approved	Lance Wee	Manager/Asset Strategy
Date submitted for approval	14 December 2016	

Change history

Revision	Date	Amendment
0	20 June 2016	Initial issue
1	20 October 2016	Option B Added. Revised for Updated Risk Cost and New SFAIRP/ALARP Methodology
2	6 December 2016	Update to format
3	14 December 2016	Minor editorial changes

1. Need/opportunity

Line 17 is a single circuit steel tower 330kV transmission line between Avon and Macarthur 330kV Substations, with a route length of 41 km. The transmission line is a key link between the Wollongong region and the Sydney metropolitan area. This transmission line was constructed in 1964 as the Dapto to Sydney West 330kV line and consists of 101 structures. The southern section of the transmission line mainly traverses through forested areas, with a significant section located in land belonging to the Sydney Catchment Authority. There are large numbers of residences and populated areas in the northern half of the line from Appin through to Macarthur. The Campbelltown area is rapidly expanding, with suburban developments likely to build up next to the line in the near future.

Network Asset Condition Assessment (NACA) [NACA 1352](#) performed in March 2016 has identified a number of condition related issues with Line 17 which require rectification in the short – medium term (in the 2018-2023 Regulatory Control Period) to ensure that asset risk levels remain within an acceptable level in the longer term.

In addition to the condition issues identified, the single circuit transmission line structures used on Line 17 are known to contain particular deficiencies due to the design philosophies used at the time of its installation. Although the structures were designed to the standards at that time, following a number of structure failures in extreme wind events, investigations found that the towers were designed to a lower set of criteria with inadequacies in the governing load combinations when compared to more recent design philosophies and standards. A program to strengthen structures with utilisation over 85% at road crossings and public areas has occurred; however, not all structures have been strengthened. Due to this, it is considered essential that condition issues on these towers be addressed so that their capacity, and as a consequence, the security of supply, are not further reduced.

2. Related Needs/opportunities

> Need 1575 – Line 10 Earthwire Condition

3. Options

All dollar values in this document are expressed in un-escalated 2016/17 dollars.

Base Case

Network Asset Condition Assessment (NACA) [NACA 1352](#) has identified existing issues with the line which require rectification. A summary of these can be found in Need/Opportunity Statement (NOS) [NS 1352](#).

Under a Base Case 'run-to-fail' option, the associated risk cost from the issues identified in Table 1 is \$1.22m per annum. A breakdown of the Base Case risk cost by category is shown in Table 1.

Table 1 – Base Case risk cost by category (\$ million)

Risk Category	Annual Risk Cost
Reliability (System)	0.24
Financial	0.03
Operational/Compliance	0
People (Safety)	0.10
Environment	0.85
Reputation	0

Risk Category	Annual Risk Cost
Total	1.22

It can be seen from Table 1 that the category with the highest risk cost is 'environment', mainly due to the significant consequences of a bushfire event resulting from conductor drop. The other substantial contributor to the overall risk cost is the 'reliability (system)' from the associated outage.

The risk cost per kilometre of line is \$0.030m per annum.

Option A — Line Refurbishment [[OFR 1352A](#), [OFS 1352A](#)]

This option involves the refurbishment of Line 17 preventing corrosion to tower steelwork which could lead to asset failure and replacement of components which have reached end of life due to corrosion. The scope of this option is summarised in Table 2.

Table 2 – Transmission Line 17 Option A scope of works

Issue	Qty	Remediation
Ground line corrosion of steel at footing	15 towers	> Abrasive blast cleaning of steelwork to remove any corrosion product, application of Zinga paint and concrete encasement to prevent future corrosion
Buried concrete foundations	20 towers	> Dig out tower legs, abrasive blast cleaning of steelwork to remove any corrosion product, application of Zinga paint and establishment of drainage channel
Corrosion of tower fasteners	35 towers	> Replacement of fasteners > Assume 5% of fasteners per tower
Insulator pin corrosion – suspension insulators	212 insulator strings	> Replacement with composite longrod insulators
Corrosion of conductor fittings	27 fittings	> Replacement of hot and cold end fittings
Corrosion of earthwire fittings	12 fittings	> Replacement of earthwire fittings
Corrosion of earthwire	50km (25km of route length)	> Like for like replacement of SC/GZ earthwire
Damaged conductor vibration dampers	10% of line 240 dampers	> Replacement of Stockbridge vibration dampers > Assumed 8 vibration dampers per full tension span per phase

It is estimated that the capital expenditure associated with the refurbishment outlined in this option is \$2.81m ±25%. Details can be found in Section 6 of Option Feasibility Study (OFS) [OFS 1352A](#).

Following the refurbishment under this option, the risk cost associated with the remediated line is \$0.12m per annum. A breakdown of the Option A risk cost by category is shown in Table 3.

Table 3 – Option A Risk cost by category (million \$)

Risk Category	Annual Risk Cost
Reliability (System)	0.04
Financial	0.01
Operational/Compliance	0
People (Safety)	0.01
Environment	0.07
Reputation	0
Total	\$0.12

The total projected risk reduction as a result of implementing Option A is \$1.10m per annum. It can be seen from Table 3 that the largest component of the reduction is in the 'environment' category, due to the reduced likelihood of conductor drop failure. Considerable reductions in risk cost in the 'reliability (system)' and 'people (safety)' categories are also expected.

The total projected risk reduction per kilometre of line is \$0.027m per annum.

Option B — Line Refurbishment with OPGW Retrofitting ([OFR 1352B](#), [OFS 1352B](#))

As with Option A, this option involves the refurbishment of Line 17 by the replacement of components which have reached end of life due to corrosion. However, given the significant proportion of earthwire identified with corrosion related issues, this option proposes to replace one earthwire with OPGW Type A between Avon and Macarthur. Sections of the other earthwire with identified corrosion related issues will be replaced like for like with SC/GZ earthwire.

With the proposed installation of OPGW, the requisite secondary systems modifications and fibre termination works has been included. The scope of this option is summarised in Table 4.

Table 4 – Transmission Line 17 Option B scope of works

Issue	Qty	Remediation
Ground line corrosion of steel at footing	15 towers	> Abrasive blast cleaning of steelwork to remove any corrosion product, application of Zinga paint and concrete encasement to prevent future corrosion
Buried concrete foundations	20 towers	> Dig out tower legs, abrasive blast cleaning of steelwork to remove any corrosion product, application of Zinga paint and establishment of drainage channel
Corrosion of tower fasteners	35 towers	> Replacement of fasteners > Assume 5% of fasteners per tower
Insulator pin corrosion – suspension insulators	212 insulator strings	> Replacement with composite longrod insulators
Corrosion of conductor fittings	27 fittings	> Replacement of hot and cold end fittings

Issue	Qty		Remediation
Corrosion of earthwire fittings	12 fittings	>	Replacement of earthwire fittings
Corrosion of earthwire	25km	>	Like for like replacement of SC/GZ earthwire
Corrosion of earthwire	50km	>	Replacement with OPGW Type A
Damaged conductor vibration dampers	10% of line	>	Replacement of Stockbridge vibration dampers
	240 dampers	>	Assumed 8 vibration dampers per full tension span per phase
Avon Substation works for OPGW termination			> Termination of OPGW into non-metallic conductor at substation gantry. Non-metallic conductor run to communications room in buried conduit and terminated onto new optical distribution frame.
Macarthur Substation works for OPGW termination			> Termination of OPGW into non-metallic conductor at substation gantry. Non-metallic conductor run to cable trench system in buried conduit and then run in conduit to the communications room to be terminated onto new optical distribution frame.

It is estimated that the capital expenditure associated with the refurbishment outlined in this option is \$3.84m ±25%. Details can be found in Section 6 of [OFS 1352B](#).

Following the refurbishment and OPGW replacement works under this option, it is expected that the risk cost associated with the retrofitted line will be the same as that under Option A at \$0.12 per annum. The total projected risk reduction as a result of implementing Option B is \$1.10m per annum, a total reduction per kilometre of line of \$0.027m per annum.

Installation of OPGW on both Lines 17 and 10, as currently proposed, will improve the communications system by bringing fibre to Avon and providing duplicated paths to Dapto, Macarthur and Marulan. The benefits of this opportunity come as a result of reduced OPEX through maintenance and licensing savings, and should OPGW be installed on both lines, the expected quantified benefit is \$0.04m per annum, with an additional efficiency savings benefit specific to the Avon site of \$0.006m per annum. It is noted that other organisation benefits have not been taken into account.

All of the options mentioned in Section 3 are considered to be technically feasible¹.

¹ An option is technically feasible if TransGrid reasonably considers that there is a high likelihood that the option, if developed, will provide the relevant service while complying with all relevant laws.

4. Evaluation

4.1 Commercial evaluation

The commercial evaluation of the technically feasible options is set out in Table 5. Details of the Net Present Value (NPV) calculations for both Options A and B are provided in Attachment 1.

Table 5 — Commercial evaluation (\$ million)

Option	Description	Total capex	Annual opex	Annual post project risk cost	Economic NPV @10%	Financial NPV @10%	Rank
Base Case	Run-to-fail	N/A	N/A	1.22	N/A	N/A	3
A	Line refurbishment	2.81	-	0.12	4.88	3.58	1
B	Line refurbishment with OPGW retrofitting	3.84	(0.04)	0.12	4.85	3.55	2

The commercial evaluation is based on:

- > A 10% discount rate
- > A life of the investment of 20 years and a corresponding residual/terminal value
- > An allowance for CAPEX avoidance for the required microwave end of life secondary systems and earthwire replacement under Option B

Discount rate sensitivities based on TransGrid's current AER-determined pre-tax real regulatory Weighted Average Cost of Capital (WACC) of 6.75% and 13% appear in Table 6.

Table 6 — Discount rate sensitivities (\$ million)

Option	Description	Economic NPV @13%	Economic NPV @6.75%
A	Line refurbishment	3.36	7.41
B	Line refurbishment with OPGW retrofitting	3.25	7.54

4.2 SFAIRP/ALARP evaluation

In the context of the Network Asset Risk Assessment Methodology, the SFAIRP (So Far As Is Reasonably Practicable)/ALARP (As Low As Reasonably Practical) principle is applicable to the following Key Hazardous Events:

- > Structure failure
- > Conductor / earthwire drop

Options to reduce the network safety risk as per the risk treatment hierarchy have been considered in other lifecycle stages of the asset, and it has been determined that no reasonably practicable options exist to reduce the risk further than those capital investment options listed in Table 7.

Evaluation of the proposed options has been completed against the SFAIRP (So Far As Is Reasonably Practicable)/ALARP (As Low As Reasonably Practical) obligation, as required by the Electricity Supply (Safety and Network Management) Regulation 2014 and the Work Health and Safety Act 2011. The Key Hazardous Events and the disproportionality multipliers considered in the evaluation are as follows:

- > Structure failure – 6 times the environment (bushfire) risk, 6 times the safety risk and 10% of the reliability risk (applicable to safety)
- > Conductor / earthwire drop – 6 times the environment (bushfire) risk, 6 times the safety risk and 10% of the reliability risk (applicable to safety)

Table 7 – Feasible options (\$ thousand)

Option	Description	CAPEX	Expected Life	Annualised CAPEX
Base	Run-to-fail	N/A	N/A	N/A
A	Line refurbishment	2,810	20 years	141
B	Line refurbishment with OPGW retrofitting	3,840	20 years	192

Table 8 – Annual risk calculations (\$ thousand)

Option	Annual Residual Risk			Annual Risk Savings		
	Safety Risk	Reliability Risk	Bushfire Risk	Safety Risk	Reliability Risk	Bushfire Risk
Base	99	241	848	N/A	N/A	N/A
A	10	39	65	89	202	782
B	10	10	10	89	202	782

Table 9 – Reasonably practicable test (\$ thousand)

Option	Network Safety Risk Reduction ²	Annualised CAPEX	Reasonably practicable ³ ?
A	5,251	141	Yes
B	5,251	192	Yes

From the above evaluation, it is considered that both Options A and B are reasonably practicable.

4.3 Preferred option

From the SFAIRP/ALARP evaluation, it is considered that both Options A and B are reasonably practicable and both options provide the same level of network safety risk reduction. In order to satisfy the organisation's SFAIRP/ALARP obligations, one of these options is required to be undertaken. Both Options A and B are commercially viable (as per the commercial evaluation), and whilst Option A is more beneficial, the NPV values of both options are very similar (\$4.85m and \$4.88m).

² The Network Safety Risk Reduction is calculated as 6 x Bushfire Risk Reduction + 6 x Safety Risk Reduction + 0.1 x Reliability Risk Reduction

³ Reasonably practicable is defined as whether the annualised CAPEX is less than the Network Safety Risk Reduction

However, Option B, due to its newer technology, is expected to provide further future efficiency savings which have not been quantified at this stage. In addition, the improvement to the communications system with the addition of fibre will provide greater visibility and interrogation of assets at the site and is foreseen to improve asset management and maintenance practices. It also meets the telecommunications development strategy of retiring the microwave network and associated assets by 2028. For these reasons, it is proposed that Option B be scoped in further detail.

Capital and operating expenditure

The estimated capital expenditure associated with the refurbishment outlined under Option A in this option is \$2.81m \pm 25%. Under Option B, the capital expenditure estimate for the refurbishment and OPGW retrofitting is \$3.84m \pm 25%, with a total expected quantified OPEX saving of \$0.04m per annum. In both instances, the vast majority of the capital expenditure is proposed to be carried out in 2022-2023.

It is expected that should works not occur by the Need date, under either A and B, an increase in corrective maintenance and subsequent operating expenditure is expected.

Regulatory Investment Test

No Regulatory Investment Test for Transmission (RIT-T) analysis is required for Option A as the works are condition based. Under Option B, no RIT-T analysis is required as the estimated CAPEX comes under the \$5m threshold.

5. Recommendation

From the above SFAIRP/ALARP evaluation in accordance with the regulatory requirements, and the commercial and technical evaluation of the available options, it is recommended that detailed scoping for the refurbishment of Line 17 including the OPGW retrofitting as outlined under Option B is undertaken. Furthermore, deploying Option B provides a technically superior option that will meet TransGrid's increasing telecommunications requirements into the foreseeable future and provide a link in a robust optical fibre backbone that will be established (in accordance with the Telecommunications Infrastructure Renewal and Maintenance Strategy) to facilitate the withdrawal of microwave infrastructure from the network.

Attachment 1 – Commercial evaluation report

Option A NPV calculation

Project_Option Name			Line 17 Refurbishment		
1. Financial Evaluation (excludes VCR benefits)					
NPV @ standard discount rate	10.00%	\$3.58m	NPV / Capital (Ratio)	1.28	
NPV @ upper bound rate	13.00%	\$2.38m	Pay Back Period (Yrs)	0.30 Yrs	
NPV @ lower bound rate (WACC)	6.75%	\$5.62m	IRR%	30.45%	
2. Economic Evaluation (includes VCR benefits but excludes tax benefits from non-cash transactions, ENS penalty and overall tax cost)					
NPV @ standard discount rate	10.00%	\$4.88m	NPV / Capital (Ratio)	-1.63	
NPV @ upper bound rate	13.00%	\$3.36m	Pay Back Period (Yrs)	2.56 Yrs	
NPV @ lower bound rate (WACC)	6.75%	\$7.41m	IRR%	37.12%	
Benefits					
Risk cost	As Is	To Be	Benefit	VCR Benefit	\$0.20m
Systems (reliability)	\$0.24m	\$0.04m	\$0.20m	ENS Penalty	\$0.00m
Financial	\$0.03m	\$0.00m	\$0.02m	All other risk benefits	\$0.89m
Operational/compliance	\$0.00m	\$0.00m	\$0.00m	Total Risk benefits	\$1.10m
People (safety)	\$0.10m	\$0.01m	\$0.09m	Benefits in the financial NPV*	\$0.89m
Environment	\$0.85m	\$0.07m	\$0.78m	*excludes VCR benefits	
Reputation	\$0.00m	\$0.00m	\$0.00m	Benefits in the economic NPV**	\$1.10m
Total Risk benefits	\$1.22m	\$0.12m	\$1.10m	**excludes ENS penalty	
Cost savings and other benefits			\$0.00m		
Total Benefits			\$1.10m		
Other Financial Drivers					
Incremental opex cost pa (no depreciation)			\$0.00m	Write-off cost	\$0.00m
Capital - initial \$m			-\$2.81m	Major Asset Life (Yrs)	20.00 Yrs
Residual Value - initial investment			\$0.00m	Re-investment capital	\$0.00m
Capitalisation period			3.00 Yrs	Start of the re-investment period	0.00 Yrs

Option B NPV calculation

Project_Option Name

Line 17 Refurbishment with OPGW Retrofit

1. Financial Evaluation (excludes VCR benefits)

NPV @ standard discount rate	10.00%	\$3.55m	NPV / Capital (Ratio)	1.02
NPV @ upper bound rate	13.00%	\$2.26m	Pay Back Period (Yrs)	0.27 Yrs
NPV @ lower bound rate (WACC)	6.75%	\$5.74m	IRR%	26.86%

2. Economic Evaluation (includes VCR benefits but excludes tax benefits from non-cash transactions, ENS penalty and overall tax cost)

NPV @ standard discount rate	10.00%	\$4.85m	NPV / Capital (Ratio)	-1.62
NPV @ upper bound rate	13.00%	\$3.25m	Pay Back Period (Yrs)	3.04 Yrs
NPV @ lower bound rate (WACC)	6.75%	\$7.54m	IRR%	32.61%

Benefits

Risk cost	As Is	To Be	Benefit	VCR Benefit	\$0.20m
Systems (reliability)	\$0.24m	\$0.04m	\$0.20m	ENS Penalty	\$0.00m
Financial	\$0.03m	\$0.00m	\$0.02m	All other risk benefits	\$0.89m
Operational/compliance	\$0.00m	\$0.00m	\$0.00m	Total Risk benefits	\$1.10m
People (safety)	\$0.10m	\$0.01m	\$0.09m	Benefits in the financial NPV*	\$0.94m
Environment	\$0.85m	\$0.07m	\$0.78m	*excludes VCR benefits	
Reputation	\$0.00m	\$0.00m	\$0.00m	Benefits in the economic NPV**	\$1.14m
Total Risk benefits	\$1.22m	\$0.12m	\$1.10m	**excludes ENS penalty	
Cost savings and other benefits			\$0.04m		
Total Benefits			\$1.14m		

Other Financial Drivers

Incremental opex cost pa (no depreciation)	\$0.00m	Write-off cost	\$0.00m
Capital - initial \$m	-\$3.47m	Major Asset Life (Yrs)	20.00 Yrs
Residual Value - initial investment	\$0.19m	Re-investment capital	\$0.67m
Capitalisation period	3.00 Yrs	Start of the re-investment period	2021-22