

OPTIONS EVALUATION REPORT (OER)



Snowy Area 330 kV Smart Grid Controls

OER 000000001484 revision 4.0

Ellipse project description: Snowy Area 330 kV Smart Grid Controls

TRIM file: [TRIM No]

Project reason: Imposed Standards - Control Systems to meet NER requirements

Project category: Prescribed - Augmentation

Author	Ronny Schnapp	Network & Connection Analysis Engineer
Reviewed	Lulu Shao	Network & Connection Analysis Senior Engineer
Endorsed	Vincent Ong	Network & Connections Analysis Manager
	Azil Khan	Investment Analysis Manager
	Garrie Chubb	Investment Support Manager
Approved	Andrew Kingsmill	Manager / Network Planning
Date submitted for approval	9 January 2017	

1. Need/opportunity

In order to meet the National Electricity Rule (NER) requirements to protect the NSW high voltage transmission system against high impact low probability multiple simultaneous contingencies, there is an opportunity for TransGrid to implement control, protection or other systems to manage the stability of both frequency and voltage following these multiple contingencies.

TransGrid studies indicated that significant voltage and dynamic stability constraints may arise under the non-credible contingencies of the loss of both Murray – Lower Tumut (66) and Murray – Upper Tumut (65) 330 kV lines. Such a multiple contingency event could result in voltage collapse and frequency control issues.

There is an opportunity to implement control, protection or other systems to avoid the stability issues of both frequency and voltage following these multiple contingencies.

For further details, refer to NOS-1484.

2. Related needs/opportunities

- > Need 1472 – Yass Area 330 kV Smart Grid Control
- > Need 1473 – North West Area 330 kV Smart Grid Control
- > Need 1482 – Sydney South Area 330 kV Smart Grid Controls
- > Need 1487 – Eraring 500 kV Smart Grid Control
- > Need 1491 – Sydney North West 330 kV Smart Grid Control
- > Need 1522 – Sydney West Area 330 kV Smart Grid Control

3. Options

Base Case

The Base Case for this Need is to continue operating the network “as is” for managing multiple simultaneous contingencies.

The risk cost was calculated using the Risk Tool, and considers the worst-case outage of both Murray – Lower Tumut (66) and Murray – Upper Tumut (65) 330 kV lines causing a loss of load of 4,000 MW¹. The load restoration time is estimated to be 8 hours². Furthermore, during works to restore the load, it is expected that the unserved energy will decrease gradually over the 8 hours. As such a load factor of 0.5 is used in the risk calculations to account for this. The probability of such an event occurring is deemed to be 1 in 100 years³.

Unserved Energy Risk Cost

Unserved energy is calculated as:

$$\text{Unserved Energy} = (\text{MW at risk} * 0.5 * \text{failure duration}) * (\text{overall failure rate})$$

$$\text{Unserved Energy} = (4000 \text{ MW} * 0.5 * 8 \text{ hrs}) * 1\%$$

$$\therefore \text{Unserved Energy} = 160 \text{ MWh}$$

The risk cost of unserved energy has been calculated as follows:

$$\text{Risk Cost of Unserved Energy} = \text{Unserved Energy} * \text{VCR}$$

¹ This event is noted to occur during severe bushfires, and it is expected that the resulting lost load in NSW will be 4,000 MW.

² Restoration time is based on TransGrid Control Room historical experience and OM666 Black Start.

³ It is assumed that this type of outage is a 1 in 100 year event.

$$\text{Risk Cost of Unserved Energy} = 160 \text{ MWh} * \$38,350/\text{MWh}^4$$

$$\therefore \text{Risk Cost of Unserved Energy} = \$6.14 \text{ million per year}$$

Other Risk Cost

In addition there are financial and reputational risk costs of \$0.09 million.⁵

Total Risk Cost

Total risk cost = Unserved energy risk cost + other risk costs

$$\therefore \text{Total risk cost} = \$6.23 \text{ million per annum.}$$

Option A — Snowy Area 330 kV Special Protection System

This option involves the implementation of a SCADA/Protection-based Hybrid Special Protection System (SPS) for the Snowy 330 kV area to prevent or minimise the effect of wide spread interruptions and a partial or full system collapse in the event of critical non-credible multiple contingencies.

The scope of works under this option can be found in OFR-1484A.

The expected capital cost for this option is \$2.97 million \pm 25% (in un-escalated 2016-17 dollars), spread over 3 years. The scope of works included in this option is outlined in [OFS-1484A](#).

The post-project risk cost of Option A is assessed to be \$2.33 million per year.

The annual unserved energy has been calculated using the same data as in the Base Case, except the targeted load lost is reduced⁶ compared to the Base Case due to the selected load shedding:

Unserved Energy Risk Cost

$$\text{Unserved Energy} = (\text{MW at risk} * 0.5 * \text{failure duration}) * (\text{overall failure rate})$$

$$\text{Unserved Energy} = (1500 \text{ MW} * 0.5 * 8 \text{ hrs}^7) * 1\%$$

$$\therefore \text{Unserved Energy} = 60 \text{ MWh}$$

The risk cost of unserved energy (which is included in the above risk cost) has been calculated as follows:

$$\text{Risk Cost of Unserved Energy} = \text{Unserved Energy} * \text{VCR}$$

$$\text{Risk Cost of Unserved Energy} = 60 \text{ MWh} * \$38,350/\text{MWh}^4$$

$$\therefore \text{Risk Cost of Unserved Energy} = \$2.3 \text{ million per annum}$$

Other Risk Cost

In addition there are reputational risk costs of \$0.03 million per annum⁸.

Total Risk Cost

Total risk cost = Unserved energy risk cost + other risk costs

$$\therefore \text{Total risk cost} = \$2.303 \text{ million per annum.}$$

⁴ TransGrid's Investment Risk Tool bases the Value of Customer Reliability (VCR) on figures published by AEMO in its Value of Customer Reliability Review - Final Report, September 2014. In this case we use the mixed residential/industrial figure of \$38,350/MWh.

⁵ These risk costs are due to this type of low probability event occurring and derived from the risk tool

⁶ Due to the selected load shedding by the Snowy area smart grid control scheme at the Dapto, Yass, Canberra and Williamsdale substations.

⁷ Restoration time is based on TransGrid Control Room historical experience and OM666 Black Start.

⁸ The operational/compliance risk are due to this type of event occurring and derived from the risk tool

Option B – Construction of a parallel transmission path

This option involves the construction of a 330 kV transmission line between the substations to prevent the existing transmission path becoming overloaded. It is anticipated that the capital costs for this option would be in excess of \$100m and would reduce the risk cost to zero.

Due to the significantly larger expected capital cost, this option will not deliver value for money and has not been considered.

Non-Network Solutions

No feasible non-network solutions have been identified to address this Need.

4. Evaluation

Both the Base Case and Option A are technically feasible. However, as seen below, implementing the Base Case (i.e. refraining from making capital investment) would generate a total risk cost of \$6.23 million for every year that the Need is not addressed. In contrast, Option A will reduce TransGrid’s average annual risk to \$2.303 million per year.

The commercial evaluation of the technically feasible options is set out in Table 1.

The full financial and economic evaluations are shown in Appendix A.

Table 1: Commercial Evaluation of Technically Feasible Options

Option	Description	Total Capex (\$m)	Annual Opex / yr (\$m)	Annual Post Project Risk Cost (\$m)	Economic NPV @ 10% (\$m)	Rank
Base Case	‘Do nothing’ – allow load to be lost and rely on manual restoration.	-	-	6.23	-	2
A	Snowy Area Special Protection System	2.97	0.06	2.30	19.70	1

The commercial evaluation is based on:

- > a 10% discount, with sensitivities based on TransGrid’s current AER-determined pre-tax real regulatory WACC of 6.75% for the lower bound, and 13% for the upper bound provided in Appendix A.
- > the applied sensitivities on the discount rate give the following economic NPVs:

Discount Rate (%)	Economic NPV (2018/19 \$m)
6.75	26.80
13.00	15.10

ALARP Evaluation

An ALARP assessment is triggered by the following hazard with the associated disproportionate factor:

- > Unplanned outage of high voltage equipment – 3 times the safety risk reduction and taking 10% of the reliability risk reduction as applicable to safety.

However, as this will only produce 30% of the benefit derived in the commercial evaluation, a full ALARP evaluation will not produce an alternative preferred solution.

Preferred Option

The preferred option is therefore Option A, as it significantly improves TransGrid's risk exposure, and yields the most benefits, as calculated using TransGrid's NPV Calculation Tool and Risk Tool (refer Appendix A).

Capital and operating expenditure

The yearly incremental operating expenditure is estimated to be 2% of the upfront capital cost of the preferred option, which equates to \$0.06 million, escalated at a rate of 2.9% per annum.

Regulatory Investment Test-Transmission

This Need is not subject to the RIT-T process as it does not exceed the \$6 million threshold requirement.

5. Recommendation

Based on the economic evaluation above, Option A is the preferred option to address the Need as it significantly reduces TransGrid's risk exposure and reduces the risk from \$6.23m to \$2.30m.

It is therefore recommended that a Request for Project Scoping (RPS) be issued for the implementation of a SCADA/Protection-based hybrid SPS for the Snowy 330 kV area in the 2018-2023 regulatory period.

Appendix A – Financial and Economic Evaluation Reports

Project_Option Name

Snowy Area Smart Grid Control System

1. Financial Evaluation (excludes VCR benefits)

NPV @ standard discount rate	10.00%	-\$2.24m	NPV / Capital (Ratio)	-0.75
NPV @ upper bound rate	13.00%	-\$2.10m	Pay Back Period (Yrs)	Not measurable
NPV @ lower bound rate (WACC)	6.75%	-\$2.41m	IRR%	Not measurable

2. Economic Evaluation (includes VCR benefits but excludes tax benefits from non-cash transactions, ENS penalty and overall tax cost)

NPV @ standard discount rate	10.00%	\$19.70m	NPV / Capital (Ratio)	6.63
NPV @ upper bound rate	13.00%	\$15.10m	Pay Back Period (Yrs)	Not measurable
NPV @ lower bound rate (WACC)	6.75%	\$26.80m	IRR%	94.38%

Benefits

	As Is	To Be	Benefit		
Risk cost				VCR Benefit	\$3.84m
Systems (reliability)	\$6.14m	\$2.30m	\$3.84m	ENS Penalty	\$0.00m
Financial	\$0.00m	\$0.00m	\$0.00m	All other risk benefits	\$0.08m
Operational/compliance	\$0.00m	\$0.00m	\$0.00m	Total Risk benefits	\$3.92m
People (safety)	\$0.00m	\$0.00m	\$0.00m	Benefits in the financial NPV*	\$0.08m
Environment	\$0.00m	\$0.00m	\$0.00m	*excludes VCR benefits	
Reputation	\$0.08m	\$0.00m	\$0.08m	Benefits in the economic NPV**	\$3.92m
Total Risk benefits	\$6.23m	\$2.30m	\$3.92m	**excludes ENS penalty	
Cost savings and other benefits			\$0.00m		
Total Benefits			\$3.92m		

Other Financial Drivers

Incremental opex cost pa (no depreciation)	-\$0.06m	Write-off cost	\$0.00m
Capital - initial \$m	-\$2.97m	Major Asset Life (Yrs)	15.00 Yrs
Residual Value - initial investment	\$0.00m	Re-investment capital	\$0.00m
Capitalisation period	3.00 Yrs	Start of the re-investment period	0.00 Yrs