

# OPTIONS EVALUATION REPORT (OER)



Protection-Time Domain Development

OER- 000000001584 revision 1.0

**Ellipse project no.:** P0009384

**TRIM file:** [TRIM No]

**Project reason:** Reliability - To meet overall network reliability requirements

**Project category:** Prescribed - Replacement

## Approvals

<b>Author</b>	Adam Hoare	Secondary Systems Senior Analyst
<b>Endorsed</b>	Mark Jones	Secondary Systems and Communications Asset Manager
	Azil Khan	Investment Strategy Manager
<b>Approved</b>	Lance Wee	M/Asset Strategy
<b>Date submitted for approval</b>	13 December 2016	

## Change history

Revision	Date	Amendment
0	23 November 2016	Initial issue
1	13 December 2016	Update to format

## 1. Need/opportunity

---

Power system stability has driven the need for faster transmission line protection. The ability to reduce network fault clearance times have several advantages such as:

- > Increased power transfer capabilities
- > Increased personnel safety
- > Decreased risk of high voltage asset damage caused by prolonged system faults
- > Improved power quality

Schweitzer Engineering Laboratories (SEL) have recently released a time-based protection relay (SEL-T400L) utilising a combination of travelling-wave principals and traditional incremental-quantity principals to provide ultra-high-speed line protection. Such a relay could potentially replace existing communication aided distance relays and result in cost savings through no longer requiring inter-trip devices.

## 2. Related Needs/opportunities

---

Nil.

## 3. Options

---

All dollar values in this document are expressed in un-escalated 2016/17 dollars.

### Base Case

The Base Case for this Need is to do nothing and continue with TransGrid's operation and maintenance (O&M) for secondary system assets.

### Option A — Time Domain Protection Development [[OFR 1584A](#), [OFS 1584A](#)]

This option covers the proof of concept, pilot deployment and in-service testing of a SEL time-domain based ultra-high-speed protection relay.

The expected total capital cost to implement this option is \$479k. This costing is estimated using TransGrid's "Success" estimating system.

A benefit figure of \$480k per annum has been calculated for this option and is based on expected savings from no longer requiring VF inter-trip units utilised in distance protection schemes. It is expected that 4 protection schemes on suitable feeders per annum can be replaced with SEL time-based relays, and therefore a total of 8 VF units can be saved per annum.

All options have been assessed as technically feasible.

## 4. Evaluation

---

### 4.1 Commercial evaluation

The commercial evaluation of the technically feasible options is set out in Table 1. Details appear in Attachment 1.

**Table 1 – Commercial evaluation (\$ million)**

Option	Description	Total capex	Annual opex	Annual post project risk cost	Economic NPV @10%	Financial NPV @10%	Rank
Base Case	Do nothing	N/A	-	0.40	N/A	N/A	2
A	Time Domain Protection Development	0.48	-	N/A	2.93	2.93	1

The commercial evaluation is based on:

- > a 10% discount rate
- > a life of the investment of 15 years and a corresponding residual/terminal value

Discount rate sensitivities based on TransGrid's current AER-determined pre-tax real regulatory Weighted Average Cost of Capital (WACC) of 6.7% and 13% appear in Table 2.

**Table 2 – Discount rate sensitivities (\$ million)**

Option	Description	Economic NPV @13%	Economic NPV @6.75%
A	Time Domain Protection Development	6.24	15.0

## 4.2 SFAIRP/ALARP evaluation

As this Need is not addressing risk there is no requirement for an SFAIRP/ALARP analysis.

## 4.3 Preferred option

The preferred option to address the Need is Option A - Time Domain Protection Development based on the commercial evaluation.

This option has been selected due to its technical viability, significant technical benefits and provides a positive Net Present Value (NPV).

### Capital and operating expenditure

There is negligible difference in predicted ongoing operational expenditure between the option and Base Case.

### Regulatory Investment Test

A Regulatory Investment Test for Transmission (RIT-T) is not required as this is an asset replacement project with no augmentation component.

## 5. Recommendation

It is the recommendation that Option A - Time Domain Protection Development be scoped in detail.

# Attachment 1 – Commercial evaluation report

## Option A NPV calculation

Project_Option Name		Time-Domain Based Protection Development			
<b>1. Financial Evaluation</b> (excludes VCR benefits)					
NPV @ standard discount rate	10.00%	\$2.93m	NPV / Capital (Ratio)	6.11	
NPV @ upper bound rate	13.00%	\$2.12m	Pay Back Period (Yrs)	Not measurable	
NPV @ lower bound rate (WACC)	6.75%	\$4.24m	IRR%	59.11%	
<b>2. Economic Evaluation</b> (includes VCR benefits but excludes tax benefits from non-cash transactions, ENS penalty and overall tax cost)					
NPV @ standard discount rate	10.00%	\$2.93m	NPV / Capital (Ratio)	6.11	
NPV @ upper bound rate	13.00%	\$2.12m	Pay Back Period (Yrs)	Not measurable	
NPV @ lower bound rate (WACC)	6.75%	\$4.24m	IRR%	59.11%	
<b>Benefits</b>					
Risk cost	As Is	To Be	Benefit	VCR Benefit	\$0.00m
Systems (reliability)	\$0.00m	\$0.00m	\$0.00m	ENS Penalty	\$0.00m
Financial	\$0.00m	\$0.00m	\$0.00m	All other risk benefits	\$0.00m
Operational/compliance	\$0.00m	\$0.00m	\$0.00m	Total Risk benefits	\$0.00m
People (safety)	\$0.00m	\$0.00m	\$0.00m	Benefits in the financial NPV*	\$0.48m
Environment	\$0.00m	\$0.00m	\$0.00m	*excludes VCR benefits	
Reputation	\$0.00m	\$0.00m	\$0.00m	Benefits in the economic NPV**	\$0.48m
Total Risk benefits	\$0.00m	\$0.00m	\$0.00m	**excludes ENS penalty	
Cost savings and other benefits			\$0.48m		
Total Benefits			\$0.48m		
<b>Other Financial Drivers</b>					
Incremental opex cost pa (no depreciation)			\$0.00m	Write-off cost	\$0.00m
Capital - initial \$m			-\$0.48m	Major Asset Life (Yrs)	15.00 Yrs
Residual Value - initial investment			\$0.00m	Re-investment capital	\$0.00m
Capitalisation period			4.00 Yrs	Start of the re-investment period	0.00 Yrs