

# Network Capability Incentive Parameter Action Plan (2014-2019)

<b>Project Number</b>	17
<b>Project Priority</b>	20
<b>Transmission Circuit / Injection Point</b>	Chapel Street Substation
<b>Project</b>	Installation of second 110 kV bus-coupler circuit breaker at Chapel Street Substation
<b>Scope of works</b>	Purchase and install a second 110 kV bus-coupler dead tank circuit breaker in series with the existing bus-coupler circuit breaker
<b>Reasons to undertake the project</b>	Chapel Street Substation has an outdoor AIS 110 kV switchyard which has a double bus arrangement. The two buses are connected via one only bus-coupler circuit breaker. Failure of this circuit breaker to open under a fault event would result in all circuits connected to both 110 kV buses being tripped. This would interrupt connections to seven 110 kV transmission circuits and four 110/11 kV supply transformers.
<b>Current value of the limit</b>	Failure of the 110 kV bus-coupler circuit breaker to open under a fault event could trip all 110 kV circuits, causing interruption of supply to significant load
<b>Target limit</b>	No interruption of supply caused by failure of a single 110 kV bus coupler circuit breaker
<b>Priority project improvement target</b>	Improve security of supply to all 110 kV connections at Chapel Street Substation
<b>Completion date</b>	June 2019
<b>Capital cost</b>	\$450K
<b>Operating cost</b>	\$0
<b>Market Benefit</b>	Mitigate risk of widespread interruption to load caused by failure of bus-coupler circuit breaker. The annualized market benefit is estimated at \$25k.