



United Energy United Energy Load Forecast Manual 2018/19

This page intentionally blank

Table of Contents

1. Purpose	5
2. Scope.....	5
3. Objective	5
4. Responsibilities.....	5
5. UE Maximum Demand Forecast	6
6. Zone Substation Maximum Demand Forecasts	7
7. Cross-border feeders	56
8. Definitions	57

This page intentionally blank

1. Purpose

The purpose of this document is to summarise UE's summer maximum demand forecasts. This document shall be updated annually to reflect the most up to date demand forecast. All enquiries relating to this document shall be directed to the email address planning@ue.com.au.

2. Scope

UE annually prepares a maximum demand forecast for each zone substation based on the historical actual demands, planned new load connections, planned new large scale developments such as data centres, urban redevelopment projects, industrial and residential estates; and knowledge of the other growth activities in local areas. This bottom-up forecast is then reconciled with the UE-wide forecast prepared annually by NIEIR for consistency.

All the actual and forecast data is provided as summer maximum demands under system normal network configuration. The ratings presented in this document are correct at the time of printing. Any revision to ratings during the year will be updated in the Ratings Database.

This document presents the following key information related to the UE's maximum demand forecast.

- Forecast 10%, 50% and 90% PoE UE 'boundary load' maximum demand for the next 10 years
- N and N-1 ratings of each zone substation
- Actual maximum demand at each zone substation for the last seven summers
- Weather corrected actual maximum demand at each zone substation for the last two summers
- Forecast 10% PoE summer maximum demand at each zone substation for the next 10 years
- N rating of each feeder
- Actual maximum demand of each feeder for last seven summers
- Forecast 10% PoE demand of each feeder for the next five years
- Anticipated load transfers and large new load information
- Reserve capacity requirements at zone substations where applicable
- For each cross-border feeder, respective N rating, actual maximum demand for last seven summers and forecast 10% PoE demand for the next five years.

3. Objective

The objective of this document is to:

- summarise UE's maximum demand forecast
- provide a common reference document for all the internal stakeholders

4. Responsibilities

The Network Planning group shall be responsible for updating this document annually.

5. UE Maximum Demand Forecast

UE System **Summer** Peak Demand MW - Historical & NIEIR Forecast Medium Economic Growth (Boundary Load)

FY Ending	UE Actual	UE Load Factor	Date/Time of MD (EST)	Avg Day Temp.	Actual PoE	Forecast at Actual PoE	Weather Corrected 10% PoE	Weather Corrected 90% PoE	Weather Corrected 50% PoE	50% PoE F'Cast Error	Corrected Load Factor	2018 Forecast		
Year	MW	MW/MW		°C	%	MW	MW	MW	MW	%	MW/MW	50% POE	90% POE	10% POE
1997	1352	0.57												
1998	1350	0.58	Thu 12/03/1998											
1999	1404	0.57	Thu 04/02/1999											
2000	1455	0.55	Thu 02/03/2000											
2001	1564	0.55	Thu 08/02/2001											
2002	1441	0.59	Fri 15/02/2002	27.7	82%									
2003	1468	0.59	Mon 24/02/2003	30.1	31%		1657		1519		0.57			
2004	1646	0.55	Wed 17/12/2003	30.1	31%	1663	1716	1450	1583	1.2%	0.57			
2005	1572	0.57	Tue 01/03/2005 14:00	26.8	98%	1508	1878	1600	1739	-3.6%	0.52			
2006	1649	0.57	Fri 24/02/2006 16:00	27.8	80%	1632	1903	1613	1758	-0.8%	0.53			
2007	1750	0.54	Tue 16/01/2007 15:00	28.8	62%	1788	1948	1643	1795	2.3%	0.52			
2008	1918	0.50	Mon 17/03/2008 16:00	29.7	47%	1893	2062	1749	1906	-1.1%	0.50			
2009	2084	0.46	Thu 29/01/2009 13:00	35.0	4%	2066	2060	1746	1903	-0.7%	0.50			
2010	2016	0.48	Mon 11/01/2010 16:00	31.3	22%	2044	2064	1743	1904	1.7%	0.51			
2011	1962	0.49	Tue 01/02/2011 13:00	32.4	15%	2225	2173	1803	1988	3.2%	0.48			
2012	1700	0.57	Tue 24/01/2012 16:00	27.7	82%	1953	2185	1868	2027	2.2%	0.48			
2013	1982	0.48	Tue 12/03/2013 16:00	29.3	77%	1932	2284	1923	2104	-3.3%	0.45			
2014	2066	0.45	Thu 16/01/2014 17:00	35.5	2%	2268	2237	1839	2038	-1.2%	0.45			
2015	1736	0.53	Thu 22/01/2015 16:00	26.9	100%	1705	2194	1787	1991	-2.5%	0.46			
2016	1964	0.47	Wed 13/01/2016 16:30	30.6	50%	1954	2152	1775	1964	-2.6%	0.47			
2017	1858	0.50	Thu 09/02/2017 13:30	31.1	40%	2027	2120	1734	1927	1.4%	0.48			
2018	1911		Fri 19/01/2018 16:30	31.4	40%	2008	2102	1728	1915	0.6%				
2019												2009	1821	2223
2020												2012	1825	2242
2021												2018	1829	2248
2022												2035	1859	2259
2023												2073	1879	2293
2024												2091	1900	2307
2025												2117	1933	2355
2026												2160	1980	2401
2027												2190	1992	2444
2028												2210	2007	2462
2029												2241	2043	2481




Figure 1: UE Summer Maximum Demand

6. Zone Substation Maximum Demand Forecasts

United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	Actual 2015	2016	2017	2018	2019	2020	2021	2022	Forecast 2023	2024	2025	2026	2027	2028
BOX HILL BH Voltage 22.7 kV																	
Load maximum demand actual / forecast (MW)	39.3	45.8	46.9	41.9	46.0	41.7	44.1	47.8	48.2	48.8	50.1	51.9	52.6	53.7	54.8	55.7	56.1
10% POE actual MD	45.0	47.8	46.9	46.1	46.9	46.6	46.1										
Load transfers (MW)																	
Extra new load (MW)			0.2	0.3	1.7	1.1	0.9	0.8	0.9	1.2	1.7	1.7	0.8				
% growth (MW)		16.7%	2.3%	-10.6%	9.7%	-9.4%	5.9%	8.4%	0.9%	1.3%	2.6%	3.6%	1.4%	2.2%	1.9%	1.7%	0.7%
Feeder summation reactive demand (MVAR)	18.1	19.2	17.3	16.7	15.1	13.1	13.1	14.7	14.9	15.2	15.7	16.5	16.8	17.3	17.8	18.2	18.3
Zone substation capacitor bank (MVAR)	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0
Feeder line capacitors (MVAR)	5.7	5.7	5.7	4.2	4.2	4.2	5.7	5.7	5.7	5.7	5.7	5.7	5.7	5.7	5.7	5.7	5.7
Reactive load on transformers (MVAR)	2.1	3.3	1.4	0.7	-0.8	-2.8	-2.8	-1.2	-1.0	-0.7	-0.2	0.6	0.9	1.4	1.8	2.2	2.4
Feeder summation power factor	0.91	0.92	0.94	0.93	0.95	0.95	0.96	0.96	0.96	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95
Transformation summation power factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	39.3	46.0	46.9	41.9	46.0	41.8	44.2	47.8	48.2	48.8	50.1	51.9	52.6	53.8	54.8	55.7	56.1
(N-1) Cyclic Rating (MVA)	36.3	36.3	72.6	72.6	72.6	72.6	72.6	72.6	72.6	72.6	72.6	72.6	72.6	72.6	72.6	72.6	72.6
(N-1) Limited Cyclic Rating (MVA)	38.7	38.7	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3
(N-1) 2 Hour Emergency Rating (MVA)	43.6	43.8	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7
(N-1) 10 Minute Emergency Rating (MVA)	43.6	43.8	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7	87.7
(N) Cyclic Rating (MVA)	72.6	72.6	108.9	87.7	108.9	108.9	108.9	108.9	108.9	108.9	108.9	108.9	108.9	108.9	108.9	108.9	108.9

Feeder	SCR (A) 2018	SCR (A) 2019	utilis (%) 2018	utilis (%) 2019	forecast utilis (%) 2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity	2018-2023 Annual growth	2019 DM (A)
BH 11	300	300	55%	58%	58%	204	220	254	140	175	137	164	174	175	176	176	178	126 A	5 MVA	1.7%
BH 12	280	280	25%	28%	33%	62	69	70	59	58	73	70	79	94	117	152	187	201 A	7.9 MVA	33.4%
BH 14	550	550	32%	96%	96%	180	162	148	179	166	169	176	526	526	527	527	527	24 A	0.9 MVA	39.9%
BH 21	285	285	50%	53%	54%	159	190	216	179	122	117	142	151	153	154	154	156	134 A	5.3 MVA	2.0%
BH 22	265	265	42%	47%	48%	85	111	117	97	115	118	111	124	127	132	136	138	141 A	5.6 MVA	4.7%
BH 23	350	350	58%	62%	63%	222	316	270	234	243	233	203	217	220	220	220	223	133 A	5.2 MVA	1.9%
BH 24	565	565	60%	96%	96%	332	343	353	326	328	334	342	542	542	543	543	543	23 A	0.9 MVA	11.8%
BH 31	265	265	36%	40%	42%			42	80	92	86	95	107	112	116	123	139	158 A	6.2 MVA	9.3%
BH 34	350	350	23%	25%	25%				64	72	65	81	86	87	88	89	90	264 A	10.4 MVA	2.1%
Average	357	357	43%	62%	62%	178	202	163	151	152	148	154	223	226	230	236	242	134 A	5.3 MVA	11.5%

Feeder	2019	2020	2021	2022	2023
BH 11	0	0	0	0	0
BH 12	0	0	0	0	0
BH 14	0	0	0	0	0
BH 21	0	0	0	0	0
BH 22	0	0	0	0	0
BH 23	0	0	0	0	0
BH 24	0	0	0	0	0
BH 31	0	0	0	0	0
BH 34	0	0	0	0	0

Feeder	2019	2020	2021	2022	2023
BH 11	0	1	0	0	0
BH 12	5	14	23	35	33
BH 14	0	0	0	0	0
BH 21	1	1	1	0	0
BH 22	6	3	5	4	0
BH 23	3	1	0	0	0
BH 24	0	0	0	0	0
BH 31	7	5	4	7	14
BH 34	0	0	1	1	0


Zone Substation Comments

- Zone substation ratings were reviewed in 2010.
- Line Capacitors: Installed 3.6MVAR line capacitors prior to summer 2000. Installed 9.0MVA capacitor bank at BH for summer 2000.
- Load transfers: 2.0MW from DC to BH prior to summer 2009.
- New Load: 4.0MW new load from Deakin University on BH21. ?? proposed 3.5MW at 249 Middleborough Rd, Box Hill on BH22.
- Carter Holt Harvey reduced their demand by about 2.0MW since Apr 1999. Carter Holt Harvey expected to reduce their demand by 4MW in 2005.

Reserve Capacity Requirements

1. SCA Hygiene (former Carter Holt Harvey): Ailsa St Box Hill
BH14 & BH24 (preferred)
Feeder ratings with one feeder out of service:
BH24 ratings (with BH14 out of service):
Summer continuous = 654A
Winter continuous = 698A
Summer cyclic = 665A
Winter cyclic = 708A
BH14 ratings (with BH24 out of service):
Summer continuous = 618A
Winter continuous = 660A
Summer cyclic = 635A
Winter cyclic = 670A

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND


Base Case; 10% Weather Probability

	Actual										Forecast										
	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028				
BEAUMARIS BR																					
Voltage	11.4 kV																				
Load maximum demand actual / forecast (MW)	23.7	25.7	27.3	21.5	25.2	26.0	29.1	30.6	30.6	30.6	30.5	30.8	30.9	31.6	32.2	32.7	32.8				
10% POE actual MD	28.4	29.0	29.4	28.5	28.6	29.5	29.7														
Load transfers (MW)																					
Extra new load (MW)			0.3	0.2	0.1	0.1	0.1	0.1	0.3	0.2	0.1	0.0									
% growth (MW)		8.4%	6.5%	-21.4%	17.3%	3.2%	11.8%	5.1%	0.2%	-0.2%	-0.2%	1.0%	0.3%	2.1%	1.9%	1.8%	0.3%				
Feeder summation reactive demand (MVar)	6.5	7.4	7.7	4.3	-4.9	-4.8	-5.2	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-4.9	-4.9	-4.8	-4.8				
Zone substation capacitor bank (MVar)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				
Feeder line capacitors (MVar)	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8				
Reactive load on transformers (MVar)	6.5	7.4	7.7	4.3	-4.9	-4.8	-5.2	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-4.9	-4.9	-4.8	-4.8				
Feeder summation power factor	0.96	0.96	0.96	0.98	0.98	0.98	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99				
Transformation summation power factor	0.96	0.96	0.96	0.98	0.98	0.98	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99				
EG and DM at peak demand (MW)																					
Overall demand on transformers (MVA)	24.5	26.7	28.4	21.9	25.7	26.4	29.5	31.0	31.0	31.0	30.9	31.2	31.3	31.9	32.5	33.1	33.2				
(N-1) Cyclic Rating (MVA)	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5				
(N-1) Limited Cyclic Rating (MVA)	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4				
(N-1) 2 Hour Emergency Rating (MVA)	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4				
(N-1) 10 Minute Emergency Rating (MVA)	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4				
(N) Cyclic Rating (MVA)	63.0	63.0	63.0	32.4	63.0	63.0	63.0	63.0	63.0	63.0	63.0	63.0	63.0	63.0	63.0	63.0	63.0				
Feeder	SCR (A)	utilis (%)	forecast utilis (%)	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity		2018-2023 Annual growth	2019 DM (A)		
BR 1	290	290	89%	92%	93%	219	233	252	141	227	224	260	267	269	272	276	281	23 A	0.5 MVA	1.7%	
BR 4	300	300	78%	80%	80%	195	215	227	189	204	206	233	239	241	242	243	245	61 A	1.2 MVA	1.0%	
BR 6	295	295	65%	69%	73%	171	185	197	164	189	206	193	203	215	225	226	228	92 A	1.8 MVA	3.7%	
BR 9	350	350	85%	88%	88%	245	253	276	218	240	247	299	307	308	310	311	314	43 A	0.8 MVA	1.0%	
BR 10	290	290	65%	67%	68%	132	159	164	146	156	173	189	195	198	201	202	203	95 A	1.9 MVA	1.6%	
BR 13	295	295	74%	76%	76%	179	190	216	172	209	197	217	223	224	225	226	228	72 A	1.4 MVA	1.0%	
BR 15	265	265	80%	82%	83%	175	189	209	169	190	187	212	218	219	220	221	223	47 A	0.9 MVA	1.0%	
Average	298	298	77%	79%	79%	188	203	220	171	202	206	229	236	239	242	244	246	62 A	1.2 MVA	1.5%	

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
BR 1	0	0	0	0	0
BR 4	0	0	0	0	0
BR 6	0	0	0	0	0
BR 9	0	0	0	0	0
BR 10	0	0	0	0	0
BR 13	0	0	0	0	0
BR 15	0	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
BR 1	0	1	2	3	2
BR 4	0	0	0	0	0
BR 6	6	11	8	0	0
BR 9	0	0	0	0	0
BR 10	1	2	2	0	0
BR 13	0	0	0	0	0
BR 15	0	0	0	0	0

Zone Substation Comments	Reserve Capacity Requirements
1. Station summer rating is limited by OV on tap. 2. Line Capacitors Install 1.8MVar in 2020. 3. Load Transfers 4. Zone substation capacitor bank is out of service. 5. New Loads:	Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
BENTLEIGH BT																				
Voltage	11.65 kV																			
Load maximum demand actual / forecast (MW)	24.2	27.3	29.2	22.6	27.3	24.9	30.1	31.7	32.3	32.5	32.7	33.0	33.1	33.7	34.4	35.0	35.1			
10% POE actual MD	27.0	27.9	29.2	28.9	31.0	30.2	30.7													
Load transfers (MW)							-1.7	0.9	-0.5											
Extra new load (MW)			0.3	0.3	0.7	1.1	0.9	0.9	0.8	0.6	0.4	0.1								
% growth (MW)		12.8%	7.1%	-22.7%	20.8%	-8.8%	21.0%	5.2%	1.8%	0.7%	0.6%	1.0%	0.1%	2.1%	1.9%	1.8%	0.2%			
Feeder summation reactive demand (MVAR)	6.5	6.5	5.5	2.9	4.1	3.2	3.5	4.0	4.2	4.2	4.3	4.4	4.4	4.6	4.8	5.0	5.0			
Zone substation capacitor bank (MVAR)	6.4	6.4	6.4	6.4	6.4	6.4	6.4	6.4	6.4	6.4	6.4	6.4	6.4	6.4	6.4	6.4	6.4			
Feeder line capacitors (MVAR)	4.5	4.5	4.5	6.9	6.9	6.9	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4			
Reactive load on transformers (MVAR)	-0.7	-0.6	-1.7	-4.3	-3.1	-3.9	-3.7	-3.2	-3.0	-2.9	-2.9	-2.8	-2.8	-2.5	-2.3	-2.1	-2.1			
Feeder summation power factor	0.97	0.97	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor	1.00	1.00	1.00	0.98	0.99	0.99	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	24.2	27.3	29.3	23.0	27.5	25.2	30.4	31.9	32.4	32.6	32.8	33.1	33.2	33.8	34.5	35.1	35.1			
(N-1) Cyclic Rating (MVA)	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1	31.1			
(N-1) Limited Cyclic Rating (MVA)	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3			
(N-1) 2 Hour Emergency Rating (MVA)	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3			
(N-1) 10 Minute Emergency Rating (MVA)	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3			
(N) Cyclic Rating (MVA)	62.1	62.1	62.1	32.3	62.1	62.1	62.1	62.1	62.1	62.1	62.1	62.1	62.1	62.1	62.1	62.1	62.1			
Feeder	SCR (A)	utilis (%)	forecast utilis (%)										2019	2018-2023	2019					
	2018	2019	2018	2019	2020								Spare capacity	Annual growth	DM (A)					
BT 2	275	275	75%	78%	79%	171	199	205	168	184	178	205	214	217	218	219	221	61 A	1.2 MVA	1.5%
BT 4	335	335	76%	80%	81%	218	237	259	268	295	196	255	266	272	276	280	283	69 A	1.4 MVA	2.2%
BT 5	285	285	37%	38%	38%	98	94	103	84	94	85	107	109	110	110	110	111	176 A	3.5 MVA	0.9%
BT 6	270	270	50%	54%	56%	134	138	149	126	134	127	136	146	152	159	163	166	124 A	2.5 MVA	4.3%
BT 9	280	280	56%	61%	65%	185	205	253	164	192	125	157	171	182	189	194	196	109 A	2.2 MVA	4.9%
BT 10	310	310	99%	92%	92%	247	287	301	235	267	254	307	285	286	287	288	291	25 A	0.5 MVA	-1.1%
BT 14	270	270	71%	73%	75%	177	258	221	165	184	176	191	198	202	202	203	203	72 A	1.4 MVA	1.5%
BT 15	305	305	68%	76%	83%	101	118	121	100	114	182	208	232	253	268	279	284	73 A	1.5 MVA	7.3%
Average	291	291	67%	70%	70%	166	192	201	164	183	165	196	203	209	214	217	220	89 A	1.8 MVA	2.4%

Feeder	2019	2020	2021	2022	2023
BT 2	0	0	0	0	0
BT 4	0	0	0	0	0
BT 5	0	0	0	0	0
BT 6	0	0	0	0	0
BT 9	0	0	0	0	0
BT 10	-29	0	0	0	0
BT 14	0	0	0	0	0
BT 15	0	0	0	0	0


Feeder	2019	2020	2021	2022	2023
BT 2	4	3	0	0	0
BT 4	6	4	4	3	0
BT 5	0	0	0	0	0
BT 6	6	6	6	4	1
BT 9	10	10	7	5	0
BT 10	0	0	0	0	0
BT 14	3	2	0	0	0
BT 15	18	20	14	10	3

Zone Substation Comments

- Station summer rating is limited by O/V on tap. With 5.4MVAR line caps installed, station rating will be limited by transformer thermal limits. Post 2001 ratings shown are based on 40deg C ambient temperature.
- Line Capacitors:
Install 5.4MVAR prior to summer 2002.
- PCB Cap Bank Replacement; 6.3MVAR in Oct 2001
- Load Transfers:
1.0MW from NB21 to BT10 prior to summer 2009
2MW from BT to CFD prior to summer 2009
0.5MW from BT to NB prior to summer 2009
0.4MW from BT to MR prior to summer 2011
1.7MW from BT04 to MR14 prior to summer 2016
- New Load:

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

		Actual										Forecast									
		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
BULLEEN	BU																				
Voltage	11.3 kV																				
Load maximum demand actual / forecast (MW)		24.5	27.2	29.3	23.2	27.3	26.0	29.8	31.3	31.3	31.0	30.9	31.3	31.3	31.8	32.3	32.7	32.9			
10% POE actual MD		26.9	29.8	30.5	30.0	29.9	29.3	30.4													
Load transfers (MW)																					
Extra new load (MW)				0.2	0.2	0.2	0.4	0.3	0.2	0.2	0.1	0.1	0.0								
% growth (MW)			10.9%	7.5%	-20.6%	17.4%	-4.6%	14.3%	5.3%	-0.1%	-0.8%	-0.3%	1.1%	0.2%	1.7%	1.5%	1.3%	0.4%			
Feeder summation reactive demand (MVAR)		5.8	6.5	6.4	4.1	4.4	4.7	4.2	4.6	4.6	4.5	4.5	4.6	4.6	4.8	4.9	5.1	5.1			
Zone substation capacitor bank (MVAR)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Feeder line capacitors (MVAR)		4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5			
Reactive load on transformers (MVAR)		5.8	6.5	6.4	4.1	4.4	4.7	4.2	4.6	4.6	4.5	4.5	4.6	4.6	4.8	4.9	5.1	5.1			
Feeder summation power factor		0.97	0.97	0.98	0.98	0.99	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor		0.97	0.97	0.98	0.98	0.99	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
EG and DM at peak demand (MW)																					
Overall demand on transformers (MVA)		25.2	28.0	30.0	23.6	27.6	26.4	30.0	31.7	31.6	31.4	31.3	31.6	31.7	32.2	32.7	33.1	33.2			
(N-1) Cyclic Rating (MVA)		29.7	29.7	29.7	29.7	29.7	29.7	29.7	29.7	29.7	29.7	29.7	29.7	29.7	29.7	29.7	29.7	29.7			
(N-1) Limited Cyclic Rating (MVA)		31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3			
(N-1) 2 Hour Emergency Rating (MVA)		31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3			
(N-1) 10 Minute Emergency Rating (MVA)		31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3	31.3			
(N) Cyclic Rating (MVA)		59.5	59.5	59.5	31.3	59.5	59.5	59.5	59.5	59.5	59.5	59.5	59.5	59.5	59.5	59.5	59.5	59.5			
Feeder	SCR (A)	utilis (%)	forecast utilis (%)	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity		2018-2023 Annual growth	2019 DM (A)		
BU 1	295	295	69%	71%	71%	167	188	217	173	184	204	204	210	211	212	212	214	85 A	1.7 MVA	1.0%	
BU 2	305	305	79%	84%	87%	199	230	259	187	230	181	241	257	265	266	267	269	48 A	0.9 MVA	2.4%	
BU 4	305	305	65%	67%	67%	169	197	212	172	195	196	200	205	206	207	208	210	100 A	2 MVA	1.0%	
BU 6	235	235	87%	89%	90%	165	192	202	159	191	178	204	210	211	214	217	221	25 A	0.5 MVA	1.7%	
BU 9	295	295	75%	77%	78%	188	206	218	171	200	189	221	227	229	232	234	236	68 A	1.3 MVA	1.4%	
BU 10	305	305	78%	81%	82%	188	215	220	181	223	202	237	246	251	254	254	257	59 A	1.1 MVA	1.7%	
BU 13	350	350	34%	35%	35%	106	115	137	106	114	116	119	122	122	123	123	123	228 A	4.5 MVA	1.0%	
BU 14	290	290	87%	89%	90%	203	220	252	203	234	222	252	259	260	261	262	265	31 A	0.6 MVA	1.0%	
Average	298	298	70%	73%	73%	173	195	215	169	196	186	210	217	219	221	222	225	80 A	1.6 MVA	1.4%	

Feeder	Load Transfers (Amps)			
	2019	2020	2021	2023
BU 1	0	0	0	0
BU 2	0	0	0	0
BU 4	0	0	0	0
BU 6	0	0	0	0
BU 9	0	0	0	0
BU 10	0	0	0	0
BU 13	0	0	0	0
BU 14	0	0	0	0


Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
BU 1	0	0	0	0	0
BU 2	9	7	0	0	0
BU 4	0	0	0	0	0
BU 6	0	1	1	3	2
BU 9	0	1	2	1	0
BU 10	3	3	2	0	0
BU 13	0	0	0	0	0
BU 14	0	0	0	0	0

Zone Substation Comments

- Station summer rating is limited by overvoltage on tap.
- Line Capacitors:
Installed 2.7MVAR in 2000 for summer 2001.
Install 1.8MVAR in 2002 for summer 2003.
- Load Transfers:
- New Loads:

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	Actual 2015	2016	2017	2018	2019	2020	2021	2022	Forecast 2023	2024	2025	2026	2027	2028
BURWOOD																	
BW																	
Voltage	11.32	kV															
Load maximum demand actual / forecast (MW)	18.8	22.2	23.6	19.0	22.1	21.3	22.9	24.0	24.1	23.9	23.8	24.1	24.1	24.5	24.8	25.2	25.4
10% POE actual MD	21.2	22.9	23.6	23.5	23.0	23.0	23.3										
Load transfers (MW)																	
Extra new load (MW)			0.1	0.5	0.8	0.5	0.6	0.2	0.0	0.0	0.0	0.0					
% growth (MW)		17.8%	6.2%	-19.2%	16.1%	-3.7%	7.4%	5.1%	0.2%	-0.6%	-0.4%	1.1%	0.2%	1.4%	1.4%	1.3%	1.1%
Feeder summation reactive demand (MVA)	3.5	3.2	3.4	2.2	1.6	1.4	2.1	2.5	2.5	2.4	2.4	2.5	2.5	2.6	2.7	2.9	3.0
Zone substation capacitor bank (MVA)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Feeder line capacitors (MVA)	5.4	5.4	5.4	6.3	6.3	6.3	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4
Reactive load on transformers (MVA)	3.5	3.2	3.4	2.2	1.6	1.4	2.1	2.5	2.5	2.4	2.4	2.5	2.5	2.6	2.7	2.9	3.0
Feeder summation power factor	0.98	0.99	0.99	0.99	1.00	1.00	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99
Transformation summation power factor	0.98	0.99	0.99	0.99	1.00	1.00	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	19.2	22.4	23.8	19.2	22.2	21.3	23.0	24.2	24.2	24.1	24.0	24.2	24.3	24.6	25.0	25.3	25.6
(N-1) Cyclic Rating (MVA)	24.3	24.3	24.3	24.3	24.3	24.3	24.3	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4
(N-1) Limited Cyclic Rating (MVA)	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4
(N-1) 2 Hour Emergency Rating (MVA)	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4
(N-1) 10 Minute Emergency Rating (MVA)	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4	25.4
(N) Cyclic Rating (MVA)	36.4	36.4	36.4	25.4	36.4	36.4	36.4	38.1	38.1	38.1	38.1	38.1	38.1	38.1	38.1	38.1	38.1

Feeder	SCR (A)	utilis (%)	forecast utilis (%)	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity	2018-2023 Annual growth	2019 DM (A)		
BW 21	290	290	84%	86%	87%	191	225	246	194	237	211	242	250	253	255	256	259	40 A	0.8 MVA	1.3%
BW 22	300	300	49%	53%	54%	156	186	167	164	126	158	146	159	161	163	165	167	141 A	2.8 MVA	2.9%
BW 23	300	300	44%	45%	46%	125	162	179	142	155	160	132	136	138	139	140	141	164 A	3.2 MVA	1.3%
BW 32	265	265	51%	53%	53%	111	128	134	103	125	118	135	139	142	144	145	147	126 A	2.5 MVA	1.7%
BW 33	295	295	64%	66%	67%	171	184	202	152	178	171	188	194	197	198	199	201	101 A	2 MVA	1.3%
BW 34	350	350	57%	59%	60%	158	181	189	148	177	171	199	206	208	210	211	213	144 A	2.8 MVA	1.3%
BW 35	350	350	74%	77%	78%	210	219	241	189	223	225	260	270	273	276	276	279	80 A	1.6 MVA	1.5%
Average	307	307	61%	63%	63%	160	184	194	156	175	173	186	193	196	198	199	201	114 A	2.2 MVA	1.6%

Feeder	2019	2020	2021	2022	2023
BW 21	0	0	0	0	0
BW 22	0	0	0	0	0
BW 23	0	0	0	0	0
BW 32	0	0	0	0	0
BW 33	0	0	0	0	0
BW 34	0	0	0	0	0
BW 35	0	0	0	0	0


Feeder	2019	2020	2021	2022	2023
BW 21	0	0	0	0	0
BW 22	8	0	1	1	1
BW 23	0	0	0	0	0
BW 32	0	1	1	1	0
BW 33	0	0	0	0	0
BW 34	0	0	0	0	0
BW 35	2	0	0	0	0

Zone Substation Comments

- Zone Substation ratings were reviewed in 2010. on 40deg C ambient temperature.
- Line Capacitors
Installed 4.5MVA in 2000.
Install 1.8MVA in 2002.
- New Loads:
15 Huntingdale road 0.7MW increase-2013
- Load Transfers:
- BW conversion (BW4 and BW8) from 6.6kV to 11kV during 2010.

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	Actual 2015	2016	2017	2018	2019	2020	2021	2022	Forecast 2023	2024	2025	2026	2027	2028
CLARINDA CDA																	
Voltage 22.59 kV																	
Load maximum demand actual / forecast (MW)	22.7	24.4	32.4	27.1	33.8	33.5	35.4	34.7	35.7	36.4	36.9	37.4	37.5	38.2	39.0	39.6	39.8
10% POE actual MD	26.5	27.4	32.4	32.4	35.5	36.5	36.8										
Load transfers (MW)		2.5						-4.0									
Extra new load (MW)		0.9	0.4	0.8	1.2	1.7	1.3	1.2	1.2	1.1	0.8						
% growth (MW)		7.7%	32.3%	-16.4%	24.8%	-0.8%	5.6%	-1.8%	2.7%	2.0%	1.5%	1.3%	0.1%	2.1%	1.9%	1.7%	0.4%
Feeder summation reactive demand (MVA)	5.9	3.4	7.7	1.8	4.8	2.3	4.7	4.5	4.8	5.1	5.3	5.5	5.5	5.9	6.1	6.4	6.5
Zone substation capacitor bank (MVA)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Feeder line capacitors (MVA)	8.1	8.1	8.1	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0
Reactive load on transformers (MVA)	5.9	3.4	7.7	1.8	4.8	2.3	4.7	4.5	4.8	5.1	5.3	5.5	5.5	5.9	6.1	6.4	6.5
Feeder summation power factor	0.97	0.99	0.97	1.00	0.99	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99
Transformation summation power factor	0.97	0.99	0.97	1.00	0.99	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	23.5	24.7	33.3	27.1	34.1	33.6	35.7	35.0	36.0	36.7	37.3	37.8	37.9	38.7	39.4	40.1	40.3
(N-1) Cyclic Rating (MVA)		25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8
(N-1) Limited Cyclic Rating (MVA)		26.1	26.1	26.1	26.1	26.1	26.1	26.1	26.1	26.1	26.1	26.1	26.1	26.1	26.1	26.1	26.1
(N-1) 2 Hour Emergency Rating (MVA)		29.1	29.1	29.1	29.1	29.1	29.1	29.1	29.1	29.1	29.1	29.1	29.1	29.1	29.1	29.1	29.1
(N-1) 10 Minute Emergency Rating (MVA)		29.1	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5	31.5
(N) Cyclic Rating (MVA)	46.7	72.5	59.4	31.5	59.4	59.4	59.4	59.4	59.4	59.4	59.4	59.4	59.4	59.4	59.4	59.4	59.4

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
CDA 11	0	0	0	0	0
CDA 12	0	0	0	0	0
CDA 21	0	0	0	0	0
CDA 22	0	0	0	0	0
CDA 23	-105	0	0	0	0
CDA 24	0	0	0	0	0

Feeder	SCR (A)		utilis (%)		forecast utilis (%)													2019 Spare capacity		2018-2023 Annual growth		2019 DM (A)
	2018	2019	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034			
CDA 11	350	350	35%	42%	46%														203 A	8 MVA	7.1%	
CDA 12	0	0																	0 A	0 MVA		
CDA 21	350	350	14%	16%	17%														293 A	11.5 MVA	5.2%	
CDA 22	400	400	55%	62%	66%														152 A	6 MVA	6.1%	
CDA 23	350	350	81%	56%	59%														153 A	6 MVA	-3.4%	
CDA 24	365	365	75%	80%	81%														74 A	2.9 MVA	2.7%	
Average	303	303	52%	52%	52%														146 A	5.7 MVA	2.4%	


Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
CDA 11	17	13	2	1	0
CDA 12	0	0	0	0	0
CDA 21	4	3	1	0	0
CDA 22	15	15	13	5	0
CDA 23	4	7	15	11	0
CDA 24	2	3	6	4	0

Zone Substation Comments

- Establish CDA with one 20/33MVA 66/22kV transformer in 2002.
- Relocate the Mobile Transformer from DVY to CDA in 2011.
install 3rd Tx at DVY in 2011 for summer 2012.
install mobile Tx at CDA in 2012 for summer 2013.
- Load Transfers to CDA
2.5MW from NO to CDA for summer 2013.
- New load:

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	Actual										Forecast									
	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
CAULFIELD																				
CFD																				
Voltage	11.5 kV																			
Load maximum demand actual / forecast (MW)	35.8	45.1	46.4	35.2	41.4	43.9	47.8	52.9	54.5	55.5	55.9	56.5	56.7	57.8	58.5	59.1	59.6			
10% POE actual MD	39.0	47.0	46.5	46.5	46.5	50.5	50.9													
Load transfers (MW)	3.0					3.3		0.5												
Extra new load (MW)			0.1	1.1	3.0	2.7	1.9	0.3	1.9	1.7	0.7	0.2								
% growth (MW)		25.8%	3.1%	-24.2%	17.6%	6.0%	8.9%	10.7%	2.9%	1.9%	0.7%	1.1%	0.3%	1.9%	1.2%	1.1%	0.7%			
Feeder summation reactive demand (MVAR)	5.6	8.5	10.9	0.3	2.9	1.5	4.3	6.2	6.8	7.2	7.4	7.6	7.7	8.1	8.4	8.6	8.8			
Zone substation capacitor bank (MVAR)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Feeder line capacitors (MVAR)	12.3	12.3	12.3	8.7	8.7	8.7	12.9	12.9	12.9	12.9	12.9	12.9	12.9	12.9	12.9	12.9	12.9			
Reactive load on transformers (MVAR)	5.6	8.5	10.9	0.3	2.9	1.5	4.3	6.2	6.8	7.2	7.4	7.6	7.7	8.1	8.4	8.6	8.8			
Feeder summation power factor	0.99	0.98	0.97	1.00	1.00	1.00	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor	0.99	0.98	0.97	1.00	1.00	1.00	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	36.3	45.9	47.7	35.2	41.5	43.9	48.0	53.3	54.9	56.0	56.4	57.1	57.2	58.3	59.1	59.8	60.2			
(N-1) Cyclic Rating (MVA)	42.1	42.1	42.1	42.1	42.1	42.1	42.1	42.1	42.1	42.1	42.1	42.1	42.1	42.1	42.1	42.1	42.1			
(N-1) Limited Cyclic Rating (MVA)	43.1	43.1	43.1	43.1	43.1	43.1	43.1	43.1	43.1	43.1	43.1	43.1	43.1	43.1	43.1	43.1	43.1			
(N-1) 2 Hour Emergency Rating (MVA)	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0			
(N-1) 10 Minute Emergency Rating (MVA)	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0	49.0			
(N) Cyclic Rating (MVA)	84.2	84.2	84.2	49.0	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2			
Feeder	2018	2019	2018	2019	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023			
CFD 11	300	300	59%	64%	66%	180	223	242	161	156	173	176	193	198	200	200	202			
CFD 12	350	350	70%	76%	78%	215	249	246	220	249	231	244	267	275	283	291	299			
CFD 13	350	350	68%	81%	82%	203	236	211	187	209	209	236	284	287	288	290	294			
CFD 14	630	630	71%	77%	80%	150	424	441	330	413	394	445	488	502	511	514	520			
CFD 15	280	280	68%	76%	80%	163	168	206	148	169	162	190	213	224	233	236	238			
CFD 16	510	510	43%	51%	59%	71	19	15	10	13	256	218	258	299	347	373	377			
CFD 21	350	350	12%	19%	22%	14	14	15	12	16	30	41	65	77	79	81	81			
CFD 22	300	300	58%	67%	73%	238	290	307	208	199	148	174	200	218	232	233	235			
CFD 23	350	350	84%	90%	91%	258	282	321	211	255	247	294	317	320	322	325	330			
CFD 24	350	350	57%	62%	62%	200	344	203	168	189	183	200	216	218	218	219	221			
CFD 25	300	300	54%	60%	62%	126	144	150	111	140	135	161	180	185	185	186	188			
CFD 26	300	300	75%	86%	89%	168	196	214	165	192	184	226	257	268	274	276	280			
Average	364	364	60%	67%	67%	166	216	214	161	183	196	217	245	256	264	269	272			
	2018	2019	2018	2019	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023			
	119 A	2.4 MVA	5.1%																	

Feeder	Load Transfers (Amps)			
	2019	2020	2021	2023
CFD 11	0	0	0	0
CFD 12	0	0	0	0
CFD 13	29	0	0	0
CFD 14	0	0	0	0
CFD 15	0	0	0	0
CFD 16	0	0	0	0
CFD 21	0	0	0	0
CFD 22	0	0	0	0
CFD 23	0	0	0	0
CFD 24	0	0	0	0
CFD 25	0	0	0	0
CFD 26	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
CFD 11	3	3	1	0	0
CFD 12	4	6	7	7	5
CFD 13	0	0	1	1	1
CFD 14	9	10	7	1	1
CFD 15	9	9	8	2	0
CFD 16	23	39	47	25	0
CFD 21	21	11	2	1	0
CFD 22	12	17	13	0	0
CFD 23	0	0	1	2	1
CFD 24	0	0	0	0	0
CFD 25	7	3	0	0	0
CFD 26	13	9	5	1	1

Zone Substation Comments


1. CFD zone substation was previously T and was rebuilt in 2007 and 2008 for summer 2009.

2. Load Transfers:
 1MW from K10 to CFD22 (T69) prior to summer 2009
 2MW from K6 to CFD22 (T69) prior to summer 2009
 2MW from BT to CFD for summer 2009.
 15.1MW from T to CFD for summer 2009.
 1.3MW from K to CFD for summer 2012.
 1.7MW from EM to CFD for summer 2012.

3. New Loads:
 1MVA in 2008 and 1.3MVA in 2009 for shopping centre along Koornang Rd, Carnegie on CFD12.
 1.2MVA in 2009 for Caulfield racecourse on CFD11.
 5.1MVA for Monash Uni redevelopment to replace Dandenong-Derby S/S, to be completed in 2010.
 5.5MVA Caulfield Village Development - 2014-2015 (CFD21-4 MVA, CFD16- 1.5 MVA)

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

		Actual										Forecast									
		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
CHELTENHAM	CM																				
Voltage 11.5 kV																					
Load maximum demand actual / forecast (MW)		26.1	25.4	26.3	23.9	25.0	23.3	23.8	27.6	28.2	28.5	28.9	29.7	30.6	31.8	32.5	32.9	33.0			
10% POE actual MD		27.6	26.5	26.6	26.5	26.7	26.3	26.1													
Load transfers (MW)																					
Extra new load (MW)				0.1	0.5	1.0	1.0	1.0	0.8	0.8	0.7	0.5	0.8	0.9	0.9						
% growth (MW)			-2.7%	3.7%	-9.1%	4.3%	-6.8%	2.4%	15.7%	2.3%	1.3%	1.2%	3.0%	3.0%	3.7%	2.5%	1.1%	0.2%			
Feeder summation reactive demand (MVar)		8.4	7.4	7.6	3.4	3.3	3.0	3.1	4.6	4.9	5.0	5.2	5.5	5.9	6.4	6.7	6.9	6.9			
Zone substation capacitor bank (MVar)		4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0			
Feeder line capacitors (MVar)		6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3			
Reactive load on transformers (MVar)		4.1	3.1	3.3	-1.0	-1.0	-1.4	-1.3	0.3	0.6	0.7	0.8	1.2	1.6	2.1	2.4	2.5	2.6			
Feeder summation power factor		0.95	0.96	0.96	0.99	0.99	0.99	0.99	0.99	0.99	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98			
Transformation summation power factor		0.99	0.99	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																					
Overall demand on transformers (MVA)		26.4	25.6	26.5	24.0	25.0	23.3	23.9	27.6	28.2	28.5	28.9	29.8	30.7	31.8	32.6	33.0	33.1			
(N-1) Cyclic Rating (MVA)		30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9	30.9			
(N-1) Limited Cyclic Rating (MVA)		33.2	33.2	33.2	33.2	33.2	33.2	33.2	33.2	33.2	33.2	33.2	33.2	33.2	33.2	33.2	33.2	33.2			
(N-1) 2 Hour Emergency Rating (MVA)		33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9			
(N-1) 10 Minute Emergency Rating (MVA)		33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9	33.9			
(N) Cyclic Rating (MVA)		61.8	61.8	61.8	33.9	61.8	61.8	61.8	61.8	61.8	61.8	61.8	61.8	61.8	61.8	61.8	61.8	61.8			
Feeder		2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034			
CM 11	315	315	37%	43%	45%	132	135	147	127	153	109	116	136	142	142	143	144	179 A	3.6 MVA	4.8%	
CM 12	300	300	70%	78%	80%	152	153	251	220	221	207	210	235	240	251	259	262	65 A	1.3 MVA	4.9%	
CM 13	335	335	42%	52%	55%	125	123	134	112	139	132	141	174	183	183	184	186	161 A	3.2 MVA	6.4%	
CM 14	300	300	40%	44%	45%	142	133	124	136	113	119	120	133	134	134	135	136	167 A	3.3 MVA	2.6%	
CM 15	300	300	25%	29%	30%	118	110	86	82	97	81	74	87	91	91	91	92	213 A	4.2 MVA	4.8%	
CM 21	330	330	56%	63%	64%	200	219	221	197	176	161	186	207	212	217	220	222	123 A	2.4 MVA	3.9%	
CM 22	315	315	22%	26%	29%	60	66	70	59	70	67	68	81	91	99	99	100	234 A	4.7 MVA	9.4%	
CM 23	335	335	34%	38%	38%	178	156	103	123	121	120	115	127	128	128	128	130	208 A	4.1 MVA	2.6%	
CM 24	315	315	48%	53%	53%	213	205	166	140	160	151	151	167	168	168	172	180	148 A	3 MVA	3.9%	
CM 25	315	315	52%	59%	63%	168	182	213	160	158	143	163	186	198	213	241	290	129 A	2.6 MVA	15.5%	
Average	316	316	43%	49%	49%	149	148	152	136	141	129	134	153	159	163	167	174	163 A	3.2 MVA	5.9%	

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
CM 11	0	0	0	0	0
CM 12	0	0	0	0	0
CM 13	0	0	0	0	0
CM 14	0	0	0	0	0
CM 15	0	0	0	0	0
CM 21	0	0	0	0	0
CM 22	0	0	0	0	0
CM 23	0	0	0	0	0
CM 24	0	0	0	0	0
CM 25	0	0	0	0	0


Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
CM 11	7	5	0	0	0
CM 12	2	5	10	7	0
CM 13	19	8	0	0	0
CM 14	0	0	0	0	0
CM 15	5	4	0	0	0
CM 21	2	4	4	2	0
CM 22	5	10	8	0	0
CM 23	0	0	0	0	0
CM 24	0	0	148	0	3
CM 25	6	11	15	27	46

Zone Substation Comments

- Due to space limitation, existing site is suitable for 2 transformers only.
- Zone Substation ratings were reviewed in 2001. Post 2001 ratings shown are based on 40deg C ambient temperature.
- Line Capacitors:
6.3MVar line capacitors installed in 1998.
- Load Transfers:
- New loads:
New load for summer 2002 :- CM 06 Loreal 0.4MW.
New load for summer 2003 :- CM 07 industrial load 0.4MW.

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
CARRUM CRM																	
Voltage	22.3 kV																
Load maximum demand actual / forecast (MW)	66.1	81.0	77.6	71.1	74.8	77.2	73.5	88.2	88.7	88.6	88.8	89.9	90.4	92.1	93.9	95.6	97.0
10% POE actual MD	71.4	81.8	82.4	82.3	81.6	84.5	85.2										
Load transfers (MW)																	
Extra new load (MW)		6.4	1.0	0.8	0.9	0.8	0.8	0.5	0.7	0.6	0.7	0.4					
% growth (MW)		22.4%	-4.1%	-8.4%	5.1%	3.3%	-4.8%	20.0%	0.6%	-0.2%	0.3%	1.2%	0.6%	1.9%	1.9%	1.8%	1.5%
Feeder summation reactive demand (MVAR)	16.0	20.1	16.3	13.7	12.2	12.8	11.9	16.5	16.6	16.6	16.7	17.0	17.2	17.7	18.3	18.8	19.2
Zone substation capacitor bank (MVAR)	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8
Feeder line capacitors (MVAR)	9.0	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8
Reactive load on transformers (MVAR)	4.9	9.0	5.2	2.6	1.1	1.7	0.8	5.4	5.5	5.5	5.6	5.9	6.1	6.6	7.2	7.7	8.1
Feeder summation power factor	0.97	0.97	0.98	0.98	0.99	0.99	0.99	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98
Transformation summation power factor	1.00	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	66.3	81.4	77.8	71.2	74.8	77.2	73.5	88.3	88.9	88.7	89.0	90.1	90.6	92.3	94.1	95.9	97.3
(N-1) Cyclic Rating (MVA)	73.9	73.9	73.9	73.9	73.9	73.9	73.9	73.9	73.9	73.9	73.9	73.9	73.9	73.9	73.9	73.9	73.9
(N-1) Limited Cyclic Rating (MVA)	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9
(N-1) 2 Hour Emergency Rating (MVA)	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8
(N-1) 10 Minute Emergency Rating (MVA)	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8	82.8
(N) Cyclic Rating (MVA)	110.8	110.8	110.8	82.8	110.8	110.8	110.8	110.8	110.8	110.8	110.8	110.8	110.8	110.8	110.8	110.8	110.8
Feeder	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
SCR (A)	390	390	390	390	390	390	390	390	390	390	390	390	390	390	390	390	390
utilis (%)	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%
forecast utilis (%)	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%	94%
2018	407	406	340	335	298	345	367	368	368	369	369	369	369	22 A	0.9 MVA	0.1%	
2019	163	170	180	165	177	173	175	261	266	269	271	274	274	49 A	1.9 MVA	11.4%	
2020	232	223	202	216	250	199	189	225	229	232	234	237	237	70 A	2.7 MVA	5.1%	
2021	224	252	266	239	256	241	258	304	310	316	323	329	329	11 A	0.4 MVA	5.5%	
2022	154	320	234	223	205	219	258	298	308	317	329	340	2 A	0.1 MVA	6.4%		
2023	223	285	257	224	237	233	319	321	327	331	333	337	29 A	1.1 MVA	1.1%		
2024	117	127	127	108	120	107	121	142	145	147	148	149	138 A	5.3 MVA	4.8%		
2025													0 A	0 MVA			
2026	314	196	198	248	176	212	218	219	219	219	219	219	171 A	6.6 MVA	0.1%		
2027	158	211	229	190	164	182	166	196	200	202	204	206	94 A	3.6 MVA	4.8%		
2028	249	120	149	164	181	173	190	233	250	263	270	274	87 A	3.4 MVA	8.9%		
2029	290	298	310	277	297	262	271	320	326	330	333	336	30 A	1.2 MVA	4.8%		
Average	299	299	71%	80%	80%	211	241	246	250	253	256	59 A	2.3 MVA	4.3%			

Feeder	2019	2020	2021	2022	2023
CRM 11	0	0	0	0	0
CRM 12	55	0	0	0	0
CRM 13	0	0	0	0	0
CRM 14	0	0	0	0	0
CRM 21	0	0	0	0	0
CRM 22	-55	0	0	0	0
CRM 24	0	0	0	0	0
CRM 31	0	0	0	0	0
CRM 32	0	0	0	0	0
CRM 33	0	0	0	0	0
CRM 34	0	0	0	0	0
CRM 35	0	0	0	0	0

Feeder	2019	2020	2021	2022	2023
CRM 11	0	0	0	0	0
CRM 12	0	0	0	0	0
CRM 13	3	0	0	0	0
CRM 14	0	1	2	4	3
CRM 21	1	4	6	10	7
CRM 22	0	0	0	0	0
CRM 24	0	0	0	0	0
CRM 31	0	0	0	0	0
CRM 32	0	0	0	0	0
CRM 33	0	0	0	0	0
CRM 34	9	13	10	4	1
CRM 35	0	0	0	0	0


Zone Substation Comments

- Zone Substation ratings were reviewed in 2010. ambient temperature.
- Line Capacitors
6MVAR line capacitors installed in 1998.
6.3MVAR of line capacitors to be installed in 2000 for summer 2001.
- Replace PCB capacitors in 2003 : #2 - 12MVAR.
- Load transfers:
Transfer 2.9MW from MC, DVY to CRM prior to summer 2010.
CRM13 - 5.0MVA from FTN12 and 2.0MVA from FTN23 (2011/12)
- New Loads
1.0MVA on CRM32 (2014)
4.5MW on CRM21 over next 3 years from 2007 for Eastlink Business Estate
9.5MW on CRM32 from ETP in 2013
- New 66/22kV Transformer
Install & commission 3rd transformer at CRM in 2009 prior to summer 2010.

Reserve Capacity Requirements

Network Support Agreements

- GreenSync, 1MVA on CRM35 for 2 years from 2014/15



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	Actual										Forecast									
	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
DONCASTER DC																				
Voltage	22.7 kV																			
Load maximum demand actual / forecast (MW)	67.4	79.0	86.0	68.3	79.2	75.7	81.5	93.9	95.1	96.1	97.3	99.3	100.2	101.9	103.4	104.7	105.1			
10% POE actual MD	73.1	81.8	86.0	86.7	86.2	85.7	89.6													
Load transfers (MW)																				
Extra new load (MW)			1.5	2.7	5.8	4.0	4.2	2.1	1.8	1.8	1.6	1.5	0.6							
% growth (MW)		17.2%	8.8%	-20.6%	16.0%	-4.4%	7.7%	15.2%	1.3%	1.0%	1.3%	2.1%	0.9%	1.7%	1.5%	1.3%	0.4%			
Feeder summation reactive demand (MVA)	16.1	12.9	16.0	8.4	5.4	3.9	3.6	7.1	7.5	7.8	8.1	8.7	8.9	9.4	9.8	10.2	10.3			
Zone substation capacitor bank (MVA)	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1	9.1			
Feeder line capacitors (MVA)	15.6	18.3	18.3	19.8	19.8	19.8	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3	18.3			
Reactive load on transformers (MVA)	6.4	3.2	6.3	-1.3	-4.3	-5.8	-6.1	-2.6	-2.2	-1.9	-1.6	-1.0	-0.8	-0.3	0.1	0.5	0.6			
Feeder summation power factor	0.97	0.99	0.98	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
Transformation summation power factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	67.7	79.1	86.2	68.3	79.3	75.9	81.7	93.9	95.2	96.1	97.3	99.3	100.2	101.9	103.4	104.7	105.1			
(N-1) Cyclic Rating (MVA)	73.6	73.6	73.6	73.6	73.6	73.6	73.6	73.6	73.6	73.6	73.6	73.6	73.6	73.6	73.6	73.6	73.6			
(N-1) Limited Cyclic Rating (MVA)	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6			
(N-1) 2 Hour Emergency Rating (MVA)	82.3	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4			
(N-1) 10 Minute Emergency Rating (MVA)	82.3	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4	81.4			
(N) Cyclic Rating (MVA)	110.4	110.4	110.4	81.4	110.4	110.4	110.4	110.4	110.4	110.4	110.4	110.4	110.4	110.4	110.4	110.4	110.4			

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
DC 1	0	0	0	0	0
DC 2	0	0	0	0	0
DC 3	0	0	0	0	0
DC 4	0	0	0	0	0
DC 5	0	0	0	0	0
DC 6	0	0	0	0	0
DC 7	0	0	0	0	0
DC 8	0	0	0	0	0
DC 10	0	0	0	0	0
DC 12	0	0	0	0	0

Feeder	SCR (A)		utilis (%)	forecast utilis (%)	2012-2028													2019		2018-2023		2019 DM (A)
	2018	2019			2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	Spare capacity	Annual growth				
DC 1	350	350	66%	77%	249	256	266	222	245	235	231	268	271	272	273	276	82 A	3.2 MVA	3.8%			
DC 2	350	350	85%	89%	247	270	295	233	270	252	297	313	315	317	320	325	37 A	1.5 MVA	1.9%			
DC 3	350	350	80%	85%	238	264	287	218	255	233	279	296	301	309	315	318	54 A	2.1 MVA	2.8%			
DC 4	350	350	62%	74%	178	217	235	178	212	197	218	258	275	289	290	293	92 A	3.6 MVA	6.9%			
DC 5	350	350	78%	88%	213	280	296	232	278	258	273	307	314	318	322	326	43 A	1.7 MVA	3.9%			
DC 6	350	350	63%	90%	124	150	167	203	218	159	221	316	325	332	340	351	34 A	1.3 MVA	11.8%			
DC 7	265	265	52%	59%	152	169	176	150	144	138	137	158	168	180	187	190	107 A	4.2 MVA	7.7%			
DC 8	265	265	58%	64%	134	147	164	127	156	166	154	171	172	174	176	178	94 A	3.7 MVA	3.1%			
DC 10	330	330	71%	79%	192	211	230	180	202	201	235	261	263	265	267	270	69 A	2.7 MVA	3.0%			
DC 12	350	350	62%	76%	192	180	178	171	158	203	216	265	270	283	307	338	85 A	3.3 MVA	11.3%			
Average	331	331	68%	79%	192	214	230	191	214	204	226	261	267	274	280	286	70 A	2.7 MVA	5.3%			

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
DC 1	3	2	0	0	0
DC 2	1	1	0	1	2
DC 3	4	4	6	5	0
DC 4	17	16	12	0	0
DC 5	6	5	2	2	1
DC 6	20	8	5	7	8
DC 7	6	10	11	6	1
DC 8	0	1	1	1	0
DC 10	1	1	1	1	0
DC 12	0	4	12	23	28


Zone Substation Comments

- Zone Substation ratings were reviewed in 2010. 2-hour rating is limited by transformer #2 cable.
- Line Capacitors
Installed 8.1MVA prior to summer 1999.
Installed 5.7MVA prior to summer 2000.
Install 2.7MVA in 2000 for summer 2001.
- Load Transfers:
2.0MW to BH prior to summer 2009.
0.4MW to NW prior to summer 2009.
- New Loads
1.0MVA new s/s on DC12, the corner of Arnold st and Spring st Box Hill, Melways p47 C8. in 2009
BH New Hospital-Addl Load 6 MVA - 2013 -DC12 & DC6 (DC8 previously)

Reserve Capacity Requirements

- Manningham City Council.
DC04 (preferred)
DC01 (reserve) - 0.65MVA (17A) reserve.
- The Pines.
DC02 (preferred)
DC03 (reserve) - 0.6MW (16A).
The contract no longer exist.
- Box Hill Hospital Reserve capacity agreement
DC12 (1 MVA)
DC06 (2 MVA)
The contract to be signed in 2016.

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	Actual										Forecast									
	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
ROMANA DMA																				
Voltage	22.22 kV																			
Load maximum demand actual / forecast (MW)	34.7	37.6	34.8	32.7	39.1	37.4	40.4	46.4	46.9	47.2	47.7	48.8	49.6	51.0	52.4	53.7	54.5			
10% POE actual MD	36.7	39.4	41.1	40.4	42.0	43.4	44.5													
Load transfers (MW)																				
Extra new load (MW)																				
% growth (MW)		8.4%	-7.4%	-6.1%	19.7%	-4.6%	8.2%	14.8%	1.0%	0.6%	1.0%	2.3%	1.7%	2.8%	2.7%	2.5%	1.5%			
Feeder summation reactive demand (MVar)	5.0	5.1	4.8	4.4	3.7	2.8	3.2	4.6	4.7	4.8	4.9	5.2	5.4	5.7	6.0	6.3	6.5			
Zone substation capacitor bank (MVar)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Feeder line capacitors (MVar)	4.5	5.4	5.4	5.1	5.1	5.1	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3			
Reactive load on transformers (MVar)	5.0	5.1	4.8	4.4	3.7	2.8	3.2	4.6	4.7	4.8	4.9	5.2	5.4	5.7	6.0	6.3	6.5			
Feeder summation power factor	0.99	0.99	0.99	0.99	1.00	1.00	1.00	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor	0.99	0.99	0.99	0.99	1.00	1.00	1.00	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	35.1	38.0	35.2	33.0	39.3	37.5	40.6	46.6	47.1	47.4	47.9	49.0	49.9	51.3	52.7	54.0	54.9			
(N-1) Cyclic Rating (MVA)							44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8	44.8			
(N-1) Limited Cyclic Rating (MVA)							48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3			
(N-1) 2 Hour Emergency Rating (MVA)							48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3			
(N-1) 10 Minute Emergency Rating (MVA)							48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3	48.3			
(N) Cyclic Rating (MVA)	44.8	44.8	44.8		44.8	89.6	89.6	89.6	89.6	89.6	89.6	89.6	89.6	89.6	89.6	89.6	89.6			

Feeder	SCR (A)		utilis (%)	forecast utilis (%)																			2019		2018-2023		2019 DM (A)
	2018	2019		2018	2019	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	Spare capacity	Annual growth								
DMA 11	0	0			156	145	154	146										151 A	5.8 MVA	4.3%							
DMA 12	315	315	47%	52%	307	321	286	265	201	120	147	164	167	171	174	178	203 A	7.8 MVA	4.4%								
DMA 13	350	350	37%	42%	186	185	173	187	114	113	130	147	149	152	155	159	203 A	7.8 MVA	4.4%								
DMA 14	315	315	74%	84%	152	184	187	180	219	224	234	265	271	276	281	287	50 A	1.9 MVA	4.6%								
DMA 15	310	310	25%	28%	110	137	135	126	81	80	78	88	89	91	93	95	222 A	8.6 MVA	4.3%								
DMA 21	260	260	70%	79%					195	181	183	206	211	217	221	226	54 A	2.1 MVA	4.7%								
DMA 22	0	0															0 A	0 MVA									
DMA 23	275	275	65%	73%					173	174	179	201	205	209	213	218	74 A	2.8 MVA	4.3%								
DMA 24	320	320	54%	61%					144	151	173	194	197	201	205	210	126 A	4.9 MVA	4.3%								
DMA 25	0	0															0 A	0 MVA									
Average	215	215	75%	59%	182	194	187	113	161	149	160	140	143	146	149	152	74 A	2.9 MVA	-1.0%								

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
DMA 11	0	0	0	0	0
DMA 12	0	0	0	0	0
DMA 13	0	0	0	0	0
DMA 14	0	0	0	0	0
DMA 15	0	0	0	0	0
DMA 21	0	0	0	0	0
DMA 22	0	0	0	0	0
DMA 23	0	0	0	0	0
DMA 24	0	0	0	0	0
DMA 25	0	0	0	0	0


Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
DMA 11	0	0	0	0	0
DMA 12	0	0	0	0	0
DMA 13	1	0	0	0	0
DMA 14	3	1	0	0	0
DMA 15	0	0	0	0	0
DMA 21	1	2	1	0	0
DMA 22	0	0	0	0	0
DMA 23	0	0	0	0	0
DMA 24	0	0	0	0	0
DMA 25	0	0	0	0	0

Zone Substation Comments

- New zone substation constructed in 2006 for summer 2007 with a single 20/33MVA transformer. Second transformer to be installed in 2016.
- Line capacitors: DMA 11 - Cap Bayview Outlook, Cap Nepean Verdon, Cap Nepean Eddystone. DMA 12 - none. DMA 13 - Cap MTN Flind Harrison. DMA 14 - Cap Marine Nepean. DMA 15 - Cap Bittern MTN Flind. All 900kVAr fixed except Cap Nepean Eddystone which is unknown.
- Load transfer 0.5MW from RBD to DMA before summer 2009. Feeder network reconfiguration in 2015.
- New Loads:

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
DANDENONG DN																	
Voltage 22.33 kV																	
Load maximum demand actual / forecast (MW)	70.6	70.5	83.2	75.3	75.3	75.8	73.4	89.0	89.2	88.7	88.4	89.4	89.7	91.5	93.2	94.9	96.0
10% POE actual MD	77.3	80.0	83.1	86.3	84.2	85.9	85.7										
Load transfers (MW)				3.4													
Extra new load (MW)		0.9	4.2	1.8	2.1	2.6	2.2	1.4	1.0	0.5	0.4	0.1					
% growth (MW)		-0.1%	18.1%	-9.5%	0.0%	0.6%	-3.1%	21.1%	0.3%	-0.6%	-0.3%	1.1%	0.4%	1.9%	1.9%	1.8%	1.1%
Feeder summation reactive demand (MVAR)	3.6	7.7	28.6	20.2	9.3	9.8	3.5	6.7	6.7	6.6	6.6	6.8	6.8	7.2	7.6	7.9	8.1
Zone substation capacitor bank (MVAR)	17.8	17.8	17.8	17.8	17.8	17.8	17.8	17.8	17.8	17.8	17.8	17.8	17.8	17.8	17.8	17.8	17.8
Feeder line capacitors (MVAR)	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.4
Reactive load on transformers (MVAR)	-14.6	-10.6	10.3	1.9	-9.0	-8.5	-14.8	-11.6	-11.6	-11.7	-11.7	-11.5	-11.4	-11.1	-10.7	-10.4	-10.2
Feeder summation power factor	1.00	0.99	0.95	0.97	0.99	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Transformation summation power factor	0.98	0.99	0.99	1.00	0.99	0.99	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99
EG and DM at peak demand (MW)	6.0	5.1	1.4	4.6	2.4	0.0	5.6	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5
Overall demand on transformers (MVA)	66.2	66.2	82.4	70.7	73.5	76.3	69.4	85.2	85.5	85.0	84.7	85.7	86.0	87.7	89.4	91.0	92.0
(N-1) Cyclic Rating (MVA)	86.7	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2	84.2
(N-1) Limited Cyclic Rating (MVA)	90.2	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6	87.6
(N-1) 2 Hour Emergency Rating (MVA)	92.7	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5
(N-1) 10 Minute Emergency Rating (MVA)	92.7	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5	92.5
(N) Cyclic Rating (MVA)	130.0	126.2	126.2	92.5	126.2	126.2	126.2	126.2	126.2	126.2	126.2	126.2	126.2	126.2	126.2	126.2	126.2

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
DN 2	0	0	0	0	0
DN 4	0	0	0	0	0
DN 6	0	0	0	0	0
DN 7	0	0	0	0	0
DN 8	0	0	0	0	0
DN 9	0	0	0	0	0
DN 10	0	0	0	0	0
DN 11	0	0	0	0	0
DN 13	0	0	0	0	0
DN 21	0	0	0	0	0
DN 22	0	0	0	0	0
DN 23	0	0	0	0	0
DN 24	0	0	0	0	0
DN 25	0	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
DN 2	0	0	0	0	0
DN 4	1	0	0	0	0
DN 6	2	4	6	7	2
DN 7	3	3	2	2	0
DN 8	2	0	0	0	0
DN 9	9	7	0	0	0
DN 10	0	0	0	0	0
DN 11	0	0	0	0	0
DN 13	4	3	0	0	0
DN 21	0	0	0	0	0
DN 22	0	0	0	0	0
DN 23	10	5	0	0	0
DN 24	3	6	4	0	0
DN 25	4	2	2	2	0


Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- Dandenong Hosp. Co-gen. - 5MW, 0MVAR, 7AM - 11PM, Mon - Frid. CoGent generation - 2MW, 0MVAR, 7AM-10PM, Mon-Fri
- Line Caps: Install 1.8MVAR line caps on DN01 for summer 2001.
- PCB Cap Bank Replacement 1998: #3 - 9MVAR
- Load Transfers:
 - DN 4 - 1.4MVA to DN8 and 1.1MVA to DN21 (2012/13)
 - DN21 - 2.5MVA to DN8 (2012/13)
 - DN13 - 1.7MVA from LD2 (2012/13)
- New Loads:
 - 2MVA on DN8, Estate One (2012)
 - 1.5MW by Hallam industrial development on DN21 over 2009-2011.
 - proposed approx 30 MVA over 20 yrs for the Dandenong revitalisation project by 2030.
 - new feeder DN23 was created in 2015 to supply Estate One demand.
- New Transformer - Third transformer at DN in 2007 for summer 2008. No 3 transformer was replaced on 30 Sep 2013

Reserve Capacity Requirements

- Pilkington Glass Greens Rd Dandenong.
 - DSH22 (preferred)
 - DN24 (reserve) - 2MVA (52A) - Changed from 7MVA in 2013
- Dandenong Hospital
 - DN11 (preferred)
 - LD4 (reserve) - 1.8MVA (47A)
- Aurora
 - DN11 (preferred)
 - LD4 (reserve) - 1.15MVA (30A)
 - The reserve construct is for 1.8MVA (Aurora inclusive)

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	Actual 2015	2016	2017	2018	2019	2020	2021	2022	Forecast 2023	2024	2025	2026	2027	2028
DANDENONG SOUTH DSH																	
Voltage	22.3 kV																
Load maximum demand actual / forecast (MW)	60.4	59.6	61.8	56.7	56.7	56.9	62.4	68.5	69.1	68.8	68.6	69.4	69.6	71.0	72.3	73.7	74.5
10% POE actual MD	63.5	61.4	64.7	59.9	60.7	60.8	64.8										
Load transfers (MW)			-9.5														
Extra new load (MW)		3.8	4.1	2.0	4.9	3.2	3.4	2.4	1.3	0.5	0.4	0.1					
% growth (MW)		-1.3%	3.6%	-8.2%	0.0%	0.4%	9.6%	9.8%	0.9%	-0.5%	-0.3%	1.1%	0.4%	1.9%	1.9%	1.8%	1.1%
Feeder summation reactive demand (MVAR)	19.4	17.9	21.9	-4.1	5.5	18.6	19.9	23.4	23.8	23.6	23.5	23.9	24.1	24.8	25.6	26.4	26.8
Zone substation capacitor bank (MVAR)	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4	12.4
Feeder line capacitors (MVAR)	19.2	19.2	19.2	21.0	21.0	21.0	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3
Reactive load on transformers (MVAR)	6.7	5.2	9.2	-16.8	-7.2	5.9	7.2	10.7	11.1	10.9	10.8	11.2	11.4	12.1	12.9	13.7	14.1
Feeder summation power factor	0.95	0.96	0.94	1.00	1.00	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.94	0.94	0.94	0.94
Transformation summation power factor	0.99	1.00	0.99	0.96	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.98	0.98	0.98	0.98
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	60.8	59.9	62.4	59.1	57.2	57.2	62.8	69.4	70.0	69.7	69.5	70.3	70.6	72.0	73.5	74.9	75.8
(N-1) Cyclic Rating (MVA)	62.8	61.3	61.3	61.3	61.3	61.3	61.3	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6
(N-1) Limited Cyclic Rating (MVA)	67.5	65.8	65.8	65.8	65.8	65.8	65.8	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6
(N-1) 2 Hour Emergency Rating (MVA)	67.5	67.5	67.5	67.5	67.5	67.5	67.5	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6
(N-1) 10 Minute Emergency Rating (MVA)	67.5	67.5	69.0	69.0	69.0	69.0	69.0	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6	96.6
(N) Cyclic Rating (MVA)	94.2	91.9	91.9	69.0	91.9	91.9	91.9	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8	144.8

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
DSH 13	0	0	0	0	0
DSH 14	0	0	0	0	0
DSH 21	0	0	0	0	0
DSH 22	0	0	0	0	0
DSH 23	0	0	0	0	0
DSH 24	0	0	0	0	0
DSH 31	0	0	0	0	0
DSH 32	0	0	0	0	0
DSH 33	0	0	0	0	0
DSH 34	0	0	0	0	0

Feeder	SCR (A)		utilis (%)	forecast utilis (%)	2012-2028													2019		2018-2023 Annual growth	2019 DM (A)
	2018	2019			2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	Spare capacity	2019			
DSH 13	344	344	89%	89%	89%	323	296	310	336	325	332	307	307	308	308	308	37 A	1.4 MVA	0.1%		
DSH 14	350	350	60%	60%	67%	164	165	152	148	158	155	211	228	234	236	237	239	122 A	4.7 MVA	2.7%	
DSH 21	350	350	83%	87%	89%	252	266	278	260	244	262	289	306	310	313	314	317	44 A	1.7 MVA	1.9%	
DSH 22	345	345	43%	45%	46%	150	157	173	176	167	154	148	157	159	160	161	162	188 A	7.3 MVA	1.9%	
DSH 23	335	335	21%	22%	23%	86	88	87	74	79	71	70	74	75	77	78	79	261 A	10.1 MVA	2.5%	
DSH 24	350	350	21%	27%	30%	148	194	198	10	39	58	73	94	104	106	107	110	256 A	9.9 MVA	10.2%	
DSH 31	350	350	55%	58%	59%	162	143	169	156	144	177	191	203	206	208	208	210	147 A	5.7 MVA	2.0%	
DSH 32	325	325	52%	57%	58%	190	211	215	207	197	211	170	184	189	190	191	193	141 A	5.5 MVA	2.6%	
DSH 33	550	550	58%	65%	67%	367	376	325	345	383	372	317	358	367	370	371	375	192 A	7.4 MVA	3.7%	
DSH 34	325	325	40%	47%	52%	90	79	113	117	106	112	129	152	170	185	194	196	173 A	6.7 MVA	10.4%	
Average	362	362	53%	57%	57%	193	198	202	183	184	190	190	206	212	215	217	219	156 A	6 MVA	3.0%	

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
DSH 13	0	0	0	0	0
DSH 14	5	4	0	0	0
DSH 21	0	0	0	0	0
DSH 22	0	0	0	0	0
DSH 23	0	0	1	1	0
DSH 24	17	9	1	1	1
DSH 31	1	0	0	0	0
DSH 32	3	2	0	0	0
DSH 33	24	4	0	0	0
DSH 34	15	17	13	8	1


Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- Line Capacitors:
33.9MVAR of line capacitors were installed in late 1997. 10.8MVAR transferred to DVY in Dec 1999.
- PCB Cap Bank Replacement - 1998: # 2 - 7MVAR; #3 - 5MVAR
- Load Transfers:
Transfer 4MW from DVY31 and DVY34 to DSH33 for summer 2009.
Transfer 7MVA from DSH24 to KBH33 for summer 2015.
- New Loads:
5MVA for Aluminium Profiles on DSH33 (2016) - HV Customer

Reserve Capacity Requirements

- Pilkingtons, Greens Rd, Dandenong DSH22 (preferred)
DN24 (reserve) - 2MVA (52A) - Changed from 7MVA in 2013

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
DANDENONG VALLEY DVY																	
Voltage	22.59 kV																
Load maximum demand actual / forecast (MW)	62.9	70.3	71.2	70.9	73.8	76.4	76.3	82.6	83.5	84.1	85.1	86.5	86.8	88.5	90.2	91.9	92.9
10% POE actual MD	65.9	72.4	73.4	73.2	74.2	78.9	78.8										
Load transfers (MW)																	
Extra new load (MW)		1.6	2.3	1.5	4.4	2.8	3.0	2.0	1.6	1.5	1.5	1.1	0.1				
% growth (MW)		11.7%	1.3%	-0.4%	4.2%	3.5%	-0.2%	8.3%	1.1%	0.7%	1.2%	1.7%	0.4%	1.9%	1.9%	1.8%	1.1%
Feeder summation reactive demand (MVAR)	25.9	28.5	28.0	24.9	26.1	24.5	22.1	25.6	26.1	26.4	27.0	27.8	27.9	28.9	29.8	30.7	31.3
Zone substation capacitor bank (MVAR)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Feeder line capacitors (MVAR)	16.2	18.9	18.9	21.6	21.6	21.6	18.9	18.9	18.9	18.9	18.9	18.9	18.9	18.9	18.9	18.9	18.9
Reactive load on transformers (MVAR)	25.9	28.5	28.0	24.9	26.1	24.5	22.1	25.6	26.1	26.4	27.0	27.8	27.9	28.9	29.8	30.7	31.3
Feeder summation power factor	0.92	0.93	0.93	0.94	0.94	0.95	0.96	0.96	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95
Transformation summation power factor	0.92	0.93	0.93	0.94	0.94	0.95	0.96	0.96	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	68.0	75.8	76.5	75.1	78.3	80.3	79.4	86.5	87.5	88.2	89.3	90.9	91.2	93.1	95.0	96.9	98.0
(N-1) Cyclic Rating (MVA)	87.8	87.8	87.8	87.8	87.8	87.8	87.8	87.8	87.8	87.8	87.8	87.8	87.8	87.8	87.8	87.8	87.8
(N-1) Limited Cyclic Rating (MVA)	94.3	93.7	93.7	93.7	93.7	93.7	93.7	93.7	93.7	93.7	93.7	93.7	93.7	93.7	93.7	93.7	93.7
(N-1) 2 Hour Emergency Rating (MVA)	101.0	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7
(N-1) 10 Minute Emergency Rating (MVA)	101.0	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7	94.7
(N) Cyclic Rating (MVA)	133.7	131.6	131.6	94.7	131.6	131.6	131.6	131.6	131.6	131.6	131.6	131.6	131.6	131.6	131.6	131.6	131.6

Feeder	Load Transfers (Amps)			
	2019	2020	2021	2023
DVY 11	0	0	0	0
DVY 12	0	0	0	0
DVY 13	0	0	0	0
DVY 14	0	0	0	0
DVY 21	0	0	0	0
DVY 22	0	0	0	0
DVY 23	0	0	0	0
DVY 24	0	0	0	0
DVY 31	0	0	0	0
DVY 32	0	0	0	0
DVY 33	0	0	0	0
DVY 34	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
DVY 11	1	3	2	0	0
DVY 12	0	0	0	0	0
DVY 13	0	2	4	7	4
DVY 14	2	0	0	0	0
DVY 21	10	1	1	1	0
DVY 22	0	0	0	0	0
DVY 23	1	0	0	0	0
DVY 24	28	22	17	11	7
DVY 31	3	3	3	1	0
DVY 32	0	0	0	0	0
DVY 33	5	4	0	0	0
DVY 34	7	9	13	23	19


Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- Line Capacitors - 4.5MVAR for summer 2001.
- Load Transfers:
 - Transfer 7.5MW from DVY to DSH and DN prior to summer 2009.
 - Transfer 2.5MW from DVY to FTN prior to summer 2009.
 - Transfer 7MW from DVY to CRM prior to summer 2010.
- New Loads:
 - 3MVA for Gentac on DVY21 (2016) - HV Customer
 - 8MVA for Nexus Estate on DVY24 (2017-18) - HV Customer
- New Transformer:
 - Install 2nd 20/33MVA transformer in 2003 for summer 2004.
 - Install 3rd 20/33MVA transformer in 2011 for summer 2012. Relocate mobile Tx to CDA.

Reserve Capacity Requirements

- Woolworths DC, Dandenong South.
DVY11 (5MVA for 2016 and 17, 4MVA for 2018)

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
EAST BURWOOD EB																	
Voltage 22.51 kV																	
Load maximum demand actual / forecast (MW)	51.3	59.0	61.9	51.5	58.4	54.4	57.4	63.5	64.5	65.4	66.4	68.3	69.3	70.3	71.6	72.8	73.1
10% POE actual MD	58.3	61.9	61.9	60.8	60.1	61.0	61.0										
Load transfers (MW)																	
Extra new load (MW)		0.6	0.3	0.3	2.4	1.3	2.1	1.2	1.7	1.7	1.5	1.8	1.1				
% growth (MW)		14.9%	4.9%	-16.7%	13.4%	-6.8%	5.5%	10.5%	1.6%	1.4%	1.4%	2.9%	1.6%	1.4%	1.9%	1.7%	0.4%
Feeder summation reactive demand (MVAR)	15.3	15.6	15.4	10.1	14.3	12.5	11.7	13.6	13.9	14.2	14.4	15.0	15.4	15.7	16.1	16.4	16.5
Zone substation capacitor bank (MVAR)	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9	13.9
Feeder line capacitors (MVAR)	5.7	5.7	5.7	6.0	6.0	6.0	5.7	5.7	5.7	5.7	5.7	5.7	5.7	5.7	5.7	5.7	5.7
Reactive load on transformers (MVAR)	0.7	1.0	0.8	-4.5	-0.3	-2.1	-2.8	-1.0	-0.7	-0.4	-0.1	0.5	0.8	1.1	1.5	1.9	2.0
Feeder summation power factor	0.96	0.97	0.97	0.98	0.97	0.97	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98
Transformation summation power factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	51.3	59.0	61.9	51.7	58.4	54.5	57.5	63.5	64.5	65.4	66.4	68.3	69.3	70.3	71.6	72.8	73.1
(N-1) Cyclic Rating (MVA)	67.8	67.8	67.8	67.8	67.8	67.8	67.8	67.8	67.8	67.8	67.8	67.8	67.8	67.8	67.8	67.8	67.8
(N-1) Limited Cyclic Rating (MVA)	72.5	72.5	72.5	72.5	72.5	72.5	72.5	72.5	72.5	72.5	72.5	72.5	72.5	72.5	72.5	72.5	72.5
(N-1) 2 Hour Emergency Rating (MVA)	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9
(N-1) 10 Minute Emergency Rating (MVA)	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9	80.9
(N) Cyclic Rating (MVA)	101.8	101.8	101.8	80.9	101.8	101.8	101.8	101.8	101.8	101.8	101.8	101.8	101.8	101.8	101.8	101.8	101.8
Feeder	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
SCR (A)	350	350	350	350	350	350	350	350	350	350	350	350	350	350	350	350	350
utilis (%)	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%	58%
forecast utilis (%)	65%	65%	65%	65%	65%	65%	65%	65%	65%	65%	65%	65%	65%	65%	65%	65%	65%
2012	162	206	208	187	218	205	201	227	240	247	249	252	123 A	4.8 MVA	5.1%		
2013	91	100	108	77	96	81	107	118	121	122	122	124	142 A	5.5 MVA	3.1%		
2014	127	141	110	101	107	98	101	187	188	192	200	218	143 A	5.6 MVA	23.3%		
2015	90	105	115	91	106	96	122	134	140	152	166	179	146 A	5.7 MVA	9.5%		
2016	87	106	109	93	104	108	102	120	135	144	144	145	150 A	5.8 MVA	8.5%		
2017	162	193	204	154	169	149	154	166	167	168	168	170	104 A	4 MVA	2.0%		
2018	190	195	202	170	180	161	159	250	251	251	251	253	80 A	3.1 MVA	11.8%		
2019	52	65	69	53	64	57	70	79	81	85	93	109	271 A	10.6 MVA	11.2%		
2020	161	173	182	158	168	160	164	178	185	194	203	213	172 A	6.7 MVA	6.1%		
2021	195	212	233	178	215	189	238	258	262	264	265	268	32 A	1.3 MVA	2.5%		
2022	162	200	201	167	195	159	193	210	213	215	216	219	55 A	2.1 MVA	2.6%		
Average	293	304	50%	57%	58%	134	154	158	130	148	133	146	175	180	185	189	195
	1	2	3	4	5	6	18	19	20	21			118 A	5 MVA	6.7%		

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
EB 11	0	0	0	0	0
EB 12	0	0	0	0	0
EB 13	0	0	0	0	0
EB 14	0	0	0	0	0
EB 21	0	0	0	0	0
EB 22	0	0	0	0	0
EB 23	0	0	0	0	0
EB 24	0	0	0	0	0
EB 31	0	0	0	0	0
EB 32	0	0	0	0	0
EB 33	0	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
EB 11	10	12	7	2	0
EB 12	3	3	1	0	0
EB 13	1	0	4	8	16
EB 14	3	5	12	13	12
EB 21	10	14	8	0	0
EB 22	0	0	0	0	0
EB 23	0	0	0	0	0
EB 24	3	2	4	8	15
EB 31	2	6	8	10	7
EB 32	1	3	2	0	0
EB 33	1	2	2	1	0


Zone Substation Comments

- Line Capacitors - Installed 6.0MVar prior to summer 2000.
- PCB Capacitors Replacement - March 1999 : #1 - 8MVar
- Load Transfers:
 - 4.0MW from GW to EB before summer 2009.
 - 3.0MW from RWT to EB before summer 2009.
- New Load:
 - HP data centre on EB03/EB07: 2.8MVA in 2005 + 1.1MVA in 2006 + 2.5MVA in 2008 (EB13).
 - 0.5MW on EB8 in 2008 by RSPCA
 - New residential and commercial development between 2007-2010 on Middleborough Rd near Burwood Highway. Total load of 10MW. (still to be confirmed)
 - EB13 extra 2MW over unknown period. Substation "Preb Church" upgrade from 750kVA to 2MVA at 18 Vision Drv (Crossway Baptis Church).
 - Deakin Uni Burwood Campus new 4MVA s/s for new auditorium on EB11 -2013/14
- New 66/22kV Transformer - 3rd Transformer at EB for summer 2008.

Reserve Capacity Requirements

- Insurance Australia Group, 23 Lakeside Drive, Burwood in Tally Ho (preferred) EB23 (reserve) - 1.6MVA (42A)
- Hewlett Packard, 4 Wesley Court, Tally Ho Business Park. 6MVA (157A) over two feeders EB13 and EB23. Assume 3MVA each.

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
ELSTERNWICK EL																	
Voltage 11.3 kV																	
Load maximum demand actual / forecast (MW)	25.3	30.1	32.0	25.4	28.9	30.0	30.6	34.9	35.3	35.5	35.8	36.2	36.3	37.0	37.7	38.6	38.8
10% POE actual MD	29.2	32.0	32.9	32.9	32.6	34.7	33.2										
Load transfers (MW)																	
Extra new load (MW)		0.2	0.2	0.8	2.0	1.8	1.3	0.9	0.7	0.6	0.4	0.0					
% growth (MW)		19.1%	6.5%	-20.7%	13.8%	3.8%	1.9%	14.1%	1.3%	0.7%	0.7%	1.1%	0.3%	1.9%	1.9%	2.2%	0.7%
Feeder summation reactive demand (MVAR)	5.3	7.7	8.3	4.2	5.5	5.1	3.8	5.2	5.3	5.4	5.5	5.6	5.6	5.8	6.1	6.3	6.4
Zone substation capacitor bank (MVAR)	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1
Feeder line capacitors (MVAR)	5.4	5.4	5.4	6.3	6.3	6.3	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4
Reactive load on transformers (MVAR)	-1.2	1.2	1.8	-2.3	-1.0	-1.4	-2.7	-1.3	-1.2	-1.1	-1.0	-0.9	-0.9	-0.6	-0.4	-0.2	-0.1
Feeder summation power factor	0.98	0.97	0.97	0.99	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99
Transformation summation power factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	25.3	30.1	32.1	25.5	28.9	30.0	30.7	34.9	35.3	35.6	35.8	36.2	36.3	37.0	37.7	38.6	38.8
(N-1) Cyclic Rating (MVA)	28.5	33.4	33.4	33.4	33.4	33.4	33.4	33.4	33.4	33.4	33.4	33.4	33.4	33.4	33.4	33.4	33.4
(N-1) Limited Cyclic Rating (MVA)	30.6	35.8	35.8	35.8	35.8	35.8	35.8	35.8	35.8	35.8	35.8	35.8	35.8	35.8	35.8	35.8	35.8
(N-1) 2 Hour Emergency Rating (MVA)	32.0	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4
(N-1) 10 Minute Emergency Rating (MVA)	32.0	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4	38.4
(N) Cyclic Rating (MVA)	57.0	66.9	66.9	38.4	66.9	66.9	66.9	66.9	66.9	66.9	66.9	66.9	66.9	66.9	66.9	66.9	66.9

Feeder	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028						
EL 5	137	128	139	110	134	138	147	169	177	179	182	185					
EL 6	165	184	203	160	181	176	210	230	232	233	234	237					
EL 7	103	107	126	81	106	118	132	155	163	165	167	169					
EL 8	152	173	178	141	175	198	221	245	248	251	254	257					
EL 9	153	186	211	145	171	156	171	190	193	194	195	197					
EL 10	185	191	197	161	182	163	143	180	198	224	244	247					
EL 11	217	222	239	182	213	194	234	257	260	261	262	265					
EL 12	124	149	142	138	149	151	153	168	170	171	171	173					
EL 13	142	170	183	154	161	168	160	179	183	183	184	186					
EL 14	166	193	193	157	162	155	143	158	161	163	164	166					
Average	303	303	57%	64%	64%	154	170	181	143	163	162	172	193	198	202	206	208

Feeder	2019	2020	2021	2022	2023
EL 5	0	0	0	0	0
EL 6	0	0	0	0	0
EL 7	0	0	0	0	0
EL 8	0	0	0	0	0
EL 9	0	0	0	0	0
EL 10	0	0	0	0	0
EL 11	0	0	0	0	0
EL 12	0	0	0	0	0
EL 13	0	0	0	0	0
EL 14	0	0	0	0	0


Feeder	2019	2020	2021	2022	2023
EL 5	8	6	1	2	1
EL 6	0	0	0	0	0
EL 7	9	7	1	1	0
EL 8	2	1	2	2	0
EL 9	2	1	0	0	0
EL 10	24	16	25	19	0
EL 11	0	0	0	0	0
EL 12	0	0	0	0	0
EL 13	3	2	0	0	0
EL 14	1	2	1	0	0

Zone Substation Comments

- Transformer no.3 rating is limited by cable rating. Transformer ratings are limited by O/V on tap.
- Line Capacitors:
Installed 1.8MVAR prior to summer 2001.
Install 4.5MVAR prior to summer 2003.
- PCB capacitor replacement
2003 : Replace 100kVAr cans (4MVAR)
- Load Transfers:
- New Load:

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	Actual										Forecast									
	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
EAST MALVERN EM																				
Voltage	11.36 kV																			
Load maximum demand actual / forecast (MW)	27.6	33.8	34.3	27.6	33.3	29.4	31.0	34.9	36.0	37.1	38.1	38.5	38.6	39.4	40.1	41.0	41.3			
10% POE actual MD	31.0	35.8	34.4	34.0	35.7	35.7	34.0													
Load transfers (MW)	-1.7						-2.0	-0.2												
Extra new load (MW)			0.3	0.4	0.5	0.8	0.9	0.5	1.4	1.6	1.3	0.4								
% growth (MW)		22.4%	1.6%	-19.8%	20.9%	-11.7%	5.3%	12.8%	3.0%	3.2%	2.6%	1.2%	0.3%	1.9%	1.9%	2.2%	0.7%			
Feeder summation reactive demand (MVAR)	6.9	6.8	5.0	1.9	3.3	2.3	2.1	3.2	3.5	3.8	4.1	4.2	4.3	4.5	4.7	5.0	5.0			
Zone substation capacitor bank (MVAR)	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1			
Feeder line capacitors (MVAR)	4.5	6.3	6.3	6.9	6.9	6.9	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3			
Reactive load on transformers (MVAR)	0.4	0.3	-1.5	-4.5	-3.2	-4.2	-4.4	-3.3	-3.0	-2.7	-2.4	-2.2	-2.2	-2.0	-1.8	-1.5	-1.5			
Feeder summation power factor	0.97	0.98	0.99	1.00	1.00	1.00	1.00	1.00	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor	1.00	1.00	1.00	0.99	1.00	0.99	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	27.6	33.8	34.4	27.9	33.5	29.7	31.3	35.1	36.1	37.2	38.2	38.6	38.7	39.4	40.2	41.1	41.3			
(N-1) Cyclic Rating (MVA)	31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9	31.9			
(N-1) Limited Cyclic Rating (MVA)	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4	35.4			
(N-1) 2 Hour Emergency Rating (MVA)	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0			
(N-1) 10 Minute Emergency Rating (MVA)	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0	38.0			
(N) Cyclic Rating (MVA)	63.9	63.9	63.9	38.0	63.9	63.9	63.9	63.9	63.9	63.9	63.9	63.9	63.9	63.9	63.9	63.9	63.9			
Feeder	SCR (A)	utilis (%)	forecast utilis (%)	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity		2018-2023 Annual growth	2019 DM (A)	
EM 1	265	265	29%	37%	48%	134	151	170	148	179	178	76	98	129	183	223	225	167 A	3.3 MVA	39.5%
EM 2	305	305	57%	63%	63%	244	249	263	189	122	179	173	192	194	194	195	197	113 A	2.2 MVA	2.8%
EM 3	325	325	41%	75%	76%	194	202	206	190	199	165	134	244	248	249	250	252	81 A	1.6 MVA	17.8%
EM 5	350	350	75%	89%	90%	152	188	199	229	267	188	262	312	316	317	318	322	38 A	0.7 MVA	4.6%
EM 6	255	255	81%	91%	93%	195	241	145	113	144	147	206	232	236	240	244	248	23 A	0.5 MVA	4.1%
EM 7	285	285	71%	79%	81%	156	195	214	172	199	198	203	226	231	238	253	265	59 A	1.2 MVA	6.1%
EM 8	265	265	94%	87%	90%	173	204	244	177	227	222	250	232	238	240	245	250	33 A	0.7 MVA	0.0%
EM 9	255	255	61%	71%	75%	164	154	157	110	136	125	156	181	191	197	204	210	74 A	1.5 MVA	6.8%
EM 10	315	315	62%	75%	84%	162	176	245	157	159	158	197	237	266	286	294	301	78 A	1.5 MVA	10.6%
EM 11	285	285	49%	55%	55%	133	156	146	124	138	135	140	156	157	158	158	160	129 A	2.5 MVA	2.8%
Average	291	291	62%	73%	73%	171	192	199	161	177	170	180	211	221	230	238	243	79 A	1.6 MVA	7.1%

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
EM 1	0	0	0	0	0
EM 2	0	0	0	0	0
EM 3	94	0	0	0	0
EM 5	21	0	0	0	0
EM 6	0	0	0	0	0
EM 7	0	0	0	0	0
EM 8	-50	0	0	0	0
EM 9	0	0	0	0	0
EM 10	0	0	0	0	0
EM 11	0	0	0	0	0


Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
EM 1	15	29	54	39	0
EM 2	0	0	0	0	0
EM 3	2	2	0	0	0
EM 5	1	1	0	0	0
EM 6	4	2	2	3	2
EM 7	0	3	7	13	10
EM 8	5	4	2	4	3
EM 9	8	9	5	5	4
EM 10	19	27	19	8	4
EM 11	0	0	0	0	0

Zone Substation Comments

- Station summer capability is limited by thermal rating of transformers and their 11kV cables.
- Line Capacitors:
Installed 5.4MVAR in 1998.
- Load Transfers:
4.0MW from EM to K prior to summer 2011 as part of the third transformer project.
1.0MW from EM to OAK prior to summer 2010 for Chadstone shopping load.
0.4MW from EM to K for summer 2010.
1.7MW from EM to CFD for summer 2012.
- New load
CHADMYER 6 (a new transformer No.4) - 1300kVA on EM3 before summer 2009/10.

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

		Actual										Forecast									
		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
ELWOOD	EW																				
Voltage	11.35 kV																				
Load maximum demand actual / forecast (MW)		19.9	21.8	22.8	18.0	20.2	20.3	24.8	26.4	26.5	26.5	26.5	26.8	26.9	27.5	28.0	28.5	28.8			
10% POE actual MD		22.3	23.5	22.9	23.0	24.0	24.7	25.5													
Load transfers (MW)																					
Extra new load (MW)			0.2	0.5	0.7	0.8	0.6	0.6	0.3	0.3	0.3	0.2	0.1	0.1							
% growth (MW)			9.9%	4.6%	-21.4%	12.7%	0.3%	22.0%	6.5%	0.3%	0.1%	0.1%	1.1%	0.5%	1.9%	1.9%	1.8%	1.1%			
Feeder summation reactive demand (MVar)		3.1	3.2	5.0	1.1	1.4	1.1	2.0	2.3	2.4	2.4	2.4	2.4	2.5	2.6	2.7	2.8	2.9			
Zone substation capacitor bank (MVar)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Feeder line capacitors (MVar)		3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6			
Reactive load on transformers (MVar)		3.1	3.2	5.0	1.1	1.4	1.1	2.0	2.3	2.4	2.4	2.4	2.4	2.5	2.6	2.7	2.8	2.9			
Feeder summation power factor		0.99	0.99	0.98	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.99			
Transformation summation power factor		0.99	0.99	0.98	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.99			
EG and DM at peak demand (MW)																					
Overall demand on transformers (MVA)		20.1	22.1	23.4	18.0	20.3	20.3	24.9	26.5	26.6	26.6	26.6	26.9	27.1	27.6	28.1	28.7	29.0			
(N-1) Cyclic Rating (MVA)		29.4	29.4	29.4	29.4	29.4	29.4	29.4	29.4	29.4	29.4	29.4	29.4	29.4	29.4	29.4	29.4	29.4			
(N-1) Limited Cyclic Rating (MVA)		32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0			
(N-1) 2 Hour Emergency Rating (MVA)		32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0			
(N-1) 10 Minute Emergency Rating (MVA)		32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0			
(N) Cyclic Rating (MVA)		58.8	58.8	58.8	32.0	58.8	58.8	58.8	58.8	58.8	58.8	58.8	58.8	58.8	58.8	58.8	58.8	58.8			

Feeder	SCR (A)	utilis (%)	forecast utilis (%)	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity		2018-2023 Annual growth	2019 DM (A)
EW 1	350	350	69%	218	228	246	191	208	203	240	251	257	262	264	266	99 A	1.9 MVA	2.2%	
EW 2	270	270	64%	145	184	166	130	143	138	174	201	205	206	207	209	69 A	1.4 MVA	4.0%	
EW 3	250	250	46%	119	126	125	96	110	99	115	124	131	135	136	138	126 A	2.5 MVA	3.9%	
EW 8	265	265	40%	72	95	93	66	87	85	106	110	111	113	117	126	155 A	3.1 MVA	3.8%	
EW 9	270	270	72%	158	173	198	140	166	157	193	204	206	207	208	210	66 A	1.3 MVA	1.7%	
EW 12	265	265	85%	182	204	203	164	188	187	226	237	243	250	254	256	28 A	0.6 MVA	2.7%	
EW 14	295	295	94%	200	234	229	188	221	222	276	273	279	282	284	287	22 A	0.4 MVA	0.8%	
Average	281	281	68%	156	178	180	139	160	156	190	200	205	208	210	213	81 A	1.6 MVA	2.4%	

Feeder	2019	2020	2021	2022	2023
EW 1	0	0	0	0	0
EW 2	20	0	0	0	0
EW 3	0	0	0	0	0
EW 8	0	0	0	0	0
EW 9	0	0	0	0	0
EW 12	0	0	0	0	0
EW 14	-20	0	0	0	0


Feeder	2019	2020	2021	2022	2023
EW 1	2	3	3	1	0
EW 2	1	1	1	0	0
EW 3	4	5	3	1	0
EW 8	0	0	2	4	7
EW 9	3	0	0	0	0
EW 12	2	4	6	3	0
EW 14	6	3	1	1	0

Zone Substation Comments

- Station summer rating is limited by overvoltage on tap. With the installation of line capacitors in 2002, station summer rating is assessed at: SCR = 30.0MVA limited by transformer cable. SLCR = 33.0MVA limited by transformer cable.
- Line Capacitors: Install 3.6MVar prior to summer 2003.
- Load Transfer: 2.0MW from NB to EW before summer 2010.
- New Loads: 0.5MW on EW3 at 221 Glenhenty Rd -2013

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
FRANKSTON SOUTH FSH																	
Voltage	22.7 kV																
Load maximum demand actual / forecast (MW)	54.3	62.1	66.8	58.0	62.6	59.4	66.3	73.9	74.0	73.6	73.4	73.8	74.1	75.1	76.2	77.2	78.0
10% POE actual MD	59.9	67.4	70.6	68.7	70.0	71.5	71.7										
Load transfers (MW)				-1.0													
Extra new load (MW)			1.0	0.7	1.2	0.7	0.8	0.4	0.2	0.2	0.1						
% growth (MW)		14.4%	7.6%	-13.2%	8.0%	-5.1%	11.6%	11.4%	0.1%	-0.6%	-0.3%	0.6%	0.3%	1.4%	1.4%	1.3%	1.0%
Feeder summation reactive demand (MVAR)	10.6	7.7	15.1	11.8	9.3	5.9	4.9	6.3	6.3	6.2	6.2	6.3	6.3	6.5	6.7	6.9	7.1
Zone substation capacitor bank (MVAR)	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0
Feeder line capacitors (MVAR)	7.2	8.1	8.1	8.1	8.1	8.1	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2
Reactive load on transformers (MVAR)	-5.4	-8.3	-0.9	-4.2	-6.7	-10.1	-11.1	-9.7	-9.7	-9.8	-9.8	-9.7	-9.7	-9.5	-9.3	-9.1	-9.0
Feeder summation power factor	0.98	0.99	0.98	0.98	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Transformation summation power factor	1.00	0.99	1.00	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	54.5	62.6	66.8	58.1	63.0	60.3	67.3	74.5	74.6	74.2	74.0	74.5	74.7	75.7	76.8	77.8	78.5
(N-1) Cyclic Rating (MVA)	62.0	62.0	62.0	62.0	62.0	62.0	62.0	62.0	62.0	62.0	62.0	62.0	62.0	62.0	62.0	62.0	62.0
(N-1) Limited Cyclic Rating (MVA)	66.6	66.6	66.6	66.6	66.6	66.6	66.6	66.6	66.6	66.6	66.6	66.6	66.6	66.6	66.6	66.6	66.6
(N-1) 2 Hour Emergency Rating (MVA)	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2
(N-1) 10 Minute Emergency Rating (MVA)	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2	70.2
(N) Cyclic Rating (MVA)	93.0	93.0	93.0	70.2	93.0	93.0	93.0	93.0	93.0	93.0	93.0	93.0	93.0	93.0	93.0	93.0	93.0

Feeder	2018	2019	2020	2021	2022	2023	2019	2018-2023	2019											
	SCR (A)	utilis (%)	forecast utilis (%)				Spare capacity	Annual growth	DM (A)											
FSH 11	350	350	48%	53%	54%	174	217	233	143	250	174	170	187	189	190	191	192	163 A	6.4 MVA	2.7%
FSH 12	260	260	78%	86%	87%	146	230	144	153	180	163	203	225	227	229	230	231	35 A	1.4 MVA	2.8%
FSH 13	335	335	80%	87%	89%	213	226	241	208	218	207	268	293	297	299	300	302	42 A	1.7 MVA	2.5%
FSH 21	350	350	41%	45%	46%	110	115	124	111	126	116	142	158	161	162	163	163	192 A	7.6 MVA	2.9%
FSH 22	365	365	61%	67%	68%	194	219	223	204	223	199	224	245	248	250	251	252	120 A	4.7 MVA	2.5%
FSH 23	260	260	35%	39%	39%	222	225	239	239	86	87	92	100	102	102	103	103	160 A	6.3 MVA	2.5%
FSH 31	260	260	87%	96%	99%	181	208	219	192	205	194	226	249	257	265	269	271	11 A	0.4 MVA	3.9%
FSH 32	335	335	63%	70%	71%	81	87	99	90	215	223	211	234	237	238	240	241	101 A	4 MVA	2.8%
FSH 33	310	310	88%	96%	97%	222	270	294	227	246	227	273	298	302	304	306	307	12 A	0.5 MVA	2.5%
FSH 34	350	350	47%	51%	52%	159	168	182	161	147	132	163	178	181	182	183	184	172 A	6.8 MVA	2.5%
Average	318	318	62%	68%	68%	170	196	200	173	190	172	197	217	220	222	224	225	101 A	4 MVA	2.8%

Feeder	2019	2020	2021	2022	2023
FSH 11	0	0	0	0	0
FSH 12	0	0	0	0	0
FSH 13	0	0	0	0	0
FSH 21	0	0	0	0	0
FSH 22	0	0	0	0	0
FSH 23	0	0	0	0	0
FSH 31	0	0	0	0	0
FSH 32	0	0	0	0	0
FSH 33	0	0	0	0	0
FSH 34	0	0	0	0	0


Feeder	2019	2020	2021	2022	2023
FSH 11	1	0	0	0	0
FSH 12	3	0	0	0	0
FSH 13	0	0	0	0	0
FSH 21	2	1	0	0	0
FSH 22	0	0	0	0	0
FSH 23	0	0	0	0	0
FSH 31	2	5	6	3	0
FSH 32	3	0	0	0	0
FSH 33	0	0	12	0	0
FSH 34	0	0	0	0	0

Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- Line Capacitors
5.4MVAR for summer 2000.
6.3MVAR for summer 2001.
3.0MW from FSH to HGS prior to summer 2009.
- PCB Capacitor Bank Replacement
Replaced & upgraded cap bank #1 with 7MVAR unit in 2000.
- Load Transfers:
3.0MW from FSH to HGS prior to summer 2009.
0.8MW from FSH to MTN prior to summer 2009.
0.5MW from FSH to FTN prior to summer 2009.
20.0MW from FSH to LWN prior to summer 2010.
1.0MW from HGS to FSH prior to summer 2010.
1.2MVA from FSH to LWN in 2014 after LWN 2nd Tx (FSH22 to LWN24)
- New Loads:

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
FRANKSTON FTN																	
Voltage	22.57 kV																
Load maximum demand actual / forecast (MW)	40.4	48.2	52.1	46.5	51.3	47.9	51.8	57.0	57.4	56.9	56.6	56.9	57.0	57.8	58.6	59.4	60.3
10% POE actual MD	45.0	53.0	53.3	52.9	54.2	54.8	55.1										
Load transfers (MW)																	
Extra new load (MW)		0.5	0.4	0.8	1.2	1.0	0.9	0.6	0.4	0.1	0.1	0.0					
% growth (MW)		19.3%	8.2%	-10.9%	10.4%	-6.6%	8.1%	10.1%	0.6%	-0.9%	-0.6%	0.6%	0.2%	1.4%	1.4%	1.3%	1.5%
Feeder summation reactive demand (MVAR)	7.2	11.4	11.9	4.7	3.6	9.4	8.2	10.0	10.1	10.0	9.9	10.0	10.0	10.3	10.6	10.8	11.1
Zone substation capacitor bank (MVAR)	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4
Feeder line capacitors (MVAR)	10.8	10.8	10.8	10.8	10.8	10.8	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3
Reactive load on transformers (MVAR)	1.6	5.7	6.3	-0.9	-2.1	3.8	2.5	4.4	4.5	4.3	4.2	4.3	4.4	4.6	4.9	5.2	5.5
Feeder summation power factor	0.98	0.97	0.97	0.99	1.00	0.98	0.99	0.98	0.98	0.99	0.99	0.98	0.98	0.98	0.98	0.98	0.98
Transformation summation power factor	1.00	0.99	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	40.4	48.5	52.5	46.5	51.3	48.1	51.9	57.2	57.6	57.1	56.7	57.1	57.2	58.0	58.8	59.7	60.5
(N-1) Cyclic Rating (MVA)	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6
(N-1) Limited Cyclic Rating (MVA)	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7
(N-1) 2 Hour Emergency Rating (MVA)	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7
(N-1) 10 Minute Emergency Rating (MVA)	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7	48.7
(N) Cyclic Rating (MVA)	91.2	91.2	91.2	48.7	91.2	91.2	91.2	91.2	91.2	91.2	91.2	91.2	91.2	91.2	91.2	91.2	91.2
Feeder	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028						
FTN 11	350	350	60%	67%	69%	155	174	176	149	152	150	211	235	243	244	245	246
FTN 12	350	350	42%	45%	46%	160	169	190	132	144	135	146	158	161	162	163	163
FTN 13	260	260	38%	41%	42%	82	86	94	83	89	85	100	108	110	110	111	111
FTN 14	260	260	50%	54%	55%	146	171	182	151	178	160	129	139	142	143	143	144
FTN 21	260	260	44%	48%	50%	88	92	89	79	89	89	115	125	131	136	139	141
FTN 22	350	350	57%	62%	63%	227	236	229	213	214	198	201	217	221	222	223	224
FTN 23	260	260	70%	78%	81%	179	180	228	191	216	191	181	203	209	211	211	212
FTN 24	260	260	78%	85%	87%	144	142	159	135	158	148	204	221	225	226	227	228
FTN 25	260	260	87%	94%	96%	125	139	189	171	180	198	225	245	249	250	251	252
Average	290	290	58%	63%	63%	145	154	171	145	158	151	168	183	188	189	190	191

Feeder	2019	2020	2021	2022	2023
FTN 11	0	0	0	0	0
FTN 12	0	0	0	0	0
FTN 13	0	0	0	0	0
FTN 14	0	0	0	0	0
FTN 21	0	0	0	0	0
FTN 22	0	0	0	0	0
FTN 23	0	0	0	0	0
FTN 24	0	0	0	0	0
FTN 25	0	0	0	0	0


Feeder	2019	2020	2021	2022	2023
FTN 11	6	4	0	0	0
FTN 12	1	0	0	0	0
FTN 13	0	0	0	0	0
FTN 14	0	0	0	0	0
FTN 21	1	3	4	3	1
FTN 22	0	0	0	0	0
FTN 23	7	3	0	0	0
FTN 24	1	0	0	0	0
FTN 25	1	0	0	0	0

Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- Line Capacitors
8.1MVAR line capacitors were installed in 1997
- PCB capacitors replaced at FTN in 1999 : #1 - 5MVAR, #3 - 6MVAR
- Load Transfers:
0.5MW from FSH to FTN prior to summer 2009.
2.5MW from DVY to FTN prior to summer 2009.
14.0MW from FTN to LWN for summer 2010.
0.7MW from FTN to CRM for summer 2010.
FTN12 - 5.0MVA to CRM13 (2011/12)
FTN23 - 2.0MVA to CRM13 (2011/12)
- New loads:
- Replace transformers #2 & #3 with a 20/33MVA unit & re-construct as a fully switched station in 2004 for summer 2005.

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	Actual										Forecast									
	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
GLEN WAVERLEY GW																				
Voltage 22.35 kV																				
Load maximum demand actual / forecast (MW)	56.4	65.2	66.6	55.8	62.6	62.5	63.5	71.2	72.8	73.6	74.0	74.9	75.1	76.7	78.1	79.4	79.7			
10% POE actual MD	71.5	68.7	68.5	67.4	68.9	70.0	69.0													
Load transfers (MW)																				
Extra new load (MW)		1.5	0.5	0.5	1.5	1.8	1.7	2.4	2.0	1.5	0.7									
% growth (MW)		15.5%	2.1%	-16.1%	12.1%	-0.1%	1.4%	12.2%	2.2%	1.2%	0.5%	1.3%	0.3%	2.1%	1.9%	1.7%	0.4%			
Feeder summation reactive demand (MVAR)	10.6	12.0	13.8	4.6	7.6	8.2	6.2	9.1	9.6	9.9	10.1	10.4	10.5	11.0	11.6	12.0	12.1			
Zone substation capacitor bank (MVAR)	13.7	13.7	13.7	13.7	8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.4			
Feeder line capacitors (MVAR)	14.1	14.1	14.1	15.6	18.3	18.3	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2			
Reactive load on transformers (MVAR)	-3.6	-2.2	-0.4	-9.6	-1.0	-0.5	-2.4	0.4	0.9	1.3	1.4	1.7	1.8	2.4	2.9	3.4	3.5			
Feeder summation power factor	0.98	0.98	0.98	1.00	0.99	0.99	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor	1.00	1.00	1.00	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	56.6	65.2	66.6	56.6	62.6	62.5	63.5	71.2	72.8	73.6	74.0	74.9	75.2	76.7	78.2	79.5	79.8			
(N-1) Cyclic Rating (MVA)	68.9	68.9	68.9	68.9	68.9	68.9	68.9	68.9	68.9	68.9	68.9	68.9	68.9	68.9	68.9	68.9	68.9			
(N-1) Limited Cyclic Rating (MVA)	73.8	73.8	73.8	73.8	73.8	73.8	73.8	73.8	73.8	73.8	73.8	73.8	73.8	73.8	73.8	73.8	73.8			
(N-1) 2 Hour Emergency Rating (MVA)	79.0	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6			
(N-1) 10 Minute Emergency Rating (MVA)	79.0	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6	78.6			
(N) Cyclic Rating (MVA)	103.4	103.4	103.4	78.6	103.4	103.4	103.4	103.4	103.4	103.4	103.4	103.4	103.4	103.4	103.4	103.4	103.4			
Feeder	SCR (A)	utilis (%)	forecast utilis (%)	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity	2018-2023 Annual growth	2019 DM (A)		
GW 1	350	350	51%	68%	76%	228	265	224	244	198	165	179	240	266	295	315	318	110 A	4.3 MVA	15.5%
GW 2	290	290	64%	80%	81%	158	196	211	203	209	171	186	231	235	236	238	240	59 A	2.3 MVA	5.8%
GW 3	335	335	44%	54%	54%	127	150	162	125	147	132	148	180	181	182	183	185	155 A	6 MVA	5.0%
GW 4	345	345	46%	57%	57%	166	183	186	166	172	170	159	196	197	198	199	201	149 A	5.8 MVA	5.3%
GW 5	260	260	80%	66%	69%	94	115	183	95	163	209	209	171	180	181	181	184	89 A	3.4 MVA	-2.4%
GW 6	350	350	51%	63%	63%	173	175	193	169	219	189	180	220	221	222	223	226	130 A	5 MVA	5.0%
GW 7	280	280	48%	59%	59%	137	146	161	119	129	128	135	165	166	167	168	170	115 A	4.4 MVA	5.0%
GW 8	260	260	48%	58%	59%	118	132	144	103	126	114	124	152	152	153	154	156	108 A	4.2 MVA	5.0%
GW 10	350	350	25%	86%	86%	129	156	89	63	75	81	86	300	301	301	302	303	50 A	1.9 MVA	50.3%
GW 11	335	335	56%	71%	77%	207	217	220	170	187	192	186	238	258	274	275	278	97 A	3.8 MVA	9.9%
GW 12	345	345	46%	57%	57%	145	171	195	140	152	143	160	195	196	197	198	200	150 A	5.8 MVA	5.0%
Average	318	318	50%	65%	65%	153	173	179	145	162	154	159	208	214	219	221	224	110 A	4.3 MVA	8.1%

Feeder	Load Transfers (Amps)			
	2019	2020	2021	2023
GW 1	0	0	0	0
GW 2	0	0	0	0
GW 3	0	0	0	0
GW 4	0	0	0	0
GW 5	-100	0	0	0
GW 6	0	0	0	0
GW 7	0	0	0	0
GW 8	0	0	0	0
GW 10	0	0	0	0
GW 11	0	0	0	0
GW 12	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)			
	2019	2020	2021	2023
GW 1	21	25	28	18
GW 2	-4	3	0	0
GW 3	0	0	0	0
GW 4	2	0	0	0
GW 5	17	8	0	0
GW 6	0	0	0	0
GW 7	0	0	0	0
GW 8	0	0	0	0
GW 10	0	0	0	0
GW 11	10	19	14	0
GW 12	0	0	0	0


Zone Substation Comments

- Zone Substation ratings were reviewed in 2010. Post 2010 ratings are based on 40deg C ambient temp. 22kV transformer #2 cables were upgraded in 1998.
- Line Capacitors: Installed 13.8MVAR prior to summer 2000.
- Load Transfers:
 - 2.0MW from GW to MGE before summer 2004.
 - 4.0MW from GW to EB before summer 2009.
 - 1.7MW from MGE to GW before summer 2010.
- New Loads:
 - 0.5MW on GW1 - Kingsway Hub - 2013
 - 1.5 MW on GW5 - Smith & Nephew site - 2013/14

Reserve Capacity Requirements

- ANZ, Forster Rd, Mt Waverley.
 - NO 03 (preferred)
 - NO 08 (preferred) from 1 May 2016
 - GW 03 (reserve) - 1.7MVA (45A);
 - 2.3MVA (60A) from 1 Nov 2002;
 - 3.0MVA (80A) from 1 Jan 2003.
 - 4.0MVA (80A) from 1 Jun 2014.
 - GW 10 (reserve) - 8.0MVA (210A) from 1 May 2016

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	Actual 2015	2016	2017	2018	2019	2020	2021	2022	Forecast 2023	2024	2025	2026	2027	2028
HASTINGS																	
HGS																	
Voltage	22.58	kV															
Load maximum demand actual / forecast (MW)	44.4	44.9	47.0	41.0	46.9	41.5	47.5	50.5	50.5	50.3	50.4	50.9	51.0	51.7	52.5	53.2	53.7
10% POE actual MD	47.8	47.9	49.9	48.0	49.5	49.8	49.0										
Load transfers (MW)							-2.6										
Extra new load (MW)			0.5	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.3				
% growth (MW)		1.1%	4.7%	-12.9%	14.5%	-11.4%	14.4%	6.2%	0.1%	-0.5%	0.3%	1.0%	0.2%	1.4%	1.4%	1.3%	1.0%
Feeder summation reactive demand (MVar)	13.5	13.6	12.8	9.5	10.0	6.7	8.3	9.1	9.2	9.1	9.1	9.3	9.3	9.5	9.7	9.9	10.0
Zone substation capacitor bank (MVar)	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0
Feeder line capacitors (MVar)	3.6	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5
Reactive load on transformers (MVar)	5.0	5.2	4.4	1.1	1.6	-1.8	-0.1	0.7	0.7	0.7	0.7	0.9	0.9	1.1	1.3	1.5	1.6
Feeder summation power factor	0.96	0.96	0.96	0.97	0.98	0.99	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98
Transformation summation power factor	0.99	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	44.7	45.2	47.2	41.0	46.9	41.6	47.5	50.5	50.5	50.3	50.4	50.9	51.0	51.7	52.5	53.2	53.7
(N-1) Cyclic Rating (MVA)	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9
(N-1) Limited Cyclic Rating (MVA)	42.4	42.4	42.4	42.4	42.4	42.4	42.4	42.4	42.4	42.4	42.4	42.4	42.4	42.4	42.4	42.4	42.4
(N-1) 2 Hour Emergency Rating (MVA)	46.9	46.9	46.9	46.9	46.9	46.9	46.9	46.9	46.9	46.9	46.9	46.9	46.9	46.9	46.9	46.9	46.9
(N-1) 10 Minute Emergency Rating (MVA)	46.9	46.9	46.9	46.9	47.6	47.6	47.6	47.6	47.6	47.6	47.6	47.6	47.6	47.6	47.6	47.6	47.6
(N) Cyclic Rating (MVA)	79.8	79.8	79.8	46.9	79.8	79.8	79.8	79.8	79.8	79.8	79.8	79.8	79.8	79.8	79.8	79.8	79.8

Feeder	SCR (A) 2018	SCR (A) 2019	utilis (%) 2018	utilis (%) 2019	forecast utilis (%) 2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
HGS 21	600	600	40%	41%	42%	94	102	119	90	102	100	237	247	251	254	258	261
HGS 22	260	260	82%	85%	86%	195	211	187	177	199	185	213	222	224	226	226	227
HGS 23	350	350	37%	39%	40%	319	301	313	287	274	258	129	136	139	140	140	141
HGS 24	0	0															
HGS 31	260	260	64%	68%	70%	135	149	152	124	150	126	166	176	181	186	195	202
HGS 32	425	425	49%	69%	70%	236	254	278	250	265	235	209	293	295	297	297	298
HGS 33	350	350	97%	93%	96%	253	267	284	246	269	280	338	327	335	339	341	343
Average	321	321	67%	62%	62%	205	214	222	196	210	197	215	200	204	206	208	210

Feeder	2019	2020	2021	2022	2023
HGS 21	0	1	1	3	2
HGS 22	0	0	0	0	0
HGS 23	2	1	0	0	0
HGS 24	0	0	0	0	0
HGS 31	3	3	4	8	6
HGS 32	0	0	0	0	0
HGS 33	4	4	2	1	1

Feeder	2019	2020	2021	2022	2023
HGS 21	0	0	0	0	0
HGS 22	0	0	0	0	0
HGS 23	0	0	0	0	0
HGS 24	0	0	0	0	0
HGS 31	0	0	0	0	0
HGS 32	0	0	0	0	0
HGS 33	-30	0	0	0	0

Feeder	2019	2020	2021	2022	2023
HGS 21	0	1	1	3	2
HGS 22	0	0	0	0	0
HGS 23	2	1	0	0	0
HGS 24	0	0	0	0	0
HGS 31	3	3	4	8	6
HGS 32	0	0	0	0	0
HGS 33	4	4	2	1	1


Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- Line Capacitors:
Installed 3.6 MVar for summer 2002.
- PCB Cap Bank Replacement; 8MVar in Oct 2001
- Load transfers:
3.0MW from FSH to HGS prior to summer 2009.
1.0MW from HGS to FSH prior to summer 2010.
- New loads:
- Establish a package zone substation with one 20/33MVA transformer in Dromana (DMA) in 2005 for summer 2006 and transfer 5MW to DMA.

Reserve Capacity Requirements

- Esso, Long Island Dve Hastings.
HGS21 (preferred)
HGS32 (reserve) - 2.8MVA (75A) reserve.

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
GARDINER K																	
Voltage 11.5 kV																	
Load maximum demand actual / forecast (MW)	36.8	39.1	43.9	33.1	41.8	35.1	36.1	45.2	45.8	46.5	47.5	48.8	49.3	50.3	51.2	52.2	52.8
10% POE actual MD	43.6	42.2	45.4	44.6	45.8	43.7	42.4										
Load transfers (MW)	-1.3						-3.3				1.1						
Extra new load (MW)		0.1	0.2	0.2	0.9	0.5	0.7	0.5	0.7	0.9	1.0	0.8	0.2				
% growth (MW)		6.5%	12.2%	-24.8%	26.5%	-16.1%	3.0%	25.1%	1.3%	1.6%	2.2%	2.6%	1.2%	1.9%	1.9%	1.8%	1.1%
Feeder summation reactive demand (MVAR)	6.7	7.3	11.9	4.8	6.6	2.6	-2.2	-0.7	-0.6	-0.5	-0.4	-0.2	-0.1	0.1	0.3	0.4	0.5
Zone substation capacitor bank (MVAR)	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6
Feeder line capacitors (MVAR)	8.1	8.1	8.1	9.6	9.6	9.6	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
Reactive load on transformers (MVAR)	0.6	1.2	5.8	-1.4	0.4	-3.6	-8.4	-6.9	-6.8	-6.7	-6.5	-6.3	-6.2	-6.1	-5.9	-5.7	-5.6
Feeder summation power factor	0.98	0.98	0.97	0.99	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Transformation summation power factor	1.00	1.00	0.99	1.00	1.00	0.99	0.97	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	36.8	39.2	44.3	33.1	41.8	35.3	37.1	45.7	46.3	47.0	48.0	49.2	49.7	50.6	51.6	52.5	53.1
(N-1) Cyclic Rating (MVA)	26.1	36.8	36.8	36.8	36.8	36.8	36.8	36.8	36.8	36.8	36.8	36.8	36.8	36.8	36.8	36.8	36.8
(N-1) Limited Cyclic Rating (MVA)	27.1	40.4	40.4	40.4	40.4	40.4	40.4	40.4	40.4	40.4	40.4	40.4	40.4	40.4	40.4	40.4	40.4
(N-1) 2 Hour Emergency Rating (MVA)	27.1	43.7	43.7	43.7	43.7	43.7	43.7	43.7	43.7	43.7	43.7	43.7	43.7	43.7	43.7	43.7	43.7
(N-1) 10 Minute Emergency Rating (MVA)	27.1	43.7	43.7	43.7	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6	45.6
(N) Cyclic Rating (MVA)	52.2	73.5	73.5	43.7	73.5	73.5	73.5	73.5	73.5	73.5	73.5	73.5	73.5	73.5	73.5	73.5	73.5
Feeder	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
	SCR (A)	utilis (%)	forecast utilis (%)														
K 2	300	300	59%	65%	70%	206	173	196	133	171	181	178	195	210	227	244	256
K 3	265	265	78%	95%	96%	162	187	208	146	169	184	207	251	255	258	260	262
K 4	270	270	70%	75%	76%	158	178	195	145	175	161	188	202	205	208	210	212
K 5	270	270	63%	67%	68%	218	201	219	164	174	158	170	182	184	189	198	213
K 6	345	345	79%	86%	87%	240	210	331	253	324	219	274	295	301	308	314	321
K 7	325	325	57%	62%	65%	154	292	205	168	194	174	185	201	210	220	234	245
K 8	245	245	78%	83%	84%	178	177	183	139	174	171	190	204	206	208	210	211
K 9	350	350	33%	35%	36%	102	115	137	106	130	120	114	124	125	127	128	129
K 10	245	245	58%	63%	66%	188	197	234	174	220	128	142	155	161	166	172	174
K 11	270	270	69%	73%	74%	179	202	200	170	194	178	185	198	200	202	204	206
K 12	245	245	56%	62%	65%	157	178	234	155	172	112	137	152	159	171	180	182
K 13	260	260	64%	69%	71%	145	85	203	137	180	162	166	179	184	191	199	206
Average	283	283	63%	69%	69%	174	183	212	158	190	162	178	195	200	206	213	218
	88 A	1.7 MVA	4.5%														

Feeder	Load Transfers (Amps)			
	2019	2020	2021	2023
K 2	0	0	0	0
K 3	0	0	0	0
K 4	0	0	0	0
K 5	0	0	0	0
K 6	0	0	0	0
K 7	0	0	0	0
K 8	0	0	0	0
K 9	0	0	0	0
K 10	0	0	0	0
K 11	0	0	0	0
K 12	0	0	0	0
K 13	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
K 2	5	13	15	15	10
K 3	1	1	1	0	0
K 4	1	1	1	0	0
K 5	0	0	4	7	14
K 6	3	2	4	4	4
K 7	4	7	8	12	9
K 8	0	0	0	0	0
K 9	2	0	0	0	0
K 10	3	4	4	4	1
K 11	0	0	0	0	0
K 12	5	5	11	8	0
K 13	2	3	5	7	5


Zone Substation Comments

- Station rating is limited by 11kV transformer cables. Upgrade transformer cables in 2011.
- Line Capacitors: Installed 5.1MVAR prior to summer 1999. Installed 3.6MVAR prior to summer 2000.
- Load Transfers:
 - 1MW from K10 to CFD22 (T69) prior to summer 2009
 - 2MW from K6 to CFD22 (T69) prior to summer 2009
 - 0.4MW from EM to K for summer 2010.
 - 1.3MW from K to CFD for summer 2012.
- New Loads:
 - 0.8MW on K7 (Eliz N14 Mountview s/s) in 2010.
 - 4.0MW on K9 over three years by Tooronga Village starting in 2010.
 - ?? 550kW and 150kW on K12 in 2010, transfer approx 700kVA to K7

Reserve Capacity Requirements

- PTC, Malvern Rd Malvern.
 - K12 (preferred)
 - K3 (reserve) - 0.7MVA (37A) reserve on each feeder.

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability


	Actual				Forecast												
	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
KEYSBOROUGH KBH																	
Voltage	22.5 kV																
Load maximum demand actual / forecast (MW)	0.0	0.0	0.0	20.3	26.1	28.7	26.1	34.6	36.4	37.6	38.5	39.4	40.1	41.0	42.0	43.0	43.7
10% POE actual MD	0.0	0.0	0.0	26.4	29.3	32.1	32.0										
Load transfers (MW)				27.1													
Extra new load (MW)					0.3	0.7	0.7	1.2	1.3	0.9	0.5	0.0					
% growth (MW)					28.7%	10.0%	-9.0%	32.7%	4.9%	3.4%	2.4%	2.3%	1.9%	2.4%	2.3%	2.2%	1.7%
Feeder summation reactive demand (MVar)	0.0	0.0	0.0	6.0	3.2	6.9	2.9	7.1	7.9	8.5	9.0	9.4	9.8	10.2	10.7	11.2	11.5
Zone substation capacitor bank (MVar)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Feeder line capacitors (MVar)	0.0	0.0	0.0	9.0	9.0	9.0	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5
Reactive load on transformers (MVar)	0.0	0.0	0.0	6.0	3.2	6.9	2.9	7.1	7.9	8.5	9.0	9.4	9.8	10.2	10.7	11.2	11.5
Feeder summation power factor				0.96	0.99	0.97	0.99	0.98	0.98	0.98	0.97	0.97	0.97	0.97	0.97	0.97	0.97
Transformation summation power factor				0.96	0.99	0.97	0.99	0.98	0.98	0.98	0.97	0.97	0.97	0.97	0.97	0.97	0.97
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	0.0	0.0	0.0	21.2	26.3	29.5	26.3	35.4	37.2	38.5	39.5	40.5	41.3	42.3	43.4	44.4	45.2
(N-1) Cyclic Rating (MVA)																	
(N-1) Limited Cyclic Rating (MVA)																	
(N-1) 2 Hour Emergency Rating (MVA)																	
(N-1) 10 Minute Emergency Rating (MVA)																	
(N) Cyclic Rating (MVA)					46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7

Feeder	SCR (A)		utilis (%)		forecast utilis (%)															2019			2018-2023			2019
	2018	2019	2018	2019	2020	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	Spare capacity	Annual growth	DM (A)					
KBH 31	330	330	47%	60%	64%				123	179	172	155	200	211	228	241	246	130 A	5.1 MVA	11.7%						
KBH 32	265	265	70%	91%	97%				138	184	175	185	242	256	264	270	275	23 A	0.9 MVA	9.8%						
KBH 33	340	340	13%	16%	17%				135	128	133	44	55	56	58	59	60	285 A	11.1 MVA	7.6%						
KBH 34	350	350	61%	83%	88%				205	212	179	215	289	308	318	327	335	61 A	2.4 MVA	11.2%						
KBH 35	260	260	70%	90%	95%				62	142	181	181	233	247	261	268	274	27 A	1 MVA	10.2%						
Average	309	309	51%	66%	66%				133	169	168	156	204	216	226	233	238	105 A	4.1 MVA	10.5%						

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
KBH 31	0	0	0	0	0
KBH 32	0	0	0	0	0
KBH 33	0	0	0	0	0
KBH 34	0	0	0	0	0
KBH 35	0	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
KBH 31	3	7	12	8	0
KBH 32	9	8	2	0	0
KBH 33	0	0	0	0	0
KBH 34	17	12	3	3	1
KBH 35	4	8	8	2	0

Zone Substation Comments	Reserve Capacity Requirements
<p>1. Commissioned on 15 Dec 2014 as a single transformer station</p> <p>2. Line capacitors: Transferred 4.5MVar from NP in 2015 Transferred 4.5MVar from DSH in 2015</p> <p>3. Load transfers: Transferred 15MW from NP (2015). Transferred 7MW from DSH (2015). Transferred 4MW from MC (2015).</p>	<p>Network Support Agreements</p>



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	Actual										Forecast									
	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
LYNDALE LD																				
Voltage 22.5 kV																				
Load maximum demand actual / forecast (MW)	40.4	47.7	56.3	46.2	51.9	45.8	48.0	58.3	58.4	58.1	57.8	58.1	58.5	59.3	60.2	61.0	61.6			
10% POE actual MD	50.1	55.0	56.3	55.4	57.6	55.5	56.4													
Load transfers (MW)			8.4																	
Extra new load (MW)			0.3	0.3	0.2	0.3	0.2	0.2	0.2	0.1	0.0									
% growth (MW)		18.1%	18.1%	-18.0%	12.4%	-11.7%	4.8%	21.5%	0.1%	-0.6%	-0.5%	0.6%	0.7%	1.4%	1.4%	1.3%	1.1%			
Feeder summation reactive demand (MVAR)	11.1	13.6	13.6	12.2	10.0	6.6	7.7	10.7	10.7	10.6	10.5	10.6	10.8	11.0	11.3	11.5	11.7			
Zone substation capacitor bank (MVAR)	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5	14.5			
Feeder line capacitors (MVAR)	5.4	5.4	5.4	5.4	5.4	5.4	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3			
Reactive load on transformers (MVAR)	-4.1	-1.6	-1.6	-3.0	-5.2	-8.6	-7.6	-4.5	-4.5	-4.6	-4.7	-4.6	-4.4	-4.2	-4.0	-3.7	-3.5			
Feeder summation power factor	0.96	0.96	0.97	0.97	0.98	0.99	0.99	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98			
Transformation summation power factor	0.99	1.00	1.00	1.00	1.00	0.98	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	40.6	47.7	56.3	46.3	52.2	46.6	48.6	58.5	58.6	58.2	57.9	58.3	58.7	59.5	60.3	61.1	61.7			
(N-1) Cyclic Rating (MVA)	33.7	67.4	67.4	67.4	67.4	67.4	67.4	67.4	67.4	67.4	67.4	67.4	67.4	67.4	67.4	67.4	67.4			
(N-1) Limited Cyclic Rating (MVA)	36.1	72.3	72.3	72.3	72.3	72.3	72.3	72.3	72.3	72.3	72.3	72.3	72.3	72.3	72.3	72.3	72.3			
(N-1) 2 Hour Emergency Rating (MVA)	38.6	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3			
(N-1) 10 Minute Emergency Rating (MVA)	38.6	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3	77.3			
(N) Cyclic Rating (MVA)	67.4	101.1	101.1	77.3	101.1	101.1	101.1	101.1	101.1	101.1	101.1	101.1	101.1	101.1	101.1	101.1	101.1			

Feeder	SCR (A)		utilis (%)		forecast utilis (%)												2019		2018-2023		2019	
	2018	2019	2018	2019	2020	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	Spare capacity	Annual growth	DM (A)	
LD 1	260	260	30%	36%	36%		169	177	99	96	88	75	78	93	94	95	95	167 A	6.5 MVA	4.6%		
LD 2	270	270	67%	79%	80%		221	245	221	183	196	180	180	214	217	219	219	221	56 A	2.2 MVA	4.6%	
LD 3	300	300	34%	40%	41%		89	90	104	86	105	97	101	121	122	123	123	124	179 A	7 MVA	4.6%	
LD 4	330	330	58%	84%	86%		176	208	230	182	207	206	191	278	282	285	286	287	52 A	2 MVA	10.0%	
LD 5	350	350	68%	82%	83%		185	195	271	278	264	241	239	286	289	291	292	294	64 A	2.5 MVA	4.6%	
LD 6	290	290	87%	98%	99%		246	257	204	209	242	233	251	284	288	290	291	292	6 A	0.2 MVA	3.2%	
LD 7	260	260	53%	63%	64%		149	159	174	149	138	142	138	164	167	169	170	171	96 A	3.7 MVA	4.9%	
LD 31	0	0																	0 A	0 MVA		
LD 32	260	260	21%	26%	27%			80	64	48	54	74	54	68	71	72	72	72	192 A	7.5 MVA	6.7%	
LD 33	290	290	73%	87%	88%			258	286	184	199	195	210	251	254	256	257	258	39 A	1.5 MVA	4.6%	
LD 34	0	0																	0 A	0 MVA		
Average	237	237	68%	67%	67%		137	186	184	157	166	160	160	162	164	164	165	77 A	3 MVA	0.6%		

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
LD 1	0	0	0	0	0
LD 2	0	0	0	0	0
LD 3	0	0	0	0	0
LD 4	0	0	0	0	0
LD 5	0	0	0	0	0
LD 6	0	0	0	0	0
LD 7	0	0	0	0	0
LD 31	0	0	0	0	0
LD 32	0	0	0	0	0
LD 33	0	0	0	0	0
LD 34	0	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
LD 1	0	0	0	0	0
LD 2	0	0	0	0	0
LD 3	0	0	0	0	0
LD 4	2	2	1	0	0
LD 5	0	0	0	0	0
LD 6	0	0	0	0	0
LD 7	0	0	1	1	0
LD 31	0	0	0	0	0
LD 32	3	2	1	0	0
LD 33	0	0	0	0	0
LD 34	0	0	0	0	0


Zone Substation Comments

- Zone Substation ratings were reviewed in 2010. Third transformer was commissioned in 09/01/2013
- Line Capacitors: 4.5MVA of Line capacitors were installed in 1998.
- PCB capacitors replaced at LD in 2000 : #1 - 8MVAR, #2 - 8MVAR.
- Load Transfers: 2.3MW from DN to LD prior to summer 2010. 7.4MW from MGE to LD prior to summer 2013. 4.3MW from NP to LD prior to summer 2013.
- New Loads: 2MW by Fujitsu Data Centre on LD05 in 2010. 2MW by Fujitsu Data Centre on LD05 in 2012.

Reserve Capacity Requirements

- Fujitsu Data Centre LD5 (preferred) SVW55 (reserve) - 2MVA (52A) reserve
- Dandenong Hospital DN11 (preferred) LD4 (reserve) - 1.8MVA (47A)
- Aurora DN11 (preferred) LD4 (reserve) - 1.15MVA (30A) The reserve contract is for 1.8MVA (inclusive of Aurora)
- SP Ausnet Datacentre LD33 1MVA reserve MGE32 1MVA reserve No reserve contracts are in place

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability


		Actual										Forecast									
		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
LANGWARRIN	LWN																				
Voltage	22.1 kV																				
Load maximum demand actual / forecast (MW)		39.7	39.4	40.7	39.4	41.8	39.4	45.2	47.2	47.2	46.8	46.7	47.0	47.1	47.8	48.5	49.1	49.9			
10% POE actual MD		44.1	44.7	44.5	44.6	46.1	45.8	46.1													
Load transfers (MW)																					
Extra new load (MW)																					
% growth (MW)			-0.7%	3.4%	-3.2%	6.0%	-5.7%	14.9%	4.5%	-0.1%	-0.8%	-0.3%	0.7%	0.4%	1.4%	1.4%	1.3%	1.5%			
Feeder summation reactive demand (MVar)		6.4	6.7	7.6	6.2	6.9	6.3	6.8	7.5	7.5	7.3	7.3	7.4	7.5	7.7	7.9	8.1	8.3			
Zone substation capacitor bank (MVar)		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Feeder line capacitors (MVar)		6.9	6.9	6.9	6.9	6.9	6.9	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8			
Reactive load on transformers (MVar)		6.4	6.7	7.6	6.2	6.9	6.3	6.8	7.5	7.5	7.3	7.3	7.4	7.5	7.7	7.9	8.1	8.3			
Feeder summation power factor		0.99	0.99	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor		0.99	0.99	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
EG and DM at peak demand (MW)																					
Overall demand on transformers (MVA)		40.2	39.9	41.4	39.9	42.3	39.9	45.7	47.8	47.8	47.4	47.2	47.6	47.7	48.4	49.1	49.8	50.5			
(N-1) Cyclic Rating (MVA)																					
(N-1) Limited Cyclic Rating (MVA)																					
(N-1) 2 Hour Emergency Rating (MVA)																					
(N-1) 10 Minute Emergency Rating (MVA)																					
(N) Cyclic Rating (MVA)		45.4	45.4	45.4	48.3	90.8	90.8	90.8	90.8	90.8	90.8	90.8	90.8	90.8	90.8	90.8	90.8	90.8			

Feeder	SCR (A)		utilis (%)		forecast utilis (%)												2019		2018-2023		2019						
	2018	2019	2018	2019	2020	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	Spare capacity	Annual growth	DM (A)						
LWN 21	350	350	87%	89%	90%					256	268	259	304	312	315	317	318	320	38 A	1.5 MVA	1.0%						
LWN 23	335	335	55%	57%	57%					163	173	165	185	189	192	193	195	197	146 A	5.6 MVA	1.3%						
LWN 24	260	260	56%	58%	59%					88	133	128	147	151	152	153	154	154	109 A	4.2 MVA	1.0%						
LWN 31	0	0					200	229	255																		
LWN 32	325	325	32%	32%	33%		255	265	276	90	95	86	103	105	107	107	108	108	220 A	8.4 MVA	1.0%						
LWN 33	280	280	61%	62%	63%		155	157	175	156	166	155	170	174	176	177	178	179	106 A	4 MVA	1.1%						
LWN 34	350	350	42%	43%	43%		265	277	299	176	151	141	146	149	151	152	152	153	201 A	7.7 MVA	1.0%						
LWN 35	285	285	62%	64%	65%		156	146	104	166	181	164	178	183	184	185	186	187	102 A	3.9 MVA	1.0%						
Average	273	273	64%	58%	66%		206	215	222	156	167	157	176	181	182	183	185	186	93 A	3.5 MVA	1.1%						

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
LWN 21	0	0	0	0	0
LWN 23	0	0	0	0	0
LWN 24	0	0	0	0	0
LWN 31					
LWN 32	0	0	0	0	0
LWN 33	0	0	0	0	0
LWN 34	0	0	0	0	0
LWN 35	0	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
LWN 21	0	0	0	0	0
LWN 23	0	0	1	1	1
LWN 24	0	0	0	0	0
LWN 31	0	0	0	0	0
LWN 32	0	0	0	0	0
LWN 33	1	0	0	0	0
LWN 34	0	0	0	0	0
LWN 35	0	0	0	0	0

Zone Substation Comments	Reserve Capacity Requirements
<p>1. New single transformer zone substation to be built near FTS in 2008/09. Second transformer was commissioned on 30 Oct 2014</p> <p>2. Load Transfers: 20.0MW from FSH to LWN prior to summer 2010. Assumed power factor of 0.9 14.0MW from FTN to LWN for summer 2010. Assumed power factor of 0.9 1.2MVA from FSH to LWN in 2014 after LWN 2nd Tx. LWN24 - 3.7MVA from LWN34 and 2.7MVA from FSH22 (2014/15) LWN34 - 1.5MVA to FSH22 (2014/15)</p> <p>3. New Loads:</p>	<p>Network Support Agreements</p>



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

		Actual										Forecast									
		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
MENTONE	M																				
Voltage 11.15 kV																					
Load maximum demand actual / forecast (MW)		28.1	33.6	36.0	30.8	35.4	33.5	34.7	41.8	42.1	41.8	41.7	42.1	42.2	43.1	43.9	44.7	45.0			
10% POE actual MD		33.0	36.9	37.5	36.5	39.1	40.1	40.1													
Load transfers (MW)																					
Extra new load (MW)			1.8	0.4	0.9	1.6	1.5	1.4	0.9	0.6	0.2	0.2	0.1								
% growth (MW)			19.8%	7.0%	-14.5%	15.1%	-5.5%	3.7%	20.5%	0.6%	-0.7%	-0.2%	1.0%	0.2%	2.1%	1.9%	1.8%	0.9%			
Feeder summation reactive demand (MVAR)		6.5	8.3	10.2	5.7	8.0	8.3	6.2	8.3	8.4	8.3	8.2	8.4	8.4	8.6	8.9	9.1	9.2			
Zone substation capacitor bank (MVAR)		12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2	12.2			
Feeder line capacitors (MVAR)		3.9	3.9	3.9	4.8	4.8	4.8	3.9	3.9	3.9	3.9	3.9	3.9	3.9	3.9	3.9	3.9	3.9			
Reactive load on transformers (MVAR)		-6.0	-4.2	-2.3	-6.8	-4.5	-4.2	-6.3	-4.2	-4.1	-4.2	-4.3	-4.1	-4.1	-3.9	-3.6	-3.4	-3.3			
Feeder summation power factor		0.97	0.97	0.96	0.98	0.98	0.97	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98			
Transformation summation power factor		0.98	0.99	1.00	0.98	0.99	0.99	0.98	0.99	1.00	0.99	0.99	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																					
Overall demand on transformers (MVA)		28.7	33.9	36.1	31.5	35.7	33.7	35.3	42.1	42.3	42.0	41.9	42.3	42.4	43.2	44.0	44.8	45.2			
(N-1) Cyclic Rating (MVA)		27.2	54.4	54.4	54.4	54.4	54.4	54.4	54.4	54.4	54.4	54.4	54.4	54.4	54.4	54.4	54.4	54.4			
(N-1) Limited Cyclic Rating (MVA)		29.9	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8			
(N-1) 2 Hour Emergency Rating (MVA)		29.9	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8			
(N-1) 10 Minute Emergency Rating (MVA)		29.9	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8	59.8			
(N) Cyclic Rating (MVA)		54.4	81.6	81.6	59.8	81.6	81.6	81.6	81.6	81.6	81.6	81.6	81.6	81.6	81.6	81.6	81.6	81.6			
Feeder		2018	2019	2018	2019	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023			
SCR (A)		335	335	60%	75%	77%	177	206	224	175	198	169	203	250	259	260	260	263			
utilis (%)		300	300	57%	67%	68%		168	175	221	157	149	170	201	205	205	206	208			
forecast utilis (%)		340	340	72%	87%	91%		234	245	207	237	226	243	296	311	316	319	323			
Spare capacity		0	0																		
Annual growth		0	0																		
DM (A)		340	340	46%	54%	54%	219	234	159	147	154	147	158	183	184	184	185	187			
2019		285	285	52%	61%	61%	158	53	132	110	121	129	149	174	175	175	177	177			
2018-2023		285	285	59%	73%	74%	221	254	132	144	163	145	169	208	211	213	214	216			
2019		0	0																		
Annual growth		285	285	62%	72%	72%	181	192	164	131	152	148	175	204	205	205	206	208			
2019		285	285	60%	72%	73%	20	43	119	109	153	150	170	206	208	212	218	224			
Annual growth		215	215	87%	99%	101%	165	164	216	145	161	162	188	213	218	219	219	221			
2019		300	300	60%	70%	70%	274	234	221	189	176	186	180	209	210	212	213	216			
Annual growth		300	300	43%	50%	50%	157	234	109	104	117	119	129	150	151	151	152	153			
2019		285	285	50%	58%	58%	153	188	155	124	149	141	143	166	167	167	168	169			
Annual growth																					
Average		222	222	78%	69%	85%	144	184	171	150	162	156	173	189	193	194	195	197			
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019																					
Annual growth																					
2019			</																		

United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	Actual 2015	2016	2017	2018	2019	2020	2021	2022	Forecast 2023	2024	2025	2026	2027	2028
MORDIALLOC MC																	
Voltage 22.5 kV																	
Load maximum demand actual / forecast (MW)	55.8	62.8	60.0	47.7	52.6	57.0	58.2	63.5	63.6	63.4	63.4	64.0	64.1	65.4	66.7	67.9	68.0
10% POE actual MD	63.0	68.0	65.9	59.3	57.7	61.8	61.2										
Load transfers (MW)				-3.1													
Extra new load (MW)		1.0	1.8	0.9	1.6	1.1	1.2	1.0	0.6	0.4	0.3	0.2					
% growth (MW)		12.6%	-4.4%	-20.5%	10.3%	8.4%	2.1%	9.2%	0.2%	-0.4%	-0.1%	1.0%	0.2%	2.1%	1.9%	1.8%	0.2%
Feeder summation reactive demand (MVAR)	12.6	17.0	16.5	8.6	10.0	6.6	6.0	8.2	8.3	8.2	8.1	8.4	8.5	9.0	9.5	10.0	10.1
Zone substation capacitor bank (MVAR)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Feeder line capacitors (MVAR)	19.5	20.4	20.4	22.0	22.0	22.0	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7
Reactive load on transformers (MVAR)	12.6	17.0	16.5	8.6	10.0	6.6	6.0	8.2	8.3	8.2	8.1	8.4	8.5	9.0	9.5	10.0	10.1
Feeder summation power factor	0.98	0.97	0.96	0.98	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99
Transformation summation power factor	0.98	0.97	0.96	0.98	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	57.2	65.0	62.2	48.5	53.5	57.4	58.5	64.1	64.2	63.9	63.9	64.6	64.7	66.1	67.4	68.6	68.7
(N-1) Cyclic Rating (MVA)	55.4	55.4	55.4	55.4	55.4	55.4	55.4	55.4	55.4	55.4	55.4	55.4	55.4	55.4	55.4	55.4	55.4
(N-1) Limited Cyclic Rating (MVA)	59.6	59.6	59.6	59.6	59.6	59.6	59.6	59.6	59.6	59.6	59.6	59.6	59.6	59.6	59.6	59.6	59.6
(N-1) 2 Hour Emergency Rating (MVA)	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0
(N-1) 10 Minute Emergency Rating (MVA)	60.0	60.0	60.0	60.0	67.6	67.6	67.6	67.6	67.6	67.6	67.6	67.6	67.6	67.6	67.6	67.6	67.6
(N) Cyclic Rating (MVA)	83.1	83.1	83.1	60.0	83.1	83.1	83.1	83.1	83.1	83.1	83.1	83.1	83.1	83.1	83.1	83.1	83.1
Feeder	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
SCR (A)	265	265	265	265	265	265	265	265	265	265	265	265	265	265	265	265	265
utilis (%)	53%	56%	60%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%
forecast utilis (%)	56%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%	61%
MC 1	130	138	145	131	131	135	139	147	148	148	149	150	118 A	4.6 MVA	1.6%		
MC 2	176	222	251	151	117	132	148	158	162	164	165	166	107 A	4.2 MVA	2.5%		
MC 3	128	150	156	124	143	135	194	206	207	208	208	210	59 A	2.3 MVA	1.7%		
MC 4	325	325	269	276	276	245	255	276	281	283	284	287	49 A	1.9 MVA	2.5%		
MC 5	305	305	249	173	179	185	199	213	215	216	218	221	92 A	3.6 MVA	2.2%		
MC 6	330	330	233	212	228	216	219	236	240	244	248	254	94 A	3.7 MVA	3.2%		
MC 7	265	265	218	140	165	201	157	175	180	185	190	193	90 A	3.5 MVA	4.6%		
MC 8	0	0											0 A	0 MVA			
MC 9	365	365	153	191	174	170	201	215	217	218	219	221	150 A	5.8 MVA	1.9%		
MC 10	330	330	161	143	144	148	221	235	237	238	239	241	95 A	3.7 MVA	1.8%		
Average	272	272	204	171	173	174	193	186	189	190	192	194	85 A	3.3 MVA	0.2%		

Feeder	2019	2020	2021	2022	2023
MC 1	0	0	0	0	0
MC 2	0	0	0	0	0
MC 3	0	0	0	0	0
MC 4	0	0	0	0	0
MC 5	0	0	0	0	0
MC 6	0	0	0	0	0
MC 7	0	0	0	0	0
MC 8	0	0	0	0	0
MC 9	0	0	0	0	0
MC 10	0	0	0	0	0


Feeder	2019	2020	2021	2022	2023
MC 1	0	0	0	0	0
MC 2	1	3	2	0	0
MC 3	1	0	0	0	0
MC 4	6	4	1	0	0
MC 5	3	0	1	1	1
MC 6	4	3	4	4	3
MC 7	9	4	4	4	1
MC 8	0	0	0	0	0
MC 9	2	1	0	0	0
MC 10	2	1	0	0	0

Zone Substation Comments

- Zone Substation ratings were reviewed in 20101.
- New Loads:
 - 1MW on MC5 in 2007.
 - 1MW on MC7 in 2007.
 - 2MW on MC10 over next 4 years from 2007.
 - 1.5MVA on MC7 (2012)
 - 1.0MVA on MC9 (2012)
- Load Transfers:
 - Transferred 1.0MW from M to MC for summer 2007.
 - Transferred 1.5MW from MC to CRM for summer 2008.
 - Transferred 2.2MW from MC to CRM for summer 2010.
 - MC7 - 3.0MVA from MC2 and 2.1MVA to NP15 (2014/15)
 - MC9 - 2.5MVA from MC4 and 1.0MVA to NP14 (2014/15)
- Line Capacitors: Installed 12MVar in 1997 and 2.7MVar in 1999.
- New 66/22kV Transformer - Installed 3rd transformer at MC & 2 feeder exits (MC09 & MC10) prior to summer 2002. Third feeder (MC07) commissioned in winter 2002.
- Established Keysborough zone substation (KBH) for summer 2015 to off-load NP, MC & DSH.

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	Actual 2015	2016	2017	2018	2019	2020	2021	2022	Forecast 2023	2024	2025	2026	2027	2028			
MULGRAVE Voltage 22.2 kV																				
Load maximum demand actual / forecast (MW)	69.1	75.2	82.3	68.7	73.2	74.9	73.4	84.3	84.4	83.9	84.0	85.0	85.1	86.7	88.4	90.0	91.0			
10% POE actual MD	77.2	81.3	82.3	82.1	78.9	81.4	79.6													
Load transfers (MW)			-5.3					1.9												
Extra new load (MW)		0.2	1.0			2.1	1.9	0.7	0.6	0.6	0.7	0.4								
% growth (MW)		8.8%	9.5%	-16.5%	6.5%	2.3%	-2.0%	14.8%	0.1%	-0.5%	0.1%	1.1%	0.2%	1.9%	1.9%	1.8%	1.1%			
Feeder summation reactive demand (MVAR)	15.1	15.2	15.1	8.4	10.3	11.2	8.1	11.8	11.7	11.7	12.0	12.0	12.0	12.6	13.1	13.7	14.0			
Zone substation capacitor bank (MVAR)	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0			
Feeder line capacitors (MVAR)	15.3	15.3	15.3	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2			
Reactive load on transformers (MVAR)	6.9	7.0	6.9	0.3	2.1	3.0	-0.1	3.6	3.6	3.5	3.5	3.8	3.8	4.4	5.0	5.5	5.8			
Feeder summation power factor	0.98	0.98	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	69.5	75.5	82.6	68.7	73.2	75.0	73.4	84.4	84.4	84.0	84.1	85.0	85.2	86.8	88.5	90.2	91.2			
(N-1) Cyclic Rating (MVA)	74.4	74.4	74.4	74.4	74.4	74.4	74.4	74.4	74.4	74.4	74.4	74.4	74.4	74.4	74.4	74.4	74.4			
(N-1) Limited Cyclic Rating (MVA)	79.0	79.0	79.0	79.0	79.0	79.0	79.0	79.0	79.0	79.0	79.0	79.0	79.0	79.0	79.0	79.0	79.0			
(N-1) 2 Hour Emergency Rating (MVA)	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3			
(N-1) 10 Minute Emergency Rating (MVA)	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3	86.3			
(N) Cyclic Rating (MVA)	111.6	111.6	111.6	86.3	111.6	111.6	111.6	111.6	111.6	111.6	111.6	111.6	111.6	111.6	111.6	111.6	111.6			
Feeder	SCR (A) 2018	SCR (A) 2019	utilis (%) 2018	forecast utilis (%) 2019	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity	2018-2023 Annual growth	2019 DM (A)
MGE 11	350	350	25%	27%	28%	67	80	90	68	81	75	87	96	97	97	97	98	254 A	9.8 MVA	2.7%
MGE 12	260	260	81%	93%	96%	175	191	202	171	197	208	211	243	249	250	250	253	17 A	0.7 MVA	4.0%
MGE 13	320	320	77%	85%	86%	254	254	257	227	239	244	246	271	275	277	279	282	49 A	1.9 MVA	2.9%
MGE 14	325	325	39%	73%	74%	184	193	197	170	157	115	126	239	242	243	243	246	86 A	3.3 MVA	19.0%
MGE 21	315	315	66%	73%	74%	181	205	220	184	203	210	208	230	234	237	244	250	85 A	3.3 MVA	4.1%
MGE 22	260	260	62%	70%	72%	167	184	204	162	156	172	160	181	188	193	196	198	79 A	3 MVA	4.7%
MGE 23	260	260	68%	75%	76%	153	171	178	135	177	155	177	195	197	198	198	200	65 A	2.5 MVA	2.7%
MGE 24	295	295	73%	81%	82%	228	244	261	225	234	218	216	238	241	242	243	245	57 A	2.2 MVA	2.7%
MGE 31	295	295	68%	75%	76%	199	214	237	203	206	178	201	221	224	225	225	228	74 A	2.8 MVA	2.7%
MGE 32	295	295	49%	55%	57%	217	225	246	115	129	134	144	162	169	176	180	181	133 A	5.1 MVA	5.2%
MGE 33	320	320	48%	53%	54%	216	213	80	154	154	230	154	169	172	172	173	174	151 A	5.8 MVA	2.7%
MGE 34	265	265	59%	65%	67%	144	153	174	130	153	138	157	173	177	181	189	197	92 A	3.6 MVA	5.1%
Average	297	297	59%	68%	68%	182	194	195	162	174	173	174	202	205	207	210	213	95 A	3.7 MVA	4.5%

Feeder	Load Transfers (Amps)			
	2019	2020	2021	2023
MGE 11	0	0	0	0
MGE 12	0	0	0	0
MGE 13	0	0	0	0
MGE 14	100	0	0	0
MGE 21	0	0	0	0
MGE 22	0	0	0	0
MGE 23	0	0	0	0
MGE 24	0	0	0	0
MGE 31	0	0	0	0
MGE 32	0	0	0	0
MGE 33	0	0	0	0
MGE 34	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
MGE 11	0	0	0	0	0
MGE 12	10	3	0	0	0
MGE 13	0	1	1	1	0
MGE 14	0	0	0	0	0
MGE 21	0	1	3	6	4
MGE 22	5	5	4	3	0
MGE 23	0	0	0	0	0
MGE 24	0	0	0	0	0
MGE 31	0	0	0	0	0
MGE 32	4	4	6	3	0
MGE 33	0	0	0	0	0
MGE 34	0	2	4	8	6

Zone Substation Comments


- Zone Substation ratings were reviewed in 2010.
- Line Capacitors
9.0MVAR prior to summer 1999.
4.5MVAR prior to summer 2002.
- Load Transfers:
1.7MW from MGE to GW for summer 2010.
7.4MW from MGE to LD prior to summer 2013.
- New Loads

Reserve Capacity Requirements

- SP Ausnet Datacentre
LD33 1MVA reserve
MGE32 1MVA reserve
No reserve contracts are in place.

Network Support Agreements

- GreenSync - 800kVA reduction for 2015/16 (1 year)



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
MOORABBIN MR																				
Voltage	11.4 kV																			
Load maximum demand actual / forecast (MW)	32.3	38.9	44.0	32.7	43.4	45.5	46.8	50.1	50.3	50.4	50.5	51.0	51.1	52.1	53.1	54.1	54.2			
10% POE actual MD	37.0	42.8	44.5	44.0	46.0	49.7	48.1													
Load transfers (MW)							3.5													
Extra new load (MW)		0.2	0.3	0.6	1.8	1.2	1.3	0.9	0.7	0.6	0.4	0.2								
% growth (MW)		20.4%	13.1%	-25.7%	32.8%	4.8%	2.8%	7.0%	0.5%	0.1%	0.2%	1.0%	0.1%	2.1%	1.9%	1.8%	0.2%			
Feeder summation reactive demand (MVAR)	7.2	8.6	9.2	3.7	7.0	7.9	7.0	8.0	8.1	8.2	8.2	8.4	8.4	8.7	9.1	9.4	9.4			
Zone substation capacitor bank (MVAR)	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1			
Feeder line capacitors (MVAR)	6.3	6.3	6.3	6.3	6.3	6.3	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1	8.1			
Reactive load on transformers (MVAR)	0.7	2.1	2.6	-2.8	0.5	1.3	0.4	1.5	1.6	1.6	1.7	1.8	1.9	2.2	2.6	2.9	2.9			
Feeder summation power factor	0.98	0.98	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	32.3	39.0	44.1	32.8	43.4	45.5	46.8	50.1	50.4	50.4	50.5	51.1	51.1	52.2	53.2	54.2	54.3			
(N-1) Cyclic Rating (MVA)	45.0	45.0	48.0	48.0	48.0	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9			
(N-1) Limited Cyclic Rating (MVA)	48.0	48.0	48.0	48.0	48.0	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9			
(N-1) 2 Hour Emergency Rating (MVA)	59.0	59.0	59.0	59.0	59.0	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9			
(N-1) 10 Minute Emergency Rating (MVA)	59.0	59.0	59.0	59.0	59.0	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9	39.9			
(N) Cyclic Rating (MVA)	90.0	90.0	72.0	59.0	72.0	72.0	72.0	79.8	79.8	79.8	79.8	79.8	79.8	79.8	79.8	79.8	79.8			
Feeder	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034			
MR 11	335	335	42%	44%	44%	134	137	148	133	147	132	142	148	149	150	151	187 A	3.7 MVA	1.3%	
MR 12	350	350	68%	71%	72%	122	145	155	130	149	174	239	249	253	260	266	268	101 A	2 MVA	2.4%
MR 13	350	350	66%	68%	69%	188	230	344	95	235	225	232	240	241	241	242	244	110 A	2.2 MVA	1.1%
MR 14	300	300	75%	79%	81%	243	285	302	203	236	197	225	238	242	243	244	246	62 A	1.2 MVA	1.8%
MR 15	350	350	89%	97%	99%	237	353	324	270	266	269	310	338	345	350	352	356	12 A	0.2 MVA	2.9%
MR 21	335	335	56%	58%	59%	268	292	204	163	194	181	189	195	196	197	199	199	140 A	2.8 MVA	1.1%
MR 22	330	330	80%	83%	84%	204	234	275	228	229	246	265	275	278	280	281	283	55 A	1.1 MVA	1.4%
MR 23	320	320	73%	78%	80%	179	199	201	166	175	226	233	250	256	268	284	296	70 A	1.4 MVA	5.4%
MR 24	265	265	69%	72%	74%	190	207	224	186	207	176	182	191	197	202	202	204	74 A	1.5 MVA	2.5%
MR 31	320	320	60%	63%	64%	178	200	199	127	181	180	193	202	206	209	210	212	118 A	2.3 MVA	1.9%
MR 32	350	350	73%	77%	79%			254	183	216	230	256	270	277	279	281	283	80 A	1.6 MVA	2.1%
MR 33	350	350	73%	74%	75%					281	255	259	263	267	269	272		91 A	1.8 MVA	1.3%
MR 34	0	0																0 A	0 MVA	
MR 35	335	335		0%	0%													335 A	6.6 MVA	
Average	306	306	74%	67%	67%	162	190	219	157	186	210	227	204	207	210	213	215	103 A	2 MVA	-1.0%

Feeder	2019	2020	2021	2022	2023
MR 11	0	0	0	0	0
MR 12	0	0	0	0	0
MR 13	0	0	0	0	0
MR 14	0	0	0	0	0
MR 15	0	0	0	0	0
MR 21	0	0	0	0	0
MR 22	0	0	0	0	0
MR 23	0	0	0	0	0
MR 24	0	0	0	0	0
MR 31	0	0	0	0	0
MR 32	0	0	0	0	0
MR 33	0	0	0	0	0
MR 34	0	0	0	0	0
MR 35	0	0	0	0	0


Feeder	2019	2020	2021	2022	2023
MR 11	1	0	0	0	0
MR 12	2	3	6	5	0
MR 13	0	0	0	0	0
MR 14	5	4	0	0	0
MR 15	19	5	4	1	0
MR 21	0	0	0	0	0
MR 22	1	2	2	0	0
MR 23	10	5	10	15	9
MR 24	3	6	4	0	0
MR 31	2	4	3	0	0
MR 32	6	5	1	1	0
MR 33	3	3	3	2	0
MR 34	0	0	0	0	0
MR 35	0	0	0	0	0

Zone Substation Comments

- Station rating is limited by 11kV transformer cables. The ultimate rating of the station is estimated at (N-1) SCR = 32MVA. Upgrade 11kV transformer cables in 2006 for summer 2007.
- Line Capacitors: Installed 4.8MVAR prior to summer 2000.
- New Loads:
- Load Transfers:
 - 2.6MW from MR to NB for summer 2009 - due to MR Tx derated
 - 1.5MW from MR to SR for summer 2009 - due to MR Tx derated
 - 1.5MW from BT, NB, SR to MR for summer 2011
- 3rd transformer at MR in 2009 for summer 2010. Tx no3 to be retired in 2009.

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

		Actual										Forecast									
		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
MORNINGTON	MTN																				
Voltage	22.6 kV																				
Load maximum demand actual / forecast (MW)		45.5	44.3	56.6	51.0	54.2	50.8	63.1	66.8	66.9	66.7	67.2	68.7	69.4	71.4	73.4	75.2	75.9			
10% POE actual MD		49.2	48.9	57.7	56.5	58.2	59.8	64.9													
Load transfers (MW)								2.6													
Extra new load (MW)			2.7	1.1	0.2	0.4	0.2	0.3	0.3	0.4	0.4	0.1									
% growth (MW)			-2.8%	27.9%	-9.9%	6.2%	-6.3%	24.3%	5.9%	0.1%	-0.3%	0.6%	2.3%	1.0%	2.8%	2.7%	2.5%	1.0%			
Feeder summation reactive demand (MVAR)		6.7	8.3	12.5	8.2	9.6	6.2	7.8	8.6	8.6	8.6	8.7	9.0	9.2	9.6	10.0	10.4	10.6			
Zone substation capacitor bank (MVAR)		6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8	6.8			
Feeder line capacitors (MVAR)		5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4			
Reactive load on transformers (MVAR)		-0.5	1.1	5.4	1.0	2.4	-1.0	0.7	1.5	1.5	1.4	1.5	1.9	2.0	2.4	2.9	3.2	3.4			
Feeder summation power factor		0.99	0.98	0.98	0.99	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor		1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																					
Overall demand on transformers (MVA)		45.5	44.3	56.8	51.0	54.2	50.8	63.1	66.8	66.9	66.8	67.2	68.8	69.5	71.5	73.4	75.2	76.0			
(N-1) Cyclic Rating (MVA)		41.8	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4			
(N-1) Limited Cyclic Rating (MVA)		45.1	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9			
(N-1) 2 Hour Emergency Rating (MVA)		45.1	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9			
(N-1) 10 Minute Emergency Rating (MVA)		45.1	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9	48.9			
(N) Cyclic Rating (MVA)		65.8	92.9	92.9	48.9	92.9	92.9	92.9	92.9	92.9	92.9	92.9	92.9	92.9	92.9	92.9	92.9	92.9			

Feeder	SCR (A)	utilis (%)	forecast utilis (%)	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity		2018-2023 Annual growth	2019 DM (A)	
MTN 21	350	350	66%	69%	72%	236	262	249	173	257	206	230	243	253	263	270	276	107 A	4.2 MVA	4.0%
MTN 22	325	325	85%	89%	90%	243	78	135	239	259	240	278	289	293	297	302	309	36 A	1.4 MVA	2.2%
MTN 23	260	260	63%	65%	66%		211	234	144	152	145	164	170	172	174	177	181	90 A	3.5 MVA	2.1%
MTN 24	260	260	87%	91%	92%	103	70	151	189	202	197	227	235	238	241	245	250	25 A	1 MVA	2.1%
MTN 31	320	320	91%	94%	95%	283	291	328	232	254	242	290	301	305	308	313	320	19 A	0.7 MVA	2.1%
MTN 32	260	260	62%	76%	77%		28	57	77	88	70	160	198	200	202	205	210	62 A	2.4 MVA	6.3%
MTN 33	0	0																0 A	0 MVA	
MTN 34	265	265	85%	90%	91%	174	187	237	216	200	185	226	237	242	244	248	254	28 A	1.1 MVA	2.4%
MTN 35	260	260	81%	84%	85%	199	224	268	162	179	176	211	219	222	225	228	233	41 A	1.6 MVA	2.1%
Average	256	256	87%	82%	82%	155	169	207	179	199	183	223	210	214	217	221	226	45 A	1.8 MVA	0.2%

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
MTN 21	0	0	0	0	0
MTN 22	0	0	0	0	0
MTN 23	0	0	0	0	0
MTN 24	0	0	0	0	0
MTN 31	0	0	0	0	0
MTN 32	30	0	0	0	0
MTN 33	0	0	0	0	0
MTN 34	0	0	0	0	0
MTN 35	0	0	0	0	0


Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
MTN 21	4	8	8	2	0
MTN 22	0	0	1	1	0
MTN 23	0	0	0	0	0
MTN 24	0	0	0	0	0
MTN 31	0	0	0	0	0
MTN 32	2	0	0	0	0
MTN 33	0	0	0	0	0
MTN 34	2	2	0	0	0
MTN 35	0	0	0	0	0

Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- Line Capacitors
3.6MVar prior to summer 2001.
1.8MVar prior to summer 2002.
- Replace PCB capacitors at MTN in 2003 : #1 - 8MVar
- Load Transfers:
0.8MW from FSH to MTN prior to summer 2009.
MTN21 - 2.1MVA from MTN34
MTN23 - 1.8MVA from MTN31, 7.0MVA to MTN22, 0.9MVA to MTN34 and 0.8MVA to MTN35
MTN32 - 1.9MVA to MTN24, 2.8MVA to MTN31 and 0.6MVA to MTN34
- New Loads
1.0MW on MTN8 (Racecourse Rd) in early 2009.
1MVA at Safeway (2012)
2 MVA at Mt Martha TTP (2012)
1.8MVA at Watts Rd Industrial Estate (2012)
1MVA at Bungrower Rd retirement village (2012)
- New 20/33MVA Tx in 2008 for summer 2008/09
Replace the remaining 3x10MVA Tx with 1x20/33MVA Tx in 2012/13

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	Actual 2015	2016	2017	2018	2019	2020	2021	2022	Forecast 2023	2024	2025	2026	2027	2028
NORTH BRIGHTON NB																	
Voltage 11.5 kV																	
Load maximum demand actual / forecast (MW)	38.2	44.0	45.3	36.7	43.2	41.4	45.7	49.7	49.8	49.5	49.5	50.0	50.1	51.1	52.1	53.0	53.1
10% POE actual MD	45.8	47.8	49.0	48.4	50.1	50.0	48.0										
Load transfers (MW)																	
Extra new load (MW)		0.1	0.7	1.5	1.6	1.4	1.2	0.6	0.4	0.3	0.3	0.2					
% growth (MW)		15.4%	2.9%	-19.1%	17.9%	-4.2%	10.3%	8.8%	0.1%	-0.5%	0.0%	1.0%	0.1%	2.1%	1.9%	1.8%	0.2%
Feeder summation reactive demand (MVAR)	8.0	7.4	9.1	5.0	7.6	5.2	8.2	9.9	9.9	9.8	9.8	10.0	10.0	10.5	10.9	11.2	11.3
Zone substation capacitor bank (MVAR)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Feeder line capacitors (MVAR)	7.5	9.3	9.3	10.2	10.2	10.2	9.6	9.6	9.6	9.6	9.6	9.6	9.6	9.6	9.6	9.6	9.6
Reactive load on transformers (MVAR)	8.0	7.4	9.1	5.0	7.6	5.2	8.2	9.9	9.9	9.8	9.8	10.0	10.0	10.5	10.9	11.2	11.3
Feeder summation power factor	0.98	0.99	0.98	0.99	0.99	0.99	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98
Transformation summation power factor	0.98	0.99	0.98	0.99	0.99	0.99	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	39.0	44.7	46.3	37.0	43.9	41.8	46.4	50.7	50.8	50.5	50.5	51.0	51.1	52.2	53.2	54.2	54.3
(N-1) Cyclic Rating (MVA)	33.2	39.8	39.8	39.8	39.8	39.8	45.4	45.4	45.4	45.4	45.4	45.4	45.4	45.4	45.4	45.4	45.4
(N-1) Limited Cyclic Rating (MVA)	36.2	39.8	39.8	39.8	39.8	39.8	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7
(N-1) 2 Hour Emergency Rating (MVA)	38.5	39.8	39.8	39.8	39.8	39.8	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7
(N-1) 10 Minute Emergency Rating (MVA)	38.5	39.8	39.8	39.8	39.8	39.8	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7	49.7
(N) Cyclic Rating (MVA)	66.4	79.7	79.7	39.8	79.7	79.7	90.8	90.8	90.8	90.8	90.8	90.8	90.8	90.8	90.8	90.8	90.8

Feeder	Load Transfers (Amps)			
	2019	2020	2021	2023
NB 11	0	0	0	0
NB 12	0	0	0	0
NB 13	0	0	0	0
NB 14	0	0	0	0
NB 15	0	0	0	0
NB 21	0	0	0	0
NB 22	0	0	0	0
NB 23	0	0	0	0
NB 24	0	0	0	0
NB 25	0	0	0	0
NB 26	0	0	0	0
NB 31	0	0	0	0
NB 32	0	0	0	0
NB 33	0	0	0	0
NB 34	0	0	0	0
NB 35	0	0	0	0
NB 36	0	0	0	0

Feeder	SCR (A)		utilis (%)		forecast utilis (%)													2019		2018-2023		2019
	2018	2019	2018	2019	2020	2021	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	Spare capacity	Annual growth	DM (A)	
NB 11	0	0					117	133	119	129	125											
NB 12	0	0					248	273	331	226	263											
NB 13	0	0					141	155	152	118	148											
NB 14	0	0					195	232	244	211	241											
NB 15	0	0					350	290	226	235	188											
NB 21	0	0					188	224	234	187	220											
NB 22	300	300	53%	57%	58%		275	301	282	220	255	156	159	172	174	177	179	180	128 A	2.5 MVA	2.7%	
NB 23	330	330	63%	69%	71%		270	304	319	252	293	251	208	229	235	236	237	239	101 A	2 MVA	3.0%	
NB 24	350	350	45%	47%	48%		243	272	248	194	237	156	156	165	167	172	180	188	185 A	3.7 MVA	4.1%	
NB 25	350	350	89%	94%	95%		216	233	233	235	264	271	312	330	331	333	334	337	20 A	0.4 MVA	1.6%	
NB 26	330	330	44%	47%	47%						120	146	154	155	155	156	157	176 A	3.5 MVA	1.6%		
NB 31	330	330	67%	72%	72%								222	236	239	241	242	244	94 A	1.9 MVA	2.0%	
NB 32	300	300	75%	83%	85%						214	226	248	256	256	256	259	52 A	1 MVA	2.9%		
NB 33	300	300	78%	82%	83%						220	233	247	249	251	253	255	53 A	1.1 MVA	1.9%		
NB 34	350	350	62%	68%	69%						191	218	236	240	243	245	247	114 A	2.3 MVA	2.7%		
NB 35	350	350	86%	92%	93%						364	301	321	325	330	338	346	29 A	0.6 MVA	3.0%		
NB 36	350	350	77%	83%	83%						221	270	289	292	293	294	297	61 A	1.2 MVA	1.9%		
Average	214	214	104%	72%	112%		224	242	239	201	223	197	223	239	242	244	247	250	0 A	0 MVA	2.4%	


Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
NB 11	0	0	0	0	0
NB 12	0	0	0	0	0
NB 13	0	0	0	0	0
NB 14	0	0	0	0	0
NB 15	0	0	0	0	0
NB 21	0	0	0	0	0
NB 22	4	1	2	2	0
NB 23	9	6	0	0	0
NB 24	0	2	4	8	6
NB 25	0	0	0	0	0
NB 26	0	0	0	0	0
NB 31	2	2	1	0	0
NB 32	9	6	0	0	0
NB 33	0	1	1	1	0
NB 34	6	3	2	1	0
NB 35	2	3	4	6	5
NB 36	3	2	0	0	0

Zone Substation Comments

- Due to space limitation, existing site is suitable for 2 transformers only.
Tx #2 to be replaced in 2011 as part of asset replacement
Tx #1 to be replaced in 2012 as part of asset replacement. As a result, N and (N-1) ratings increases.
- Station summer capability is limited by thermal rating of transformers and their 11kV cables.
- Line Capacitors:
Installed 8.1MVAR prior to summer 2000.
- Load Transfers:
1.0MW from NB to BT for summer 2009.
2.6MW from MR to NB for summer 2009 - due to derated Tx at MR.
0.5MW from BT to NB for summer 2009 - due to derated Tx at MR.
2.0MW from NB to EW for summer 2010
0.2MW from NB to MR for summer 2011
- New Load:

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
NOTTING HILL	NO																
Voltage	22.3 kV																
Load maximum demand actual / forecast (MW)	38.7	43.3	43.9	40.7	43.0	43.5	47.1	57.3	58.2	59.1	60.4	61.7	63.5	65.2	66.4	67.5	68.0
10% POE actual MD	44.8	45.9	45.8	46.2	46.0	47.6	49.4										
Load transfers (MW)		-2.5					1.3	4.0									
Extra new load (MW)			1.2	1.9	2.8	5.8	4.2	2.4	1.0	1.2	1.3	0.8	1.4	1.0			
% growth (MW)		11.9%	1.5%	-7.4%	5.6%	1.3%	8.3%	21.7%	1.5%	1.6%	2.2%	2.2%	2.8%	2.8%	1.9%	1.7%	0.6%
Feeder summation reactive demand (MVar)	8.1	7.9	7.1	5.6	5.7	5.0	-5.8	-3.9	-3.7	-3.6	-3.3	-3.1	-2.8	-2.4	-2.2	-2.0	-1.9
Zone substation capacitor bank (MVar)	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1	15.1
Feeder line capacitors (MVar)	12.6	13.5	13.5	13.5	13.5	13.5	14.1	14.1	14.1	14.1	14.1	14.1	14.1	14.1	14.1	14.1	14.1
Reactive load on transformers (MVar)	-7.4	-7.6	-8.4	-9.9	-9.8	-10.5	-21.3	-19.4	-19.2	-19.1	-18.8	-18.6	-18.3	-17.9	-17.7	-17.5	-17.4
Feeder summation power factor	0.98	0.98	0.99	0.99	0.99	0.99	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Transformation summation power factor	0.98	0.98	0.98	0.97	0.97	0.97	0.91	0.95	0.95	0.95	0.95	0.96	0.96	0.96	0.97	0.97	0.97
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	39.4	43.9	44.7	41.9	44.1	44.7	51.7	60.5	61.3	62.1	63.3	64.5	66.0	67.7	68.8	69.8	70.2
(N-1) Cyclic Rating (MVA)	37.0	37.0	37.0	37.0	37.0	37.0	74.0	74.0	74.0	74.0	74.0	74.0	74.0	74.0	74.0	74.0	74.0
(N-1) Limited Cyclic Rating (MVA)	39.7	39.7	39.7	39.7	39.7	39.7	79.4	79.4	79.4	79.4	79.4	79.4	79.4	79.4	79.4	79.4	79.4
(N-1) 2 Hour Emergency Rating (MVA)	42.4	42.4	42.4	42.4	42.4	42.4	84.9	84.9	84.9	84.9	84.9	84.9	84.9	84.9	84.9	84.9	84.9
(N-1) 10 Minute Emergency Rating (MVA)	42.4	42.4	47.3	47.3	47.3	47.3	94.6	94.6	94.6	94.6	94.6	94.6	94.6	94.6	94.6	94.6	94.6
(N) Cyclic Rating (MVA)	74.0	74.0	74.0	47.3	74.0	74.0	111.0	111.0	111.0	111.0	111.0	111.0	111.0	111.0	111.0	111.0	111.0

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
NO 1	0	0	0	0	0
NO 2	0	0	0	0	0
NO 3	0	0	0	0	0
NO 4	0	0	0	0	0
NO 5	0	0	0	0	0
NO 6	0	0	0	0	0
NO 7	35	0	0	0	0
NO 8	0	0	0	0	0
NO 9	0	0	0	0	0
NO 31	70	0	0	0	0
NO 32	0	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
NO 1	8	16	32	24	0
NO 2	0	1	2	4	3
NO 3	2	1	0	0	0
NO 4	12	9	0	0	0
NO 5	1	0	0	0	0
NO 6	1	0	0	0	0
NO 7	1	1	0	0	0
NO 8	0	0	0	0	0
NO 9	0	0	0	0	0
NO 31	0	0	0	10	19
NO 32	0	0	0	0	0


Zone Substation Comments

- Ratings were reviewed in 2010.
- Line Capacitors:
Installed 8.1MVar prior to summer 1999.
Installed 4.5MVar prior to summer 2000.
- Load Transfers:
Transfer 3MW to CDA prior to summer 2003.
Transfer 12MW to SV and SVW prior to summer 2008.
2.5MW from NO to CDA for summer 2013.
90A from NO3 --> NO2 -2012
70A from NO7 --> CDA11 - 2012
- New Loads:
1.5MW on NO5 in 2008 and 2009.
1.0MW on NO5 in 2008 by customer at 680 Blackburn Rd, Notting Hill.
0.8MW on NO4 in 2009 by Fonterra.
0.9MW on NO3 in 2014 by ANZ Data Centre
1.1MW on NO2 in 2013 by Goodmans site
0.8MW on NO2 in 2013 at 660 BBurn Rd

Reserve Capacity Requirements

- ANZ, Forster Rd, Mt Waverley.
NO 03 (preferred)
NO 08 (preferred) from 1 May 2016
GW 03 (reserve) - 1.7MVA (45A);
2.3MVA (60A) from 1 Nov 2002;
3.0MVA (80A) from 1 Jan 2003.
3.5MVA (91A) from 12 Jul 2012
4.0MVA (80A) from 1 Jun 2014.
GW 10 (reserve) - 8.0MVA (~210A) from 1 May 2016
- Monash University (Clayton):
SVW51 = 2MVA
NO6 = 4MVA
NO2 = 2MVA
- Telstra (New Data Centre)
NO 01 (Duty) from 1 Jan 2016
SV31 (Reserve) - 8MVA (210A) from 1 Jan 2016
- Telstra (Old Data Centre)
SVW43 (Duty) from 1 Jan 2016
NO 09 (Reserve) - 8MVA (210A) from 1 Jan 2016

Network Support Agreements
Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
NOBLE PARK NP																	
Voltage	22.5 kV																
Load maximum demand actual / forecast (MW)	65.3	64.3	77.8	54.3	58.5	55.1	56.0	63.9	63.5	63.0	62.7	63.5	63.5	64.8	66.0	67.1	67.2
10% POE actual MD	80.4	68.9	77.9	57.3	61.6	61.5	61.8										
Load transfers (MW)		-4.3															
Extra new load (MW)			1.5	-17.9	1.8	1.2	1.2	0.6	0.5	0.6	0.4	0.1					
% growth (MW)		-1.4%	21.0%	-30.3%	7.8%	-5.9%	1.6%	14.2%	-0.6%	-0.7%	-0.6%	1.3%	0.1%	2.1%	1.9%	1.7%	0.1%
Feeder summation reactive demand (MVAR)	15.6	18.0	16.2	7.1	11.1	9.0	8.7	12.2	12.1	11.9	11.7	12.0	12.1	12.7	13.2	13.7	13.7
Zone substation capacitor bank (MVAR)	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1
Feeder line capacitors (MVAR)	18.0	19.8	19.8	11.7	11.7	11.7	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3
Reactive load on transformers (MVAR)	4.0	6.4	4.6	-4.5	-0.5	-2.5	-2.9	0.7	0.5	0.3	0.1	0.5	0.5	1.1	1.6	2.1	2.1
Feeder summation power factor	0.97	0.96	0.98	0.99	0.98	0.99	0.99	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98
Transformation summation power factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	65.4	64.7	78.0	54.5	58.5	55.1	56.0	63.9	63.5	63.0	62.7	63.5	63.5	64.9	66.1	67.2	67.2
(N-1) Cyclic Rating (MVA)	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0
(N-1) Limited Cyclic Rating (MVA)	73.0	73.0	73.0	73.0	73.0	73.0	73.0	73.0	73.0	73.0	73.0	73.0	73.0	73.0	73.0	73.0	73.0
(N-1) 2 Hour Emergency Rating (MVA)	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8
(N-1) 10 Minute Emergency Rating (MVA)	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8	81.8
(N) Cyclic Rating (MVA)	108.0	108.0	108.0	81.8	108.0	108.0	108.0	108.0	108.0	108.0	108.0	108.0	108.0	108.0	108.0	108.0	108.0

Feeder	SCR (A)	utilis (%)	forecast utilis (%)	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
NP 11	350	350	40%	242	251	258	128	137	137	139	157	158	158	158	160
NP 12	285	285	53%	160		173	149	154	133	152	172	175	179	182	184
NP 13	0	0													
NP 14	260	260	50%	135	210	240	117	133	127	130	152	154	157	159	161
NP 16	320	320	48%	186	94	230	196	208	170	154	174	175	176	177	179
NP 23	260	260	59%	182	271	203	133	146	125	153	173	174	174	174	177
NP 24	325	325	30%	208	220	205	89	94	109	99	111	112	112	112	114
NP 25	260	260	56%	208	96	169	136	103	160	146	166	168	171	173	176
NP 31	305	305	37%	200	212	210	125	119	114	114	128	129	129	129	131
NP 33	255	255	73%	168	217	206	167	170	174	186	210	212	215	216	219
NP 34	260	260	64%	135	142	143	139	167	163	168	192	196	198	201	204
NP 36	260	260	56%	208	173	204	194	155	108	147	167	172	176	176	178
Average	262	262	55%	185	172	204	143	144	138	144	150	152	154	155	157

Feeder	2019	2020	2021	2022	2023
NP 11	0	0	0	0	0
NP 12	1	2	4	3	0
NP 13	0	0	0	0	0
NP 14	6	1	3	2	0
NP 16	0	1	1	0	0
NP 23	1	0	0	0	0
NP 24	0	0	0	0	0
NP 25	2	1	2	2	1
NP 31	0	0	1	0	0
NP 33	1	1	2	1	0
NP 34	4	3	2	2	1
NP 36	2	4	3	0	0

Feeder	2019	2020	2021	2022	2023
NP 11	0	0	0	0	0
NP 12	0	0	0	0	0
NP 13	0	0	0	0	0
NP 14	0	0	0	0	0
NP 16	0	0	0	0	0
NP 23	0	0	0	0	0
NP 24	0	0	0	0	0
NP 25	0	0	0	0	0
NP 31	0	0	0	0	0
NP 33	0	0	0	0	0
NP 34	0	0	0	0	0
NP 36	0	0	0	0	0


Feeder	2019	2020	2021	2022	2023
NP 11	0	0	0	0	0
NP 12	1	2	4	3	0
NP 13	0	0	0	0	0
NP 14	6	1	3	2	0
NP 16	0	1	1	0	0
NP 23	1	0	0	0	0
NP 24	0	0	0	0	0
NP 25	2	1	2	2	1
NP 31	0	0	1	0	0
NP 33	1	1	2	1	0
NP 34	4	3	2	2	1
NP 36	2	4	3	0	0

Zone Substation Comments

- Station rating limited by 22kV transformer cables. Transformer cables updated in 2001. Zone Substation ratings were reviewed in 2001. Post 2001 ratings are based on 40deg C ambient temp.
- Line Capacitors
Install 1.8MVAR for summer 2001, and 19.8MVAR for summer 2002.
- PCB Cap Bank Replacement; 11MVAR in Oct 2001
- Load Transfers:
Transfer 10MW from NP to SS in 2010.
4.3MW from NP to LD prior to summer 2013.
15MW from NP to KBH in 2015.
- New Load:
- Switchboard replacement in 2012/13: OLD/NEW Feeders = 11/36, 15/34, 2/33, 4/31, 18/25, 12/24, 9/23,
- Established Keysborough zone substation (KBH) in 2014 for summer 2015.

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	Actual										Forecast									
	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
NUNAWADING NW																				
Voltage	22.5 kV																			
Load maximum demand actual / forecast (MW)	52.4	61.3	66.2	53.2	60.3	59.0	57.6	66.2	66.5	66.4	66.5	67.3	67.4	68.9	70.2	71.3	71.5			
10% POE actual MD	63.4	64.1	67.5	66.4	64.3	66.3	64.0													
Load transfers (MW)																				
Extra new load (MW)			0.4	0.4	0.7	0.7	0.8	0.8	0.8	0.7	0.4	0.2								
% growth (MW)		17.0%	8.0%	-19.7%	13.4%	-2.2%	-2.3%	14.9%	0.5%	-0.1%	0.1%	1.3%	0.1%	2.2%	1.9%	1.7%	0.1%			
Feeder summation reactive demand (MVAR)	13.2	15.9	15.4	11.5	9.2	9.1	4.3	6.4	6.5	6.5	6.5	6.7	6.7	7.1	7.4	7.7	7.7			
Zone substation capacitor bank (MVAR)	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0	15.0			
Feeder line capacitors (MVAR)	9.3	9.3	9.3	7.8	7.8	7.8	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3			
Reactive load on transformers (MVAR)	-2.5	0.2	-0.3	-4.2	-6.5	-6.6	-11.4	-9.3	-9.2	-9.2	-9.2	-9.0	-9.0	-8.6	-8.3	-8.0	-8.0			
Feeder summation power factor	0.97	0.97	0.97	0.98	0.99	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.99	0.99	0.99	0.99			
Transformation summation power factor	1.00	1.00	1.00	1.00	0.99	0.99	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	52.5	61.3	66.2	53.3	60.6	59.3	58.7	66.8	67.1	67.1	67.1	67.9	68.0	69.4	70.7	71.8	71.9			
(N-1) Cyclic Rating (MVA)	67.4	67.4	67.4	67.4	67.4	67.4	89.0	89.0	89.0	89.0	89.0	89.0	89.0	89.0	89.0	89.0	89.0			
(N-1) Limited Cyclic Rating (MVA)	72.3	72.3	72.3	72.3	72.3	72.3	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4			
(N-1) 2 Hour Emergency Rating (MVA)	74.3	74.3	74.3	74.3	74.3	74.3	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4			
(N-1) 10 Minute Emergency Rating (MVA)	74.3	74.3	74.3	74.3	74.3	74.3	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4	97.4			
(N) Cyclic Rating (MVA)	101.1	101.1	101.1	74.3	101.1	101.1	133.0	133.0	133.0	133.0	133.0	133.0	133.0	133.0	133.0	133.0	133.0			
Feeder	SCR (A)	utilis (%)	forecast utilis (%)	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity	2018-2023 Annual growth	2019 DM (A)		
NW 11	350	350	32%	37%	39%	99	119	133	110	119	120	113	131	138	142	143	146	219 A	8.5 MVA	5.8%
NW 13	330	330	63%	71%	72%	190	212	227	182	217	187	208	235	238	239	240	243	95 A	3.7 MVA	3.3%
NW 14	335	335	56%	66%	69%	184	204	220	201	202	254	187	220	232	240	247	253	115 A	4.5 MVA	7.1%
NW 21	265	265	82%	93%	94%	194	231	238	195	225	224	217	246	249	254	256	259	19 A	0.7 MVA	3.8%
NW 22	345	345	53%	72%	73%	149	181	157	122	165	155	182	250	251	252	252	255	95 A	3.7 MVA	8.0%
NW 23	340	340	62%	70%	70%	162	192	209	171	196	194	211	237	239	241	242	245	103 A	4 MVA	3.2%
NW 31	305	305	70%	79%	79%	177	193	207	179	215	188	213	240	242	244	244	247	65 A	2.5 MVA	3.2%
NW 32	265	265	51%	58%	59%	153	154	153	147	147	140	135	153	156	158	160	162	112 A	4.3 MVA	4.0%
NW 33	315	315	68%	77%	77%	195	220	283	260	225	215	214	241	244	247	249	252	74 A	2.9 MVA	3.5%
NW 34	300	300	22%	33%	33%	69	52	53	45	66	64	67	98	99	99	99	100	202 A	7.9 MVA	9.9%
NW 35	0	0																0 A	0 MVA	
Average	286	286	61%	65%	65%	157	176	188	161	178	174	175	187	190	192	194	197	100 A	3.9 MVA	2.5%

Feeder	Load Transfers (Amps)			
	2019	2020	2021	2023
NW 11	0	0	0	0
NW 13	0	0	0	0
NW 14	0	0	0	0
NW 21	0	0	0	0
NW 22	0	0	0	0
NW 23	0	0	0	0
NW 31	0	0	0	0
NW 32	0	0	0	0
NW 33	0	0	0	0
NW 34	0	0	0	0
NW 35	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)			
	2019	2020	2021	2023
NW 11	4	6	4	1
NW 13	1	1	0	0
NW 14	10	11	7	3
NW 21	2	2	3	2
NW 22	0	0	0	0
NW 23	1	0	1	0
NW 31	1	1	0	0
NW 32	2	1	1	1
NW 33	1	1	2	2
NW 34	0	0	0	0
NW 35	0	0	0	0


Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- Line Capacitors
Installed 8.4MVAR prior to summer 1999.
- Replace #1 PCB capacitor bank in 2002 : 8.0MVAR
- Load Transfers:
0.4MW from DC prior to summer 2009.
- New Loads:
- New 66/22kV Transformer:
Install 3rd transformer in 2006 for summer 2007.

Reserve Capacity Requirements

- Eastlink Tunnel
Proposed reserve capacity. No contracts in place
- EDC
RWT12 (Duty)
NW33 - 1.7MVA (45A) reserve
Previously was on NW33 (Now NW22 with load transfers)
- Eastlink Tunnel
Shared NW34, RWT13
NW34 - 0.9MVA (23A)
RWT13 - 1.55MVA (40A)
1-year agreement (expires 15/12/2017)

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND


Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
OAKLEIGH																	
OAK																	
Voltage	11.44	kV															
Load maximum demand actual / forecast (MW)	32.4	36.1	37.0	31.0	37.9	36.4	38.9	44.4	45.1	45.0	45.1	45.7	45.9	47.1	48.2	49.3	49.7
10% POE actual MD	35.4	37.9	37.0	36.8	40.1	41.1	42.1										
Load transfers (MW)																	
Extra new load (MW)		1.2	0.1	0.7	1.0	2.2	1.7	1.4	1.2	0.4	0.4	0.4	0.1				
% growth (MW)		11.3%	2.5%	-16.4%	22.3%	-3.9%	7.1%	14.0%	1.7%	-0.3%	0.2%	1.2%	0.5%	2.6%	2.5%	2.2%	0.7%
Feeder summation reactive demand (MVar)	8.0	6.6	4.3	1.7	0.3	-0.2	0.3	2.0	2.3	2.2	2.3	2.4	2.5	2.9	3.2	3.6	3.7
Zone substation capacitor bank (MVar)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Feeder line capacitors (MVar)	9.3	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1	11.1
Reactive load on transformers (MVar)	8.0	6.6	4.3	1.7	0.3	-0.2	0.3	2.0	2.3	2.2	2.3	2.4	2.5	2.9	3.2	3.6	3.7
Feeder summation power factor	0.97	0.98	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Transformation summation power factor	0.97	0.98	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	33.4	36.7	37.3	31.0	37.9	36.4	38.9	44.4	45.2	45.1	45.2	45.8	46.0	47.2	48.4	49.5	49.8
(N-1) Cyclic Rating (MVA)	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6	43.6
(N-1) Limited Cyclic Rating (MVA)	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4
(N-1) 2 Hour Emergency Rating (MVA)	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7
(N-1) 10 Minute Emergency Rating (MVA)	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7	46.7
(N) Cyclic Rating (MVA)	87.2	87.2	87.2	46.7	87.2	87.2	87.2	87.2	87.2	87.2	87.2	87.2	87.2	87.2	87.2	87.2	87.2
Feeder	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
SCR (A)	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315
utilis (%)	83%	81%	81%	81%	81%	81%	81%	81%	81%	81%	81%	81%	81%	81%	81%	81%	81%
forecast utilis (%)	91%	90%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%
OAK 21	196	176	206	165	216	190	262	288	291	294	298	302	27 A	0.5 MVA	3.0%		
OAK 22	266	225	250	210	229	247	254	285	289	290	290	292	30 A	0.6 MVA	3.0%		
OAK 23	224	258	220	203	167	176	202	228	235	236	237	238	122 A	2.4 MVA	3.5%		
OAK 24	153	145	141	135	106	208	226	269	287	288	289	290	81 A	1.6 MVA	5.6%		
OAK 25	121	136	140	116	74	132	143	188	177	178	178	179	182 A	3.6 MVA	5.1%		
OAK 26	84	217	241	189	216	217	246	269	271	272	273	274	81 A	1.6 MVA	2.2%		
OAK 30						47	59	83	98	102	109	121	267 A	5.3 MVA	21.2%		
OAK 31	151	209	222	151	355	224	253	276	279	280	280	282	54 A	1.1 MVA	2.2%		
OAK 32	63	80	85	64	78	66	74	83	84	84	84	85	217 A	4.3 MVA	2.7%		
OAK 33	267	215	242	193	219	206	232	253	255	256	257	258	97 A	1.9 MVA	2.2%		
OAK 34	333	304	251	285	219	206	200	218	223	231	245	256	132 A	2.6 MVA	5.6%		
OAK 35	106	125	124	102	112	115	105	115	116	116	116	117	200 A	4 MVA	2.2%		
Average	335	335	335	335	335	335	335	335	335	335	335	335	124 A	2.5 MVA	3.9%		

Feeder	Load Transfers (Amps)			
	2019	2020	2021	2023
OAK 21	0	0	0	0
OAK 22	0	0	0	0
OAK 23	0	0	0	0
OAK 24	0	0	0	0
OAK 25	0	0	0	0
OAK 26	0	0	0	0
OAK 30	0	0	0	0
OAK 31	0	0	0	0
OAK 32	0	0	0	0
OAK 33	0	0	0	0
OAK 34	0	0	0	0
OAK 35	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
OAK 21	2	1	2	3	2
OAK 22	7	2	0	0	0
OAK 23	7	5	0	0	0
OAK 24	22	16	0	0	0
OAK 25	12	8	0	0	0
OAK 26	0	0	0	0	0
OAK 30	19	15	3	7	11
OAK 31	0	0	0	0	0
OAK 32	2	0	0	0	0
OAK 33	0	0	0	0	0
OAK 34	0	3	7	14	10
OAK 35	0	0	0	0	0

Zone Substation Comments	Reserve Capacity Requirements	Network Support Agreements
<p>1. Rebuild station in 2004 & 2005 as 66/11kV. Station capacity was derated in 2002 due to marked increase in hydro-carbon gases within No 3 transformer. 3rd transformer planned in 2013.</p> <p>2. Load Transfers: 1.0MW from EM to OAK for summer 2010.</p> <p>3. New Loads: 2.0MW on OAK23 between OA8081 and "Colins-Batesford" - estimated in 2010. New OAK26 feeder to offload OAK23</p> <p>4. No.1 zone sub cap bank was derated by 230kVAr in March 1999.</p> <p>5. Line Capacitors Installed 5.7MVar prior to summer 2000. Installed 3.6MVar prior to summer 2001. Rebuild O with two 20/33MVA 66/11kV transformers in 2004 & 2005.</p>		



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028				
OAKLEIGH EAST OE																					
Voltage 11.44 kV																					
Load maximum demand actual / forecast (MW)	11.3	13.1	12.9	11.5	12.1	12.6	13.7	15.7	15.7	15.7	15.7	15.9	15.9	16.3	16.6	16.8	16.9				
10% POE actual MD	13.2	14.4	12.9	12.8	12.6	13.2	15.3														
Load transfers (MW)							2.0														
Extra new load (MW)			0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.3	0.2										
% growth (MW)		15.8%	-1.4%	-10.8%	5.0%	4.1%	9.2%	14.7%	-0.5%	0.2%	0.2%	1.3%	0.1%	2.1%	1.9%	1.7%	0.1%				
Feeder summation reactive demand (MVA)	5.6	5.8	6.1	5.2	4.8	5.0	4.5	5.2	5.2	5.2	5.2	5.3	5.3	5.4	5.5	5.6	5.6				
Zone substation capacitor bank (MVA)	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1	10.1				
Feeder line capacitors (MVA)	0.0	0.0	0.0	0.9	0.9	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0				
Reactive load on transformers (MVA)	-5.3	-5.1	-4.8	-5.7	-6.1	-5.9	-6.4	-5.7	-5.7	-5.7	-5.7	-5.6	-5.6	-5.5	-5.4	-5.3	-5.3				
Feeder summation power factor	0.90	0.91	0.90	0.91	0.93	0.93	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95	0.95				
Transformation summation power factor	0.91	0.93	0.94	0.89	0.89	0.90	0.91	0.94	0.94	0.94	0.94	0.94	0.94	0.95	0.95	0.95	0.95				
EG and DM at peak demand (MW)																					
Overall demand on transformers (MVA)	12.5	14.0	13.7	12.8	13.5	13.9	15.1	16.7	16.7	16.7	16.7	16.9	16.9	17.2	17.4	17.7	17.7				
(N-1) Cyclic Rating (MVA)	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4				
(N-1) Limited Cyclic Rating (MVA)	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4				
(N-1) 2 Hour Emergency Rating (MVA)	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4				
(N-1) 10 Minute Emergency Rating (MVA)	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4	32.4				
(N) Cyclic Rating (MVA)	64.8	64.8	64.8	32.4	64.8	64.8	64.8	64.8	64.8	64.8	64.8	64.8	64.8	64.8	64.8	64.8	64.8				
Feeder	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034				
OE 1	235	235	22%	25%	25%	65	64	61	53	51	52	51	58	58	58	58	59	177 A	3.5 MVA	2.9%	DM (A)
OE 2	220	220	15%	17%	17%	28	32	31	28	31	27	34	38	38	38	38	39	182 A	3.6 MVA	2.9%	
OE 4	260	260	132%	90%	94%	115	172	306	146	173	202	344	234	243	260	272	275	26 A	0.5 MVA	-4.0%	
OE 5	250	250	44%	49%	49%	71	81	155	71	72	75	109	123	124	124	124	125	127 A	2.5 MVA	2.9%	
OE 6	265	265	33%	37%	37%	81	86	83	79	79	85	87	98	98	99	99	100	167 A	3.3 MVA	2.9%	
OE 9	260	260	27%	30%	30%	56	68	78	56	70	62	69	78	78	78	78	79	182 A	3.6 MVA	2.9%	
OE 10	260	260	21%	23%	23%	112	104	89	89	90	61	54	60	61	61	61	61	200 A	4 MVA	2.9%	
OE 14	265	265	41%	71%	71%	112	112	116	99	113	109	109	188	189	190	190	192	77 A	1.5 MVA	15.2%	
OE 15	300	300	30%	33%	33%	90	107	103	85	85	100	89	100	100	101	101	102	200 A	4 MVA	2.9%	
Average	257	257	41%	42%	42%	81	92	114	78	85	86	105	109	110	112	113	115	149 A	2.9 MVA	1.8%	

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
OE 1	0	0	0	0	0
OE 2	0	0	0	0	0
OE 4	-157	0	0	0	0
OE 5	0	0	0	0	0
OE 6	0	0	0	0	0
OE 9	0	0	0	0	0
OE 10	0	0	0	0	0
OE 14	65	0	0	0	0
OE 15	0	0	0	0	0


Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
OE 1	0	0	0	0	0
OE 2	0	0	0	0	0
OE 4	4	8	16	12	0
OE 5	0	0	0	0	0
OE 6	0	0	0	0	0
OE 9	0	0	0	0	0
OE 10	0	0	0	0	0
OE 14	1	0	0	0	0
OE 15	0	0	0	0	0

Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- Load Transfers:
- New Loads:

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	Actual										Forecast							
	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
ORMOND																		
OR																		
Voltage	11.5 kV																	
Load maximum demand actual / forecast (MW)	28.8	34.5	38.9	29.5	35.2	32.4	35.0	38.6	38.7	38.5	38.4	39.1	39.2	40.2	41.2	42.2	42.4	
10% POE actual MD	34.1	37.1	39.0	38.1	38.4	37.9	37.4											
Load transfers (MW)																		
Extra new load (MW)				0.1	0.3	0.8	-0.9											
% growth (MW)		19.7%	12.9%	-24.2%	19.2%	-7.9%	8.1%	10.1%	0.2%	-0.4%	-0.1%	1.6%	0.5%	2.6%	2.5%	2.2%	0.7%	
Feeder summation reactive demand (MVAR)	5.3	6.9	7.0	3.9	6.8	4.3	4.9	5.9	5.9	5.8	5.8	6.0	6.1	6.3	6.6	6.9	6.9	
Zone substation capacitor bank (MVAR)	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	
Feeder line capacitors (MVAR)	3.6	3.6	3.6	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	
Reactive load on transformers (MVAR)	-8.1	-6.5	-6.4	-9.5	-6.7	-9.2	-8.6	-7.6	-7.6	-7.6	-7.6	-7.4	-7.4	-7.1	-6.8	-6.6	-6.5	
Feeder summation power factor	0.98	0.98	0.98	0.99	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	
Transformation summation power factor	0.96	0.98	0.99	0.95	0.98	0.96	0.97	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.99	0.99	0.99	
EG and DM at peak demand (MW)																		
Overall demand on transformers (MVA)	29.9	35.1	39.5	31.0	35.8	33.7	36.1	39.3	39.4	39.2	39.2	39.8	39.9	40.9	41.8	42.7	42.9	
(N-1) Cyclic Rating (MVA)	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	32.3	
(N-1) Limited Cyclic Rating (MVA)	34.7	34.7	34.7	34.7	34.7	34.7	34.7	34.7	34.7	34.7	34.7	34.7	34.7	34.7	34.7	34.7	34.7	
(N-1) 2 Hour Emergency Rating (MVA)	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	
(N-1) 10 Minute Emergency Rating (MVA)	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	34.9	
(N) Cyclic Rating (MVA)	64.6	64.6	64.6	34.9	64.6	64.6	64.6	64.6	64.6	64.6	64.6	64.6	64.6	64.6	64.6	64.6	64.6	

Feeder	SCR (A)	utilis (%)	forecast utilis (%)															2019			2018-2023			2019
	2018	2019	2018	2019	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	Spare capacity	Annual growth	DM (A)				
OR 11	0	0				126	143	267										252 A	5 MVA	18.1%				
OR 22	280	280	7%	10%	12%	106	109	101	102	87	64	18	28	34	34	34	35	63 A	1.2 MVA	-2.8%				
OR 23	275	275	61%	65%	66%	219	233	255	201	197	188	167	180	182	182	183	185	29 A	0.6 MVA	4.6%				
OR 24	335	335	83%	91%	94%	205	259	292	230	271	215	279	306	315	324	332	343	51 A	1 MVA	3.1%				
OR 25	265	265	93%	76%	78%	203	207	230	185	213	194	246	202	207	207	208	211	112 A	2.2 MVA	6.1%				
OR 31	270	270	28%	30%	31%	131	127	131	110	111	76	76	82	82	83	83	84	20 A	0.4 MVA	1.9%				
OR 32	260	260	86%	90%	91%	174	200	212	171	201	194	222	235	236	237	238	242	51 A	1 MVA	3.1%				
OR 33	595	595	66%	81%	82%	200	202	114	292	351	338	391	483	490	497	503	510	20 A	0.4 MVA	1.9%				
OR 34	280	280	75%	82%	84%	214	250	215	223	268	256	210	229	235	238	239	242	61 A	1.2 MVA	5.4%				
OR 35	335	335	89%	94%	95%	223	246	209	213	294	240	299	315	319	321	322	327							
Average	290	290	66%	71%	79%	180	198	203	173	199	176	191	229	233	236	238	242	61 A	1.2 MVA	5.4%				

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
OR 11	0	0	0	0	0
OR 22	0	0	0	0	0
OR 23	0	0	0	0	0
OR 24	0	0	0	0	0
OR 25	-60	0	0	0	0
OR 31	0	0	0	0	0
OR 32	0	0	0	0	0
OR 33	60	0	0	0	0
OR 34	0	0	0	0	0
OR 35	0	0	0	0	0


Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
OR 11	0	0	0	0	0
OR 22	8	6	0	0	0
OR 23	0	0	0	0	0
OR 24	5	7	7	8	6
OR 25	4	2	0	0	0
OR 31	0	0	0	0	0
OR 32	1	0	0	0	0
OR 33	1	3	6	4	0
OR 34	3	4	2	0	0
OR 35	1	2	1	0	0

Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- Load Transfers:
- New Loads:

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
ROSEBUD RBD																				
Voltage 22.4 kV																				
Load maximum demand actual / forecast (MW)	39.7	42.1	41.7	37.9	40.2	38.3	40.3	46.8	47.0	46.9	47.1	48.2	48.9	50.3	51.6	52.9	53.4			
10% POE actual MD	42.5	44.6	45.7	44.9	44.0	46.8	45.2													
Load transfers (MW)																				
Extra new load (MW)			0.5	0.3	0.1	0.5	0.3	0.3	0.2	0.1	0.2	0.4	0.3							
% growth (MW)		6.1%	-0.8%	-9.1%	5.9%	-4.8%	5.2%	16.3%	0.3%	-0.2%	0.5%	2.3%	1.4%	2.8%	2.7%	2.5%	1.0%			
Feeder summation reactive demand (MVAR)	6.6	8.1	7.5	7.0	8.5	7.8	5.4	7.4	7.4	7.4	7.5	7.8	8.0	8.5	8.9	9.3	9.4			
Zone substation capacitor bank (MVAR)	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0			
Feeder line capacitors (MVAR)	6.9	7.8	7.8	9.0	9.0	9.0	6.9	6.9	6.9	6.9	6.9	6.9	6.9	6.9	6.9	6.9	6.9			
Reactive load on transformers (MVAR)	-0.7	0.8	0.3	-0.3	1.2	0.5	-1.9	0.1	0.2	0.2	0.2	0.6	0.8	1.2	1.6	2.0	2.2			
Feeder summation power factor	0.99	0.98	0.98	0.98	0.98	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.98	0.98			
Transformation summation power factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	39.7	42.1	41.7	37.9	40.2	38.3	40.3	46.8	47.0	46.9	47.1	48.2	48.9	50.3	51.7	52.9	53.5			
(N-1) Cyclic Rating (MVA)	45.0	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8	45.8			
(N-1) Limited Cyclic Rating (MVA)	47.6	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5			
(N-1) 2 Hour Emergency Rating (MVA)	47.6	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5			
(N-1) 10 Minute Emergency Rating (MVA)	47.6	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5			
(N) Cyclic Rating (MVA)	90.0	91.6	91.6	48.5	91.6	91.6	91.6	91.6	91.6	91.6	91.6	91.6	91.6	91.6	91.6	91.6	91.6			
Feeder	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034			
RBD 11	265	265	34%	39%	39%	87	91	82	78	91	103	104	105	107	109	162 A	6.3 MVA	4.0%		
RBD 12	285	285	53%	60%	60%	127	135	136	122	118	150	170	172	177	184	199	115 A	4.5 MVA	6.6%	
RBD 13	355	355	55%	63%	64%	183	195	204	175	201	192	196	225	229	231	234	239	130 A	5.1 MVA	4.4%
RBD 14	260	260	38%	43%	43%	109	112	96	96	104	101	98	111	113	114	115	117	149 A	5.8 MVA	4.0%
RBD 21	260	260	54%	63%	66%	185	202	199	214	155	137	140	165	171	173	174	178	95 A	3.7 MVA	5.6%
RBD 22	350	350	32%	36%	37%	93	102	125	140	153	103	111	127	128	129	131	134	223 A	8.7 MVA	4.0%
RBD 23	265	265	64%	73%	74%	246	250	164	176	178	179	171	194	196	198	200	205	71 A	2.8 MVA	4.0%
RBD 24	260	260	66%	75%	76%	154	160	169	146	161	160	171	194	197	199	201	205	66 A	2.6 MVA	4.0%
Average	288	288	49%	56%	56%	157	165	148	145	145	133	141	161	164	166	168	173	126 A	4.9 MVA	4.6%

Feeder	2019	2020	2021	2022	2023
RBD 11	0	0	0	0	0
RBD 12	0	0	0	0	0
RBD 13	0	0	0	0	0
RBD 14	0	0	0	0	0
RBD 21	0	0	0	0	0
RBD 22	0	0	0	0	0
RBD 23	0	0	0	0	0
RBD 24	0	0	0	0	0


Feeder	2019	2020	2021	2022	2023
RBD 11	0	0	0	0	0
RBD 12	0	0	3	5	11
RBD 13	2	1	0	0	0
RBD 14	0	0	0	0	0
RBD 21	6	4	0	0	0
RBD 22	0	0	0	0	0
RBD 23	0	0	0	0	0
RBD 24	0	0	0	0	0

Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- Line Capacitors: 6.3 MVAR for summer 2001.
1.8 MVAR for summer 2002.
- PCB Cap Bank Replacement
Replaced & upgraded cap bank #3 (7.0MVAR) unit in 2000.
- Load Transfers:
Transfer 0.8MW from DMA to RBD for summer 2008
Transfer 0.5MW from RBD to DMA for summer 2009
- New Loads:
2.5MVA on RBD21 by RACV resort, Cape Schanck (2016).
- Established a package zone substation with one 20/33MVA transformer in Dromana (DMA) in 2005 for summer 2006 and transfer 16MW to DMA.
- RBD replace 1 Tx in 2010 and rebuild complete in 2011

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	Actual 2015	2016	2017	2018	2019	2020	2021	2022	Forecast 2023	2024	2025	2026	2027	2028
RINGWOOD RWT																	
Voltage 22.7 kV																	
Load maximum demand actual / forecast (MW)	26.2	31.4	32.9	26.5	32.6	31.0	32.5	38.5	38.5	38.1	37.9	38.5	38.6	39.4	40.2	40.9	41.0
10% POE actual MD	32.3	34.8	34.0	34.8	36.9	37.8	36.9										
Load transfers (MW)																	
Extra new load (MW)			0.4	0.6	1.6	1.1	1.1	0.7	0.3	0.1							
% growth (MW)		19.9%	4.9%	-19.4%	23.0%	-5.1%	4.9%	18.4%	0.0%	-0.9%	-0.6%	1.5%	0.3%	2.1%	2.0%	1.8%	0.3%
Feeder summation reactive demand (MVA)	13.0	15.7	18.6	5.1	5.3	-1.0	4.7	6.5	6.5	6.4	6.3	6.5	6.6	6.8	7.1	7.3	7.3
Zone substation capacitor bank (MVA)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Feeder line capacitors (MVA)	5.1	5.1	5.1	6.0	6.0	6.0	5.1	5.1	5.1	5.1	5.1	5.1	5.1	5.1	5.1	5.1	5.1
Reactive load on transformers (MVA)	13.0	15.7	18.6	5.1	5.3	-1.0	4.7	6.5	6.5	6.4	6.3	6.5	6.6	6.8	7.1	7.3	7.3
Feeder summation power factor	0.90	0.89	0.87	0.98	0.99	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.98	0.98	0.98
Transformation summation power factor	0.90	0.89	0.87	0.98	0.99	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.98	0.98	0.98
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	29.2	35.1	37.8	27.0	33.1	31.0	32.8	39.0	39.0	38.7	38.4	39.0	39.1	40.0	40.8	41.6	41.7
(N-1) Cyclic Rating (MVA)																	
(N-1) Limited Cyclic Rating (MVA)																	
(N-1) 2 Hour Emergency Rating (MVA)																	
(N-1) 10 Minute Emergency Rating (MVA)																	
(N) Cyclic Rating (MVA)																	

Feeder	2018	2019	utilis (%) 2018	forecast utilis (%) 2019	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity	2018-2023 Annual growth	2019 DM (A)	
RWT 12	265	265	44%	48%	49%	116	125	131	109	119	116	117	128	129	130	132	137 A	5.4 MVA	2.6%		
RWT 13	300	300	22%	37%	37%	63	37	53	29	39	65	66	112	112	113	114	188 A	7.4 MVA	14.8%		
RWT 23	350	350	54%	61%	62%	160	187	209	172	191	193	191	215	218	219	223	135 A	5.3 MVA	3.4%		
RWT 24	350	350	52%	58%	59%	152	193	206	155	195	181	181	203	208	210	210	213	147 A	5.8 MVA	3.5%	
RWT 34	350	350	83%	93%	94%	221	247	276	220	277	248	290	327	330	331	332	337	23 A	0.9 MVA	3.3%	
RWT 35	265	265	66%	74%	74%	140	156	171	140	159	145	176	196	197	197	198	201	69 A	2.7 MVA	2.8%	
Average	313	313	54%	63%	63%	142	158	174	138	163	158	170	197	199	200	200	203	117 A	4.6 MVA	3.9%	

Feeder	2019	2020	2021	2022	2023
RWT 12	0	0	0	0	0
RWT 13	0	0	0	0	0
RWT 23	0	0	0	0	0
RWT 24	0	0	0	0	0
RWT 34	0	0	0	0	0
RWT 35	0	0	0	0	0

Feeder	2019	2020	2021	2022	2023
RWT 12	0	0	0	0	0
RWT 13	0	0	0	0	0
RWT 23	5	2	0	0	0
RWT 24	3	4	2	0	0
RWT 34	8	2	0	0	0
RWT 35	3	0	0	0	0


Zone Substation Comments

- RWT is SPI PowerNet asset supplying both UED and SPIE.
- Metering errors: Prior to 18/1/06 SCADA metering on feeders RWT16, RWT18 and RWT28 all were reading of 75% of their actual value. The figures above have been corrected.
- Line Capacitors:
- Load Transfers:
 - Transfer about 4.5MW to NW before summer 2007.
 - Transfer about 3.0MW to EB before summer 2009.
- New load:
 - 1.1MW in 2006 for construction of the EastLink tunnel.
 - 1.4MW additional load in 2007 for the tunnel once construction is complete.
 - 1MW on RWT24 in 2007 for commercial offices.

Reserve Capacity Requirements

- Eastlink
Expected reserve capacity for the EastLink. No contract in place.
- EDC (Data Centre)
RWT12 (Duty)
NW33 (Reserve) - 1.7MVA
- Eastlink Tunnel
Shared NW34, RWT13
NW34 - 0.9MVA (23A)
RWT13 - 1.55MVA (40A)
1-year agreement (expires 15/12/2017)

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	Actual 2015	2016	2017	2018	2019	2020	2021	2022	Forecast 2023	2024	2025	2026	2027	2028			
SANDRINGHAM SR																				
Voltage 11.6 kV																				
Load maximum demand actual / forecast (MW)	28.0	34.1	33.9	29.9	32.0	28.6	31.6	35.1	35.2	35.3	35.4	35.7	35.8	36.6	37.3	37.9	38.0			
10% POE actual MD	31.9	36.4	36.6	36.0	34.9	34.6	34.0													
Load transfers (MW)	-1.4						-0.5													
Extra new load (MW)				0.2	0.3	0.8	0.4	0.4	0.3	0.3	0.4	0.3								
% growth (MW)		21.8%	-0.6%	-11.9%	7.1%	-10.6%	10.5%	11.0%	0.3%	0.2%	0.3%	1.0%	0.3%	2.1%	1.9%	1.8%	0.3%			
Feeder summation reactive demand (MVAR)	6.3	5.7	6.0	2.7	4.6	3.3	4.7	5.7	5.7	5.7	5.8	5.9	5.9	6.1	6.3	6.5	6.5			
Zone substation capacitor bank (MVAR)	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1			
Feeder line capacitors (MVAR)	5.7	5.7	5.7	6.6	6.6	6.6	3.9	3.9	3.9	3.9	3.9	3.9	3.9	3.9	3.9	3.9	3.9			
Reactive load on transformers (MVAR)	-0.4	-1.1	-0.8	-4.1	-2.2	-3.5	-2.1	-1.1	-1.1	-1.1	-1.0	-0.9	-0.9	-0.7	-0.5	-0.3	-0.3			
Feeder summation power factor	0.98	0.99	0.98	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor	1.00	1.00	1.00	0.99	1.00	0.99	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00			
EG and DM at peak demand (MW)																				
Overall demand on transformers (MVA)	28.0	34.1	33.9	30.1	32.1	28.8	31.7	35.1	35.2	35.3	35.4	35.7	35.8	36.6	37.3	37.9	38.0			
(N-1) Cyclic Rating (MVA)	35.5	36.5	36.5	36.5	36.5	36.5	36.5	36.5	36.5	36.5	36.5	36.5	36.5	36.5	36.5	36.5	36.5			
(N-1) Limited Cyclic Rating (MVA)	38.0	37.5	37.5	37.5	37.5	37.5	37.5	37.5	37.5	37.5	37.5	37.5	37.5	37.5	37.5	37.5	37.5			
(N-1) 2 Hour Emergency Rating (MVA)	38.0	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8			
(N-1) 10 Minute Emergency Rating (MVA)	38.0	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8	38.8			
(N) Cyclic Rating (MVA)	71.0	73.1	73.1	38.8	73.1	73.1	73.1	73.1	73.1	73.1	73.1	73.1	73.1	73.1	73.1	73.1	73.1			
Feeder	2018	2019	utilis (%) 2018	forecast utilis (%) 2019	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2019 Spare capacity	2018-2023 Annual growth	2019 DM (A)
SR 11	255	255	71%	77%	78%	143	144	169	134	156	153	182	197	198	199	200	202	58 A	1.2 MVA	2.1%
SR 12	260	260	30%	35%	37%	35	47	46	46	61	68	78	91	96	96	96	97	169 A	3.4 MVA	4.8%
SR 13	350	350	68%	74%	75%	288	342	330	332	211	213	239	259	261	265	268	270	91 A	1.8 MVA	2.6%
SR 14	260	260	37%	40%	41%	78	84	87	75	93	90	96	104	105	107	109	110	156 A	3.1 MVA	2.9%
SR 15	285	285	90%	94%	95%	196	210	238	194	215	210	256	269	271	273	275	278	16 A	0.3 MVA	1.7%
SR 19	245	245	65%	70%	71%	121	136	133	115	121	105	158	172	173	174	175	176	73 A	1.5 MVA	2.3%
SR 20	250	250	75%	84%	85%	174	189	199	168	181	186	188	210	213	214	215	217	40 A	0.8 MVA	3.1%
SR 23	300	300	54%	59%	59%	253	283	233	257	226	199	162	177	177	178	179	181	123 A	2.5 MVA	2.3%
SR 24	260	260	66%	71%	71%	202	173	201	155	151	122	171	185	186	187	188	189	75 A	1.5 MVA	2.1%
SR 25	280	280	39%	42%	43%	147	168	180	115	128	129	110	119	119	120	121	122	161 A	3.2 MVA	2.1%
Average	275	275	60%	65%	65%	164	178	182	159	154	147	164	178	180	181	183	184	96 A	1.9 MVA	2.5%

Feeder	2019	2020	2021	2022	2023
SR 11	0	0	0	0	0
SR 12	0	0	0	0	0
SR 13	0	0	0	0	0
SR 14	0	0	0	0	0
SR 15	0	0	0	0	0
SR 19	0	0	0	0	0
SR 20	0	0	0	0	0
SR 23	0	0	0	0	0
SR 24	0	0	0	0	0
SR 25	0	0	0	0	0


Feeder	2019	2020	2021	2022	2023
SR 11	0	0	0	0	0
SR 12	6	4	0	0	0
SR 13	1	1	2	2	0
SR 14	0	1	1	1	0
SR 15	0	0	1	1	0
SR 19	1	0	0	0	0
SR 20	7	2	4	0	0
SR 23	1	0	0	0	0
SR 24	0	0	0	0	0
SR 25	0	0	0	0	0

Zone Substation Comments

- Station rating is limited by 11kV transformer cables. Upgraded transformer cables in 2011.
- Line Capacitors
Installed 5.7MVAR prior to summer 1999.
- Load Transfers
1.5MW from MR to SR for summer 2009 - due to MR Tx derated
Transfer 1.4MW from SR to MR prior to summer 2011
- New load
0.5MW for new indoor s/s in 2009 for new apartment/retail complex (SR20).
1MVA for Sandringham Hospital on SR19, with reserve on BR10 - proposal for late 2009
0.5 MW - Sandringham Hospital Supply Increase - 2013/14 - SR19

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
SPRINGVALE SOUTH SS																	
Voltage 22.4 kV																	
Load maximum demand actual / forecast (MW)	37.9	38.5	41.1	35.8	39.3	38.1	36.3	46.7	46.5	46.0	45.7	46.3	46.3	47.3	48.1	48.9	49.0
10% POE actual MD	43.7	43.4	43.7	43.0	45.5	45.9	45.3										
Load transfers (MW)																	
Extra new load (MW)				0.2	1.7	1.5	1.4	0.8	0.5	0.3	0.3	0.2					
% growth (MW)		1.6%	6.8%	-12.9%	9.9%	-3.2%	-4.6%	28.6%	-0.5%	-1.0%	-0.7%	1.3%	0.1%	2.1%	1.9%	1.7%	0.1%
Feeder summation reactive demand (MVAR)	2.9	1.4	-1.4	-0.4	0.1	2.7	-1.6	4.0	3.9	3.7	3.5	3.8	3.8	4.3	4.8	5.2	5.3
Zone substation capacitor bank (MVAR)	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3	12.3
Feeder line capacitors (MVAR)	20.7	21.6	21.6	20.7	20.7	20.7	20.7	20.7	20.7	20.7	20.7	20.7	20.7	20.7	20.7	20.7	20.7
Reactive load on transformers (MVAR)	-9.8	-11.4	-14.2	-13.2	-12.7	-10.1	-14.4	-8.7	-8.9	-9.1	-9.3	-9.0	-9.0	-8.4	-8.0	-7.5	-7.5
Feeder summation power factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	0.99	0.99
Transformation summation power factor	0.94	0.92	0.92	0.90	0.94	0.94	0.87	0.98	0.98	0.97	0.97	0.97	0.97	0.98	0.98	0.98	0.98
EG and DM at peak demand (MW)	11.3	11.1	7.6	9.4	5.5	9.1	10.6	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0
Overall demand on transformers (MVA)	28.4	29.7	36.4	29.5	36.1	30.6	29.5	40.7	40.5	40.1	39.8	40.3	40.3	41.1	41.9	42.6	42.6
(N-1) Cyclic Rating (MVA)	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1	40.1
(N-1) Limited Cyclic Rating (MVA)	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6
(N-1) 2 Hour Emergency Rating (MVA)	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4	46.4
(N-1) 10 Minute Emergency Rating (MVA)	46.4	46.4	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5	48.5
(N) Cyclic Rating (MVA)	80.2	80.2	80.2	48.5	80.2	80.2	80.2	80.2	80.2	80.2	80.2	80.2	80.2	80.2	80.2	80.2	80.2
Feeder	2018	2019	2018	2019	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
SS 11	260	260	58%	73%	75%	209	177	216	148	155	162	152	191	194	198	207	215
SS 12	260	260	44%	57%	58%	110	117	120	107	105	106	115	148	150	150	150	152
SS 13	270	270	48%	60%	60%	117	122	140	113	128	112	128	161	162	163	163	165
SS 14	260	260	42%	55%	57%	121	130	132	124	122	117	110	143	148	148	148	150
SS 21	265	265	46%	61%	63%	126	110	104	119	129	114	123	160	167	169	170	171
SS 22	280	280	42%	54%	54%	103	112	111	102	111	104	119	150	152	154	154	156
SS 23	300	300	80%	89%	89%	218	230	251	210	222	174	240	267	268	269	269	272
SS 24	330	330	54%	70%	70%	200	243	197	199	197	190	179	230	231	231	231	234
Average	278	278	52%	65%	65%	151	155	159	140	146	135	146	181	184	185	186	189
	1	2	3	4	5	6	18	19	20	21							

Feeder	Load Transfers (Amps)			
	2019	2020	2021	2023
SS 11	0	0	0	0
SS 12	0	0	0	0
SS 13	0	0	0	0
SS 14	0	0	0	0
SS 21	0	0	0	0
SS 22	0	0	0	0
SS 23	0	0	0	0
SS 24	0	0	0	0


Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
SS 11	0	2	4	8	6
SS 12	3	1	0	0	0
SS 13	0	0	0	0	0
SS 14	5	4	0	0	0
SS 21	6	6	2	0	0
SS 22	1	2	1	0	0
SS 23	3	0	0	0	0
SS 24	4	0	0	0	0

Zone Substation Comments

- Zone Substation ratings were reviewed in 2010.
- SER GASCO co-generation (18MW): The Station MD (MW) is actual customer load (not SS load).
- Line Capacitors: Installed 3.6MVAR for summer 2000 & 18.9MVAR for summer 2001.
- Load Transfers before summer of each year:
For summer 2003: 4MW SS -> MC & 4MW SS -> CDA
For summer 2004: 2MW SV -> SS
Transfer 10MW from NP to SS in 2010.
- New Loads:
- Embedded generation are on SS11 and SS23

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

		Actual										Forecast									
		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028			
SORRENTO	STO																				
Voltage 22.1 kV																					
Load maximum demand actual / forecast (MW)		37.4	38.3	34.6	35.3	41.3	40.0	41.8	47.2	47.3	47.1	47.2	48.3	48.8	50.2	51.5	52.8	53.3			
10% POE actual MD		39.4	40.1	40.8	41.8	43.5	45.9	45.5													
Load transfers (MW)																					
Extra new load (MW)				0.4	0.8	0.4	0.3	0.3	0.3	0.2	0.0										
% growth (MW)			2.5%	-9.6%	2.0%	16.7%	-3.1%	4.6%	12.8%	0.2%	-0.3%	0.1%	2.3%	1.0%	2.8%	2.7%	2.5%	1.0%			
Feeder summation reactive demand (MVA)		4.3	4.5	8.1	6.9	7.8	6.0	4.1	5.2	5.2	5.2	5.2	5.4	5.5	5.8	6.1	6.3	6.4			
Zone substation capacitor bank (MVA)		12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0			
Feeder line capacitors (MVA)		4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5			
Reactive load on transformers (MVA)		-7.8	-7.6	-4.0	-5.2	-4.3	-6.1	-8.0	-6.9	-6.9	-6.9	-6.9	-6.7	-6.6	-6.3	-6.0	-5.8	-5.7			
Feeder summation power factor		0.99	0.99	0.97	0.98	0.98	0.99	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
Transformation summation power factor		0.98	0.98	0.99	0.99	0.99	0.99	0.98	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99			
EG and DM at peak demand (MW)		0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5			
Overall demand on transformers (MVA)		37.7	38.6	34.4	35.2	41.0	39.9	42.1	47.2	47.3	47.1	47.2	48.2	48.7	50.1	51.4	52.6	53.1			
(N-1) Cyclic Rating (MVA)		36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0	36.0			
(N-1) Limited Cyclic Rating (MVA)		45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9	45.9			
(N-1) 2 Hour Emergency Rating (MVA)		47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8			
(N-1) 10 Minute Emergency Rating (MVA)		47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8	47.8			
(N) Cyclic Rating (MVA)		72.0	72.0	72.0	47.8	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0	72.0			
Feeder																					
SCR (A)																					
utilis (%)																					
forecast utilis (%)																					
2018		2019	2018	2019	2020	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2023			
Spare capacity																					
2018-2023																					
2019																					
DM (A)																					
STO 13	350	350	75%	82%	83%	220	239	212	220	251	238	262	288	292	295	298	304	62 A	2.4 MVA	3.2%	
STO 14	350	350	77%	86%	87%	294	296	259	281	310	269	271	302	306	309	312	319	48 A	1.8 MVA	3.5%	
STO 21	350	350	64%	71%	72%	175	183	166	166	198	248	224	248	252	255	257	263	102 A	3.9 MVA	3.5%	
STO 22	350	350	49%	54%	54%	134	147	140	132	150	144	171	188	190	192	194	198	162 A	6.2 MVA	3.2%	
STO 23	350	350	51%	57%	58%	170	179	197	193	214	196	177	198	204	207	210	214	152 A	5.8 MVA	4.2%	
Average	350	350	63%	70%	70%	198	209	195	198	224	219	221	245	249	251	254	260	105 A	4 MVA	3.5%	

		Load Transfers (Amps)				
Feeder		2019	2020	2021	2022	2023
STO 13		0	0	0	0	0
STO 14		0	0	0	0	0
STO 21		0	0	0	0	0
STO 22		0	0	0	0	0
STO 23		0	0	0	0	0


		New Load / New Capacitors (Net Amps)				
Feeder		2019	2020	2021	2022	2023
STO 13		0	0	0	0	0
STO 14		4	0	0	0	0
STO 21		2	1	0	0	0
STO 22		0	0	0	0	0
STO 23		3	3	1	0	0

Zone Substation Comments

- Zone Substation ratings were reviewed in 2010. Transformer summer ratings are limited by 66kV dropper resulting in an (N-1) rating of just 37MVA.
- Embedded generation = 770kW on STO21.
- Load Transfers:
- New Loads: 0.5MW in 2009 and 2MW in 2010 (on STO12) by SE water, sewerage treatment plant.

Reserve Capacity Requirements

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
SPRINGVALE SV																	
Voltage	22.59 kV																
Load maximum demand actual / forecast (MW)	48.0	46.6	50.7	46.2	51.0	48.3	49.8	56.8	56.7	56.6	56.9	57.4	57.5	58.7	59.8	60.8	60.8
10% POE actual MD	54.5	51.1	52.4	52.2	54.3	54.2	54.9										
Load transfers (MW)																	
Extra new load (MW)				1.1			1.5	1.2	0.4	0.4	0.5	0.6	0.3				
% growth (MW)		-2.8%	8.8%	-8.8%	10.3%	-5.3%	3.2%	14.0%	-0.2%	-0.2%	0.5%	0.9%	0.1%	2.1%	1.9%	1.7%	0.1%
Feeder summation reactive demand (MVar)	6.3	14.1	16.0	13.1	12.3	12.5	12.5	15.7	15.6	15.6	15.7	15.9	16.0	16.5	17.0	17.5	17.5
Zone substation capacitor bank (MVar)	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3
Feeder line capacitors (MVar)	8.7	8.7	8.7	17.4	17.4	17.4	17.4	9.6	9.6	9.6	9.6	9.6	9.6	9.6	9.6	9.6	9.6
Reactive load on transformers (MVar)	-2.5	5.3	7.3	4.4	3.6	3.7	3.8	6.9	6.9	6.8	7.0	7.2	7.2	7.8	8.3	8.7	8.8
Feeder summation power factor	0.99	0.96	0.95	0.96	0.97	0.97	0.97	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96
Transformation summation power factor	1.00	0.99	0.99	1.00	1.00	1.00	1.00	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99
EG and DM at peak demand (MW)																	
Overall demand on transformers (MVA)	48.0	46.9	51.2	46.4	51.1	48.4	50.0	57.2	57.1	57.0	57.3	57.8	57.9	59.2	60.3	61.4	61.5
(N-1) Cyclic Rating (MVA)	80.8	80.8	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0
(N-1) Limited Cyclic Rating (MVA)	86.6	86.6	86.6	86.6	86.6	86.6	86.6	86.6	86.6	86.6	86.6	86.6	86.6	86.6	86.6	86.6	86.6
(N-1) 2 Hour Emergency Rating (MVA)	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0
(N-1) 10 Minute Emergency Rating (MVA)	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0	94.0
(N) Cyclic Rating (MVA)	80.8	80.8	80.0	94.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0

Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
SV 11	0	0	0	0	0
SV 12	0	0	0	0	0
SV 13	0	0	0	0	0
SV 14	0	0	0	0	0
SV 15	0	0	0	0	0
SV 16	0	0	0	0	0
SV 17	0	0	0	0	0
SV 18	0	0	0	0	0
SV 19	0	0	0	0	0
SV 20	0	0	0	0	0
SV 21	0	0	0	0	0
SV 22	0	0	0	0	0
SV 23	0	0	0	0	0
SV 31	0	0	0	0	0
SV 32	0	0	0	0	0
SV 33	0	0	0	0	0
SV 34	0	0	0	0	0

Feeder	SCR (A)		utilis (%)		forecast utilis (%)												2019		2018-2023		2019
	2018	2019	2018	2019	2018	2019	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	Spare capacity	Annual growth	DM (A)
SV 11	0	0																	0 A	0 MVA	
SV 12	0	0																	0 A	0 MVA	
SV 13	0	0																	0 A	0 MVA	
SV 14	260	260	48%	53%	54%		125	127	133	151	131	126	124	139	139	140	140	141	121 A	4.7 MVA	2.8%
SV 15	0	0																	0 A	0 MVA	
SV 16	290	290	47%	53%	54%		225	157	171	153	164	136	154	156	158	159	160	160	136 A	5.3 MVA	3.5%
SV 17	285	285	47%	53%	53%		51	79	118	74	160	90	134	151	152	152	152	153	134 A	5.2 MVA	2.8%
SV 18	0	0																	0 A	0 MVA	
SV 19	285	285	37%	42%	42%		80	109	3	3	3	105	106	119	120	120	121	121	166 A	6.5 MVA	2.8%
SV 20	350	350	52%	58%	60%		188	173	169	171	168	163	181	205	209	216	222	223	145 A	5.7 MVA	4.7%
SV 21	350	350	14%	56%	56%		159	169	181	165	138	142	49	195	195	195	196	196	155 A	6.1 MVA	60.0%
SV 22	290	290	27%	31%	31%		71	85	86	75	76	79	79	89	90	90	90	91	201 A	7.9 MVA	2.8%
SV 23	260	260	61%	70%	70%		189	190	189	160	175	152	159	182	182	183	184	185	78 A	3.1 MVA	3.2%
SV 31	350	350	10%	71%	71%		69	76	86	92	108	74	34	248	248	248	248	248	102 A	4 MVA	127.5%
SV 32	260	260	54%	60%	61%		167	239	166	175	153	143	139	157	158	159	160	103 A	4 MVA	2.9%	
SV 33	260	260	40%	47%	48%		156	144	151	144	135	135	104	121	124	125	126	126	139 A	5.4 MVA	4.4%
SV 34	350	350	41%	84%	85%		82	52	53	48	137	140	145	292	296	302	313	322	58 A	2.3 MVA	24.5%
Average	211	211	55%	57%	57%		130	133	125	117	128	126	116	121	122	123	124	125	90 A	3.5 MVA	1.6%

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
SV 11	0	0	0	0	0
SV 12	0	0	0	0	0
SV 13	0	0	0	0	0
SV 14	0	0	0	0	0
SV 15	0	0	0	0	0
SV 16	1	2	1	1	0
SV 17	0	0	0	0	0
SV 18	0	0	0	0	0
SV 19	0	0	0	0	0
SV 20	2	3	7	5	0
SV 21	0	0	0	0	0
SV 22	0	0	0	0	0
SV 23	3	0	0	0	0
SV 31	0	0	0	0	0
SV 32	1	0	0	0	0
SV 33	5	2	1	0	0
SV 34	2	3	5	11	8


Zone Substation Comments

- Zone Substation ratings were reviewed in 2001. Post 2001 based on 40deg C ambient temp.
- Line Capacitors: 7.2MVar for summer 1999, 17MVar for summer 2000, 10MVar for summer 2002.
- Load Transfers:
- New Loads:
 - 1MVA by Telstra on SVW43 (with reserve on SV31) in 2009.
 - 2MVA by Telstra on SVW43 in 2011. Reserve capacity also increased.
 - 7.5MW at 917 Princes Hwy on SV14 and new feeder SV22 before summer 11/12.

Reserve Capacity Requirements

- Monash Medical Centre, Clayton Rd Clayton: SVW54 (reserve) - 5MVA (128A); SV34 (reserve) - 5MVA (128A)
- Telstra Clayton Energy Centre, Princes Hwy, Clayton: SVW43 (preferred); SV31 (reserve) - 8MVA (210A) from 1500; SVW43 (preferred); NO 09 (reserve) - 8MVA (210A) from 1500
- Telstra New Data Centre: SVW42 (preferred) - 3 MVA; NO 01 (preferred); SV31 (reserve); 8MVA (210A) from 1500
- Bosch, Centre Rd Clayton: SVW52 (preferred); SV21 (reserve) - 5.4MVA (140A) With MM reconfiguration, SV21 (reserve) - 5.4MVA (140A)
- Monash University (Clayton): SVW51 = 2MVA; NO6 = 4MVA; NO2 = 2MVA
- Synchrotron: SVW44 (Duty) SV19 (reserve) - 5MVA (130A)

Network Support Agreements



United Energy Load Forecast

SUMMER MAXIMUM DEMAND

Base Case; 10% Weather Probability

	Actual										Forecast							
	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
WEST DONCASTER WD																		
Voltage	11.5 kV																	
Load maximum demand actual / forecast (MW)	43.4	47.4	51.9	42.5	48.1	44.1	49.3	54.5	54.4	54.1	53.9	54.5	54.7	55.6	56.5	57.2	57.4	
10% POE actual MD	49.6	52.3	51.9	50.9	52.3	52.7	52.9											
Load transfers (MW)																		
Extra new load (MW)						0.2	0.6	0.5	0.5	0.5	0.3	0.3	0.4	0.2				
% growth (MW)		9.3%	9.5%	-18.2%	13.2%	-8.3%	11.8%	10.5%	-0.1%	-0.7%	-0.2%	1.1%	0.4%	1.7%	1.5%	1.3%	0.4%	
Feeder summation reactive demand (MVAR)	8.9	9.7	12.0	8.6	10.0	8.6	10.1	11.7	11.7	11.6	11.6	11.7	11.8	12.1	12.4	12.6	12.7	
Zone substation capacitor bank (MVAR)	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	2.9	
Feeder line capacitors (MVAR)	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	5.4	
Reactive load on transformers (MVAR)	5.7	6.5	8.8	5.4	6.8	5.4	6.8	8.5	8.5	8.4	8.3	8.5	8.6	8.9	9.2	9.4	9.5	
Feeder summation power factor	0.98	0.98	0.97	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	
Transformation summation power factor	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	0.99	
EG and DM at peak demand (MW)																		
Overall demand on transformers (MVA)	43.8	47.9	52.7	42.8	48.6	44.4	49.8	55.2	55.1	54.7	54.6	55.2	55.4	56.3	57.2	58.0	58.2	
(N-1) Cyclic Rating (MVA)	63.3	63.3	63.3	63.3	63.3	63.3	63.3	63.3	63.3	63.3	63.3	63.3	63.3	63.3	63.3	63.3	63.3	
(N-1) Limited Cyclic Rating (MVA)	66.9	66.4	66.4	66.4	66.4	66.4	66.4	66.4	66.4	66.4	66.4	66.4	66.4	66.4	66.4	66.4	66.4	
(N-1) 2 Hour Emergency Rating (MVA)	69.1	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	
(N-1) 10 Minute Emergency Rating (MVA)	69.1	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	68.5	
(N) Cyclic Rating (MVA)	94.9	94.9	94.9	68.5	94.9	94.9	94.9	94.9	94.9	94.9	94.9	94.9	94.9	94.9	94.9	94.9	94.9	


Feeder	Load Transfers (Amps)				
	2019	2020	2021	2022	2023
WD 11	0	0	0	0	0
WD 13	0	0	0	0	0
WD 14	0	0	0	0	0
WD 15	0	0	0	0	0
WD 16	0	0	0	0	0
WD 21	0	0	0	0	0
WD 22	0	0	0	0	0
WD 23	0	0	0	0	0
WD 24	0	0	0	0	0
WD 26	0	0	0	0	0
WD 31	0	0	0	0	0
WD 32	0	0	0	0	0
WD 33	0	0	0	0	0
WD 34	0	0	0	0	0
WD 36	0	0	0	0	0

Feeder	New Load / New Capacitors (Net Amps)				
	2019	2020	2021	2022	2023
WD 11	0	0	0	0	0
WD 13	0	0	0	0	0
WD 14	8	8	3	6	5
WD 15	3	2	9	11	15
WD 16	0	0	0	0	0
WD 21	0	0	0	0	0
WD 22	0	0	0	0	0
WD 23	16	16	6	0	0
WD 24	0	0	0	0	0
WD 26	0	0	0	0	0
WD 31	0	0	0	0	0
WD 32	0	0	0	0	0
WD 33	0	0	0	0	0
WD 34	0	0	0	0	0
WD 36	0	0	0	0	0

- Zone Substation Comments**
- Zone Substation ratings were reviewed in 2010.
 - Line Capacitors:
Installed 5.4MVAR of line capacitors in 2000.
 - Load Transfers:
 - New Loads:
7.0MW by Doncaster shoppingtown for summer 2009.
 - CP feeders:
WD 11, WD 12, WD 21, WD 22, WD 31, WD 32

Reserve Capacity Requirements

Network Support Agreements



7. Cross-border feeders

Feeder	SCR (A)		utilis (%)		forecast utilis (%)		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2018	2017-2022	2018
	2017	2018	2017	2018	2018	2019	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	Spare capacity	Annual growth	DM (A)
ARB	350	350	58%	61%	62%		224	217	222	194	203	197	203	215	217	218	219	221	135 A	1.8%	
AR12	255	255	98%	88%	89%		232	244	76	203	232	264	249	224	226	227	228	230	31 A	-1.5%	
BC11	255	255	47%	50%	51%		45	135	58	100	113	112	121	128	129	130	131	132	127 A	1.8%	
BC23	255	255	90%	96%	98%		259	270	104	231	244	226	230	245	249	252	257	263	10 A	2.9%	
RD04	255	255	109%	97%	99%		106	317	282	236	291	264	279	247	253	257	258	260	8 A	-1.3%	
RD10	255	255	67%	71%	72%			145	157	128	146	135	170	181	184	187	191	195	74 A	3.0%	

8. Definitions

TERM	DEFINITION
BH	Box Hill zone substation
BR	Beaumaris zone substation
BU	Bulleen zone substation
BW	Burwood zone substation
CDA	Clarinda zone substation
CFD	Caulfield zone substation
CM	Cheltenham zone substation
CRM	Carrum zone substation
DMA	Dromana zone substation
DC	Doncaster zone substation
DN	Dandenong zone substation
DSH	Dandenong South zone substation
DVY	Dandenong Valley zone substation
EB	East Burwood zone substation
EL	Elsternwick zone substation
EM	East Malvern zone substation
EW	Elwood zone substation
FSH	Frankston South zone substation
FTN	Frankston zone substation
GW	Glen Waverley zone substation
HGS	Hastings zone substation
HT	Heatherston zone substation
K	Gardiner zone substation
KBH	Keysborough zone substation
LD	Lyndale zone substation
LWN	Langwarrin zone substation
M	Mentone zone substation
MD	Maximum demand

TERM	DEFINITION
MC	Mordialloc zone substation
MGE	Mulgrave zone substation
MR	Moorabbin zone substation
MTN	Mornington zone substation
NIEIR	National Institute of Economic and Industry Research
NB	North Brighton zone substation
NO	Notting Hill zone substation
NP	Noble Park zone substation
NW	Nunawading zone substation
OAK	Oakleigh zone substation
OE	Oakleigh East zone substation
OR	Ormond zone substation
POE	Probability of exceedance
RBD	Rosebud zone substation
RD	Riversdale zone substation
RWT	Ringwood terminal station feeders
SH	Surrey Hills zone substation
SR	Sandringham zone substation
SS	Springvale South zone substation
STO	Sorrento zone substation
SV	Springvale zone substation
SVW	Springvale West zone substation
UE	United Energy
WD	West Doncaster zone substation